

Customer Energy Efficiency Program
Measurement and Evaluation Program

**TECHNICAL APPENDICES --
IMPACT EVALUATION OF
PACIFIC GAS & ELECTRIC COMPANY'S
1996 AGRICULTURAL PROGRAMS
ENERGY EFFICIENCY INCENTIVES PROGRAM:
PUMPING AND RELATED END USE
INDOOR LIGHTING END USE
&
ENERGY MANAGEMENT SERVICES PROGRAM**

*PG&E Study ID numbers:
354: Pumping and Related End Use
385: Indoor Lighting End Use
360: Energy Management Services*

March 1, 1998

Measurement and Evaluation
Customer Energy Efficiency Policy & Evaluation Section
Pacific Gas and Electric Company
San Francisco, California

Disclaimer of Warranties and Limitation of Liabilities

As part of its Customer Energy Efficiency Programs, Pacific Gas and Electric Company (PG&E) has engaged consultants to conduct a series of studies designed to increase the certainty of and confidence in the energy savings delivered by the programs. This report describes one of those studies. It represents the findings and views of the consultant employed to conduct the study and not of PG&E itself.

Furthermore, the results of the study may be applicable only to the unique geographic, meteorological, cultural, and social circumstances existing within PG&E's service area during the time frame of the study. PG&E and its employees expressly disclaim any responsibility or liability for any use of the report or any information, method, process, results or similar item contained in the report for any circumstances other than the unique circumstances existing in PG&E's service area and any other circumstances described within the parameters of the study.

All inquiries should be directed to:

Lisa K. Lieu
Revenue Requirements
Pacific Gas and Electric Company
P. O. Box 770000, Mail Code B9A
San Francisco, CA 94177

TABLE OF CONTENTS
1996 AGRICULTURAL PROGRAM EVALUATION APPENDICES

APPENDIX A - SELF REPORT ANALYSIS AND MODEL RESULTS..... A-1
 OVERVIEW A-1
 METHODOLOGY A-1
 DATA SOURCES..... A-3
 MODEL DIAGNOSTICS..... A-3
 MODEL RESULTS..... A-4

**APPENDIX B - FINAL EEI PARTICIPANT TELEPHONE SURVEY WITH RESPONSE FREQUENCIES
..... B-1**

**APPENDIX C - FINAL EEI NONPARTICIPANT TELEPHONE SURVEY WITH RESPONSE
FREQUENCIES C-1**

**APPENDIX D - FINAL EMS PARTICIPANT TELEPHONE SURVEY WITH RESPONSE
FREQUENCIES D-1**

APPENDIX E - ENGINEERING TECHNICAL ANALYSIS E-1
 OVERVIEWE-1
 DATA SOURCES.....E-1
 PUMPING END USEE-3
 LIGHTING END USEE-15
 ENERGY MANAGEMENT SERVICESE-22

APPENDIX F - FINAL ON-SITE INSTRUMENT.....F-1

APPENDIX G - COSTING PERIOD ALLOCATION TABLE..... G-1
 GROSS DEMAND AND ENERGY SAVINGS BY COSTING PERIOD FOR THE AEEI PROGRAM – PUMPING END USE... G-1
 GROSS DEMAND AND ENERGY SAVINGS BY COSTING PERIOD FOR THE AEEI PROGRAM – INDOOR LIGHTING END
 USE G-2
 GROSS DEMAND AND ENERGY SAVINGS BY COSTING PERIOD FOR THE AEMS PROGRAM..... G-3

APPENDIX H - PUMP TEST DATA SUMMARIES..... H-1

Appendix A - Self Report Analysis and Model Results

Overview

As mentioned in the main body of the report, the focus of this approach is to determine whether the program participants would have installed the measures in the absence of the programs. Self-reported responses from the telephone survey of AEEI participants were used to find out whether customers would have installed the same measures if the program were not offered. Responses were then used to identify whether a customer is a free rider or not. After determining whether the customer as a free rider, a free-ridership model is developed to predict whether a customer is a free rider or not based on customer characteristics. The program effects are defined as one minus the average predicted free-ridership. Thus, this approach, approved through a CADMAC waiver, uses stated intentions regarding the role of the program in installing program measures, but it does not make use of a comparison group as required by the Protocols.

Methodology

The following three questions from the participant survey were considered to define free-ridership.

1. Q15a (of participant survey). How important would the availability of a rebate be in your decision to install high efficiency equipment?
2. Q25 (of participant survey). Did you hear about PG&E's rebate program before or after you picked out the specific equipment to buy?
3. Q27 (of participant survey). If the PG&E rebate had not been available, how likely is it you would have installed the same energy-efficient equipment?

One option is to use the responses of only one of the above question. However, The Quality Assurance Guidelines For Statistical, Engineering, and Self-Report Methods for Estimating DSM Program Impacts states that "... Using multiple questionnaire items (both quantitative and qualitative) to measure one construct is preferable to using only one item....". (Richard Ridge et. al. 1997). Therefore the option of using responses to only one question is not appropriate.

The second option is to use responses to more than one question. If responses to all the three questions or any two questions are used then, from the frequencies, we gather that free ridership is less than 5% for indoor lighting measures and less then 17% for the pumping and related end use. This implies a very high net-to-gross ratio for both end uses. However, since most of the customers are not free riders, it becomes almost impossible to develop a logistic regression model predicting free ridership. The reason for such low free ridership is due to inconsistent answers to two or more questions that were asked. There are two possible reasons for such inconsistencies. One possibility is that the respondent may want to give an answer that he thinks will be pleasing to the interviewer. The direction of this bias would be unclear – up or down, depending on what the respondent thinks the interviewer wants to hear. The second possibility is that some people will like to portray themselves in a positive light; e.g., they might like to think that they would have installed energy-efficient equipment without any incentive. This type of motivation could result in an artificially low net-to-gross ratio. To avoid such bias, we tried to identify the inconsistent responses by participants of the pumping and related and indoor lighting end uses.

In order to be conservative while estimating the net-to-gross ratio using self-report analysis, to pay attention to inconsistent responses, and to be able to develop a logistic regression model, we were forced to take the following approach to define free ridership.

Responses from following two questions were used.

1. Q15a (of participant survey). How important would the availability of a rebate be in your decision to install high efficiency equipment?
2. Q27 (of participant survey). If the PG&E rebate had not been available, how likely is it you would have installed the same energy-efficient equipment?

In this approach, all participating customers are assumed to be free riders. The participants with inconsistent responses are not considered free riders. For example, if customers responded to Q27 that they were very likely to have installed the same energy-efficient equipment even if the rebate was not offered to them, and responded to Q15a that availability of rebate is very important factor in deciding to install efficient equipment, they are not free riders.

For the pumping and related end use, 19 out of a total of 49 participants gave inconsistent responses and, therefore, are not considered free riders. For indoor lighting measures, 28 out of a total of 48 participants responded that they were very or somewhat likely to have implemented the same measures if the rebate was not offered and at the same time considered the availability of the rebate as very or somewhat important in deciding to implement efficient equipment. Thus, without estimating the predicted free-ridership, the apparent net-to-gross ratio for the pumping and related end use, using self-reports, is 39%. For the indoor lighting model, it is 58%. It is important to note that in using the self report analysis incorporating all three questions, the net-to-gross ratio are much higher than these. However, in order for us to be able to estimate a free-ridership model, we have selected the approach that gives us lower net-to-gross ratios and thereby leave some variation in responses. The free ridership model can be expressed as:

$$FR_i = \frac{e^{(bZ_i)}}{1 + e^{(bZ_i)}}$$

Where,

FR_i = the probability that customer “i” is a free rider in the 1996 AEEI program,

Z_i = a vector of explanatory variables that include factors affecting customer i’s status as a free-rider or not a free-rider,

β = a vector of estimated coefficients that maximizes FR_i

And the net-to-gross ratio for each end use is calculated as:

$$\left(\begin{array}{c} \text{Self Report} \\ \text{Net - To - Gross} \\ \text{Ratio for end use j} \end{array} \right) = 1 - \left(\begin{array}{c} \text{Average Predicted Probability of} \\ \text{Free ridership for end use j} \end{array} \right)$$

The model results that predict the probability of free ridership for both end uses and the data sources to get information on the variables used in the model are discussed in subsequent sections.

Data Sources

Self-report analysis requires information on the stated intentions, particularly regarding what would the customer have done if the program is not offered. Further, to use these stated intentions, and model them to estimate the predicted probability of the customer being a free-rider, information is required on customer characteristics such as attitudes, beliefs, and opinions about conservation.

A free-ridership model for both end uses is specified assuming that each decision constitutes a unit. A total of 49 participants of the pumping and related end use and 48 participants of the indoor lighting end use were included in the analysis. Separate free-ridership models for the two end uses were estimated, using in each model only a subset of participants (decision-makers) who implemented efficient measures for that end use.

Mainly, two sources of information were used.

(1) Telephone Survey: For estimating free-ridership models, it was important to capture the effects of customer characteristics on the stated intention of the customer for a particular measure type. The combination of explanatory variables varied for end-use-specific free-ridership models. A set of customer characteristics was drawn from the information contained in the telephone surveys for participants. Repeated contact was avoided while collecting information via the telephone survey. A total of 67 participants were interviewed. Since 67 participants were involved in a total of 97 decisions, using 67 complete surveys, data for 97 decisions were simulated. Thus, the telephone survey information was available for a total of 97 customer decisions.

(2) Billing data: Billing data from PG&E provided information on the SIC code, kWh consumption, and the location of all the participants and nonparticipants. Billing data for the 97 surveyed customer decisions were pulled from the billing files provided by PG&E.

Model Diagnostics

As in estimation of any statistical models, a coefficient was estimated for each explanatory variable. A positive coefficient in the free-ridership model indicates that the factor represented by the variable increases the probability that the customer is a free rider. A negative coefficient for a variable in the free-ridership model indicates that the factor represented by the variable decreases the probability that the customer is a free rider.

Wald Chi-square - As an indication of the explanatory power of each variable, a Wald-statistic was also produced for each coefficient. Wald Chi-square is computed as the square of the value obtained by dividing the parameter estimate by its standard error. As a general rule, the larger the magnitude of the Wald-statistic (Chi-square distribution), the greater the explanatory power of the variable. In particular, if the Wald-statistic has a magnitude exceeding 1.32, then the hypothesis that the coefficient is zero can be rejected at the seventy-five percent significance level.

Percentage of Probabilities Correctly Predicted - As part of the logistic procedures, SAS provides a concordant index that reflects the percentage of probabilities correctly predicted. This statistic helps assess the quality of the logistic model. In a relative sense, a model with higher values for the concordant index has a better predictive ability than a model with lower values for the concordant index.

Max-rescaled R-square - A rescaled generalized coefficient of determination (Max-rescaled R-Square) is a formal statistical test for the goodness-of-fit of the logistic regression model. It gives an objective measure of how well the specified model fits the data. The values of adjusted R-square can range between 0 and 1. As a general rule, a higher value of Max-rescaled R-Square indicates a better fit.

Log Likelihood at zero and at convergence. - Generally, it is expected that a binary choice model without any explanatory variables has less explanatory power than a model with an appropriate combination of explanatory variables reflecting the customer's characteristics. Hence, it is expected, that for any model, Log Likelihood at convergence (that model with parameter estimates that maximize the likelihood function) will be higher than the Log Likelihood at zero (that model with all parameter estimates set to zero). As a result, we can judge how well a particular combination of explanatory variables describes the customers' choices by comparing the Log Likelihood at convergence with the Log Likelihood at zero. The difference between these values indicates the explanatory power of the model with a higher difference suggesting a higher explanatory power.

The model results presented in the two exhibits were compared with the results of the many other alternative model specifications on the basis of the above mentioned criteria. The possibility of serious collinearity among any explanatory variables in all the models was also explored by examining the correlation matrix of the explanatory variables. The sensitivity of the results was tested for any possible collinearity. Variables with high correlation affected the estimated coefficients and the resultant net-to-gross ratios. Of the two variables with high correlation, one of the two variables was selected primarily on the basis of two criteria: (1) explanatory power of the variable as determined by the correlation with the dependent variable, and (2) contribution to the predictive power of the model as measured by the percentage correctly predicted. Out of two highly correlated variables, the variable with higher explanatory power is preferred. The variable that contributes more to the predictive power as measured by concordant is preferred.

Model Results.

A logistic regression model predicting free ridership was developed for both the end uses. The dependent variable in the logit model was derived based on the observed inconsistency. Then a set of independent variables was used from the survey data to predict the probability of a customer being a free-rider. The model results are presented in the following exhibits.

Pumping and related end use. - As mentioned earlier, 19 out of a total of 49 participants for the pumping and related end use gave inconsistent responses and therefore are not free riders. The remaining 30 participants are defined as free riders. Using this as a binary indicator of free riders, a model was developed to predict the free-ridership for the pumping and related end use.

The results of the pumping and related end use free-ridership model is presented in Exhibit A.1.

Exhibit A.1

Results of Free ridership Model for the Pumping and related End Use.

Explanatory Variables	Parameter Estimates	Wald Chi-Square
Intercept	9.5*	6.27
Importance of improving the efficiency of the equipment at business site.	-2.36*	2.18
Dummy = 1 if primary source of information is a brochure in the mail or a bill insert	2.24*	3.62
Familiarity with PG&E's energy efficiency programs.	-1.01	1.76
Annual kWh usage category	-1.34*	6.46
Dummy=1 if the customer considers business operated as a company	-2.24*	5.34
Dummy =1 if a farm manager is the decision maker to install energy-efficient improvements	2.68*	3.58
Number of observations (i.e. participants)	49	
Percentage of probabilities correctly predicted (Concordant)	92%	
Adjusted R square	0.6	
-2(LLR-LLU)	31.7	

All the coefficients without brackets are statistically different from zero at 95% significance level. Those marked * are statistically different from zero at 99% significance level.

Results of the free ridership model for the pumping and related end use indicate that the model predicts the probability of a customer being a free rider correctly for 92% of the customers. The results indicated that:

- If the primary source of information regarding efficient equipment is a bill insert or a brochure in the mail, then customers are likely to be a free rider. Or if the decisions regarding efficient installations are taken by a farm manager, then customer is likely to be a free rider.
- Whereas if energy efficiency is important to the customers, if they are familiar with PG&E's programs, if the customers thought their company is managed as a company, or if the annual usage is high, then they are less likely to be free-riders. This also suggests that these customers are less likely to be consistent with their responses to the two questions. Using

estimated coefficients of this model, probability of free-ridership was predicted for each participant of the pumping and related end use. Then, free-ridership was calculated as the average predicted probabilities across all participants of the pumping and related end use. We found that the average predicted probability across all participants of the pumping and related end use is 0.62. This gives us a net-to-gross ratio of 38%.

Indoor lighting end use. - As mentioned earlier, 28 out of a total of 48 participants for the indoor lighting end use gave inconsistent responses and therefore are not free riders. The remaining 20 participants are defined as free riders. Using this as a binary indicator of free riders, a model was developed to predict the free-ridership for the indoor lighting end use.

The results of indoor lighting end use free ridership model is presented in ExhibitA.2.

Exhibit A.2
Results of Free ridership Model for Indoor lighting End Use

Explanatory Variables	Parameter Estimates	Wald Chi-Square
Intercept	10.00*	2.85
Importance of improving the efficiency of the equipment at business site.	1.54*	2.53
Helpfulness of PG&E representative in making the customer aware of any programs	0.72*	2.69
Number of times customer participated prior to 1996	0.48	1.35
Dummy=1 if became aware about the program before customer started collecting information about new equipment	2.09*	2.51
Dummy =1 if a packing plant, winery, or a dairy farm	0.8	1.13
Dummy=1 if the customer considers business operated as a company	-1.14*	1.99
Dummy=1 if the customer categorize the business small	-1.04	1.20
Number of observations (i.e. participants)	47	
Percentage of probabilities correctly predicted (Concordant)	82%	
Adjusted R square	0.4	
-2(LLR-LLU)	16.7	

All the coefficients without brackets are significantly different from zero at 75% significance level. Those marked * are statistically different from zero at 99% significance level.

Results of the free ridership model for the indoor lighting end use indicate that the model predicts the probability of a customer being a free rider correctly for 82% of the customers. The results indicated that:

- If customers think their business is operated like a company, or if their business is small compared to other similar business, then they are less likely to be free riders.

- Whereas if energy efficiency is important to the customers, if they have participated in similar programs by PG&E prior to 1996, or if the customers became aware of the program before they started to collect the information regarding new equipment, then they are more likely to be free riders. This also suggests that these customers are likely to give consistent responses to survey questions. Using the estimated coefficients of this model, the probability of free-ridership was predicted for each participant of the indoor lighting end use. Then, the free-ridership was calculated as the average predicted probabilities across all participants of the indoor lighting end use. The resulting average predicted probability across all participants of the indoor lighting end use is 0.41. This produces a net-to-gross ratio of 59%.

The estimated net-to-gross ratios using the self-report analysis are presented in Exhibit A.3.

Exhibit A.3
End Use Specific Net-To-Gross Ratios Using Self-Report Analysis

	Pumping and related	Indoor lighting
Estimate of net-to-gross	38%	59%
Confidence Interval*	35%---92%	6%---98%

*Confidence interval around Self-Report net-to-gross is derived using consistency and inconsistency of the responses.

The net-to-gross ratio for the pumping and related end use suggests that, on average, six out of ten customer decisions would have installed efficient pumping and related measures without any incentive. Whereas, four out of ten customer decisions would have installed efficient indoor lighting measures without any incentive. The net-to-gross ratio for the indoor lighting end use is higher than that of the pumping and related end use. The range within which the self-report net-to-gross ratios vary is 57% for the pumping and related end use and 92% for the indoor lighting end use.

It is important to note that these self-report net-to-gross ratios are not used for filing purposes. The Protocol requires a contrasting of participants with a nonparticipant comparison group, and self-report analysis presented in this appendix does not compare participants with nonparticipants. Therefore, these results were not used for filing purposes.

Appendix B - Final EEI Participant Telephone Survey with Response Frequencies

START OF SURVEY

TIME STARTED: C208-211

1. PG&E records indicate that (BUSINESS) implemented (MEASURE) and received a rebate in 1996. Is this correct? **C212-213**

Yes..... 11 (GO TO Q3)
 No 12 (ASK Q2)

Q1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	67	100.0	67	100.0

IF NO, ASK:

2. Why is this incorrect (READ LIST)? **C214-215**

You did not implement this measure 11 (THANK AND TERM.)

You did not receive a rebate for this measure..... 12 (THANK AND TERM.)

We have the incorrect business or organization name..... 13

SPECIFY CORRECTION: _____

We have the incorrect measure 14

SPECIFY CORRECTION: _____

(IF CODE 13 OR 14 CONTINUE AFTER GETTING CORRECT

INFO.)

Q2	Frequency	Percent	Cumulative Frequency	Cumulative Percent

Frequency Missing = 67

3. First, I would like to ask you some general questions about your business or organization. How would you classify your business or organization? (READ LIST AND ENTER ALL THAT APPLY) "Yes" to item denoted by "1" in column. "No" denoted by "0" in column.

a. General Farm	11	C217
b. Ranch	12	C218
c. Ornamental Nursery	13	C219
d. Indoor Crops	14	C220
e. Packing Plant	15	C221
f. Winery	16	C222
g. Dairy Farm	17	C223
h. Water District	18	C224
i. Other _____	... 19	C225
Specify		
j. Don't Know (DO NOT READ).....	77	C226
k. Refused (DO NOT READ).....	88	C227
l. Cold Storage	20	C228

Q3A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	43	64.2	43	64.2
1	24	35.8	67	100.0

Q3B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	57	85.1	57	85.1
1	10	14.9	67	100.0

Q3C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	62	92.5	62	92.5
1	5	7.5	67	100.0

Q3D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	64	95.5	64	95.5
1	3	4.5	67	100.0

Q3E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	56	83.6	56	83.6
1	11	16.4	67	100.0

Q3F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	66	98.5	66	98.5
1	1	1.5	67	100.0

Q3G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	64	95.5	64	95.5
1	3	4.5	67	100.0

Q3H	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	59	88.1	59	88.1
1	8	11.9	67	100.0

Q3I	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	59	88.1	59	88.1
1	8	11.9	67	100.0

Other responses

- Vineyard (not a winery).
- Trucking is a major part.
- Government fire department.
- Truck dealership.
- Mushroom company.
- Seed research company.
- Parts distributor/diesel engines.
- Public resources.

Q3J	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	100.0	67	100.0

Q3K	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	100.0	67	100.0

Q3L	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	65	97.0	65	97.0
1	2	3.0	67	100.0

4. Compared to other businesses or organizations similar to yours, would you categorize this business or organization as small, medium or large? **C230-231**

Small	11
Medium	12
Large	13
Don't Know	77
Refused	88

Q4	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	14	20.9	14	20.9
12	30	44.8	44	65.7
13	22	32.8	66	98.5
77	1	1.5	67	100.0

5. How long has your company or organization been operating at this location? (READ LIST) **C232-233**

1 to 3 years	11
4 to 10 years	12
More than 10 years	13
Don't Know (DO NOT READ)	77
Refused (DO NOT READ)	88

Q5	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	7.5	5	7.5
12	8	11.9	13	19.4
13	54	80.6	67	100.0

ASK EVERYONE:

6. Would you consider your business or organization operated by a family or a company? **C234-235**

Family	11
Company	12
Not applicable.....	13
Don't Know.....	77
Refused	88

Q6	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	39	58.2	39	58.2
12	23	34.3	62	92.5
13	5	7.5	67	100.0

IF PUMP SAMPLE (C102=1), ASK:

7. How many pumps do you have under your control? **C236-238** (SPECIFY #)

Q7	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	1	3.0	1	3.0
2	1	3.0	2	6.1
3	3	9.1	5	15.2
4	3	9.1	8	24.2
5	1	3.0	9	27.3
6	1	3.0	10	30.3
7	3	9.1	13	39.4
8	1	3.0	14	42.4
10	2	6.1	16	48.5
12	1	3.0	17	51.5
16	1	3.0	18	54.5
20	1	3.0	19	57.6
25	1	3.0	20	60.6
28	1	3.0	21	63.6
30	2	6.1	23	69.7
36	1	3.0	24	72.7
40	2	6.1	26	78.8
45	1	3.0	27	81.8
60	1	3.0	28	84.8
75	1	3.0	29	87.9
80	1	3.0	30	90.9
84	1	3.0	31	93.9
100	1	3.0	32	97.0
200	1	3.0	33	100.0

Frequency Missing = 34

8. On average, how many months per year are the pumps in use? (READ LIST) **C239-240**

Less than 3 months per year.....	11
3-6 months per year	12
7-9 months per year	13
Year round.....	14
Don't Know (DO NOT READ).....	77
Refused (DO NOT READ).....	88

Q8	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	7	21.2	7	21.2
13	15	45.5	22	66.7
14	11	33.3	33	100.0

Frequency Missing = 34

9. If you grow crops, do you grow annual or permanent crops? **C241-242**

Annual.....	11
Permanent.....	12
Both annual and permanent.....	13

Don't grow crops.....	14
Don't Know.....	77
Refused.....	88

(GO TO Q13)

Q9	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	8	24.2	8	24.2
12	5	15.2	13	39.4
13	12	36.4	25	75.8
14	6	18.2	31	93.9
77	2	6.1	33	100.0

Frequency Missing = 34

IF LIGHTING SAMPLE (C102=2), ASK:

Next I'd like to ask you a few questions about your site. If a residence is included in the accounts for this site, please exclude the residence when you answer the following questions.

10. In what year was your facility built? C243-246 (SPECIFY YEAR)

Q10	Frequency	Percent	Cumulative Frequency	Cumulative Percent
000&	1	2.9	1	2.9
0096	1	2.9	2	5.9
1926	1	2.9	3	8.8
1929	1	2.9	4	11.8
1930	2	5.9	6	17.6
1932	1	2.9	7	20.6
1940	1	2.9	8	23.5
1948	1	2.9	9	26.5
1956	1	2.9	10	29.4
1957	2	5.9	12	35.3
1958	1	2.9	13	38.2
1960	2	5.9	15	44.1
1962	1	2.9	16	47.1
1967	2	5.9	18	52.9
1972	3	8.8	21	61.8
1973	1	2.9	22	64.7
1974	1	2.9	23	67.6
1977	1	2.9	24	70.6
1978	4	11.8	28	82.4
1979	2	5.9	30	88.2
1989	1	2.9	31	91.2
1993	1	2.9	32	94.1
1994	1	2.9	33	97.1
1996	1	2.9	34	100.0

Frequency Missing = 33

11. Was the total area of the facility altered in 1995 or 1996?	C247-248
Yes.....	11
No.....	12

Don't Know..... 77
 Refused 88

Q11	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	7	20.6	7	20.6
12	24	70.6	31	91.2
77	3	8.8	34	100.0

Frequency Missing = 33

12. Approximately, what percent of the time are the lights at your facility on, annually?

C249-251 (SPECIFY %)

(GO TO Q13)

Q12	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	2	5.9	2	5.9
005	1	2.9	3	8.8
020	1	2.9	4	11.8
025	1	2.9	5	14.7
030	2	5.9	7	20.6
033	1	2.9	8	23.5
035	2	5.9	10	29.4
040	5	14.7	15	44.1
045	1	2.9	16	47.1
050	3	8.8	19	55.9
051	1	2.9	20	58.8
060	2	5.9	22	64.7
065	2	5.9	24	70.6
067	1	2.9	25	73.5
070	2	5.9	27	79.4
075	3	8.8	30	88.2
080	2	5.9	32	94.1
095	1	2.9	33	97.1
100	1	2.9	34	100.0

Frequency Missing = 33

ASK EVERYONE:

13. Typically, who decides to install energy-efficient improvements? (READ LIST) (ENTER ALL THAT APPLY) "Yes" to item denoted by "1" in column. "No" denoted by "0" in column.

- a. The owner(s)..... 11 **C252**
- b. A partner or partners 12 **C253**
- c. The farm manager 13 **C254**
- d. An Ag Engineer or a consultant..... 14 **C255**
- e. It's a group decision process..... 15 **C256**
- f. Other (DO NOT READ)_____ 16 **C257**
(Specify)
- g. Don't Know (DO NOT READ)..... 77 **C258**
- h. Refused (DO NOT READ)..... 88 **C259**
- i. **Site/plant/operations manager** **17** **C260**

Q13A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	37	55.2	37	55.2
1	30	44.8	67	100.0

Q13B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	64	95.5	64	95.5
1	3	4.5	67	100.0

Q13C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	56	83.6	56	83.6
1	11	16.4	67	100.0

Q13D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	66	98.5	66	98.5
1	1	1.5	67	100.0

Q13E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	48	71.6	48	71.6
1	19	28.4	67	100.0

Q13F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	64	95.5	64	95.5
1	3	4.5	67	100.0

Q13G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	100.0	67	100.0

Q13H	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	100.0	67	100.0

Q13I	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	62	92.5	62	92.5
1	5	7.5	67	100.0

Other responses

- Sons/Vice Presidents.
- Board of Directors.
- Board of Directors.

14. Which of these financial methods do you typically use to evaluate energy-efficiency improvements? (READ LIST) **C263-264**
- Simple payback 11
 - Lowest First Cost..... 12
 - A more complex financial analysis..... 13
 - Don't know (DO NOT READ) 77
 - Refused (DO NOT READ)..... 88

Q14	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	36	53.7	36	53.7
12	12	17.9	48	71.6
13	17	25.4	65	97.0
77	2	3.0	67	100.0

15. How would you rate the importance of improving the efficiency of the equipment at your site?
(READ LIST) C265-266

- Very important 11
- Somewhat important..... 12
- Not too important 13
- Not at all important..... 14
- Don't Know (DO NOT READ) 77
- Refused (DO NOT READ)..... 88

Q15	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	51	76.1	51	76.1
12	15	22.4	66	98.5
13	1	1.5	67	100.0

ASK EVERYONE:

Please rate the importance of the following factors in any decision to install high-efficiency equipment.

16. How important would (ITEM) be in your decision to install high-efficiency equipment? Would that be: (READ LIST)?

					(DO NOT READ)		
	Very Important	Somewhat Important	Not too Important	Not at all Important	Don't Know	Refused	
a. The availability of a rebate	11	12	13	14	77	88	C308-309
b. The low performance of current equipment	11	12	13	14	77	88	C310-311
c. A low purchase cost	11	12	13	14	77	88	C312-313
d. An expected reduction of operating costs	11	12	13	14	77	88	C314-315
e. A low maintenance cost	11	12	13	14	77	88	C316-317
f. A lower energy bill	11	12	13	14	77	88	C318-319
g. The questionable reliability of your current equipment	11	12	13	14	77	88	C320-321
h. Having a lower environmental impact	11	12	13	14	77	88	C322-323
i. Improving the resale value of the property	11	12	13	14	77	88	C324-325
j. The general health of the economy	11	12	13	14	77	88	C326-327

Q16A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	36	53.7	36	53.7
12	27	40.3	63	94.0
13	4	6.0	67	100.0

Q16B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	42	62.7	42	62.7
12	19	28.4	61	91.0
13	4	6.0	65	97.0
14	2	3.0	67	100.0

Q16C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	38	56.7	38	56.7
12	23	34.3	61	91.0
13	4	6.0	65	97.0
14	2	3.0	67	100.0

Q16D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	49	73.1	49	73.1
12	15	22.4	64	95.5
13	2	3.0	66	98.5
14	1	1.5	67	100.0

Q16E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	47	70.1	47	70.1
12	16	23.9	63	94.0
13	4	6.0	67	100.0

Q16F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	56	83.6	56	83.6
12	10	14.9	66	98.5
13	1	1.5	67	100.0

Q16G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	38	56.7	38	56.7
12	25	37.3	63	94.0
13	3	4.5	66	98.5
77	1	1.5	67	100.0

Q16H	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	21	31.3	21	31.3
12	33	49.3	54	80.6
13	7	10.4	61	91.0
14	5	7.5	66	98.5
77	1	1.5	67	100.0

Q16I	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	11	16.4	11	16.4
12	26	38.8	37	55.2
13	13	19.4	50	74.6
14	16	23.9	66	98.5
77	1	1.5	67	100.0

Q16J	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	15	22.4	15	22.4
12	31	46.3	46	68.7
13	13	19.4	59	88.1
14	6	9.0	65	97.0
77	2	3.0	67	100.0

Now I want to ask you some questions about your current and or previous participation in PG&E programs and your PG&E service representative.

17. How familiar are you with PG&E's energy-efficiency programs? Would you say you are: (READ LIST)? **C328-329**

- Very familiar 11
- Somewhat familiar..... 12
- Not too familiar 13
- Not at all familiar..... 14
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

Q17	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	20	29.9	20	29.9
12	36	53.7	56	83.6
13	9	13.4	65	97.0
14	2	3.0	67	100.0

18. What are the primary sources of advice and information you use when planning to invest in energy using equipment? (READ LIST AND ENTER ALL THAT APPLY).

“Yes” to item denoted by “1” in column. “No” denoted by “0” in column.

- a. A PG&E service representative 11 **C331**
- b. A PG&E brochure in the mail or a bill insert 12 **C332**
- c. A vendor or contractor 13 **C333**
- d. General media like television, radio, or the newspaper..... 14 **C334**
- e. Word of mouth..... 15 **C335**
- f. Don't Know (DO NOT READ)..... 77 **C336**
- g. Refused (DO NOT READ) 88 **C337**

Q18A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	16	23.9	16	23.9
1	51	76.1	67	100.0

Q18B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	47	70.1	47	70.1
1	20	29.9	67	100.0

Q18C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	31	46.3	31	46.3
1	36	53.7	67	100.0

Q18D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	60	89.6	60	89.6
1	7	10.4	67	100.0

Q18E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	44	65.7	44	65.7
1	23	34.3	67	100.0

Q18F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	100.0	67	100.0

Q18G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	100.0	67	100.0

19. How helpful was your PG&E representative in: (ITEM). (READ LIST.)

					(DO NOT READ)		
	Very Helpful	Somewh at Help-ful	Not too Helpful	Not at all Helpful	Don't now	Refused	
a. Making you aware of any programs	11	12	13	14	77	88	C342-343
b. Letting you know energy-efficient equipment options	11	12	13	14	77	88	C344-345

Q19A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	49	73.1	49	73.1
12	9	13.4	58	86.6
13	7	10.4	65	97.0
14	2	3.0	67	100.0

Q19B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	36	53.7	36	53.7
12	16	23.9	52	77.6
13	9	13.4	61	91.0
14	1	1.5	62	92.5
77	5	7.5	67	100.0

ASK EVERYONE:

20. Within the past two years and before you participated in the retrofit program, did you have a pump test or a site survey done by PG&E?

Yes.....	11	C346-347
No.....	12	
Don't Know.....	77	
Refused.....	88	

Q20	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	41	61.2	41	61.2
12	24	35.8	65	97.0
77	2	3.0	67	100.0

21. How many times did you participate in PG&E's energy-efficiency programs before 1996?
(READ LIST) **C348-349**

Once..... 11
 Twice 12
 Several times 13
 Never..... 14
 Don't Know (DO NOT READ) 77
 Refused (DO NOT READ) 88

Q21	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	9	13.4	9	13.4
12	11	16.4	20	29.9
13	27	40.3	47	70.1
14	16	23.9	63	94.0
77	4	6.0	67	100.0

22. How many times did PG&E's service representative contact you before 1996? (READ LIST)
 **C350-351**

Once..... 11
 Twice 12
 Several times 13
 Never..... 14
 Don't Know (DO NOT READ) 77
 Refused (DO NOT READ) 88

Q22	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	1.5	1	1.5
12	6	9.0	7	10.4
13	41	61.2	48	71.6
14	16	23.9	64	95.5
77	3	4.5	67	100.0

ASK EVERYONE:

23. Did you hear about PG&E's rebate program before or after you began thinking about replacing your equipment?.....**C352-353**

Before 11 (GO TO Q27)
 After..... 12 (ASK Q24)
 Don't Know..... 77 (ASK Q24)
 Refused 88 (GO TO Q27)

Q23	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	49	73.1	49	73.1
12	18	26.9	67	100.0

IF Q23 = "AFTER" OR "DON'T KNOW," ASK:

24. Did you hear about PG&E's rebate program before or after you started to look for or collect information about the new equipment? **C354-355**
- Before..... 11 (GO TO Q27)
 After..... 12 (ASK Q25)
 Don't Know..... 77 (ASK Q25)
 Refused..... 88 (GO TO Q27)

Q24	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	6	33.3	6	33.3
12	12	66.7	18	100.0

Frequency Missing = 49

IF Q24 = "AFTER" OR "DON'T KNOW," ASK:

25. Did you hear about PG&E's rebate program before or after you picked out the specific equipment to buy? **C356-357**
- Before..... 11 (GO TO Q27)
 After..... 12 (ASK Q26)
 Don't Know..... 77 (ASK Q26)
 Refused..... 88 (GO TO Q27)

Q25	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	33.3	4	33.3
12	8	66.7	12	100.0

Frequency Missing = 55

IF Q25 = "AFTER" OR "DON'T KNOW," ASK:

26. Did you hear about PG&E's rebate program before or after you replaced the equipment? **C358-359**
- Before..... 11
 After..... 12
 Don't Know..... 77
 Refused..... 88

(GO TO Q27)

Q26	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	62.5	5	62.5
12	3	37.5	8	100.0

Frequency Missing = 59

ASK EVERYONE:

27. If the PG&E rebate had not been available, how likely is it you would have installed the same energy-efficient equipment? (READ LIST) **C360-361**
- Very likely..... 11
 - Somewhat likely 12
 - Not too likely..... 13
 - Not at all likely 14
 - Don't Know (DO NOT READ) 77
 - Refused (DO NOT READ) 88

Q27	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	30	44.8	30	44.8
12	22	32.8	52	77.6
13	7	10.4	59	88.1
14	8	11.9	67	100.0

ASK EVERYONE:

28. How long did you take to decide to participate after becoming aware of the PG&E rebate program? (READ LIST)..... **C362-363**
- Less than 6 months..... 11
 - 6-9 months 12
 - 9-12 months 13
 - More than a year 14
 - Don't Know (DO NOT READ) 77
 - Refused (DO NOT READ)..... 88

Q28	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	52	77.6	52	77.6
12	10	14.9	62	92.5
13	4	6.0	66	98.5
77	1	1.5	67	100.0

The last set of questions I have for you are questions about energy-efficient equipment you may have installed in 1996 and for which you did not get a rebate.

29. After getting a rebate in 1996, have you repaired any deep well pumps without applying for a rebate?C364-365

- Yes.....11 (ASK Q30)
- No.....12 (GO TO Q34)
- Don't Know.....77 (GO TO Q34)
- Refused88 (GO TO Q34)

Q29	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	11	16.4	11	16.4
12	55	82.1	66	98.5
77	1	1.5	67	100.0

IF YES, ASK:

30. How many deep well pumps did you repair without a rebate? C366-368 (SPECIFY #)

Q30	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	3	27.3	3	27.3
2	4	36.4	7	63.6
3	4	36.4	11	100.0

Frequency Missing = 56

31. Why did you repair these non-rebated pumps? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C408-409
b. The current equipment was not performing well	11	12	77	88	C410-411
c. You were worried about equipment reliability	11	12	77	88	C412-413
d. Your previous experience with pump repairs	11	12	77	88	C414-415
e. Any other reason? (SPECIFY)	11	12	77	88	C416-417

Q31A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	8	72.7	8	72.7
12	3	27.3	11	100.0

Frequency Missing = 56

Q31B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	7	63.6	7	63.6
12	4	36.4	11	100.0

Frequency Missing = 56

Q31C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	45.5	5	45.5
12	6	54.5	11	100.0

Frequency Missing = 56

Q31D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	36.4	4	36.4
12	7	63.6	11	100.0

Frequency Missing = 56

Q31E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	11	100.0	11	100.0

Frequency Missing = 56

32. Why didn't you apply for a rebate? (READ LIST) **C418-419**

- The rebate was too small 11
- It was too much of a hassle 12
- It was too late to apply..... 13
- You did not think about it..... 14
- You did not know about it 15
- Other (SPECIFY) _____ 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ)..... 88

Q32	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	18.2	2	18.2
13	1	9.1	3	27.3
14	2	18.2	5	45.5
15	3	27.3	8	72.7
16	3	27.3	11	100.0

Frequency Missing = 56

Other responses:

- Did not know if it was still in effect after 4 or 5 months
- Not covered under the program
- No rebate available for this

33. Would you have gotten your non-rebated pumps repaired if you had not received a rebate in 1996? **C420-421**

- Yes..... 11
- No..... 12
- Don't Know 77
- Refused..... 88

Q33	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	10	90.9	10	90.9
12	1	9.1	11	100.0

Frequency Missing = 56

ASK EVERYONE:

34. After getting a rebate in 1996, have you installed any low pressure sprinkler nozzles without applying for a rebate? **C422-423**

Yes..... 11 (ASK Q35)
 No 12 (GO TO Q41)
 Don't Know..... 77 (GO TO Q41)
 Refused 88 (GO TO Q41)

Q34	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	4.5	3	4.5
12	62	92.5	65	97.0
77	2	3.0	67	100.0

IF YES, ASK:

35. How many low pressure sprinkler nozzles did you install without a rebate? **C424-427** (SPECIFY #)

Q35	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0010	1	33.3	1	33.3
0250	1	33.3	2	66.7
1000	1	33.3	3	100.0

Frequency Missing = 64

36. Of these, how many replaced other sprinkler nozzles? **C708-711** (SPECIFY #)

Q36	Frequency	Percent	Cumulative Frequency	Cumulative Percent
10	1	33.3	1	33.3
250	1	33.3	2	66.7
1000	1	33.3	3	100.0

Frequency Missing = 64

37. Why did you install these non-rebated low pressure sprinkler nozzles? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused
a. The equipment was broken	11	12	77	88
b. The current equipment was not performing well	11	12	77	88
c. You wanted to improve equipment reliability	11	12	77	88

C430-431

C432-433

C434-435

d. Your previous experience with the energy efficiency of low pressure nozzles	11	12	77	88	C436-437
e. Any other reason? (SPECIFY) _____	11	12	77	88	C438-439

Q37A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	33.3	1	33.3
12	2	66.7	3	100.0
Frequency Missing = 64				

Q37B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	100.0	3	100.0
Frequency Missing = 64				

Q37C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	66.7	2	66.7
12	1	33.3	3	100.0
Frequency Missing = 64				

Q37D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	2	66.7	2	66.7
77	1	33.3	3	100.0
Frequency Missing = 64				

Q37E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	33.3	1	33.3
12	1	33.3	2	66.7
77	1	33.3	3	100.0
Frequency Missing = 64				

Other responses:
To save on utility bills

38. Why didn't you apply for a rebate? (READ LIST) **C440-441**

- The rebate was too small 11
- It was too much of a hassle..... 12
- It was too late to apply 13
- You did not think about it..... 14
- You did not know about it..... 15
- Other (SPECIFY) _____ 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ)..... 88
- The rebate was too small AND it was too much of a hassle..... 19**

Q38	Frequency	Percent	Cumulative Frequency	Cumulative Percent
15	2	66.7	2	66.7
19	1	33.3	3	100.0
Frequency Missing = 64				

39. Would you have installed these non-rebated low pressure sprinkler nozzles if you had not received a rebate in 1996?..... **C442-443**

Yes 11
 No..... 12
 Don't Know 77
 Refused..... 88

Q39	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	100.0	3	100.0

Frequency Missing = 64

40. How did you first learn about low pressure sprinkler nozzles? (READ LIST) **C444-445**

You were contacted by someone at PG&E 11
 You were contacted by a contractor or vendor 12
 Through media contact such as
 a bill insert, TV, radio, or brochure 13
 From word of mouth 14
 From previously participating in a program 15
 Other (DO NOT READ) 16
 Don't Know (DO NOT READ)..... 77
 Refused (DO NOT READ)..... 88

Q40	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	33.3	1	33.3
12	2	66.7	3	100.0

Frequency Missing = 64

ASK EVERYONE:

41. After getting a rebate in 1996, have you converted any sprinkler systems to micro irrigation systems or installed any new micro irrigation systems without applying for a rebate? **C446-447**

Yes..... 11 (ASK Q42)
 No 12 (GO TO Q48)
 Don't Know..... 77 (GO TO Q48)
 Refused 88 (GO TO Q48)

Q41	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	10	14.9	10	14.9
12	54	80.6	64	95.5
77	3	4.5	67	100.0

IF YES, ASK:

42. How many acres did you convert or install? **C448-450** (# OF ACRES)

Q42	Frequency	Percent	Cumulative Frequency	Cumulative Percent
001	2	20.0	2	20.0
005	1	10.0	3	30.0
008	1	10.0	4	40.0
010	1	10.0	5	50.0
025	1	10.0	6	60.0
032	1	10.0	7	70.0
035	1	10.0	8	80.0
150	1	10.0	9	90.0
400	1	10.0	10	100.0

Frequency Missing = 57

43. Of these, how many acres replaced old sprinkler systems? **C451-453** (# OF ACRES)

Q43	Frequency	Percent	Cumulative Frequency	Cumulative Percent
000	3	30.0	3	30.0
001	2	20.0	5	50.0
005	1	10.0	6	60.0
010	1	10.0	7	70.0
032	1	10.0	8	80.0
035	1	10.0	9	90.0
100	1	10.0	10	100.0

Frequency Missing = 57

44. Why did you install the micro irrigation system? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C454-455
b. The current equipment was not performing well	11	12	77	88	C456-457
c. You wanted to improve equipment reliability	11	12	77	88	C458-459
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C460-461
e. Any other reason? (SPECIFY)	11	12	77	88	C462-463
f. New installation/new building/expansion	11	12	Not applicable		C714-715

Q44A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	9	90.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 57

Q44B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	30.0	3	30.0
12	6	60.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 57

Q44C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	40.0	4	40.0
12	5	50.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 57

Q44D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	30.0	3	30.0
12	7	70.0	10	100.0

Frequency Missing = 57

Q44E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	50.0	5	50.0
12	5	50.0	10	100.0

Frequency Missing = 57

Other Responses:

- Better production, ease of operation, and efficiency
- New Planning
- Labor savings
- Better health of crops
- Water conservation / better crop growth

Q44F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	30.0	3	30.0
12	7	70.0	10	100.0

Frequency Missing = 57

45. Why didn't you apply for a rebate? (READ LIST)..... **C464-465**

- The rebate was too small.....11
- It was too much of a hassle12
- It was too late to apply13
- You did not think about it14
- You did not know about it.....15
- Other (SPECIFY)16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q45	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	20.0	2	20.0
14	3	30.0	5	50.0
15	4	40.0	9	90.0
16	1	10.0	10	100.0

Frequency Missing = 57

Other Responses
Still in process

46. Would you have installed the non-rebated micro irrigation system if you had not received a rebate in 1996? **C466-467**

- Yes.....11
- No.....12
- Don't Know.....77
- Refused88

Q46	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	10	100.0	10	100.0

Frequency Missing = 57

47. How did you first learn about micro irrigation systems? (READ LIST) **C468-469**

- You were contacted by someone at PG&E.....11
- You were contacted by a contractor or vendor.....12
- Through media contact such as
a bill insert, TV, radio, or brochure.....13
- From word of mouth.....14
- From previously participating in a program.....15
- Other (DO NOT READ).....16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q47	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	10.0	1	10.0
12	2	20.0	3	30.0
13	2	20.0	5	50.0
14	2	20.0	7	70.0
15	1	10.0	8	80.0
16	1	10.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 57

ASK EVERYONE:

48. After getting a rebate in 1996, have you installed any compact fluorescent lamps without applying for a rebate? **C470-471**

- Yes..... 11 (ASK Q49)
- No 12 (GO TO Q55)
- Don't Know..... 77 (GO TO Q55)
- Refused 88 (GO TO Q55)

Q48	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	7	10.4	7	10.4
12	58	86.6	65	97.0
77	2	3.0	67	100.0

IF YES, ASK:

49. How many compact fluorescent lamps did you install without a rebate? C472-474 (SPECIFY #)

Q49	Frequency	Percent	Cumulative Frequency	Cumulative Percent
005	2	28.6	2	28.6
010	1	14.3	3	42.9
012	1	14.3	4	57.1
024	1	14.3	5	71.4
050	1	14.3	6	85.7
300	1	14.3	7	100.0

Frequency Missing = 60

50. Of these, how many replaced old lamps? C475-477 (SPECIFY #)

Q50	Frequency	Percent	Cumulative Frequency	Cumulative Percent
002	1	14.3	1	14.3
005	1	14.3	2	28.6
010	1	14.3	3	42.9
012	1	14.3	4	57.1
024	1	14.3	5	71.4
050	1	14.3	6	85.7
150	1	14.3	7	100.0

Frequency Missing = 60

51. Why did you install compact fluorescent lamps? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C508-509
b. The current equipment was not performing well	11	12	77	88	C510-511
c. You wanted to improve equipment reliability	11	12	77	88	C512-513
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C514-515
e. Any other reason? (SPECIFY) _____	11	12	77	88	C516-517
f. New installation/new building/expansion	11	12	Not applicable		C716-717

Q51A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	28.6	2	28.6
12	5	71.4	7	100.0

Frequency Missing = 60

Q51B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	57.1	4	57.1
12	3	42.9	7	100.0

Frequency Missing = 60

Q51C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
12	5	71.4	6	85.7
77	1	14.3	7	100.0

Frequency Missing = 60

Q51D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	42.9	3	42.9
12	3	42.9	6	85.7
77	1	14.3	7	100.0

Frequency Missing = 60

Q51E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
12	6	85.7	7	100.0

Frequency Missing = 60

Other responses
Economy

Q51F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	28.6	2	28.6
12	5	71.4	7	100.0

Frequency Missing = 60

52. Why didn't you apply for a rebate? (READ LIST).....C518-519

- The rebate was too small.....11
- It was too much of a hassle12
- It was too late to apply13
- You did not think about it14
- You did not know about it.....15
- Other (SPECIFY)16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q52	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
12	2	28.6	3	42.9
15	1	14.3	4	57.1
16	2	28.6	6	85.7
19	1	14.3	7	100.0

Frequency Missing = 60

Other responses

- They would come one or two at a time
- Don't think I quality for polycarbonate

53. Would you have installed the non-rebated compact fluorescent lamps if you had not received a rebate in 1996?C520-521

- Yes.....11
- No12
- Don't Know.....77
- Refused88

Q53	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	57.1	4	57.1
12	3	42.9	7	100.0

Frequency Missing = 60

54. How did you first learn about compact fluorescent lamps? (READ LIST) **C522-523**

- You were contacted by someone at PG&E.....11
- You were contacted by a contractor or vendor.....12
- Through media contact such as
a bill insert, TV, radio, or brochure.....13
- From word of mouth.....14
- From previously participating in a program.....15
- Other (DO NOT READ).....16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q54	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	3	42.9	3	42.9
13	1	14.3	4	57.1
16	1	14.3	5	71.4
77	2	28.6	7	100.0

Frequency Missing = 60

ASK EVERYONE:

55. After getting a rebate in 1996, have you delamped any fluorescent fixtures without applying for a rebate? **C524-525**

- Yes..... 11 (ASK Q56)
- No 12 (GO TO Q63)
- Don't Know..... 77 (GO TO Q63)
- Refused 88 (GO TO Q63)

Q55	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	3.0	2	3.0
12	62	92.5	64	95.5
77	3	4.5	67	100.0

IF YES, ASK:

56. How many fluorescent fixtures did you delamp without a rebate? **C526-528** (SPECIFY #)

Q56	Frequency	Percent	Cumulative Frequency	Cumulative Percent
020	1	50.0	1	50.0
025	1	50.0	2	100.0

Frequency Missing = 65

57. On average, how many lamps did you take out per fixture? C529-531 (SPECIFY #)

Q57	Frequency	Percent	Cumulative Frequency	Cumulative Percent
002	2	100.0	2	100.0

Frequency Missing = 65

58. On average, how many lamps were left in the fixture? C532-534 (SPECIFY #)

Q58	Frequency	Percent	Cumulative Frequency	Cumulative Percent
000	1	50.0	1	50.0
002	1	50.0	2	100.0

Frequency Missing = 65

59. Why did you delamp these fluorescent fixtures? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. Of your previous experience with the energy efficiency of delamping	11	12	77	88	C535-536
b. You did not need the extra light	11	12	77	88	C537-538
c. Any other reason? (SPECIFY) _____	11	12	77	88	C539-540

Q59A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	50.0	1	50.0
12	1	50.0	2	100.0

Frequency Missing = 65

Q59B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	2	100.0	2	100.0

Frequency Missing = 65

Q59C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	100.0	2	100.0

Frequency Missing = 65

Other Response
 Upgrading
 To reduce ballast failure

60. Why didn't you apply for a rebate? (READ LIST)..... **C541-542**

- The rebate was too small.....11
- It was too much of a hassle12
- It was too late to apply13
- You did not think about it14
- You did not know about it.....15
- Other (SPECIFY) _____.....16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88
- The rebate was too small AND it was too much of a hassle 19**

Q60	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	1	50.0	1	50.0
19	1	50.0	2	100.0

Frequency Missing = 65

61. Would you have delamped these non-rebated fluorescent fixtures if you had not received a rebate in 1996? **C543-544**
- Yes.....11
 - No.....12
 - Don't Know.....77
 - Refused88

Q61	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	100.0	2	100.0

Frequency Missing = 65

62. How did you first learn about delamping fluorescent fixtures? (READ LIST) **C545-546**
- You were contacted by someone at PG&E.....11
 - You were contacted by a contractor or vendor.....12
 - Through media contact such as
a bill insert, TV, radio, or brochure.....13
 - From word of mouth.....14
 - From previously participating in a program.....15
 - Other (DO NOT READ).....16
 - Don't Know (DO NOT READ)77
 - Refused (DO NOT READ)88

Q62	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	2	100.0	2	100.0

Frequency Missing = 65

ASK EVERYONE:

63. After getting a rebate in 1996, have you installed any T-8 lamp and electronic ballast fixtures without applying for a rebate? **C547-548**
- Yes..... 11 (ASK Q64)
 - No..... 12 (GO TO Q70)
 - Don't Know..... 77 (GO TO Q70)
 - Refused 88 (GO TO Q70)

Q63	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	11	16.4	11	16.4
12	54	80.6	65	97.0
77	2	3.0	67	100.0

IF YES, ASK:

64. How many of these fixtures did you install without a rebate? C549-551 (SPECIFY #)

Q64	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	1	9.1	1	9.1
003	1	9.1	2	18.2
004	1	9.1	3	27.3
006	2	18.2	5	45.5
007	1	9.1	6	54.5
010	1	9.1	7	63.6
012	1	9.1	8	72.7
030	1	9.1	9	81.8
060	1	9.1	10	90.9
160	1	9.1	11	100.0

Frequency Missing = 56

65. Of these, how many replaced old fixtures? C552-554 (SPECIFY #)

Q65	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	2	20.0	2	20.0
3	1	10.0	3	30.0
4	1	10.0	4	40.0
6	1	10.0	5	50.0
7	1	10.0	6	60.0
10	1	10.0	7	70.0
12	1	10.0	8	80.0
30	1	10.0	9	90.0
60	1	10.0	10	100.0

Frequency Missing = 57

66. Why did you install the fixtures? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C555-556
b. The current equipment was not performing well	11	12	77	88	C557-558
c. You wanted to improve equipment reliability	11	12	77	88	C559-560
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C561-562
e. Any other reason? (SPECIFY) _____	11	12	77	88	C563-564
f. New installation/new building/expansion	11	12	Not applicable		C718-719

Q66A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	45.5	5	45.5
12	6	54.5	11	100.0

Frequency Missing = 56

Q66B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	45.5	5	45.5
12	5	45.5	10	90.9
77	1	9.1	11	100.0

Frequency Missing = 56

Q66C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	45.5	5	45.5
12	5	45.5	10	90.9
77	1	9.1	11	100.0

Frequency Missing = 56

Q66D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	36.4	4	36.4
12	5	45.5	9	81.8
77	2	18.2	11	100.0

Frequency Missing = 56

Q66E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	27.3	3	27.3
12	8	72.7	11	100.0

Frequency Missing = 56

Other Response

Old

Discussion with PG&E Representative

More light

Q66F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	18.2	2	18.2
12	9	81.8	11	100.0

Frequency Missing = 56

67. Why didn't you apply for a rebate? (READ LIST)..... **C565-566**
 The rebate was too small.....11
 It was too much of a hassle12
 It was too late to apply13
 You did not think about it14
 You did not know about it.....15
 Other (SPECIFY) _____16
 Don't Know (DO NOT READ)77
 Refused (DO NOT READ)88
The rebate was too small AND it was too much of a hassle 19

Q67	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	9.1	1	9.1
12	2	18.2	3	27.3
14	3	27.3	6	54.5
15	3	27.3	9	81.8
19	1	9.1	10	90.9
77	1	9.1	11	100.0

Frequency Missing = 56

68. Would you have installed these non-rebated fixtures if you had not received a rebate in 1996?..... **C567-568**
 Yes.....11
 No12
 Don't Know.....77
 Refused88

Q68	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	10	90.9	10	90.9
77	1	9.1	11	100.0

Frequency Missing = 56

69. How did you first learn about T-8 fixtures? (READ LIST) **C569-570**

- You were contacted by someone at PG&E.....11
- You were contacted by a contractor or vendor.....12
- Through media contact such as
a bill insert, TV, radio, or brochure.....13
- From word of mouth.....14
- From previously participating in a program.....15
- Other (DO NOT READ).....16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q69	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	18.2	2	18.2
12	4	36.4	6	54.5
13	1	9.1	7	63.6
14	1	9.1	8	72.7
16	1	9.1	9	81.8
77	2	18.2	11	100.0

Frequency Missing = 56

ASK EVERYONE:

70. After getting a rebate in 1996, have you installed any High Intensity Discharge, or HID, fixtures without applying for a rebate? **C571-572**

- Yes..... 11 (ASK Q71)
- No 12 (GO TO Q77)
- Don't Know..... 77 (GO TO Q77)
- Refused 88 (GO TO Q77)

Q70	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	6	9.0	6	9.0
12	59	88.1	65	97.0
77	2	3.0	67	100.0

IF YES, ASK:

71. How many HID fixtures did you install without a rebate? **C573-575** (SPECIFY #)

Q71	Frequency	Percent	Cumulative Frequency	Cumulative Percent
2	1	16.7	1	16.7
4	1	16.7	2	33.3
9	1	16.7	3	50.0
13	1	16.7	4	66.7
20	1	16.7	5	83.3
25	1	16.7	6	100.0

Frequency Missing = 61

72. Of these, how many replaced old fixtures? **C576-578** (SPECIFY #)

Q72	Frequency	Percent	Cumulative Frequency	Cumulative Percent
002	1	16.7	1	16.7
004	1	16.7	2	33.3
008	2	33.3	4	66.7
009	1	16.7	5	83.3
020	1	16.7	6	100.0

Frequency Missing = 61

73. Why did you install HID fixtures? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C608-609
b. The current equipment was not performing well	11	12	77	88	C610-611
c. You wanted to improve equipment reliability	11	12	77	88	C612-613
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C614-615
e. Any other reason? (SPECIFY) _____	11	12	77	88	C616-617

Q73A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	50.0	3	50.0
12	2	33.3	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

Q73B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	50.0	3	50.0
12	3	50.0	6	100.0

Frequency Missing = 61

Q73C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	5	83.3	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

Q73D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	66.7	4	66.7
12	1	16.7	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

Q73E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	33.3	2	33.3
12	3	50.0	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

Other responses

Electrician recommended
Need HID for special use

74. Why didn't you apply for a rebate? (READ LIST)..... **C618-619**

- The rebate was too small.....11
- It was too much of a hassle12
- It was too late to apply13
- You did not think about it14
- You did not know about it.....15
- Other (SPECIFY) _____16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q74	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	16.7	1	16.7
12	1	16.7	2	33.3
14	1	16.7	3	50.0
15	2	33.3	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

75. Would you have installed these non-rebated HID fixtures if you had not received a rebate in 1996?..... **C620-621**

- Yes.....11
- No.....12
- Don't Know.....77
- Refused88

Q75	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	66.7	4	66.7
12	1	16.7	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

76. How did you first learn about HID fixtures? (READ LIST) **C622-623**
- You were contacted by someone at PG&E.....11
 - You were contacted by a contractor or vendor.....12
 - Through media contact such as
 - a bill insert, TV, radio, or brochure.....13
 - From word of mouth.....14
 - From previously participating in a program.....15
 - Other (DO NOT READ).....16
 - Don't Know (DO NOT READ)77
 - Refused (DO NOT READ)88

Q76	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	16.7	1	16.7
12	3	50.0	4	66.7
13	1	16.7	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 61

ASK EVERYONE:

77. After getting a rebate in 1996, have you installed any energy-efficient motors without applying for a rebate? **C624-625**
- Yes..... 11 (ASK Q78)
 - No 12 (GO TO Q83)
 - Don't Know..... 77 (GO TO Q83)
 - Refused 88 (GO TO Q83)

Q77	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	7	10.4	7	10.4
12	58	86.6	65	97.0
77	2	3.0	67	100.0

IF YES, ASK:

78. How many energy-efficient motors and of what horsepower did you install without a rebate? (FOR EXAMPLE: “ 5 MOTORS AT 25 HORSEPOWER”)
- a. (SPECIFY #) C626-628 motors at C629-631 (SPECIFY HORSEPOWER)
 - b. (SPECIFY #) C632-634 motors at C635-637 (SPECIFY HORSEPOWER)
 - c. (SPECIFY #) C638-640 motors at C641-643 (SPECIFY HORSEPOWER)
 - d. (SPECIFY #) C644-646 motors at C647-649 (SPECIFY HORSEPOWER)

Q78A1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	2	28.6	2	28.6
2	2	28.6	4	57.1
3	2	28.6	6	85.7
40	1	14.3	7	100.0
Frequency Missing = 60				

Q78A2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
001	3	42.9	3	42.9
005	1	14.3	4	57.1
020	1	14.3	5	71.4
050	1	14.3	6	85.7
075	1	14.3	7	100.0
Frequency Missing = 60				

Q78B1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
3	1	100.0	1	100.0
Frequency Missing = 66				

Q78B2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	1	100.0	1	100.0
Frequency Missing = 66				

Q78C1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
Frequency Missing = 67				

Q78C2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
Frequency Missing = 67				

Q78D1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
Frequency Missing = 67				

Q78D2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
Frequency Missing = 67				

79. Of these, how many replaced old motors? **C650-653** (SPECIFY #)

Q79	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0000	1	14.3	1	14.3
0001	2	28.6	3	42.9
0002	1	14.3	4	57.1
0003	1	14.3	5	71.4
0006	1	14.3	6	85.7
0040	1	14.3	7	100.0

Frequency Missing = 60

80. Why did you install these energy-efficient motors? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C654-655
b. The current equipment was not performing well	11	12	77	88	C656-657
c. You wanted to improve equipment reliability	11	12	77	88	C658-659
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C660-661
e. Any other reason? (SPECIFY) _____	11	12	77	88	C662-663
f. New installation/new building/expansion	11	12	Not applicable		C720-721

Q80A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	57.1	4	57.1
12	3	42.9	7	100.0

Frequency Missing = 60

Q80B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	28.6	2	28.6
12	5	71.4	7	100.0

Frequency Missing = 60

Q80C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	28.6	2	28.6
12	5	71.4	7	100.0

Frequency Missing = 60

Q80D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	28.6	2	28.6
12	5	71.4	7	100.0

Frequency Missing = 60

Q80E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
12	6	85.7	7	100.0

Frequency Missing = 60

Other Response

Drive switched to variable frequency

Q80F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
12	6	85.7	7	100.0

Frequency Missing = 60

81. Why didn't you apply for a rebate? (READ LIST).....C664-665
- The rebate was too small.....11
 - It was too much of a hassle12
 - It was too late to apply13
 - You did not think about it14
 - You did not know about it.....15
 - Other (SPECIFY) _____16
 - Don't Know (DO NOT READ)77
 - Refused (DO NOT READ)88
 - The rebate was too small AND it was too much of a hassle 19

Q81	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
14	3	42.9	4	57.1
15	1	14.3	5	71.4
16	1	14.3	6	85.7
19	1	14.3	7	100.0

Frequency Missing = 60

Other response

Not in the PG&E service area

82. Would you have installed these non-rebated energy-efficient motors if you had not received a rebate in 1996?C666-667
- Yes.....11
 - No12
 - Don't Know.....77
 - Refused88

(CONTINUE WITH Q83)

Q82	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	6	85.7	6	85.7
77	1	14.3	7	100.0

Frequency Missing = 60

83. How did you first learn about energy-efficient motors? (READ LIST) **C668-669**

- You were contacted by someone at PG&E.....11
- You were contacted by a contractor or vendor.....12
- Through media contact such as
a bill insert, TV, radio, or brochure.....13
- From word of mouth.....14
- From previously participating in a program.....15
- Other (DO NOT READ).....16
- Don't Know (DO NOT READ)77
- Refused (DO NOT READ)88

Q83	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	14.3	1	14.3
12	4	57.1	5	71.4
77	2	28.6	7	100.0

Frequency Missing = 60

84. Those are all the questions I have. On behalf of PG&E, I greatly appreciate your time and cooperation in this survey. Thank you very much.

NOTE: IF RESPONDENT REQUESTED CONTACT INFORMATION FOR PG&E, CHECK BOX AT BOTTOM OF CONTACT RECORD SHEET.

NOTE: IF RESPONDENT WANTED COMMENTS FORWARDED TO PG&E, ENTER THEM HERE:

RESPONDENT NAME: _____

SAMPLE ID NUMBER: C124-129 AND C670-675

INTERVIEWER ID: _____

TIME ENDED: C676-680

DATE: C130-135

Reasons for Refusing the Survey

	<u>Total</u>	<u>EI Participant</u>	
		<u>Lighting</u>	<u>Pumping</u>
No ans. on last attempt/Ans. Mach.	8	4	4
Busy	0	0	0
Respondent not avail. on last attempt	13	7	6
Unable to reach respondent to finish interview	0	0	0
Disconnected/fax (no listing with direct. asst.)	3	0	3
Wrong number (no listing with direct. asst.)	2	1	1
Refusal (before contact determined)	1	0	1
Refusal (by correct contact)	5	2	3
Only partial interview	1	0	1
Other	6	3	3
<u>Completes</u>	<u>67</u>	<u>34</u>	<u>33</u>
<u>Total</u>	<u>106</u>	<u>51</u>	<u>55</u>

Appendix C - Final EEI Nonparticipant Telephone Survey with Response Frequencies

START OF SURVEY

TIME STARTED: C208-211

Sample Type:

Pumping: 3

Lighting: 4

SMPLTYPE	Frequency	Percent	Cumulative Frequency	Cumulative Percent
3	42	55.3	42	55.3
4	34	44.7	76	100.0

1. First, I would like to ask you some general questions about your business or organization. How would you classify your business or organization? (READ LIST) (ENTER ALL THAT APPLY)

- a. General farm 11 **C212**
- b. Ranch 12 **C213**
- c. Ornamental nursery 13 **C214**
- d. Indoor crops 14 **C215**
- e. Packing plant 15 **C216**
- f. Winery 16 **C217**
- g. Dairy farm 17 **C218**
- h. Water district 18 **C219**
- i. Other _____ 19 **C220**
Specify
- j. Don't Know (DO NOT READ) 77
- k. Refused (DO NOT READ) 88
- l. **Cold Storage** 20 **C223**

Q1A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	42	55.3	42	55.3
1	34	44.7	76	100.0

Q1B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	51	67.1	51	67.1
1	25	32.9	76	100.0

Q1C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	70	92.1	70	92.1
1	6	7.9	76	100.0

Q1D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	75	98.7	75	98.7
1	1	1.3	76	100.0

Q1E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	70	92.1	70	92.1
1	6	7.9	76	100.0

Q1F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0

Q1G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	65	85.5	65	85.5
1	11	14.5	76	100.0

Q1H	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0

Q1I	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	70	92.1	70	92.1
1	6	7.9	76	100.0

Other response
 Government Agency
 Shopping Center
 Fertilizer Company
 School
 Commercial rice dryers
 Green houses

Q1J	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0

Q1K	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0

Q1L	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	75	98.7	75	98.7
1	1	1.3	76	100.0

2. Compared to other businesses or organizations similar to yours, would you categorize your business or organization as small, medium or large? **C226-227**

Small.....	11
Medium.....	12
Large.....	13
Don't Know.....	77
Refused.....	88

Q2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	26	34.2	26	34.2
12	29	38.2	55	72.4
13	21	27.6	76	100.0

3. How long has your company or organization been operating at this location? **C228-229**

1 to 3 years.....	11
4 to 10 years.....	12
More than 10 years.....	13
Don't Know.....	77
Refused.....	88

Q3	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	6	7.9	6	7.9
12	8	10.5	14	18.4
13	62	81.6	76	100.0

4. Would you consider your business or organization operated by a family or a company? **C230-231**

Family.....	11
Company.....	12
Not applicable.....	13
Don't Know.....	77
Refused.....	88

Q4	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	56	73.7	56	73.7
12	17	22.4	73	96.1
13	3	3.9	76	100.0

IF PUMP SAMPLE (CXXX=1) ASK:

5. How many pumps do you have under your control? **C232-234** (SPECIFY #)

Q5	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	1	2.4	1	2.4
1	5	11.9	6	14.3
2	3	7.1	9	21.4
3	1	2.4	10	23.8
4	5	11.9	15	35.7
5	6	14.3	21	50.0
6	1	2.4	22	52.4
8	4	9.5	26	61.9
10	2	4.8	28	66.7
11	1	2.4	29	69.0
12	3	7.1	32	76.2
15	2	4.8	34	81.0
20	3	7.1	37	88.1
21	1	2.4	38	90.5
25	1	2.4	39	92.9
30	1	2.4	40	95.2
45	1	2.4	41	97.6
46	1	2.4	42	100.0

Frequency Missing = 34

6. On average, how many months per year are the pumps in use? (READ LIST) **C235-236**

Less than 3 months per year.....	11
3-6 months per year	12
7-9 months per year	13
Year round.....	14
Don't Know (DO NOT READ).....	77
Refused (DO NOT READ).....	88

Q6	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	18	43.9	18	43.9
13	13	31.7	31	75.6
14	8	19.5	39	95.1
77	2	4.9	41	100.0

Frequency Missing = 35

7. If you grow crops, do you grow annual or permanent crops? **C237-238**

Annual.....	11
Permanent.....	12
Both annual and permanent.....	13
Don't grow crops.....	14

Don't Know..... 77
 Refused..... 88

(GO TO Q11)

Q7	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	14	33.3	14	33.3
12	15	35.7	29	69.0
13	7	16.7	36	85.7
14	6	14.3	42	100.0

Frequency Missing = 34

IF LIGHTING SAMPLE (CXXX=0), ASK:

Next I'd like to ask you a few questions about your site. If a residence is included in the accounts for this site, please exclude the residence when you answer the following questions.

8. In what year was your facility built? C239-242 (SPECIFY YEAR)

Q8	Frequency	Percent	Cumulative Frequency	Cumulative Percent
000&	3	8.8	3	8.8
1919	1	2.9	4	11.8
1920	1	2.9	5	14.7
1921	1	2.9	6	17.6
1941	1	2.9	7	20.6
1948	1	2.9	8	23.5
1949	1	2.9	9	26.5
1950	1	2.9	10	29.4
1953	1	2.9	11	32.4
1964	2	5.9	13	38.2
1965	1	2.9	14	41.2
1968	1	2.9	15	44.1
1970	1	2.9	16	47.1
1972	1	2.9	17	50.0
1976	3	8.8	20	58.8
1977	1	2.9	21	61.8
1980	2	5.9	23	67.6
1983	1	2.9	24	70.6
1984	1	2.9	25	73.5
1987	2	5.9	27	79.4
1989	1	2.9	28	82.4
1990	2	5.9	30	88.2
1992	1	2.9	31	91.2
1993	1	2.9	32	94.1
1995	2	5.9	34	100.0

Frequency Missing = 42

9. Was the total area of the facility altered in 1995 or 1996? **C243-244**
- Yes..... 11
- No..... 12
- Don't Know..... 77
- Refused..... 88

Q9	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	8	23.5	8	23.5
12	25	73.5	33	97.1
77	1	2.9	34	100.0

Frequency Missing = 42

10. Approximately, what percent of the time are the lights at your facility on, annually?

C245-247 (SPECIFY %)

(GO TO Q11)

Cumulative	Q10	Frequency	Percent	Cumulative Frequency	Percent
	00&	5	14.7	5	14.7
	000	3	8.8	8	23.5
	005	1	2.9	9	26.5
	010	2	5.9	11	32.4
	025	1	2.9	12	35.3
	030	1	2.9	13	38.2
	038	1	2.9	14	41.2
	040	3	8.8	17	50.0
	045	3	8.8	20	58.8
	050	4	11.8	24	70.6
	055	2	5.9	26	76.5
	060	3	8.8	29	85.3
	070	1	2.9	30	88.2
	075	2	5.9	32	94.1
	080	1	2.9	33	97.1
	100	1	2.9	34	100.0

Frequency Missing = 42

ASK EVERYONE:

11. Typically, who decides to install energy-efficient improvements? (READ LIST) (ENTER ALL THAT APPLY)

- a. The owner(s)..... 11 **C248**
- b. A partner or partners..... 12 **C249**
- c. The farm manager..... 13 **C250**

- d. An Ag Engineer or a consultant..... 14 **C251**
- e. It's a group decision process..... 15 **C252**
- f. Other (DO NOT READ)_____ 16 **C253**
- (Specify)
- g. Don't Know (DO NOT READ)..... 77
- h. Refused (DO NOT READ)..... 88
- i. **Site/plant/operations manager** 17 **C257**

Q11A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	27	35.5	27	35.5
1	49	64.5	76	100.0
Q11B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	71	93.4	71	93.4
1	5	6.6	76	100.0
Q11C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	69	90.8	69	90.8
1	7	9.2	76	100.0
Q11D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0
Q11E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	61	80.3	61	80.3
1	15	19.7	76	100.0
Q11F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0
Q11G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0
Q11H	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0
Q11I	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	74	97.4	74	97.4
1	2	2.6	76	100.0

12. Which of these financial methods do you typically use to evaluate energy-efficiency improvements? (READ LIST) **C259-260**

Simple payback	11
Lowest First Cost.....	12
A more complex financial analysis.....	13
Don't Know (DO NOT READ)	77
Refused (DO NOT READ)	88

Q12	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	43	56.6	43	56.6
12	12	15.8	55	72.4
13	8	10.5	63	82.9
14	2	2.6	65	85.5
77	11	14.5	76	100.0

13. How would you rate the importance of improving the efficiency of the equipment at your site? (READ LIST) **C261-262**

Very important	11
Somewhat important.....	12
Not too important	13
Not at all important.....	14
Don't Know (DO NOT READ)	77
Refused (DO NOT READ)	88

Q13	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	39	51.3	39	51.3
12	29	38.2	68	89.5
13	7	9.2	75	98.7
14	1	1.3	76	100.0

14. What are the primary sources of advice and information you use when planning to invest in energy-using equipment? (READ LIST AND ENTER ALL THAT APPLY).

a. A PG&E service representative	11	C263
b. A PG&E brochure in the mail or a bill insert	12	C264
c. A vendor or contractor	13	C265
d. General media like television, radio, or the newspaper.....	14	C266
e. Word of mouth.....	15	C267
f. Don't Know (DO NOT READ).....	77	
g. Refused (DO NOT READ)	88	

Q14A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	33	43.4	33	43.4
1	43	56.6	76	100.0

Q14B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	61	80.3	61	80.3
1	15	19.7	76	100.0

Q14C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	40	52.6	40	52.6
1	36	47.4	76	100.0

Q14D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	67	88.2	67	88.2
1	9	11.8	76	100.0

Q14E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	54	71.1	54	71.1
1	22	28.9	76	100.0

Q14F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	72	94.7	72	94.7
1	4	5.3	76	100.0

Q14G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	76	100.0	76	100.0

ASK EVERYONE:

Please rate the importance of the following factors in any decision to install high-efficiency equipment.

15. How important would (ITEM) be in your decision to install high-efficiency equipment? Would that be: (READ LIST)?

					(DO NOT READ)		
	Very Important	Somewhat Important	Not too important	Not at all Important	Don't Know	Refused	
a. The availability of a rebate	11	12	13	14	77	88	C308-309
b. The low performance of current equipment	11	12	13	14	77	88	C310-311
c. A low purchase cost	11	12	13	14	77	88	C312-313
d. An expected reduction of operating costs	11	12	13	14	77	88	C314-315
e. A low maintenance cost	11	12	13	14	77	88	C316-317
f. A lower energy bill	11	12	13	14	77	88	C318-319
g. The questionable reliability of your current equipment	11	12	13	14	77	88	C320-321
h. Having a lower environmental impact	11	12	13	14	77	88	C322-323
i. Improving the resale value of the property	11	12	13	14	77	88	C324-325
j. The general health of the economy	11	12	13	14	77	88	C326-327

Q15A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	33	43.4	33	43.4
12	33	43.4	66	86.8
13	4	5.3	70	92.1
14	2	2.6	72	94.7
77	3	3.9	75	98.7
88	1	1.3	76	100.0

Q15B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	42	55.3	42	55.3
12	27	35.5	69	90.8
13	5	6.6	74	97.4
77	1	1.3	75	98.7
88	1	1.3	76	100.0

Q15C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	38	50.0	38	50.0
12	29	38.2	67	88.2
13	5	6.6	72	94.7
14	2	2.6	74	97.4
77	2	2.6	76	100.0

Q15D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	59	77.6	59	77.6
12	17	22.4	76	100.0

Q15E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	54	71.1	54	71.1
12	19	25.0	73	96.1
13	2	2.6	75	98.7
77	1	1.3	76	100.0

Q15F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	69	90.8	69	90.8
12	5	6.6	74	97.4
77	2	2.6	76	100.0

Q15G	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	35	46.1	35	46.1
12	36	47.4	71	93.4
13	3	3.9	74	97.4
14	1	1.3	75	98.7
77	1	1.3	76	100.0

Q15H	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	17	22.4	17	22.4
12	39	51.3	56	73.7
13	11	14.5	67	88.2
14	5	6.6	72	94.7
77	3	3.9	75	98.7
88	1	1.3	76	100.0

Q15I	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	19	25.0	19	25.0
12	28	36.8	47	61.8
13	12	15.8	59	77.6
14	14	18.4	73	96.1
77	3	3.9	76	100.0

Q15J	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	16	21.1	16	21.1
12	28	36.8	44	57.9
13	21	27.6	65	85.5
14	10	13.2	75	98.7
77	1	1.3	76	100.0

ASK EVERYONE:

Now I want to ask you some questions about PG&E programs and your PG&E service representative.

16. How familiar are you with PG&E's energy-efficiency programs? Would you say you are: (READ LIST)? **C328-329**

Very familiar	11
Somewhat familiar.....	12
Not too familiar	13
Not at all familiar.....	14
Don't Know (DO NOT READ).....	77
Refused (DO NOT READ)	88

Q16	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	6.6	5	6.6
12	29	38.2	34	44.7
13	30	39.5	64	84.2
14	12	15.8	76	100.0

17. How many total times have you participated in PG&E energy-efficiency programs? (READLIST) **C330-331**

Once.....	11
Twice	12
Several times	13
Never.....	14
Don't Know (DO NOT READ).....	77
Refused (DO NOT READ)	88

Q17	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	18	23.7	18	23.7
12	10	13.2	28	36.8
13	17	22.4	45	59.2
14	30	39.5	75	98.7
77	1	1.3	76	100.0

18. How many total times has the PG&E service representative contacted you? (READ LIST) **C332-333**

Once..... 11 (ASK Q19)
 Twice 12 (ASK Q19)
 Several times 13 (ASK Q19)
 Never..... 14 (GO TO Q20)
 Don't Know (DO NOT READ)..... 77 (GO TO Q20)
 Refused (DO NOT READ)..... 88 (GO TO Q20)

Q18	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	17	22.4	17	22.4
12	8	10.5	25	32.9
13	18	23.7	43	56.6
14	30	39.5	73	96.1
77	3	3.9	76	100.0

IF Q18 = CONTACTED AT LEAST ONCE, ASK:

19. How helpful was your PG&E representative in: (ITEM). (READ LIST)

	(DO NOT READ)					
	Very Helpful	Somewhat Helpful	Not too Helpful	Not at all Helpful	Don't know	Refused
a. Making you aware of any programs	11	12	13	14	77	88
b. Letting you know energy-efficient equipment options	11	12	13	14	77	88

C334-335

C336-337

Q19A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	19	44.2	19	44.2
12	15	34.9	34	79.1
13	7	16.3	41	95.3
14	1	2.3	42	97.7
77	1	2.3	43	100.0

Frequency Missing = 33

Q19B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	8	18.6	8	18.6
12	23	53.5	31	72.1
13	6	14.0	37	86.0
14	4	9.3	41	95.3
77	2	4.7	43	100.0

Frequency Missing = 33

ASK EVERYONE:

The last set of questions I have for you are questions about energy-efficient equipment you may have installed in 1996.

20. Did you repair any deep well pumps in 1996?.....**C338-339**
 Yes..... 11 (ASK Q21)
 No 12 (GO TO Q24)
 Don't Know..... 77 (GO TO Q24)
 Refused 88 (GO TO Q24)

Q20	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	23	30.3	23	30.3
12	53	69.7	76	100.0

IF YES, ASK:

21. How many deep well pumps did you repair? **C340-342** (SPECIFY #)

Q21	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	16	69.6	16	69.6
2	3	13.0	19	82.6
5	3	13.0	22	95.7
6	1	4.3	23	100.0

Frequency Missing = 53

22. Why did you repair the pumps? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C343-344
b. The current equipment was not performing well	11	12	77	88	C345-346
c. You were worried about equipment reliability	11	12	77	88	C347-348
d. Your previous experience with pump repairs	11	12	77	88	C349-350
e. Any other reason? (SPECIFY)	11	12	77	88	C351-352

Q22A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	17	73.9	17	73.9
12	5	21.7	22	95.7
77	1	4.3	23	100.0

Frequency Missing = 53

Q22B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	12	52.2	12	52.2
12	11	47.8	23	100.0

Frequency Missing = 53

Q22C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	10	43.5	10	43.5
12	13	56.5	23	100.0

Frequency Missing = 53

Q22D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	13.0	3	13.0
12	19	82.6	22	95.7
77	1	4.3	23	100.0

Frequency Missing = 53

Q22E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	23	100.0	23	100.0

Frequency Missing = 53

23. According to PG&E records, you did not obtain a rebate for repairing deep well pumps. Why didn't you apply for a rebate? (READ LIST).....C353-354

- The rebate was too small..... 11
- It was too much of a hassle 12
- It was too late to apply 13
- You did not think about it 14
- You did not know about it..... 15
- Other (SPECIFY) _____..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

(GO TO Q24)

ASK EVERYONE:

Q23	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	1	4.3	1	4.3
14	3	13.0	4	17.4
15	16	69.6	20	87.0
16	3	13.0	23	100.0

Frequency Missing = 53

Responses specified in 'other'.
 We were told no rebate program was available.
 The vendor was supposed to apply.
 Not eligible.

24. Did you install any low pressure sprinkler nozzles in 1996? **C355-356**
- Yes..... 11 (ASK Q25)
 - No..... 12 (GO TO Q30)
 - Don't Know..... 77 (GO TO Q30)
 - Refused 88 (GO TO Q30)

Q24	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	10	13.2	10	13.2
12	66	86.8	76	100.0

IF YES, ASK:

25. How many low pressure sprinkler nozzles did you install? **C357-359** (SPECIFY #)

Q25	Frequency	Percent	Cumulative Frequency	Cumulative Percent
000&	2	20.0	2	20.0
0015	1	10.0	3	30.0
0030	1	10.0	4	40.0
0100	1	10.0	5	50.0
0250	1	10.0	6	60.0
0500	1	10.0	7	70.0
0999	2	20.0	9	90.0
1000	1	10.0	10	100.0

Frequency Missing = 66

26. Of these, how many replaced other sprinkler nozzles? C360-362 (SPECIFY #)

Q26	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	8	80.0	8	80.0
7	2	20.0	10	100.0

Frequency Missing = 66

27. Why did you install these low pressure sprinkler nozzles? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C363-364
b. The current equipment was not performing well	11	12	77	88	C365-366
c. You wanted to improve equipment reliability	11	12	77	88	C367-368
d. Your previous experience with the energy efficiency of low pressure nozzles	11	12	77	88	C369-370
e. Any other reason? (SPECIFY) _____	11	12	77	88	
f. New installation/new building/expansion	11	12	Not applicable	C160-161	C371-372

Q27A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	20.0	2	20.0
12	6	60.0	8	80.0
77	2	20.0	10	100.0

Frequency Missing = 66

Q27B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	20.0	2	20.0
12	7	70.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 66

Q27C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	40.0	4	40.0
12	6	60.0	10	100.0

Frequency Missing = 66

Q27D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	50.0	5	50.0
12	4	40.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 66

Q27E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	20.0	2	20.0
12	7	70.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 66

Other responses

To improve landscaping. We had just been using hoses.
Old ones were taken out because they needed replacement

Q27F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	30.0	3	30.0
12	7	70.0	10	100.0

Frequency Missing = 66

28. How did you first learn about low pressure sprinkler nozzles? (READ LIST) **C373-374**

- You were contacted by someone at PG&E 11
- You were contacted by a contractor or vendor..... 12
- Through media contact such as
a bill insert, TV, radio, or brochure..... 13
- From word of mouth..... 14
- From previously participating in a program..... 15
- Other (DO NOT READ)..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

Q28	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	7	70.0	7	70.0
14	1	10.0	8	80.0
77	2	20.0	10	100.0

Frequency Missing = 66

29. According to PG&E records, you did not obtain a rebate for installing low pressure sprinkler nozzles. Why didn't you apply for a rebate? (READ LIST). **C375-376**

- The rebate was too small..... 11
- It was too much of a hassle 12
- It was too late to apply 13
- You did not think about it 14
- You did not know about it..... 15
- Other (SPECIFY) _____..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

(GO TO Q30)

Q29	Frequency	Percent	Cumulative Frequency	Cumulative Percent
15	9	90.0	9	90.0
77	1	10.0	10	100.0

Frequency Missing = 66

ASK EVERYONE:

30. Did you convert any sprinkler systems to micro irrigation systems or install any new micro irrigation systems in 1996? **C408-409**

- Yes.....11 (ASK Q31)
- No12 (GO TO Q36)
- Don't Know.....77 (GO TO Q36)
- Refused88 (GO TO Q36)

Q30	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	8	10.5	8	10.5
12	67	88.2	75	98.7
77	1	1.3	76	100.0

IF YES, ASK:

31. How many acres did you convert or install? C410-412 (# OF ACRES)

Q31	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	1	12.5	1	12.5
001	1	12.5	2	25.0
010	1	12.5	3	37.5
015	1	12.5	4	50.0
100	1	12.5	5	62.5
150	1	12.5	6	75.0
200	1	12.5	7	87.5
999	1	12.5	8	100.0

Frequency Missing = 68

32. Of these, how many acres replaced old sprinkler systems? C413-415 (# OF ACRES)

Q32	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	2	25.0	2	25.0
000	2	25.0	4	50.0
005	1	12.5	5	62.5
010	1	12.5	6	75.0
200	1	12.5	7	87.5
999	1	12.5	8	100.0

Frequency Missing = 68

33. Why did you install the micro irrigation system? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C416-417
b. The current equipment was not performing well	11	12	77	88	C418-419
c. You wanted to improve equipment reliability	11	12	77	88	C420-421
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C422-423
e. Any other reason? (SPECIFY)	11	12	77	88	C424-425
f. New installation/new building/expansion	11	12	Not applicable		C162-163

Q33A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	8	100.0	8	100.0

Frequency Missing = 68

Q33B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	8	100.0	8	100.0

Frequency Missing = 68

Q33C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	25.0	2	25.0
12	6	75.0	8	100.0

Frequency Missing = 68

Q33D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	25.0	2	25.0
12	6	75.0	8	100.0

Frequency Missing = 68

Q33E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	62.5	5	62.5
12	3	37.5	8	100.0

Frequency Missing = 68

Other response

- Fits our program better. Saves on fertilizer and tests show it produced more and better
- Better for trees and cost
- More efficient water handling
- More water efficiency
- Waste less energy and water

Q33F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	50.0	4	50.0
12	4	50.0	8	100.0

Frequency Missing = 68

34. How did you first learn about micro irrigation systems? (READ LIST) **C426-427**

You were contacted by someone at PG&E	11
You were contacted by a contractor or vendor	12
Through media contact such as a bill insert, TV, radio, or brochure	13
From word of mouth	14
From previously participating in a program	15
Other (DO NOT READ)	16
Don't Know (DO NOT READ).....	77
Refused (DO NOT READ)	88

Q34	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	1	12.5	1	12.5
14	2	25.0	3	37.5
16	2	25.0	5	62.5
77	3	37.5	8	100.0

Frequency Missing = 68

35. According to PG&E records, you did not obtain a rebate for installing or converting to micro irrigation systems. Why didn't you apply for a rebate? (READ LIST) **C428-429**

The rebate was too small.....	11
It was too much of a hassle.....	12
It was too late to apply	13
You did not think about it	14
You did not know about it.....	15
Other (SPECIFY) _____	16
Don't Know (DO NOT READ).....	77
Refused (DO NOT READ)	88

(GO TO Q36)

Q35	Frequency	Percent	Cumulative Frequency	Cumulative Percent
14	1	12.5	1	12.5
15	5	62.5	6	75.0
16	2	25.0	8	100.0

Frequency Missing = 68

Responses specified in 'other'

Not eligible, since it wasn't a replacement or an upgrade.
I thought I did.

ASK EVERYONE:

36. Did you install any compact fluorescent lamps in 1996? **C430-431**

Yes.....11 (ASK Q37)
 No.....12 (GO TO Q42)
 Don't Know.....77 (GO TO Q42)
 Refused.....88 (GO TO Q42)

			Cumulative	Cumulative
Q36	Frequency	Percent	Frequency	Percent
11	9	11.8	9	11.8
12	67	88.2	76	100.0

IF YES, ASK:

37. How many compact fluorescent lamps did you install? **C432-434** (SPECIFY #)

			Cumulative	Cumulative
Q37	Frequency	Percent	Frequency	Percent
00&	1	11.1	1	11.1
001	1	11.1	2	22.2
002	1	11.1	3	33.3
003	2	22.2	5	55.6
006	1	11.1	6	66.7
010	2	22.2	8	88.9
090	1	11.1	9	100.0

Frequency Missing = 67

38. Of these, how many replaced old lamps? **C435-437** (SPECIFY #)

			Cumulative	Cumulative
Q38	Frequency	Percent	Frequency	Percent
00&	1	11.1	1	11.1
000	2	22.2	3	33.3
001	1	11.1	4	44.4
002	1	11.1	5	55.6
003	2	22.2	7	77.8
005	1	11.1	8	88.9
010	1	11.1	9	100.0

Frequency Missing = 67

39. Why did you install compact fluorescent lamps? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C438-439
b. The current equipment was not performing well	11	12	77	88	C440-441
c. You wanted to improve equipment reliability	11	12	77	88	C442-443
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C444-445
e. Any other reason? (SPECIFY) _____	11	12	77	88	C446-447

Q39A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	33.3	3	33.3
12	5	55.6	8	88.9
77	1	11.1	9	100.0

Frequency Missing = 67

Q39B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	22.2	2	22.2
12	7	77.8	9	100.0

Frequency Missing = 67

Q39C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	55.6	5	55.6
12	3	33.3	8	88.9
77	1	11.1	9	100.0

Frequency Missing = 67

Q39D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	5	55.6	5	55.6
12	3	33.3	8	88.9
77	1	11.1	9	100.0

Frequency Missing = 67

Q39E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	22.2	2	22.2
12	7	77.8	9	100.0

Frequency Missing = 67

Other responses
 Security
 Accommodate expansion

40. How did you first learn about compact fluorescent lamps? (READ LIST) **C448-449**
- You were contacted by someone at PG&E..... 11
 - You were contacted by a contractor or vendor..... 12
 - Through media contact such as
a bill insert, TV, radio, or brochure..... 13
 - From word of mouth..... 14
 - From previously participating in a program..... 15
 - Other (DO NOT READ)..... 16
 - Don't Know (DO NOT READ)..... 77
 - Refused (DO NOT READ)..... 88

Q40	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	6	66.7	6	66.7
13	1	11.1	7	77.8
14	2	22.2	9	100.0

Frequency Missing = 67

41. According to PG&E records you did not apply for a rebate for installing compact fluorescent lamps. Why didn't you apply for a rebate? (READ LIST)**C450-451**
- The rebate was too small..... 11
 - It was too much of a hassle 12
 - It was too late to apply 13
 - You did not think about it 14
 - You did not know about it..... 15
 - Other (SPECIFY) _____..... 16
 - Don't Know (DO NOT READ)..... 77
 - Refused (DO NOT READ)..... 88

(GO TO Q42)

Q41	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	1	11.1	1	11.1
14	1	11.1	2	22.2
15	6	66.7	8	88.9
16	1	11.1	9	100.0

Frequency Missing = 67

Other responses
Handled by contractor

ASK EVERYONE:

42. Did you delamp any fluorescent fixtures in 1996? **C452-453**
 Yes.....11 (ASK Q43)
 No.....12 (GO TO Q49)
 Don't Know.....77 (GO TO Q49)
 Refused88 (GO TO Q49)

Q42	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	3.9	3	3.9
12	73	96.1	76	100.0

If YES, ASK:

43. How many fluorescent fixtures did you delamp without a rebate? C454-456 (SPECIFY #)

Q43	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	1	33.3	1	33.3
004	2	66.7	3	100.0

Frequency Missing = 73

44. On average, how many lamps did you take out per fixture? C457-459 (SPECIFY #)

Q44	Frequency	Percent	Cumulative Frequency	Cumulative Percent
002	1	33.3	1	33.3
006	1	33.3	2	66.7
008	1	33.3	3	100.0

Frequency Missing = 73

45. On average, how many lamps were left in the fixture? C460-462 (SPECIFY #)

Q45	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	1	33.3	1	33.3
004	2	66.7	3	100.0

Frequency Missing = 73

46. Why did you delamp these fluorescent fixtures? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. Of your previous experience with the energy efficiency of delamping	11	12	77	88	C463-464
b. You did not need the extra light	11	12	77	88	C465-466
c. Any other reason? (SPECIFY) _____	11	12	77	88	C467-468

Q46A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	1	33.3	1	33.3
77	2	66.7	3	100.0

Frequency Missing = 73

Q46B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	33.3	1	33.3
77	2	66.7	3	100.0

Frequency Missing = 73

Q46C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	66.7	2	66.7
12	1	33.3	3	100.0

Frequency Missing = 73

Other responses
 Efficiency of the light
 Changed lamp style

47.	How did you <u>first</u> learn about delamping fluorescent fixtures? (READ LIST)	C469-470
	You were contacted by someone at PG&E.....	11
	You were contacted by a contractor or vendor.....	12
	Through media contact such as a bill insert, TV, radio, or brochure.....	13
	From word of mouth.....	14
	From previously participating in a program.....	15
	Other (DO NOT READ).....	16
	Don't Know (DO NOT READ).....	77
	Refused (DO NOT READ).....	88

Q47	Frequency	Percent	Cumulative Frequency	Cumulative Percent
14	1	33.3	1	33.3
15	1	33.3	2	66.7
77	1	33.3	3	100.0

Frequency Missing = 73

48. According to PG&E records you did not apply for a rebate for delamping fluorescent fixtures. Why didn't you apply for a rebate? (READ LIST)C471-472

- The rebate was too small..... 11
- It was too much of a hassle 12
- It was too late to apply 13
- You did not think about it 14
- You did not know about it..... 15
- Other (SPECIFY) _____..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

(GO TO Q49)

Q48	Frequency	Percent	Cumulative Frequency	Cumulative Percent
15	3	100.0	3	100.0

Frequency Missing = 73

ASK EVERYONE:

49. Did you install any T-8 lamp and electronic ballast fixtures in 1996? **C508-509**

- Yes..... 11 (ASK Q50)
- No 12 (GO TO Q55)
- Don't Know..... 77 (GO TO Q55)
- Refused 88 (GO TO Q55)

Q49	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	2.6	2	2.6
12	72	94.7	74	97.4
77	2	2.6	76	100.0

IF YES, ASK:

50. How many of these fixtures did you install? C510-512 (SPECIFY #)

Q50	Frequency	Percent	Cumulative Frequency	Cumulative Percent
002	1	50.0	1	50.0
016	1	50.0	2	100.0
Frequency Missing = 74				

51. Of these, how many replaced old fixtures? C513-515 (SPECIFY #)

Q51	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	1	50.0	1	50.0
2	1	50.0	2	100.0
Frequency Missing = 74				

52. Why did you install the fixtures? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C516-517
b. The current equipment was not performing well	11	12	77	88	C518-519
c. You wanted to improve equipment reliability	11	12	77	88	C520-521
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C522-523
e. Any other reason? (SPECIFY)	11	12	77	88	C524-525
f. New installation/new building/expansion	11	12	Not applicable		C164-165

Q52A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	2	100.0	2	100.0

Frequency Missing = 74

Q52B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	50.0	1	50.0
12	1	50.0	2	100.0

Frequency Missing = 74

Q52C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	50.0	1	50.0
12	1	50.0	2	100.0

Frequency Missing = 74

Q52D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	2	100.0	2	100.0

Frequency Missing = 74

Q52E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	2	100.0	2	100.0

Frequency Missing = 74

Q52F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	50.0	1	50.0
12	1	50.0	2	100.0

Frequency Missing = 74

53. How did you first learn about T-8 fixtures? (READ LIST)C526-527

- You were contacted by someone at PG&E 11
- You were contacted by a contractor or vendor..... 12
- Through media contact such as
a bill insert, TV, radio, or brochure..... 13
- From word of mouth..... 14
- From previously participating in a program..... 15
- Other (DO NOT READ)..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ).....88

Q53	Frequency	Percent	Cumulative Frequency	Cumulative Percent
14	2	100.0	2	100.0

Frequency Missing = 74

54. According to PG&E records you did not apply for a rebate for installing the fixtures.
Why didn't you apply for a rebate? (READ LIST).....C528-529

- The rebate was too small..... 11
- It was too much of a hassle 12
- It was too late to apply 13
- You did not think about it 14
- You did not know about it..... 15
- Other (SPECIFY) _____..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

(GO TO Q55)

Q54	Frequency	Percent	Cumulative Frequency	Cumulative Percent
15	2	100.0	2	100.0

Frequency Missing = 74

ASK EVERYONE:

55. Did you install any High Intensity Discharge, or HID, fixtures in 1996? C530-531

- Yes.....11 (ASK Q56)
- No12 (GO TO Q61)
- Don't Know.....77 (GO TO Q61)
- Refused88 (GO TO Q61)

Q55	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	6	7.9	6	7.9
12	70	92.1	76	100.0

IF YES, ASK:

56. How many HID fixtures did you install? C532-534 (SPECIFY #)

Q56	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	2	33.3	2	33.3
4	1	16.7	3	50.0
5	2	33.3	5	83.3
12	1	16.7	6	100.0

Frequency Missing = 70

57. Of these, how many replaced old fixtures? C535-537 (SPECIFY #)

Q57	Frequency	Percent	Cumulative Frequency	Cumulative Percent
00&	1	16.7	1	16.7
000	2	33.3	3	50.0
001	1	16.7	4	66.7
004	2	33.3	6	100.0

Frequency Missing = 70

58. Why did you install HID fixtures? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C538-539
b. The current equipment was not performing well	11	12	77	88	C540-541
c. You wanted to improve equipment reliability	11	12	77	88	C542-543
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C544-545
e. Any other reason? (SPECIFY)	11	12	77	88	C546-547
f. New installation/new building/expansion	11	12	Not applicable		C166-167

Q58A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	16.7	1	16.7
12	5	83.3	6	100.0

Frequency Missing = 70

Q58B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	16.7	1	16.7
12	5	83.3	6	100.0

Frequency Missing = 70

Q58C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	33.3	2	33.3
12	4	66.7	6	100.0

Frequency Missing = 70

Q58D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	16.7	1	16.7
12	5	83.3	6	100.0

Frequency Missing = 70

Q58E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	33.3	2	33.3
12	4	66.7	6	100.0

Frequency Missing = 70

Other responses
Security
Better lighting

Q58F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	33.3	2	33.3
12	4	66.7	6	100.0

Frequency Missing = 70

59. How did you first learn about HID fixtures? (READ LIST)C548-549

- You were contacted by someone at PG&E..... 11
- You were contacted by a contractor or vendor..... 12
- Through media contact such as
a bill insert, TV, radio, or brochure..... 13
- From word of mouth..... 14
- From previously participating in a program..... 15
- Other (DO NOT READ)..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ).....88

Q59	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	5	83.3	5	83.3
77	1	16.7	6	100.0

Frequency Missing = 70

60. According to PG&E records, you did not apply for a rebate for installing HID fixtures.
Why didn't you apply for a rebate? (READ LIST).....C550-551

- The rebate was too small..... 11
- It was too much of a hassle 12
- It was too late to apply 13
- You did not think about it 14
- You did not know about it..... 15
- Other (SPECIFY) _____..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88

(GO TO Q61)

Q60	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	1	16.7	1	16.7
15	4	66.7	5	83.3
16	1	16.7	6	100.0

Frequency Missing = 70

Other responses
Got rebate in 1995 but installed in 1996

ASK EVERYONE:

61. Did you install any energy-efficient motors in 1996? **C552-553**
 Yes..... 11 (ASK Q62)
 No..... 12 (GO TO Q67)
 Don't Know..... 77 (GO TO Q67)
 Refused 88 (GO TO Q67)

Q61	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	12	15.8	12	15.8
12	63	82.9	75	98.7
77	1	1.3	76	100.0

IF YES, ASK:

62. How many energy-efficient motors and of what horsepower did you install without a rebate? (FOR EXAMPLE: “ 5 MOTORS AT 25 HORSEPOWER”)
 a. (SPECIFY #) C554-556 motors at C557-559 (SPECIFY HORSEPOWER)

Q62A1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	3	25.0	3	25.0
2	3	25.0	6	50.0
3	3	25.0	9	75.0
4	1	8.3	10	83.3
6	1	8.3	11	91.7
20	1	8.3	12	100.0

Frequency Missing = 64

Q62A2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
001	3	25.0	3	25.0
002	1	8.3	4	33.3
003	1	8.3	5	41.7
010	2	16.7	7	58.3
025	1	8.3	8	66.7
030	1	8.3	9	75.0
040	2	16.7	11	91.7
150	1	8.3	12	100.0

Frequency Missing = 64

b. (SPECIFY #) C560-562 motors at C563-565 (SPECIFY HORSEPOWER)

Q62B1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	2	50.0	2	50.0
2	2	50.0	4	100.0

Frequency Missing = 72

Q62B2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	1	25.0	1	25.0
2	1	25.0	2	50.0
5	1	25.0	3	75.0
40	1	25.0	4	100.0

Frequency Missing = 72

c. (SPECIFY #) C566-568 motors at C569-571 (SPECIFY HORSEPOWER)

Q62C1	Frequency	Percent	Cumulative Frequency	Cumulative Percent
2	2	100.0	2	100.0

Frequency Missing = 74

Q62C2	Frequency	Percent	Cumulative Frequency	Cumulative Percent
001	1	50.0	1	50.0
005	1	50.0	2	100.0

Frequency Missing = 74

d. (SPECIFY #) C572-574 motors at C575-577 (SPECIFY HORSEPOWER)

Q62D1	Frequency	Percent	Cumulative	Cumulative
			Frequency	Percent
1	1	100.0	1	100.0

Frequency Missing = 75

Q62D2	Frequency	Percent	Cumulative	Cumulative
			Frequency	Percent
8	1	100.0	1	100.0

Frequency Missing = 75

63. Of these, how many replaced old motors? C578-580 (SPECIFY #)

Q63	Frequency	Percent	Cumulative	Cumulative
			Frequency	Percent
00&	1	8.3	1	8.3
000	3	25.0	4	33.3
001	2	16.7	6	50.0
002	1	8.3	7	58.3
003	2	16.7	9	75.0
006	1	8.3	10	83.3
007	1	8.3	11	91.7
020	1	8.3	12	100.0

Frequency Missing = 64

64. Why did you install these energy-efficient motors? Was it because: (ITEM)?

(READ ITEMS ONE AT A TIME AND RECORD RESPONSE FOR EACH)	Yes	No	Don't Know	Refused	
a. The equipment was broken	11	12	77	88	C608-609
b. The current equipment was not performing well	11	12	77	88	C610-611
c. You wanted to improve equipment reliability	11	12	77	88	C612-613
d. Your previous experience with the energy efficiency of new equipment	11	12	77	88	C614-615
e. Any other reason? (SPECIFY)	11	12	77	88	C616-617
f. New installation/new building/expansion	11	12	Not applicable		C168-169

Q64A	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	9	75.0	9	75.0
12	3	25.0	12	100.0

Frequency Missing = 64

Q64B	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	16.7	2	16.7
12	9	75.0	11	91.7
77	1	8.3	12	100.0

Frequency Missing = 64

Q64C	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	4	33.3	4	33.3
12	7	58.3	11	91.7
77	1	8.3	12	100.0

Frequency Missing = 64

Q64D	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	2	16.7	2	16.7
12	9	75.0	11	91.7
77	1	8.3	12	100.0

Frequency Missing = 64

Q64E	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	8.3	1	8.3
12	11	91.7	12	100.0

Frequency Missing = 64

Other responses

Incentive from pump company came with new pump

Q64F	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	3	25.0	3	25.0
12	9	75.0	12	100.0

Frequency Missing = 64

65. How did you first learn about energy-efficient motors? (READ LIST) **C618-619**

- You were contacted by someone at PG&E..... 11
- You were contacted by a contractor or vendor..... 12
- Through media contact such as
a bill insert, TV, radio, or brochure..... 13
- From word of mouth..... 14
- From previously participating in a program..... 15
- Other (DO NOT READ)..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ)..... 88

Q65	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	1	8.3	1	8.3
12	8	66.7	9	75.0
16	1	8.3	10	83.3
77	2	16.7	12	100.0

Frequency Missing = 64

66. According to PG&E records, you did not apply for a rebate for installing efficient motors. Why didn't you apply for a rebate? (READ LIST).....**C620-621**

- The rebate was too small..... 11
- It was too much of a hassle 12
- It was too late to apply 13
- You did not think about it 14
- You did not know about it..... 15
- Other (SPECIFY) _____..... 16
- Don't Know (DO NOT READ)..... 77
- Refused (DO NOT READ) 88
- The rebate was too small AND it was too much of a hassle 19**

(GO TO Q67)

Q66	Frequency	Percent	Cumulative Frequency	Cumulative Percent
12	3	23.1	3	23.1
15	6	46.2	9	69.2
16	2	15.4	11	84.6
19	1	7.7	12	92.3
77	1	7.7	13	100.0

Frequency Missing = 63

- Other responses
- Told no rebate program available
- Handled by contractor

67. Those are all the questions I have. On behalf of PG&E, I greatly appreciate your time and cooperation in this survey. Thank you very much.

NOTE: IF RESPONDENT REQUESTED CONTACT INFORMATION FOR PG&E, CHECK BOX AT BOTTOM OF CONTACT RECORD SHEET.

NOTE: IF RESPONDENT WANTED COMMENTS FORWARDED TO PG&E, ENTER THEM HERE:

RESPONDENT NAME: _____

SAMPLE ID NUMBER: C124-129 AND C622-627

INTERVIEWER ID: _____

TIME ENDED: C628-632

DATE: C130-135

Reasons for Refusing the Survey

Final disposition 11/5/97	<u>Total</u>	<u>EEl non-participant</u>	
		<u>Lighting</u>	<u>Pumping</u>
No ans. on last attempt/Ans. Mach.	24	10	14
Respondent not avail. on last attempt	29	7	22
Disconnected/fax (no listing with direct. asst.)	6	1	5
Wrong number (no listing with direct. asst.)	11	3	8
Refusal (before contact determined)	9	2	7
Refusal (by correct contact)	23	12	11
Other	12	7	5
<u>Completes</u>	<u>76</u>	<u>34</u>	<u>42</u>
<u>Total</u>	<u>190</u>	<u>76</u>	<u>114</u>

Appendix D - Final EMS Participant Telephone Survey with Response Frequencies

START OF SURVEY

TIME STARTED: _____ **C109-116**

Following three questions from Market Transformation survey are used for calculating the number of pumps repaired by EMS participants.

ASK EVERYONE:

Now I'm going to ask you some questions regarding pump repairs and pump tests.

28. Did your business or organization repair any deep well pumps since January 1996? **C378-379**

Yes 11 (ASK Q29 and Q30)
No 12 (GO TO Q31)
Don't Know 77 (GO TO Q31)
Refused..... 88 (GO TO Q31)

Q28	Frequency	Percent	Cumulative Frequency	Cumulative Percent
11	161	46.0	161	46.0
12	183	52.3	344	98.3
77	5	1.4	349	99.7
88	1	0.3	350	100.0

IF Q28 = YES, ASK:

29. How many? C408-411 (# REPAIRED SINCE JAN. 1996)

Q29	Frequency	Percent	Cumulative Frequency	Cumulative Percent
1	83	51.6	83	51.6
2	27	16.8	110	68.3
3	13	8.1	123	76.4
4	15	9.3	138	85.7
5	6	3.7	144	89.4
6	5	3.1	149	92.5
7	3	1.9	152	94.4
8	1	0.6	153	95.0
10	3	1.9	156	96.9
12	2	1.2	158	98.1
15	1	0.6	159	98.8
30	1	0.6	160	99.4
100	1	0.6	161	100.0

Frequency Missing = 189

30. How many of these pumps were/Was this pump repaired simply as a result of equipment breakdown? C412-415 (# REPAIRED DUE TO BREAKDOWN)

Q30	Frequency	Percent	Cumulative Frequency	Cumulative Percent
0	34	21.1	34	21.1
1	74	46.0	108	67.1
2	21	13.0	129	80.1
3	9	5.6	138	85.7
4	9	5.6	147	91.3
5	5	3.1	152	94.4
6	3	1.9	155	96.3
7	1	0.6	156	96.9
8	1	0.6	157	97.5
10	1	0.6	158	98.1
15	1	0.6	159	98.8
30	1	0.6	160	99.4
50	1	0.6	161	100.0

Frequency Missing = 189

Appendix E - Engineering Technical Analysis

Overview

The engineering analyses covered in this appendix resulted in estimates of the gross energy and demand impact for both the 1996 Agricultural Energy Efficiency Incentives (AEEI) and the 1996 Agricultural Energy Management Services (AEMS) Programs. The analyses used information gathered during on-site surveys from a census of the AEEI participants and from telephone surveys of a sample of AEMS participants.

The 1996 AEEI program encompasses two end uses, pumping and indoor lighting (miscellaneous end uses were not evaluated). The methodology will be discussed briefly (the complete write up is in the body of the report), then details of each separate analysis will be presented, along with the results. The AEMS program analysis follows the indoor lighting end use discussion. First, information regarding the sources of data used in the analyses is presented.

Data Sources

The engineering analyses used information gathered during on-site audits for the AEEI participants. Exhibit E.1 shows the break down, by end use, of the participant population and completed audits.

Exhibit E.1

Completed Participant On-Site Audits

	Pumping End Use	Indoor Lighting End Use
Participant Population Applications	91	70
On-Site Audited Applications	74	54
Completion Percentage	81%	77%

The indoor lighting end use had no other data sources for the analysis. The on-site audit consisted of a short interview with the owner to determine if any productivity changes had resulted from the change in lighting. Then the rebated fixtures were verified and grouped into similar schedules. Information about when the lights were used throughout the year was collected. Lights were counted and the current status of the lights were determined (i.e., how many were on). A retention panel was created for the rebated lights.

In addition to the participants shown in Exhibit E.1, the pumping end use gathered information from a group of 68 nonparticipants. The on-site audits consisted of a pump test, follow up information about the pump, and any other loads on the meter. There are four measures within the pumping end use. Three of the measures had pump tests performed during the on-site audit (pump repair, low pressure sprinkler nozzle, and micro drip conversion). Custom sites (eight applications) had an audit, but no pump test. Exhibit E.2 presents the pump tests performed by measure. Of the remaining ten applications within the pumping end use, eight are Custom sites and two are pumping adjustment measures which were not analyzed.

**Exhibit E.2
Pump Tests by Measure**

	Pump Repair	Low Pressure Sprinkler Nozzles	Micro-drip Irrigation Conversion	Nonparticipants
# Paid Applications	67	3	11	NA
# Unique Customers	46	3	6	49
# Pump Tests	46	2	18 (10 Apps)	68
Completion Percentage	69%	69%	91%	NA

Exhibit E.3 shows the completed pump tests by pump type and horsepower (hp) bin. Submersible pumps have been included under the turbine pump type, as have turbine boosters and deep well pumps.

**Exhibit E.3
Pump Tests by Pump Type and Horsepower Bin**

hp	Type of Pump	Participant	Nonparticipant
< 20	Axial/Propeller	1	4
	Centrifugal	0	0
	Turbine	2	12
<i>Total Bin 1</i>		3	16
20 - 75	Axial/Propeller	2	1
	Centrifugal	5	0
	Turbine	32	36
<i>Total Bin 2</i>		39	37
> 75	Axial/Propeller	7	4
	Centrifugal	0	0
	Turbine	17	11
<i>Total Bin 3</i>		24	15
Total		66	68

The AEMS analysis was based on information gathered during participant telephone surveys. The customer was asked if their business had repaired any deep well pumps since January, 1996. If so, they were then asked how many. A follow up question asked the customer to state how many of the pumps were “repaired simply as a result of equipment breakdown”. The AEMS analysis used 350 completed surveys.


Throughout the analysis, agricultural engineers on the Equipoise Team were also used as sources of information to check assumptions made or clarify questionable test results.

Pumping End Use

Methodology

The complete methodology section is provided within the body of the report. Exhibit E.4 presents an overview of the flow of information within the analysis.


Exhibit E.4 Method for Gross Impact Analysis



The best laid plans can sometimes require re-thinking. In this analysis, the original plan was to use the evaluation pump tests as the post-repair information and PG&E pump test database information as the pre-repair information. (There are 25 participants with pump tests within the PG&E database.) However, data attrition due to poor quality pump test results in the evaluation pump tests and the determination that many of the participant PG&E pump tests were done AFTER the pump had been repaired, vastly decreased the number of possible pre- and post-repair pump test comparisons. Exhibit E.5 shows the breakdown of good and poor quality pump tests across both the participant and nonparticipant pump test sites. Data quality for pump tests were set by the two pump testers on the Equipoise Team. A pump test could be set as “poor” for multiple reasons, among them the unavailability of a long enough piece of piping for the test (and resultant turbulent flow) or inability to sound the well. Any difficulties during the pump test which would cause the results to be suspect, based on the experience of the pump testers, created a poor data quality rating. As Exhibit E.5 indicates, 65% of the tests provided good or fair results, while 35% had poor data quality. However, of the 25 pump tests within the PG&E database, only 9 were determined to actually have been performed prior to the pump repair. The

pre-and post-repair assignment of the PG&E pump test for each participant was based on the self-reported date of pump repair (gathered during the on-site audit) and the date of the pump test as recorded in the MDSS. If the date of pump repair was unknown, the date the rebate check was cut for the repair and the date of the pump test were compared to determine when the pump tests occurred.

**Exhibit E.5
Pump Test Data Quality**



With this new found dearth of information, additional information was sought and the original approach was modified. As much information was gleaned from the pump tests as possible and supplemented by information within the PG&E pump test database. The small sample within each pump type as shown in Exhibit E.3, especially for axial and centrifugal pumps, meant that multiple curve functions based on pump type, geographical location, and irrigation type could not be used as originally planned.

The pump repair measure energy impact was determined by applying an Overall Pump Efficiency (OPE) ratio to the 1996 billing data usage. The OPE ratio application, shown in Exhibit E.6, is similar to the approach used for the ex ante estimate of savings.

**Exhibit E.6
Engineering Pump Repair Algorithm**

$$\text{kWh Savings} = 1996 \text{ kWh} * \left(1 - \frac{\text{OPE}_{\text{pre}}}{\text{OPE}_{\text{post}}} \right)$$

To determine demand impact, the demand analysis used pre- and post-pump repair pump test data. The percent of motor load was analyzed to determine if there was an increase or decrease in the motor load (and therefore, the demand).

The analysis indicated that there was no change in the motor load pre- and post-repair.

Therefore, no ex post kW savings were applied to pump repairs.

Both the low pressure sprinkler nozzle (LPSN) and micro-drip irrigation conversion (micro) energy and demand analysis methods relied heavily on the information gathered during the on-site audits and then moved the information to the population on a measure by measure basis.

Details are discussed more fully below.

Results

Pump Tests

The participant pump test effort attempted a census of the population. The nonparticipant test schedule lagged the participant test schedule slightly to attempt to mimic the geographical location of the participants. As indicated in Exhibit E.7, this goal was met to a certain degree. Fresno was the one exception, where there was an overabundance of nonparticipants. The spread of tests was deemed to be acceptable for use within the analysis.

Exhibit E.7

Pump Tests by PG&E Division

PG&E Division	Participant s	Nonparticipant s	Total
Central Coast	5	6	11
Los Padres	10	7	17
North Valley	2	3	5
Sacramento / Sierra	3	6	9
Stockton	13	7	20
Fresno	1	19	20
Kern	30	19	49
Yosemite	2	1	3
Total	66	68	134


Exhibit E.8 breaks out the information from Exhibit E.3 into the specific pump type and where the pump was placed (i.e., deep well or booster). As is typical when a sample is further subdivided, the number of points within each cell goes down and becomes less useful within an analysis for leveraging to a population.

**Exhibit E.8
Pump Tests by Type and Placement**

hp	Pump Type	Pump Placement	Participants	Nonparticipants
< 20	Axial/Propeller	Well	1	4
	Centrifugal	Booster	0	0
	Submersible	Well	0	8
	Turbine	Booster	2	0
	Turbine	Well	0	4
<i>Total Bin 1</i>			3	16
20 - 75	Axial/Propeller	Well	2	1
	Centrifugal	Booster	5	0
	Submersible	Well	2	2
	Turbine	Booster	15	1
	Turbine	Well	15	33
<i>Total Bin 2</i>			39	37
> 75	Axial/Propeller	Well	7	4
	Centrifugal	Booster	0	0
	Submersible	Well	1	0
	Turbine	Booster	2	1
	Turbine	Well	14	10
<i>Total Bin 3</i>			24	15
Total			66	68

The number of good and fair pump tests by participation and pump type is shown below in Exhibit E.9.

**Exhibit E.9
Good Pump Tests by Participation and Pump Type**



Each of the pump tests were used to the fullest extent possible within the AEEI analyses of the various measures.

Pump Repair

The energy analysis will be discussed first, followed by the demand analysis. After the data was compiled and prior to any analysis of pre- and post-pump tests, the pump test data was compared between the participants and nonparticipants. The statistical t-test (one-tailed) was used to see if the differences between the two groups were significant at the 90% confidence level. Only pump types with greater than ten sample points in each group were tested with the t-test. Smaller sample groups were compared only on a point basis, with no significance applied to the result. Therefore, while there are average differences between small sample groups, no analysis decisions were based upon those differences. The nonparticipant pump tests were collected based on the original analysis plan. However, with the changes to the analysis, the comparison between the participant and nonparticipant pump tests merely provided a touch stone of reality to the pre-/post-analysis and nothing more. When all pump types are compared between the participants and nonparticipants, the average OPE difference was 7.7% (with the participants having the higher average OPE), and indicated a significant difference at the 90% confidence level. The algorithm used to determine the energy impact for pump repair is shown in Exhibit E.6. There were five participant pump repair sites with both a good pump test and pre-repair pump test data from the PG&E database. Of these, four were deep well turbine pumps and one was a submersible turbine. Since the evaluation could not rest on these few pre- and post-tests, the only other source of pre- and post-data was analyzed. Within the 1995/96 PG&E pump test database is a variable stating 'Pump Test Type'. This variable has multiple choices, two of which are 'routine' and 'after pump repair'. Each pump test represents a single test. The database contains many tests which appear to have been made on the same pump, only at different times. Tests which were made on the same pump and had both a 'routine' and 'after pump repair' designation were pulled from the database and analyzed. The tests were determined to be on the same pump based on the horsepower of the pump and the meter number. Only those pump tests with a 'routine' pump test prior to the 'after pump repair' were kept. As shown in Exhibit E.10, there were mainly turbine pumps with pre- and post-pump repair data.

**Exhibit E.10
PG&E Pump Test Pre- and Post-Tests by Pump Type**

Pump Type	Number of Pre- / Post- Tests
Mixed Flow	2
Propeller	2
Submersible	3
Turbine	22
Vertical Turbine	2
Booster	
Total	31

The submersible and turbine OPEs were taken from the PG&E database for the 3 submersible and 22 turbine pump tests with both a pre- and post-pump repair. Additionally, three growers with good post-pump test data from the evaluation had had pump tests performed on the pumps by independent pump testers prior to the pump repair and were able to find the results. Exhibit E.11 indicates the results of this analysis. The more conservative OPE ratio from the turbine pumps of 0.14 was used to determine the impact of the program.

**Exhibit E.11
Pre- and Post-OPE**

Type of Pump	Source of Data	Number of Points	Old OPE	Evaluation OPE	OPE Difference	OPE Ratio
Submersible	Evaluation	1	0.54	0.64	0.100	0.16
	PG&E	3	0.34	0.40	0.064	0.15
	Database					
Weighted Submersible	Both	4	0.39	0.46	0.073	0.16
Turbine	Evaluation	1	0.47	0.65	0.185	0.28
Turbine	Evaluation	1	0.29	0.61	0.319	0.52
Turbine	Evaluation	1	0.47	0.56	0.095	0.17
Turbine	Evaluation	1	0.26	0.63	0.371	0.59
Turbine	Evaluation	1	0.60	0.67	0.069	0.10
Turbine	Evaluation	1	0.61	0.70	0.085	0.12
Turbine	Evaluation	1	0.57	0.60	0.033	0.05
Turbine	PG&E	22	0.54	0.60	0.061	0.10
	Database					
Weighted Turbine	Both	29	0.52	0.61	0.086	0.14

The OPE ratio was applied to the summed 1996 kWh billing data to determine the program impact. However, the actual billing data does not reflect only the pump repaired because some meters have other loads. This appeared to be especially true for axial pumps which were moving great quantities of water using large horsepower pumps. The on-site audits had collected the other loads on the meters. All other loads were taken out of the known accounts. Any non-audited sites used the actual billing data. The MDSS indicates the pump usage for 12 months prior to the repair. While that information is mainly for 1995 energy usage, the individual account energy use values for the 1995 billing data and the MDSS did not always match. However, the sum of the MDSS and the 1995 billing data (with other loads removed), were within 2% of each other, with the estimated 1995 billing data being slightly lower than the MDSS. This was considered acceptable, and the same load percents were removed for specific accounts for the 1996 energy usage. Exhibit E.13 indicates the usage of the pump repair participants and the program level impact.

The demand analysis used the same pre- and post-pump repair sites as the energy analysis. The three sites with independent pump test information provided by the growers did not have the motor load value provided. Therefore, the pre- and post-motor loads were based on twenty-six turbine pumps.

**Exhibit E.12
Pre- and Post-Motor Loads**

Type of Pump	Source of Data	Number of Points	Old Motor Load	Evaluation Motor Load	Difference
Submersible	Evaluation	1	0.51	1.07	0.56
	PG&E Database	3	0.75	0.81	0.06
Weighted Submersible	Both	4			0.18
Turbine	Evaluation	1	0.95	0.88	-0.07
Turbine	Evaluation	1	1.06	0.85	-0.21
Turbine	Evaluation	1	1.07	1.09	0.02
Turbine	Evaluation	1	0.84	0.91	0.07
Turbine	PG&E Database	22	1.01	1.03	0.02
Weighted Turbine	Both	26			0.01

The motor loads were only slightly greater post-repair than pre-repair. The 80% confidence interval around the average includes zero. Because of this, the demand impact was set to zero for the evaluation.

**Exhibit E.13
Pump Repair Measure - Program Usage and Impacts**

	kWh	kW
MDSS	19,363,469	-
1995 Billing Data	19,035,731	-
1996 Billing Data	20,058,575	-
OPE Ratio	0.14	-
Ex Post Impact	2,831,503	0
Ex Ante Impact	1,858,469	323
Gross Realization Rate	1.52	0

Pump Adjustments

The pump adjustment measure obtained a waiver such that the analysis consisted of a review of the ex ante estimate with adjustment if needed. The ex ante estimate was reviewed and found to have used a savings estimate of 11% of the average pump usage of 125,910 kWh. From previous evaluation of this measure, a pump adjustment most likely provides from 1.5% to 2% of savings of the energy used. Therefore, the savings percent for this measure was reduced from 11% to 1.5%, decreasing the ex ante value of 13,573 kWh to an ex post value of 3,777 kWh. There are no demand savings for this measure.

Low Pressure Sprinkler Nozzle

There were 3 low pressure sprinkler nozzle (LPSN) applications representing 21,720 nozzles. The evaluation team visited 2 sites where 6,400 nozzles were installed. One of the sites was also paid for 12,500 more nozzles than installed at the site visited. That grower was queried about how they installed the other nozzles to determine how best to provide impacts to the population. The on-site audit collected the pumping accounts which had been affected by the LPSN. This was required since one application was for a portable system and the other application was for a permanent system which applied for the nozzles under a single account although they were used across more than one account when actually installed. Energy analysis will be discussed first, followed by the demand analysis, and then moving the results to the population .

Certain assumptions were made during the LPSN analysis. It was assumed that the OPE of the old and new system were the same because neither audited site changed their pumping system. It was also assumed that the irrigation efficiency (IE) of the old system and the new system were the same. Therefore, there was no assumed difference between the acre feet (AF) of water pumped in 1996 and what would have been pumped with the old high pressure sprinkler system. These are conservative assumptions. The nozzle pressures in pounds per square inch (psi) for the pre- and post-nozzles were based on grower self-report. Given these assumptions, the engineering algorithms used to determine the kWh / nozzle impact are shown in Exhibit E.14.

Exhibit E.14

LPSN Engineering Energy Algorithms

- (1) Post total dynamic head (TDH) from nozzles = post psi * 2.31 ft/psi
- (2) Post TDH outside of nozzles = Actual TDH from pump test – (1)
- (3) Pre TDH = pre psi * 2.31 ft/psi + (2)
- (4) $AF = 1996 \text{ kWh} / (\text{kWh}/AF)_{\text{from pump test}}$
- (5) $\text{kWh} / AF_{\text{pre}} = 1.0241 \text{ kWh}/(\text{AF ft}) * (3) / \text{pre OPE}$
- (6) $\text{kWh}_{\text{pre}} = (4) * (5)$
- (7) $\text{kWh Impact} = \text{kWh } 1996 - (6)$
- (8) $\text{kWh} / \text{nozzle impact} = (7) / \text{nozzles installed}$

Of the two sites audited, one had made no actual change to the TDH since they simply installed a butterfly valve to decrease the pressure to the nozzles. This site received no energy or demand impacts. The other site had extended the acreage irrigated, thereby decreasing the actual pressure at the pump. This site received the estimated kWh/nozzle impact as determined in the evaluation. The demand analysis used an approach similar to the ex ante algorithms. The TDH difference value used the estimated pre-TDH from the energy analysis. The post-TDH value came from the pump test. The engineering algorithms are shown in Exhibit E.15.

Exhibit E.15

LPSN Engineering Demand Algorithms

- (1) $\Delta \text{hp} = (\text{GPM}_{\text{from pump test}}) * \Delta \text{TDH} / (3960 \text{ GPM Ft}/\text{hp} * \text{current OPE})$
- (2) $\Delta \text{hp} / \text{acre} = (1) / \text{acres irrigated}$
- (3) $\text{Nozzles} / \text{acre} = \text{nozzles found at site} / \text{acres irrigated}$
- (4) $\Delta \text{kW} / \text{nozzle} = (2) * 0.746 \text{ kW}/\text{hp} / (3)$
- (5) $\text{Peak kW} / \text{nozzle impact} = (4) * \text{Coincident Diversity Factor of } 0.78$

The evaluation team discussed how the additional non-audited nozzles had been installed at one site with the grower. It was determined that all systems increased the acreage irrigated. Since there were only three applications within this measure, moving to the population consisted of setting one application's impact to zero (the site with the butterfly valve), multiplying the number of rebated nozzles with the kWh/nozzle and peak kW/nozzle at the one site with known correct decreasing of pressure, and using an average per nozzles energy and demand impact weighted by paid units for the third site. The results are shown in Exhibit E.16.

Exhibit E.16
LPSN Measure - Program Impacts

Site	MDSS Information					Estimated Impact			
	P_KWH	P_KW	Ex ante kWh / Nozzle	Ex ante kW / Nozzle	P_Units	kWh	kW	Ex Post kWh / Nozzle	Ex Post kW / Nozzle
1	16,800	6.0	12	0.0082	1,400	-	-	-	-
2	39,480	5.9	14	0.0040	2,820	51,840	4.7	18.4	0.0021
3	175,000	26.3	10	0.0029	17,500	411,777	37.5	23.5	0.0027
Impact						463,617	42		
Gross Realization Rate						2.00	1.11		

The site specific details of the analysis are shown at the end of this appendix on the pages labeled Exhibit E.33, LPSN analysis.

Micro-drip Irrigation Conversion

The micro-drip irrigation conversion (micro) sites totaled eleven applications representing six unique customers. The on-site audits went to ten of the applications and five of the unique customers. Five of the applications were short-coupled lift pumps. At those sites, each pump was tested, giving a total of eighteen pump tests for the ten applications.

The analysis of the micro sites used the pump test information in a fashion similar to the LPSN analysis. The estimated pre- and post-pressure of the systems were based on grower self-reports. The current system's IE was estimated in the field by expert auditors. The previous IE of the high pressure system relied upon information from the previous two Agricultural Program evaluations. All previous systems were high pressure, and the same pre-retrofit IE (0.76) was applied to all sites. All systems audited, except one, had changed out the pumps. The pre-OPE designated to each pump was based on the previous pump type. If the post-pump was a turbine booster and the pre-pump had been a centrifugal pump, the average OPE for 'routine' tests on centrifugal pumps within the PG&E pump test was applied (0.55) for the pre-retrofit OPE. If the both the post-and pre-pumps were turbine booster pumps, it was assumed that the retrofit also enhanced the pumping of the new pump. Based on the pump repair analysis, the pre-OPE was set to 8.5% less than the OPE found during the pump test. The one site which made no change had the same OPE applied pre- and post-conversion. The algorithms used in the analysis are shown in Exhibit E.17.

Exhibit E.17

Micro Conversion Engineering Energy Algorithms

- (1) Post total dynamic head (TDH) from system = post psi * 2.31 ft/psi
- (2) Post TDH outside of drip system = Actual TDH from pump test – (1)
- (3) Pre TDH = pre psi * 2.31 ft/psi + (2)
- (4) $AF_{post} = 1996 \text{ kWh} / (\text{kWh}/AF)_{\text{from pump test}}$
- (5) $AF_{pre} = AF_{post} * \text{post IE} / \text{pre IE}$
- (6) $\text{kWh} / AF_{pre} = 1.0241 \text{ kWh}/(\text{AF ft}) * (3) / \text{pre OPE}$
- (7) $\text{kWh}_{pre} = (5) * (6)$
- (8) $\text{kWh Impact} = \text{kWh}_{pre} - \text{kWh}_{post}$
- (9) $\text{kWh} / \text{Acre Impact} = (8) / \text{Acres converted}$

There were four applications which replaced one large pump and with two or three smaller pumps for the micro conversion. All pumps were on one meter and each pump was tested during the evaluation. For each of these sites the auditor collected the percent of time each pump was run. The 1996 kWh data was parceled to each new pump based on this information. Each pump then used the algorithms in Exhibit E.17 to determine a kWh Impact for that pump. The values were summed across the pumps to obtain a savings for the site.

The demand savings were calculated using algorithms shown below. It was assumed that the systems run 22 hours per day when in use. Therefore, the peak kW equals the kW impact.

Exhibit E.18

Micro Conversion Engineering Demand Algorithms

- (1) $\text{Delta TDH} = \text{Pre TDH} - \text{Post TDH}$
- (2) $\text{kW Impact} = (\text{GPM from pump test}) * (1) / (3960 \text{ GPM ft}/\text{hp} * \text{post OPE}) * 0.746 \text{ kW}/\text{hp}$
- (3) $\text{kW Impact} / \text{acre} = (2) / \text{acres converted}$

Since ten out of the eleven applications had had an on-site audit and pump testing done, there was little leveraging to move to the population. For the ten applications, the kWh impact determined in the analysis was used for the program impact. For the one application with no audit, a realization rate was determined for each of the ten applications and the average realization rate was applied to the ex ante estimate. For energy, the average realization rate applied to the non-audited site was 0.94.

The population estimates were calculated in the same manner as the energy estimates. The demand realization rate applied to the one non-audited site was 0.81. The program impacts are shown in Exhibit E.19.

**Exhibit E.19
Micro Drip Conversion Measure – Program Impacts**

Application	MDSS Information			Evaluation Impacts	
	P_KWH	P_KW	P_UNITS (acres)	kWh	kW
1	25,102	10.5	26	23,498	10.8
2	30,380	14.1	35	8,212	4.0
3	12,654	5.0	18	4,491	5.1
4	33,150	13.1	50	49,559	17.1
5	41,769	16.5	63	34,350	17.4
6	53,040	21.0	80	46,964	76.9
7	238,005	176.5	387	367,811	110.3
8	238,005	176.5	387	274,868	119.1
9	177,120	131.3	288	192,644	70.2
10	137,145	101.7	223	163,926	72.2
11	44,405	21.2	107	24,399	8.5
Impact				1,190,723	511.7
Gross Realization Rate				1.16	0.74

The site specific details of the analysis are shown at the end of this appendix on the pages labeled Exhibit E.34 – Micro-Drip Conversion Analysis.

Custom Applications

There were seven Custom Incentives (CI) applications and one Advanced Performance Options (APO) application. All were audited. Engineering reviews were performed on each application in order to assess the assumptions and algorithms used for each site. Any changes to the sites result in a change in the ex ante estimate of impact. The reviews are presented next, grouped by the type of application.

Pacific Gas & Electric 1996 Agricultural Program – Custom Rebate Assessment

Drip Irrigation Conversion

Recommendation	None
Technology Description	Micro drip system installed
Number of Sites Reviewed	2
Assessment of Assumptions	Assumptions appear reasonable
Assessment of Algorithms	Reviewed and deemed appropriate
On-Site Assessment	Systems in place and working as shown in paperwork.

Pacific Gas & Electric 1996 Agricultural Program – Custom Rebate Assessment

Enhanced Irrigation Well

Recommendation	None
Technology Description	Design and construction features of the well produce energy savings from reduced lift.
Number of Sites Reviewed	1
Assessment of Assumptions	Assumption appears high for pump efficiency, but provided conservative estimate of savings. Therefore, no change recommended
Assessment of Algorithms	Reviewed and deemed appropriate
On-Site Assessment	Systems in place and working as shown in paperwork

Pacific Gas & Electric 1996 Agricultural Program – Custom Rebate Assessment

Pump Repair on Natural Gas Engine

Recommendation	None
Technology Description	Repair bowls for natural gas engine pumping system.
Number of Sites Reviewed	3
Assessment of Assumptions	Assumptions appear reasonable
Assessment of Algorithms	Reviewed and deemed appropriate
On-Site Assessment	Systems in place and working as shown in paperwork

Pacific Gas & Electric 1996 Agricultural Program – Custom Rebate Assessment

Refrigeration for Berries

Recommendation	Decrease Peak kW Impact
Technology Description	Installation of pressure cooling with VSD fans. Replacement of compressor and condenser system with change from ammonia to hydrocarbon refrigerant.
Number of Sites Reviewed	1
Assessment of Assumptions	Assumptions appear reasonable
Assessment of Algorithms	Reviewed and deemed appropriate
On-Site Assessment	System in place and functional as shown in paperwork.

Pacific Gas & Electric 1996 Agricultural Program – Custom Rebate Assessment

Irrigation Supply Piping

Recommendation	None
Technology Description	Change out of 10” diameter pipe to a 12” diameter PVC pipe to enhance flow.
Number of Sites Reviewed	1
Assessment of Assumptions	Assumptions appear reasonable
Assessment of Algorithms	Reviewed and deemed appropriate
On-Site Assessment	System in place and working as indicated in paperwork.

The population impact results of the custom sites are shown below in Exhibit E.20.

Exhibit E.20

Custom Sites - Program Impacts

	kWh	kW	Therm
Ex Ante Impact	406,258	315	110,743
Ex Post Impact	406,258	298	110,743
Gross Realization Rate	1.00	0.95	1.00

Lighting End Use

Methodology

The methodology for the lighting end use is provided in greater detail within the body of the report. Exhibit E.4 shows the method used for the analysis of gross impacts. The engineering analysis provided the estimates of both energy and demand impacts.

Results

There were 70 measures, representing 51 unique customers, paid under the 1996 Agricultural programs. Of these, on-site audits visited 54 measures and 42 unique customers. There were a variety of SIC codes within the evaluation, as shown in Exhibit E.21 and Exhibit E.22.

Exhibit E.21
Unique Customers by SIC Description

SIC DESCRIPTION	MDSS	On Site Audit
ANIMAL SPECIALITIES, NEC	1	1
BROILER, FRYER, AND ROASTER CHICKENS	3	3
CROP PREPARATION SERVICES FOR	11	10
DAIRY FARMS	5	4
DECIDUOUS TREE FRUITS	1	0
FOOD CROPS GROWN UNDER COVER	3	3
FOREST PRODUCTS	1	1
FORESTRY SERVICES	1	1
FRUITS AND TREE NUTS, NEC	1	1
GENERAL FARMS, PRIMARILY CROP	5	4
GRAPES	4	3
IRRIGATION SYSTEMS	1	1
ORNAMENTAL NURSERY PRODUCTS	6	4
POULTRY AND EGGS	1	1
REFRIGERATED WAREHOUSING AND	3	3
TREE NUTS	2	1
TURKEYS AND TURKEY EGGS	1	0
VEGETABLES AND MELONS	1	1
TOTAL	51	42

Exhibit E.22
Measures by SIC Description

MDSS SIC DESCRIPTION	MDSS Population Measures	On Site Audit Measures
ANIMAL SPECIALITIES, NEC	1	1
BROILER, FRYER, AND ROASTER CHICKENS	6	6
CHICKEN EGGS	1	0
CROP PREPARATION SERVICES FOR	12	11
DAIRY FARMS	6	5
DECIDUOUS TREE FRUITS	1	0
FOOD CROPS GROWN UNDER COVER	3	3
FOREST PRODUCTS	1	1
FORESTRY SERVICES	2	2
FRUITS AND TREE NUTS, NEC	1	1
GENERAL FARMS, PRIMARILY CROP	5	4
GRAPES	7	6
IRRIGATION SYSTEMS	1	1
ORNAMENTAL NURSERY PRODUCTS	12	7
POULTRY AND EGGS	1	1
REFRIGERATED WAREHOUSING AND	3	3
TREE NUTS	5	1
TURKEYS AND TURKEY EGGS	1	0
VEGETABLES AND MELONS	1	1
TOTAL	70	54

Although the measures rebated covered many PG&E measure codes, they could basically be placed into four groups (compact fluorescent, T-8 fluorescent, high intensity discharge, and other). Exhibit E.23 shows which measures were covered by the on-site audits and Exhibit E.24 shows the audited number of paid units by fixture type.

Exhibit E.23
Audited Sites by Lighting Group




Exhibit E.24
Audited Units by Fixture Type

Fixture Type	# of Units	# of Units
	Paid	Audited
CFL	2,743	2,638
T8	2,185	1,133
HID	1,247	1,212
Other	56	12
Total	6,231	4,995

**Exhibit E.25
Indoor Lighting Annual Hours of Operation Algorithm**

$$\text{Annual Hours of Operation} = \sum_{s=1}^3 [\text{Open Hours}_s * \text{OF}_{\text{open}, s} + \text{Closed Hours}_s * \text{OF}_{\text{closed}, s}]$$

Where

Open Hours_s = Schedule Group Annual Hours Open

OF_{open,s} = Open Operating Factor for Schedule Group, s

Closed Hours_s = Schedule Group Annual Hours Closed

Of_{closed,s} = Closed Operating Factor for Schedule Group, s

During the audit, the majority of lights within the audited group were found to be either 100% on or off, based on their schedule. The open operating factor was 0.96 and the closed operating factor was 0.04. Each group of lights had their own annual hours of operation applied to all fixture types within the group. The total annual hours of operation were less than the ex ante estimate of 4,000 hours. Exhibit E.25 shows the operating hours by fixture type with the average operating hours weighted by number of units paid.

**Exhibit E.26
Annual Hours of Operation by Fixture Type**

Fixture Type	Annual Hours of Operation
CFL	2,301
T8	2,313
HID	2,245
Other	5,811
Weighted Average	2,299

The energy impact used the annual hours of operation for each fixture type by SIC code designation, the change in technology wattage, and the number of paid fixtures as shown below in Exhibit E.27. The demand algorithm is shown in Exhibit E.28.

Exhibit E.27
Indoor Lighting Engineering Algorithm

$$kWh_{\text{impact}} = \sum_{\text{sic}=1}^{18} \left\{ \sum_{t=1}^6 \Delta UOL_{t, \text{sic}} * \# \text{ of Paid Units}_{t, \text{sic}} * \text{Annual Hours of Operation}_{t, \text{sic}} \right\}$$

Where

$UOL_{t, \text{sic}}$ = Change in connected load for technology, t

$\text{Paid Units}_{t, \text{sic}}$ = Units paid under the program for technology, t

Annual Hrs of Operation from Exhibit E.25

Exhibit E.28
Indoor Lighting Engineering Demand Algorithm

$$kW_{\text{impact}} = \sum_{\text{sic}=1}^{18} \left[\sum_{t=1}^6 \Delta UOL_{t, \text{sic}} \right] * OF_{\text{open}, p}$$

Where

$UOL_{t, \text{sic}}$ = Change in connected load for technology, t within the SIC designation

$OF_{\text{open}, p}$ = Open Operating Factor at time of peak, p

The peak operating factor for the hours between 3 PM and 4 PM was 0.47. This was less than the ex ante peak operating factor of 0.67.

The change in connected load for each technology is applied in both the energy and demand impact analysis. This variable uses the data collected from the audit for both pre- and post-retrofit fixture wattage. Within the agricultural sector, the pre-wattages were different than expected, particularly for the high intensity discharge (HID) fixtures. This will be discussed separately.

HID

Buildings of Uniform Building Code groups I and U do not have the California Energy Standards applied to them.¹ Agricultural buildings (UBC group U), therefore, do not have to follow any set pattern for lighting their buildings. The ex ante assumptions are based on commercial and industrial buildings with energy standards applied to maintain a specified lumens and watts per square foot. For the audited growers this often resulted in replacement of 60 to 100 watt incandescent lights with new 400 watt HID fixtures. Anecdotal evidence based on conversations by the auditor with the owners indicated that they were all quite happy with the level of light now within their buildings.

One of these sites installed all new lighting into an existing building that previously had no lights and another site built a larger building in which the new lights were installed and one site installed lighting into a renovated building. Using the screening for possible rebate measure

¹ Nonresidential Manual, California Energy Commission, Effective July 1995 and Updated March 1996, p. 2-2.

influence on output², these sites were considered new and the measure was assumed to fit into the ‘did not cause the change’ bin. Within this bin, the gross savings are defined to be: “(Consumption of the affected systems in the post-installation conditions at the observed post-installation output level) minus (consumption that would have occurred if the unimproved system had been used to achieve the same level of output).” Since there was no way the old system could have been used to achieve the same level of output without actual installation of more lights, the impact was set to zero for these two sites. Both growers at these two sites were contacted to query about why they installed HID fixtures rather than other possible technologies. One stated “After looking at both mercury vapor and incandescent fixtures, we decided that HIDs provided the best light wavelength for our crop.” The other stated “I looked at similar fixtures at neighbors buildings and liked the HID fixtures the best. Plus they seemed to be the most energy efficient.”

While many growers were thinking that more light within their buildings would be nice, it was the program incentive which appeared to cause them to act and purchase the additional wattage fixtures. Therefore, the increase in load seen by many with HID fixtures installed was considered to be caused by the program and applied as a negative impact. Although some of the fixtures were installed on a one-for-one change out, others installed fewer HID fixtures than the lower wattage fixtures which had been in previously. This was accounted for in the average change in connected load variable applied to each fixture.

There was only one SIC designation without HID audits performed. The HID per fixture impact for this group was ‘borrowed’ from a similar SIC code designation (deciduous tree fruit SIC code used the same per fixture impact as the tree nuts SIC code). Other than this one group, each HID group used the information gathered during the on-site audits to determine the program level impacts.

Other Measures

The compact fluorescent lamps (CFL) technology was generally applied as expected. Lower wattage CFLs took the place of higher wattage incandescent lamps. The audits covered 2,638 of the 2,743 lamps paid under the program and all groups used the information gathered during the audits to determine the program level impacts.

The T-8 fixtures had the fewest actual units audited (1,133 of the 2,185 paid units). The technology was spread out across many SIC description types. Because of these issues, the ex ante energy and demand impacts were used when the site was not audited.

There were three technologies within the ‘Other’ grouping – exit signs, delamping, and lighting controls. The delamping site was not visited and the ex ante energy and demand impacts were applied to this measure. The exit signs and lighting controls were audited. The exit signs were given the ex ante energy and demand impacts since no previous wattage could be determined. The lighting controls were not being used. The lights that should have been controlled were remaining on. This measure had zero impacts applied.

Productivity Changes

The on-site audit collected information from the growers to determine if there were any productivity changes due to an increase in wattage. Twelve audits indicated that there was an increase in productivity due to the increased wattage. Exhibit E.29 shows the product and stated

² Agenda Supplement for December 12, 1997 Meeting of CADMAC Modeling and Base Efficiency Subcommittees.

increase in production gathered during the audit. The last two columns indicate if the stated increase in productivity was taken into account within the analysis. For the two sites where it was, the impact was set to zero. Sites that stated they would not have increased their lighting hours with the old lights were not given any productivity increase since the old system would not have been used to achieve the same output as the new system.

**Exhibit E.29
Productivity Changes**

Audit	Product	Replacement wattage compared to previous wattage	Why increased wattage?	Production Increased?	How Much	Increased hours/day use	Productivity Taken Into Account?	Accounting for Productivity Reason
101	Grows Roses	Higher	Because of rebate program	Yes	10%	0	No	Assume that plants now have more buds per plant, which could not have gotten with old lights
111	Farm Workshop	Higher	Because of rebate program	Yes	60%	0	No	No quantifiable output
113	Growing seed potatoes	Higher	Because of rebate program	Yes	5%	0	No	Stated that lights don't speed up production, but have healthier plants. Old lights not used for growing.
114	Storage and packing lines	Same	Because of rebate program	Yes	7.5%	0		Can't do this since don't know old wattage
118	Packing Line	Higher	Before the rebate program	Yes	5%	0	No	Stated that lights provide better light and can select better quality fruit for packing
122	Growing plants	New	Both before and because of the program	Yes	20%	0	Yes	New lights, meets "did not cause change" criteria, conversation with owner states considered mercury vapor and incandescent, but HID's provided the best wavelength for the plants
124	Packing Shed	Higher	Before the rebate program	Yes	5%	3	No	No quantifiable output, stated would not have increased lighting hours with old lights
130	Barn for feeding cows	Higher	Before the rebate program	Yes	24%	0	Yes	New barn, meets "did not cause change" criteria, conversation with owner said would have put these in anyway, did not look at other lights
135	Offices and growing	New	Before the rebate program				Yes	New lights in new building, meets "did not cause change" criteria, no other types of fixtures considered
137	Growing plants	Higher	Because of rebate program	Yes	10%	0	No	Stated that would not have changed lighting hours with old lights
138	Growing plants	Higher	Because of rebate program	Yes	15%	0	No	Stated that would not have changed lighting hours with old lights
152	Growing plants	Higher	Because of rebate program	Yes	15%	0	No	Stated that would not have changed lighting hours with old lights

The population impacts are shown below in Exhibit E.30.

**Exhibit E.30
Lighting End Use – Program Impacts**

	kWh	kW
Ex Ante Impact	3,640,704	609
Ex Post Impact	(38,928)	(32)
Gross Realization Rate	(0.01)	(0.05)

The details of the analysis are shown at the end of this appendix in Exhibit E.35 – Indoor Lighting Analysis.

Energy Management Services

The AEMS analysis covered only those customers with a pump test. The site surveys were not analyzed within this evaluation. Past experience with evaluation of the Agricultural sector indicated that, on the phone, the grower had great difficulty zeroing in about which actual pump the surveyor was questioning them. Therefore, the plan did not narrow the questions to a specific pump, but kept to a specific business. This entailed some data cleaning on the PG&E pump test database since business names are not exactly the same. All 9,689 Agricultural sector pump test records were cleaned based on the business name and the business address. Often multiple corporations with similar names had the same address. Once cleaned, there were 1,446 businesses within the 1995/96 pump test database with pump tests in 1996. Since the telephone

survey spoke with the one person responsible for all pumps across the corporation, any businesses with the same address was cleaned to refer to one business. The AEMS estimate of gross savings was based on the 350 participant telephone surveys, information from the PG&E pump test database, and the pump repair OPE ratio. The engineering algorithm used to determine savings is shown in Exhibit E.31.

Exhibit E.31
AEMS Engineering Algorithm

$$\text{kWh Impact} = \text{Participant Business Population} * \text{Percent of Pumps Repaired per Business} * \\ \text{Average kWh Use} * \text{OPE Ratio}$$

The detailed values are shown at the end of this appendix Exhibit E.36 – AEMS Analysis. There were no kW savings applied based on the analysis of pump repair within the AEEI analysis. Exhibit E.32 shows the impacts for the AEMS program.

Exhibit E.32
AEMS Program Impacts

	kWh	kW
Ex Ante Estimate	21,432,296	6,032
Ex Post-Estimate	7,172,261	0
Gross Realization Rate	0.33	0

This completes the write up of the engineering technical appendix. The total program impacts are shown in the report. Following are the detailed pages from the LPSN, micro, indoor lighting and AEMS engineering analyses.

Appendix F - Final On-site Instrument

The final on-site instruments are available only in the hardcopy version of this report.

Appendix G - Costing Period Allocation Table

*Gross Demand and Energy Savings by Costing Period
For the AEEI Program – Pumping End Use*

PG&E Cost Period	Pumping End Use			
	Program kW Savings Coincident with System Max in Period	kW H-Factor	kWh Savings	kWh H-Factor
Summer On-Peak: May 1 to Oct 31 12:00 - 6:00 PM Weekdays	803.9	1.00	636,482	0.13
Summer Partial-Peak: May 1 to Oct 31 8:30 AM - 12:00 PM 6:00 PM - 9:30 PM Weekdays	820.0	1.02	783,363	0.16
Summer Off-Peak: May 1 to Oct 31 Other	956.6	1.19	2,154,248	0.44
Winter Partial-Peak: Nov 1 to April 31 8:30 AM - 9:30 PM Weekdays	321.6	0.40	538,562	0.11
Winter Off-Peak: Nov 1 to April 31 Other	184.9	0.23	734,403	0.15

**Gross Demand and Energy Savings by Costing Period
For the AEEI Program – Indoor Lighting End Use**

PG&E Cost Period	Indoor Lighting End Use			
	Program kW Savings Coincident with System Max in Period	kW H-Factor	kWh Savings	kWh H-Factor
Summer On-Peak: May 1 to Oct 31 12:00 - 6:00 PM Weekdays	-31.6	1.00	-5,839	0.15
Summer Partial-Peak: May 1 to Oct 31 8:30 AM - 12:00 PM 6:00 PM - 9:30 PM Weekdays	-29.4	0.93	-6,229	0.16
Summer Off-Peak: May 1 to Oct 31 Other	-27.5	0.87	-14,403	0.37
Winter Partial-Peak: Nov 1 to April 31 8:30 AM - 9:30 PM Weekdays	-12.7	0.40	-6,229	0.16
Winter Off-Peak: Nov 1 to April 31 Other	-14.9	0.47	-6,618	0.17

**Gross Demand and Energy Savings by Costing Period
For the AEMS Program**

PG&E Cost Period	AEMS Program			
	Program kW Savings Coincident with System Max in Period	kW H-Factor	kWh Savings	kWh H-Factor
Summer On-Peak: May 1 to Oct 31 12:00 - 6:00 PM Weekdays	0.0	1.00	932,394	0.13
Summer Partial-Peak: May 1 to Oct 31 8:30 AM - 12:00 PM 6:00 PM - 9:30 PM Weekdays	0.0	1.17	1,147,562	0.16
Summer Off-Peak: May 1 to Oct 31 Other	0.0	1.09	3,012,350	0.42
Winter Partial-Peak: Nov 1 to April 31 8:30 AM - 9:30 PM Weekdays	0.0	0.81	860,671	0.12
Winter Off-Peak: Nov 1 to April 31 Other	0.0	0.79	1,219,284	0.17

Appendix H - Pump Test Data Summaries

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
1	Participant	202	11-Sep-97	1	1	R03115	28.8	1	30	Turbine, Well	11.95	0	6.375
2	Participant	203	17-Sep-97	1	1	0128R5	4.8	40	250	Turbine, Well	392	0	10.25
3	Participant	205	07-Aug-97	1	1	R54388	28.8	1	20	Turbine, Well	11.55	2	6.375
4	Participant	206	07-Aug-97	1	1	R36890	4.8	40	40	Turbine, Well		0	8.375
5	Participant	207	11-Sep-97	3	3	05R043	43.2	1	60	Turbine, Well	83	0	10.125
6	Participant	208	22-Aug-97	1	1	4419R4	21.6	1	40	Centrifugal, Booster		0	10
7	Participant	209	21-Aug-97	1	1	R29607	57.6	1	40	Turbine, Well	36	0	6
8	Participant	212	22-Aug-97	1	1	2732R5	21.6	1	50	Submersible		0	4
9	Participant	213	21-Aug-97	3	3	86R332	3.6	40	125	Submersible	278	0	8
10	Participant	216	11-Sep-97	3	3	R08400	57.6	1	30	Turbine, Well		0	8.25
11	Participant	221	18-Sep-97	1	1	0507R2	21.6	1	30	Turbine, Well	81	0	7.625
12	Participant	222	18-Sep-97	1	1	R70858	57.6	1	30	Turbine, Well	77	0	8.125
13	Participant	229	07-Aug-97	1	1	41437T	4.8	40	100	Turbine, Well		0	10.375
14	Participant	230	07-Aug-97	1	1	227R38	4.8	40	125	Turbine, Well		0	10.375
15	Participant	231	02-Sep-97	4	1	R04178	4.8	40	150	Turbine, Well	198	0	12.25
16	Participant	232	10-Sep-97	3	1	6672R2	1.8	1200	200	Axial/Propeller		0	35.375

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
17	Participant	233	10-Sep-97	3	1	6672R2	1.8	1200	300	Axial/Propeller		0	29.375
18	Participant	235	08-Aug-97	3	3	R37245	4.8	40	75	Turbine, Well	145.8	0.5	8
19	Participant	236	08-Aug-97	3	3	5390R3	21.6	1	15	Axial/Propeller	118	3.5	4
20	Participant	237	07-Aug-97	1	1	R70159	57.6	1	75	Turbine, Well	83	0	10.125
21	Participant	238	19-Aug-97	4	1	7868R5	1.2	1200	300	Turbine, Booster	5.9	0	12.25
22	Participant	240	07-Aug-97	1	1	5187R4	21.6	1	25	Axial/Propeller		0	15.5
23	Participant	241	02-Sep-97	1	1	R72218	4.8	40	150	Turbine, Well		0	10.25
24	Participant	242.1	19-Aug-97	3	1	502R59	4.8	40	75	Turbine, Booster		0	12.25
25	Participant	242.2	19-Aug-97	3	3	502R59	4.8	40	60	Turbine, Booster		0	12.25
26	Participant	243	19-Aug-97	3	1	219R47	4.8	120	150	Turbine, Booster	4.4	0	0
27	Participant	244	19-Aug-97	3	1	1721R6	1.2	120	75	Turbine, Booster	7.9	0	0
28	Participant	245.1	18-Aug-97	4	1	5438R5	4.8	40	15	Turbine, Booster		3	6.125
29	Participant	245.2	18-Aug-97	3	1	5438R5	4.8	40	10	Turbine, Booster		0	6.125
30	Participant	247	18-Aug-97	4	1	R05228	57.6	1	20	Turbine, Booster		2	6.125

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
31	Participant	248.1	19-Aug-97	3	1	R54897	57.6	1	20	Centrifugal, Booster		0	6.125
32	Participant	248.2	18-Aug-97	1	1	R54897	57.6	1	50	Centrifugal, Booster		1	8.125
33	Participant	250	05-Aug-97	2	1	2T1777	4.8	40	100	Turbine, Well		6	9.5
34	Participant	252	19-Sep-97	1	1	2632R8	4.8	120	125	Axial/Propeller	15.9	0	30
35	Participant	255	19-Sep-97	1	1	2632R8	1.2	400	200	Axial/Propeller	15.9	0	41
36	Participant	257.1	19-Aug-97	4	1	60r157	3.6	40	50	Turbine, Booster		1	10.125
37	Participant	257.2	19-Aug-97	4	1	60R157	3.6	40	30	Turbine, Booster		0	10.25
38	Participant	257.3	19-Aug-97	4	1	60R157	3.6	40	50	Turbine, Booster		0	10.25
39	Participant	258.1	19-Aug-97	4	1	84R417	3.6	40	50	Turbine, Booster		0	12.25
40	Participant	258.2	19-Aug-97	4	1	84R417	3.6	40	30	Turbine, Booster		0	12.25
41	Participant	258.3	19-Aug-97	4	1	84R417	3.6	40	50	Turbine, Booster		0	12.25
42	Participant	259.1	20-Aug-97	4	1	1016R6	3.6	40	50	Turbine, Booster		0	10.25
43	Participant	259.2	20-Aug-97	4	1	1016R6	3.6	40	60	Turbine, Booster		0	10.25
44	Participant	260.1	20-Aug-97	4	1	91342T	57.6	1	50	Turbine, Booster		0	12.25
45	Participant	260.2	20-Aug-97	5	1	91342T	57.6	1	30	Turbine, Booster		0	12.25

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
46	Participant	262	11-Aug-97	3	3	4381R0	21.6	1	30	Turbine, Well		0	10.25
47	Participant	263	02-Sep-97	3	1	052R28	4.8	80	250	Turbine, Well	267	0	10.25
48	Participant	265	19-Sep-97	1	1	9622T9	4.8	120	350	Axial/Propeller		0	47
49	Participant	268	02-Sep-97	1	1	R29234	4.8	40	125	Turbine, Well	235	0	10.25
50	Participant	270	30-Sep-97	1	1	6672R0	57.6	10	2000	Axial/Propeller		0	0
51	Participant	271	30-Sep-97	1	1	2633R2	1.2	2400	600	Axial/Propeller		0	0
52	Participant	273	08-Aug-97	1	1	42577T	4.8	40	30	Axial/Propeller		2	17.5
53	Participant	275	08-Aug-97	3	3	R36571	28.8	1	25	Turbine, Well	141	1	6.125
54	Participant	276	22-Aug-97	3	3	99R269	57.6	1	50	Centrifugal, Booster		1	4
55	Participant	280	12-Aug-97	1	1	60R689	57.6	1	100	Turbine, Well	214	0	10.25
56	Participant	282	04-Sep-97	1	1	14R619	57.6	1	60	Turbine, Well	115	0	10.375
57	Participant	283	10-Sep-97	3	1	R36934	4.8	40	30	Turbine, Well	0.95	0	6.125
58	Participant	287	10-Sep-97	3	2	3923R2	21.6	1	50	Centrifugal, Booster		0	6.25
59	Participant	288	24-Sep-97	3	1	42580T	4.8	40	150	Turbine, Well		0	10.25
60	Participant	289	04-Sep-97	3	3	R49316	57.6	1	25	Submersible	88	0.5	4

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
61	Participant	290	14-Jul-97	3	1	R94447	4.8	40	125	Turbine, Well		1	10.25
62	Participant	291	29-Jul-97	3	1	4222R3	4.8	40	75	Turbine, Well	142	1	10
63	Participant	292	18-Sep-97	4	1	98R837	4.8	40	100	Turbine, Well		0	10.25
64	Participant	293	03-Sep-97	4	1	42595T	4.8	80	150	Turbine, Well	271	0	8.125
65	Participant	297	20-Aug-97	1	1	092R54	4.8	120	200	Turbine, Well	378	0	10.25
66	Participant	301	07-Aug-97	1	1	R79186	57.6	1	25	Turbine, Booster	4.9	0	11.5
67	Nonparticipant	305	30-Sep-97	1	1	172819	14.4	1	10	Submersible	26	1	3
68	Nonparticipant	319	12-Aug-97	1	1	90637T	57.6	1	75	Turbine, Booster		0	10.25
69	Nonparticipant	320	29-Aug-97	3	1	R67694	28.8	1	15	Turbine, Well	137.5	0	6.125
70	Nonparticipant	328	29-Aug-97	4	1	R44643	28.8	1	25	Turbine, Well		0	8.625
71	Nonparticipant	329	12-Aug-97	3	1	6874R1	57.6	1	75	Turbine, Well	74	0	10.25

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
72	Nonparticipant	335	20-Aug-97	4	1	R06206	57.6	1	60	Turbine, Well	108.5	0	6.125
73	Nonparticipant	338	21-Aug-97	3	3	81R922	3.6	40	125	Turbine, Well	59	2	10.25
74	Nonparticipant	341	10-Sep-97	4	4	R36159	28.8	1	15	Submersible	276	0.5	4
75	Nonparticipant	347	21-Aug-97	1	1	45R610	57.6	1	40	Turbine, Well	204	0	6.125
76	Nonparticipant	349	21-Aug-97	3	3	R04477	4.8	40	60	Turbine, Well	88	1.5	10
77	Nonparticipant	350	22-Aug-97	2	2	15R955	28.8	1	15	Submersible	195	0	2.75
78	Nonparticipant	357	18-Sep-97	1	1	R93213	28.8	1	15	Turbine, Well	54	0	6.0625
79	Nonparticipant	362.1	19-Sep-97	1	1	21846T	4.8	120	50	Axial/Propeller		0	0
80	Nonparticipant	362.2	19-Sep-97	1	1	21846T	4.8	120	150	Axial/Propeller		0	0
81	Nonparticipant	362.3	19-Sep-97	1	1	21846T	4.8	120	100	Axial/Propeller		0	0
82	Nonparticipant	362.4	19-Sep-97	1	1	21846T	4.8	120	100	Axial/Propeller		0	0
83	Nonparticipant	366	04-Sep-97	1	1	345R54	43.2	1	40	Turbine, Well	139	0	7.75
84	Nonparticipant	375	04-Sep-97	1	1	85794T	28.8	1	7.5	Submersible		0	2.5
85	Nonparticipant	377	05-Sep-97	1	1	20R500	57.6	1	50	Turbine, Well		0	17
86	Nonparticipant	381	05-Sep-97	1	1	57641T	57.6	1	20	Turbine, Well		0	18
87	Nonparticipant	383	04-Sep-97	1	1	R72530	57.6	1	75	Turbine, Well	129	4	7.75
88	Nonparticipant	389	10-Sep-97	4	1	R44969	4.8	40	50	Turbine, Well	156.5	4	6.125
89	Nonparticipant	394	11-Sep-97	1	1	098R70	3.6	40	200	Turbine, Well	95.21	0	10.375
90	Nonparticipant	395	22-Aug-97	2	1	R39785	57.6	1	40	Turbine, Well	88.3	0	10
91	Nonparticipant	396	20-Aug-97	1	1	8080T1	57.6	1	40	Turbine, Well	137	0	8.125

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
92	Nonparticipant	397	20-Aug-97	1	1	54R887	57.6	1	75	Turbine, Well	176	0	8.125
93	Nonparticipant	399	05-Sep-97	2	1	855R53	43.2	1	40	Turbine, Well	33	0.5	5.75
94	Nonparticipant	400	05-Sep-97	1	1	5153R7	57.6	1	50	Turbine, Well		4	7.75
95	Nonparticipant	401	04-Sep-97	1	1	R50068	28.8	1	7.5	Submersible	100	0	3
96	Nonparticipant	402	09-Sep-97	1	1	R38902	28.8	1	20	Turbine, Well	63	0	6
97	Nonparticipant	403	09-Sep-97	3	1	R98321	57.6	1	30	Turbine, Well	37.5	0	8.125
98	Nonparticipant	404	25-Sep-97	4	1	217R96	43.2	1	30	Turbine, Well	67	0	8.625
99	Nonparticipant	405	09-Sep-97	1	1	R70052	57.6	1	30	Turbine, Well	29.5	0	8.5625
100	Nonparticipant	406	08-Oct-97	1	1	322R48	43.2	1	125	Turbine, Well	131	0	10.625
101	Nonparticipant	408	03-Sep-97	1	1	R11171	57.6	1	30	Submersible	140	0	4
102	Nonparticipant	409	08-Oct-97	1	1	5382R1	21.6	1	15	Turbine, Well	0	0	8.125
103	Nonparticipant	410	10-Sep-97	1	1	602R86	43.2	1	75	Turbine, Well	109.6	0	10.25
104	Nonparticipant	411	09-Sep-97	1	1	R28100	28.8	1	10	Submersible	24	0	4
105	Nonparticipant	412	08-Oct-97	4	3	65361T	28.8	1	7.5	Submersible	62	0	5.625
106	Nonparticipant	414	25-Sep-97	4	1	R09668	28.8	1	10	Submersible	23	0	4
107	Nonparticipant	415	25-Sep-97	1	1	1704R5	21.6	1	75	Turbine, Well	72	0	10.25
108	Nonparticipant	416	25-Sep-97	1	1	24T518	57.6	1	40	Turbine, Well	80	0	8.125

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
109	Nonparticipant	417	19-Sep-97	1	1	2852R0	28.8	1	7.5	Turbine, Well		0	2.5
110	Nonparticipant	418	17-Sep-97	1	1	21716T	4.8	40	15	Axial/Propeller		0	12.125
111	Nonparticipant	420	23-Sep-97	3	3	R12077	4.8	40	75	Turbine, Well	13	0	10.25
112	Nonparticipant	421	23-Sep-97	1	1	4221R3	4.8	40	75	Turbine, Well		0	10.25
113	Nonparticipant	422	24-Sep-97	3	1	6434R9	21.6	1	50	Turbine, Well		5	10.25
114	Nonparticipant	423	24-Sep-97	3	1	3516R9	21.6	1	50	Turbine, Well		1	10.25
115	Nonparticipant	424	24-Sep-97	3	1	3526R6	21.6	1	50	Turbine, Well		2	10.25
116	Nonparticipant	425	23-Sep-97	4	1	4262R3	57.6	1	50	Turbine, Well	90.8	0	6.125
117	Nonparticipant	426	23-Sep-97	1	1	R72571	57.6	1	75	Turbine, Well	90.8	0	10.25
118	Nonparticipant	427	23-Sep-97	1	1	91412T	4.8	40	150	Turbine, Well	344	0	10.25
119	Nonparticipant	429	24-Sep-97	3	1	R28925	4.8	80	250	Turbine, Well	493	0	10.25
120	Nonparticipant	430	24-Sep-97	4	1	R06136	57.6	1	50	Submersible	526	0	4
121	Nonparticipant	431	17-Sep-97	1	1	21716T	4.8	40	15	Axial/Propeller		0	12.125
122	Nonparticipant	432	17-Sep-97	1	1	52321T	4.8	120	15	Axial/Propeller		0	12
123	Nonparticipant	433	17-Sep-97	1	1	52321T	4.8	120	15	Axial/Propeller		0	12

Appendix H
Pump Test Data Summary

Pump Tests

Record Number	Participant Type	On-site Audit ID	Date of Test	Number of Flow Points in Test	Normal Flow Point	Meter Number	Kh	Meter Multiplier	Nameplate HP	Type of Pump	Standing Water Level	Correction To Gauge	PipeID
124	Nonparticipant	434	17-Sep-97	3	1	R28928	4.8	120	100	Turbine, Booster		0	12
125	Nonparticipant	435	23-Sep-97	3	1	52338T	4.8	40	150	Turbine, Well	344	0	10.25
126	Nonparticipant	436	23-Sep-97	1	1	90602T	4.8	40	150	Turbine, Well	344	0	10.25
127	Nonparticipant	437	01-Oct-97	1	1	5137R4	4.8	80	250	Turbine, Well	284	0	10
128	Nonparticipant	438	30-Sep-97	3	1	R74565	4.8	40	200	Turbine, Well	266	0	10.25
129	Nonparticipant	439	30-Sep-97	1	1	R36895	4.8	80	300	Turbine, Well	319	0	10.25
130	Nonparticipant	440	30-Sep-97	1	1	2633R2	1.2	2400	200	Axial/Propeller		0	0
131	Nonparticipant	441	08-Oct-97	1	1	R06329	57.6	1	75	Turbine, Well	131.5	0	8
132	Nonparticipant	442	08-Oct-97	4	1	R46201	28.8	1	20	Turbine, Well	40	0	8.125
133	Nonparticipant	443	18-Sep-97	1	1	616R52	28.8	1	20	Turbine, Well	55	0	6
134	Nonparticipant	444	18-Sep-97	1	1	R46352	28.8	1	20	Turbine, Well		0	8

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Participant	202	0	3.4	3.5	0	Poor	0.61	DRILL 2; 60' setting; PWL estimated; centerline readings estimated
Participant	203	82.516	0	0	0	Fair	0.69	no valve for multipoint test
Participant	205	0	4.5	4.7	0	Fair	0.59	drill 2, pumps sand
Participant	206	0	4.4	4.4	0	Poor	0.61	pump running, no standing level = no calc of yield
Participant	207	0	6.05	6.1	0	Good	0.65	drill 2; normal run wide open
Participant	208	0	5.7	5.75	0	Good	0.61	nameplate estimated; no Pumping Water Level possible - no access
Participant	209	0	4.2	4.2	0	Poor	0.61	tried first run with gate valve closed -- too much turbulence; simulated centerline readings; ?falling water
Participant	212	0	9.4	9.3	0	Good	0.58	submersible; drill 2; requested shortest possible stop time
Participant	213	0	4.2	4.35	0	Fair	0.64	recovery for static = 30 minutes; run 3 wide open to reservoir; 60 HP booster on meter
Participant	216	0	2.7	2.9	0	Poor	0.61	obstruction in well 8-10' -- could not sound well; big pump in little well
Participant	221	0	6.85	6.8	0	Good	0.61	drilled 3
Participant	222	0	6.42	6.45	0	Good	0.61	vibrates
Participant	229	0	5.5	5.4	0	Good	0.69	no gate valve, open discharge to ditch
Participant	230	0	6.4	6.3	0	Good	0.69	no gate valve (operable), open ditch; was running on arrival (OK to stop if emergency)
Participant	231	117.86	0	0	0	Fair	0.69	
Participant	232	982.84	0	0	0	Poor	0.59	Test hole close to check valve May have affected flow measurements. Manometer/tube not balanced at start. Total of 6 pumps. Used 36" calibration chart; very poor test

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Participant	233	677.7	0	0	0	Poor	0.59	Other loads --6 pumps total at site. Very short test section--used cw cox tube to measure flow
Participant	235	0	4	4.2	0	Poor	0.69	needed hammer to turn valve (pin); lots of turbulence; runs to orchard
Participant	236	0	4.9	4.8	0	Good	0.49	drilled 2; check valves upstream; requested shortest possible run
Participant	237	0	5.8	5.7	0	Good	0.69	no gate valve
Participant	238	0	1	1	-1	CustMeter	0.71	staff IDed as pump repaired in 1996
Participant	240	0	4.5	4.5	0	Good	0.50	drill 2
Participant	241	82.516	0	0	0	Poor	0.69	difficulty getting PWL tight; H2O readings not accurate; very, very poor test section -- TESTER RECOMMENDS -- DO NOT USE RESULTS; nearby well (ID 231) had yeild of 52 GPM/ft of DD
Participant	242.1	117.86	0	0	0	Fair	0.71	
Participant	242.2	117.86	0	0	0	Fair	0.67	
Participant	243	0	1	1	-1	CustMeter	0.71	customer did not want to drill for manometer
Participant	244	0	1	1	-1	CustMeter	0.71	customer did not want to drill pipe for manometer; customer IDed pump as repaired in 1996
Participant	245.1	29.465	0	0	0	Fair	0.61	
Participant	245.2	29.465	0	0	0	Fair	0.60	corrected Run 2 power meter time to 92.5 from 72.5 seconds
Participant	247	29.465	0	0	0	Poor	0.61	flow measurement may be impaired due to poor test section

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Participant	248.1	29.465	0	0	0	Fair	0.59	
Participant	248.2	82.516	0	0	0	Fair	0.63	
Participant	250	0	3.4	3	0	Poor	0.69	boot in well therefore no water levels possible, air in water; all open for run 1, no gate valve; results odd re: increase in flow with increase in pressure -- data suspect.
Participant	252	0	0	0	-1	Fair	0.59	assumed kH
Participant	255	0	0	0	-1	Poor	0.59	assume kH & mult.; pipe not full; canal too low to create back pressure
Participant	257.1	82.516	0	0	0	Fair	0.65	CUSTOMER WATER METER "BOUNCING" & NOT CONSIDERED RELIABLE
Participant	257.2	82.516	0	0	0	Fair	0.63	
Participant	257.3	82.516	0	0	0	Fair	0.65	
Participant	258.1	117.86	0	0	0	Fair	0.65	
Participant	258.2	117.86	0	0	0	Fair	0.63	
Participant	258.3	117.86	0	0	0	Fair	0.65	
Participant	259.1	82.516	0	0	0	Fair	0.65	
Participant	259.2	82.516	0	0	0	Fair	0.67	
Participant	260.1	117.86	0	0	0	Fair	0.65	Gate valve may affect flow readings at higher pressure
Participant	260.2	117.86	0	0	0	Fair	0.63	Gate valve may affect flow readings at higher pressure

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Participant	262	0	2	2	0	Good	0.61	no standing level = no calc of yield
Participant	263	82.516	0	0	0	Poor	0.69	NOTE: transposition of meter number digits?; fair test section; pump idle at start; measured SWL with DC line; obstruction in well preventing PWL sounding.
Participant	265	0	0	0	-1	CustMeter	0.59	assumed kH & multiplier; used overhung tube
Participant	268	82.516	0	0	0	Fair	0.69	no valve for multipoint test
Participant	270	0	0	0	-1	Poor (OPE High)	0.59	kH & mult. est.; used volt amp method; State water meter used for GPM; assisted by Ben Lazama (Dist.
Participant	271	0	0	0	-1	CustMeter	0.55	this combination test (pumps 1 & 5 running together) was run to use flowmeter near design conditions
Participant	273	0	7.65	7.7	0	Poor	0.51	drill 2; put pumps 1 & 2 back on "auto" position
Participant	275	0	2.3	2.4	0	Good	0.60	drill 3
Participant	276	0	4.5	4	0	Fair	0.63	pressurized suction, other boosters on meter; drill 3
Participant	280	82.516	0	0	0	Fair	0.69	
Participant	282	0	4.8	4.9	0	Fair	0.65	waited for me to start siphons. Only 1 place to drill.
Participant	283	0	4.7	4.4	0	Fair	0.61	no place for gauge; changed sprinklers
Participant	287	0	8.3	8.25	0	Good	0.63	different meter (3502R4 original); 98 PSI normal; drill 3; normal run wide open; booster
Participant	288	0	5	5	0	Fair	0.69	rebuilt in last month; 50 HP booster; pumps to reservoir
Participant	289	0	3	3	0	Good	0.55	no Kh given, assume 57.6; assume submersible based on est. motor eff; assume Run #3 is normal point; drill 3

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Participant	290	0	7.8	7.75	0	Good	0.69	FLOW STRAIGHT FOR UPPER RESERVOIR; TURN RIGHT FOR LOWER
Participant	291	0	4.6	4.7	0	Poor	0.69	some sand in collins; normal flow reservoir, throttle with gate valve; can't sound well deeper than 195'; run 3 able to sound "2 psi @ 162' extension"; estimated PWL for Runs 1
Participant	292	82.516	0	0	0	Poor	0.69	obstruction at 330 ft prevented PWL measurements
Participant	293	51.849	0	0	0	Fair	0.69	cal @ 500 ft per pump dealer; filter system no longer in use
Participant	297	82.516	0	0	0	Fair	0.69	no valve for pressure
Participant	301	0	9.4	9.45	0	Good	0.62	drainage ditch, pump into slough; drill 2
Nonparticipant	305	0	4.2	4.3	0	Fair	0.53	meter number format is odd; assumed nameplate HP; tanks were overflowing; second pump possible; filter on discharge
Nonparticipant	319	82.516	0	0	0	Fair	0.71	original listed pump could not be tested - this pump offered by customer as closest
Nonparticipant	320	29.465	0	0	0	Poor	0.59	customer selected different than selected pump for test; deep well turbine pump used to flood irrigate; also uses booster for trickle irrigation; irrigator said pump has been bad for 5 years; most irrigation done with ditch water
Nonparticipant	328	58.426	0	0	0	Poor	0.60	no entrance to sound well; est. PWL at 50-70 ft.
Nonparticipant	329	82.516	0	0	0	Fair	0.69	adjusted water levels by 28 ft for 35 ft of oil

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Nonparticipant	335	29.465	0	0	-1	CustMeter	0.65	flow affected by gate valve - use customer water meter
Nonparticipant	338	0	6.55	6.45	0	Good	0.69	drip - above ground; 8" loop system; run 3 wide open
Nonparticipant	341	0	1.4	1.2	0	Fair	0.54	HP estimated; drill 2; pump filled tank before test
Nonparticipant	347	0	3.9	4	0	Good	0.61	
Nonparticipant	349	0	3.6	3.6	0	Fair	0.65	pulled vacuum with booster on; run 3 wide open
Nonparticipant	350	0	5.3	5.4	0	Fair	0.54	drill 2, small pipe, flowmeter
Nonparticipant	357	0	6.7	6.6	0	Good	0.59	Barn Pump; ID hard to read; was ID 357.1
Nonparticipant	362.1	0	0	0	-1	Fair	0.53	water meter only exposed component; survey for total head - no place to attach pressure gauges
Nonparticipant	362.2	0	0	0	-1	Fair	0.59	survey for Total Lift
Nonparticipant	362.3	0	0	0	-1	Fair	0.59	survey for Total Lift
Nonparticipant	362.4	0	0	0	-1	Fair	0.59	survey for Total Lift
Nonparticipant	366	0	6.9	7	0	Poor	0.61	different meter number (original 264T61); test section poor; drill 2
Nonparticipant	375	0	9.5	9.4	0	Fair	0.51	ASSUME SUBMERSIBLE; drill 2; not at design, can't valve; take out 2 1/2 plug, gate valve studs close
Nonparticipant	377	0	9.1	9.2	0	Good	0.63	drill 2;
Nonparticipant	381	0	23.75	24	0	Fair	0.59	drill 2; difficult conditions
Nonparticipant	383	0	5.4	5.4	0	Good	0.69	no configuration noted
Nonparticipant	389	29.465	0	0	0	Fair	0.63	
Nonparticipant	394	0	4	4.2	0	Poor	0.69	hole in base has plastic tubing; obstruction at 130' - PWL estimated
Nonparticipant	395	0	5.3	5.45	0	Poor	0.61	combined well & booster on meter; Run 1 with booster, run 2 deep well only; new tenant on ranch
Nonparticipant	396	51.849	0	0	0	Fair	0.61	

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Nonparticipant	397	51.849	0	0	0	Fair	0.69	no valve
Nonparticipant	399	0	9.35	9.4	0	Good	0.61	different meter (58R968 ORIGINAL)
Nonparticipant	400	0	3.8	3.8	0	Good	0.63	DIFFERENT METER NUMBERS (ORIGINAL R92511)
Nonparticipant	401	0	3.8	3.7	0	Good	0.51	ASSUME SUBMERSIBLE; no entrance to well -- assume SWL &
Nonparticipant	402	28.274	0	0	0	Fair	0.59	pump set @ 130'; lots of vibration; no valve or check
Nonparticipant	403	51.844	0	0	0	Fair	0.61	gate valve may have affected measurement on runs 2 & 3
Nonparticipant	404	58.426	0	0	0	Poor	0.61	Old Meter# 68R298; oil on water in well -- may have affected water level readings
Nonparticipant	405	57.583	0	0	0	Poor	0.61	poor test section; gate valve stuck -- no multipoint test
Nonparticipant	406	88.664	0	0	0	Fair	0.69	no valve for multipoint test
Nonparticipant	408	12.566	0	0	0	Poor	0.56	Kh & mult. est.; nameplate HP est. by customer; very poor test section; volt-amp method used for input HP est.
Nonparticipant	409	51.849	0	0	0	Poor	0.59	poor test section; unable to sound well; valve in wrong location for multipoint test
Nonparticipant	410	82.516	0	0	0	Omit Test	0.69	could not build pressure for multipoint test -- no valve; poor test section
Nonparticipant	411	12.566	0	0	0	Fair	0.53	no place for PSI ahead of valve; drip to citrus
Nonparticipant	412	31.29	0	0	0	Fair	0.51	normal PSI = 35; trickle system to vineyard
Nonparticipant	414	12.566	0	0	0	Fair	0.53	wagon wheel well; operates at three different pressures: 9psi for flodd; 34 psi for trickle; 61 psi for uphill trickle
Nonparticipant	415	82.516	0	0	0	Fair	0.69	Not previously tested
Nonparticipant	416	51.849	0	0	0	Fair	0.61	no valve for multipoint test

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Nonparticipant	417	0	0.7	0.6	0	Poor	0.56	drill 2; no entrance to well
Nonparticipant	418	115.147	0	0	0	Poor	0.49	poor test section; station 14 pump 5; was labelled 418A
Nonparticipant	420	0	9.65	9.6	0	Poor	0.69	New meter -- old was R04770; test form did not have kWh or pump type -- assumed 4.8x40 and Turbine
Nonparticipant	421	0	8.8	8.9	0	Poor	0.69	75 HP booster pump on same meter; booster was on for this test
Nonparticipant	422	0	7.4	7.35	0	Poor	0.63	boot in well - could not sound -- no SWL or PWL or OPE
Nonparticipant	423	0	5.5	5.6	0	Poor	0.63	boot in well - could not sound -- no SWL or PWL or OPE
Nonparticipant	424	0	6.8	7.05	0	Poor	0.63	boot in well - could not sound -- no SWL or PWL or OPE
Nonparticipant	425	29.465	0	0	0	Fair	0.63	adjusted water levels 11.2 ft for 14 ft of oil
Nonparticipant	426	82.516	0	0	0	Poor	0.69	no entrance to well -- cannot sound; nearby well had SWL = 90.8 ft; PWL estimated
Nonparticipant	427	82.516	0	0	0	Poor	0.69	airline without known length -- used nearby well (ID 436) for SWL estimate & air pressure differential for PWL estimate; no entrance for
Nonparticipant	429	82.516	0	0	0	Fair	0.69	fair test section
Nonparticipant	430	12.566	0	0	0	Fair	0.58	
Nonparticipant	431	115.47	0	0	0	Fair	0.49	poor test section; variable speed drive & motor; ; station 14 pump 4; was labelled 418B & 431
Nonparticipant	432	113.098	0	0	0	Fair	0.49	variable speed drive; was labelled 420A & 432
Nonparticipant	433	113.098	0	0	0	Fair	0.49	variable speed drive for motor; was labelled 420B and 433

Appendix H
Pump Test Data Summary

Participant Type	On-site Audit ID	Cox Area	Centerline Vel1	Centerline Vel2	Check to Use Flowmeter for GPM	Data Quality	OPE Target	Comments
Nonparticipant	434	113.098	0	0	0	Poor	0.71	Station 12 pump 5; very poor test section; est. HPI for run 3; was labelled 421
Nonparticipant	435	82.516	0	0	0	Poor	0.69	used customer airline but length unknown; used SWL from ID 436; no entrance to sound well
Nonparticipant	436	82.516	0	0	0	Fair	0.69	no valve for multipoint test
Nonparticipant	437	78.54	0	0	0	Poor	0.69	Very poor test section to measure
Nonparticipant	438	82.516	0	0	0	Fair	0.69	good test section; water to reservoir
Nonparticipant	439	82.516	0	0	0	Fair	0.69	no valve for multipoint test
Nonparticipant	440	0	0	0	-1	CustMeter	0.59	flow determined by difference in flow for single vs multiple pumps
Nonparticipant	441	50.266	0	0	0	Fair	0.69	no valve for multipoint test
Nonparticipant	442	51.849	0	0	0	Fair	0.59	pump was idle
Nonparticipant	443	0	3.4	3.4	0	Poor	0.59	Lindsay; was ID 357.2
Nonparticipant	444	0	3	2.9	0	Poor	0.59	North 70; casing plugged - could not sound; was numbered 357.3

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Participant	202	1	11-Sep-97	281.0	296.6	0	31.16	1.24	0.56	0.50	Poor	7.8
Participant	203	1	17-Sep-97	450.5	2010.9	0	205.90	1.02	0.90	0.83	Good	50.3
Participant	205	1	07-Aug-97	117.4	491.2	0	20.21	1.19	0.61	0.54	Fair	42.9
Participant	206	1	07-Aug-97	149.2	786.4	0	35.56	1.07	0.69	0.62	Good	0.0
Participant	207	1	11-Sep-97	144.7	1268.4	0	59.71	1.21	0.64	0.58	Fair	105.7
Participant	207	2	11-Sep-97	135.3	1312.3	0	60.80	1.23	0.61	0.55	Fair	100.9
Participant	207	3	11-Sep-97	125.9	1365.7	0	61.04	1.23	0.59	0.53	Poor	97.6
Participant	208	1	22-Aug-97	13.9	1221.9	0	36.20	1.09	0.10	0.00	Poor	0.0
Participant	209	1	21-Aug-97	117.8	360.4	0	28.35	0.85	0.31	0.28	Poor	4.7
Participant	212	1	22-Aug-97	281.3	365.7	0	37.97	0.87	0.60	0.51	Fair	0.0
Participant	213	1	21-Aug-97	409.5	927.3	0	112.31	1.06	0.72	0.64	Fair	58.0
Participant	213	2	21-Aug-97	376.9	1018.5	0	113.54	1.07	0.72	0.64	Fair	56.6
Participant	213	3	21-Aug-97	366.0	1051.5	0	113.29	1.07	0.73	0.64	Good	50.1
Participant	216	1	11-Sep-97	63.5	458.7	0	28.35	1.13	0.22	0.00	Poor	0.0
Participant	216	2	11-Sep-97	49.7	483.5	0	28.67	1.14	0.18	0.00	Poor	0.0
Participant	216	3	11-Sep-97	41.6	508.3	0	28.79	1.15	0.15	0.00	Poor	0.0
Participant	221	1	18-Sep-97	106.2	991.5	0	30.50	1.22	0.73	0.65	Good	62.0
Participant	222	1	18-Sep-97	94.5	967.3	0	28.33	1.13	0.68	0.61	Fair	69.1
Participant	229	1	07-Aug-97	158.8	1338.4	0	71.14	0.87	0.62	0.56	Poor	0.0
Participant	230	1	07-Aug-97	172.2	1546.1	0	89.28	0.88	0.61	0.56	Poor	0.0
Participant	231	1	02-Sep-97	261.1	2054.3	0	143.71	1.18	0.77	0.70	Good	51.4
Participant	231	2	02-Sep-97	273.0	2002.4	0	144.31	1.19	0.78	0.71	Good	52.7
Participant	231	3	02-Sep-97	285.3	1942.3	0	143.95	1.18	0.79	0.73	Good	53.2
Participant	231	4	02-Sep-97	301.8	1799.7	0	144.13	1.18	0.77	0.71	Good	52.2
Participant	232	1	10-Sep-97	27.0	24777.4	0	156.25	0.96	0.88	0.81	Good	0.0
Participant	232	2	10-Sep-97	32.8	23352.3	0	171.32	1.06	0.91	0.84	Good	0.0
Participant	232	3	10-Sep-97	37.4	21249.0	0	185.04	1.14	0.88	0.81	Good	0.0
Participant	233	1	10-Sep-97	44.1	18907.8	0	215.00	0.88	0.79	0.73	Good	0.0
Participant	233	2	10-Sep-97	47.5	17484.7	0	223.00	0.92	0.76	0.70	Good	0.0
Participant	233	3	10-Sep-97	52.2	16603.7	0	224.94	0.92	0.79	0.73	Good	0.0
Participant	235	1	08-Aug-97	306.3	593.6	0	67.23	1.09	0.56	0.51	Poor	114.2
Participant	235	2	08-Aug-97	296.7	776.0	0	67.89	1.11	0.70	0.64	Fair	107.8
Participant	235	3	08-Aug-97	266.4	843.9	0	68.77	1.12	0.68	0.62	Fair	91.7
Participant	236	1	08-Aug-97	235.7	171.6	0	14.57	1.13	0.60	0.52	Good	171.6

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Participant	236	2	08-Aug-97	215.4	192.7	0	14.68	1.14	0.61	0.53	Good	128.5
Participant	236	3	08-Aug-97	175.3	225.4	0	15.12	1.18	0.57	0.49	Good	75.1
Participant	237	1	07-Aug-97	131.2	1306.0	0	51.35	0.84	0.69	0.63	Fair	27.8
Participant	238	1	19-Aug-97	188.5	4500.0	4500	230.30	0.95	0.75	0.69	Fair	45000.0
Participant	238	2	19-Aug-97	203.5	4275.0	4275	236.17	0.97	0.75	0.69	Fair	42750.0
Participant	238	3	19-Aug-97	216.2	4095.0	4095	231.22	0.95	0.78	0.72	Good	40950.0
Participant	238	4	19-Aug-97	225.5	3870.0	3870	226.18	0.93	0.79	0.73	Good	38700.0
Participant	240	1	07-Aug-97	21.6	2663.5	0	20.87	0.99	0.58	0.52	Good	0.0
Participant	241	1	02-Sep-97	226.0	1595.9	0	144.91	1.19	0.51	0.47	Poor	0.0
Participant	242.1	1	19-Aug-97	127.6	1383.7	1010	57.40	0.93	0.64	0.58	Poor	0.0
Participant	242.1	2	19-Aug-97	166.9	1196.3	864	56.86	0.93	0.73	0.66	Fair	0.0
Participant	242.1	3	19-Aug-97	203.9	1001.8	717	54.70	0.89	0.77	0.70	Fair	0.0
Participant	242.2	1	19-Aug-97	201.5	921.7	684	55.54	1.12	0.70	0.63	Fair	0.0
Participant	242.2	2	19-Aug-97	190.0	1089.0	782	56.14	1.14	0.77	0.69	Good	0.0
Participant	242.2	3	19-Aug-97	169.2	1221.0	912	57.25	1.16	0.75	0.68	Good	0.0
Participant	243	1	19-Aug-97	143.1	2648.0	2648	119.55	0.98	0.65	0.60	Poor	26480.0
Participant	243	2	19-Aug-97	177.8	2468.0	2468	123.43	1.01	0.73	0.67	Fair	24680.0
Participant	243	3	19-Aug-97	203.2	2020.0	2020	117.02	0.96	0.72	0.66	Fair	20200.0
Participant	244	1	19-Aug-97	130.4	1436.0	1436	58.74	0.96	0.66	0.60	Poor	14360.0
Participant	244	2	19-Aug-97	174.3	1077.0	1077	71.37	1.16	0.54	0.50	Poor	10770.0
Participant	244	3	19-Aug-97	204.4	808.0	808	54.31	0.88	0.63	0.57	Poor	8080.0
Participant	245.1	1	18-Aug-97	102.6	455.5	515	15.80	1.23	0.64	0.56	Fair	0.0
Participant	245.1	2	18-Aug-97	114.1	420.2	465	15.66	1.22	0.66	0.58	Fair	0.0
Participant	245.1	3	18-Aug-97	124.5	376.3	425	15.34	1.19	0.66	0.58	Fair	0.0
Participant	245.1	4	18-Aug-97	134.9	317.6	350	14.23	1.11	0.65	0.57	Fair	0.0
Participant	245.2	1	18-Aug-97	142.6	162.1	104	8.37	0.96	0.61	0.52	Fair	0.0
Participant	245.2	2	18-Aug-97	151.8	143.5	91	7.48	0.86	0.64	0.55	Fair	0.0
Participant	245.2	3	18-Aug-97	174.9	41.3	65	7.36	0.85	0.21	0.18	Poor	0.0
Participant	247	1	18-Aug-97	87.4	612.6	665	16.04	0.95	0.71	0.63	Good	0.0
Participant	247	2	18-Aug-97	98.9	562.8	610	16.33	0.96	0.73	0.64	Good	0.0
Participant	247	3	18-Aug-97	112.8	476.4	520	16.13	0.95	0.71	0.63	Good	0.0
Participant	247	4	18-Aug-97	124.3	368.3	440	15.60	0.92	0.63	0.55	Fair	0.0
Participant	248.1	1	19-Aug-97	73.9	628.5	960	19.01	1.12	0.52	0.46	Poor	0.0
Participant	248.1	2	19-Aug-97	83.2	627.0	900	19.08	1.13	0.59	0.51	Fair	0.0

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Participant	248.1	3	19-Aug-97	97.0	576.3	850	19.27	1.14	0.62	0.55	Fair	0.0
Participant	248.2	1	18-Aug-97	86.5	2893.8	0	62.08	1.50	0.84	0.76	Good	0.0
Participant	250	1	05-Aug-97	110.0	639.8	0	61.22	0.75	0.24	0.00	Poor	0.0
Participant	250	2	05-Aug-97	135.4	711.6	0	62.33	0.76	0.32	0.00	Poor	0.0
Participant	252	1	19-Sep-97	17.2	16900.0	16900	106.85	1.05	0.56	0.51	Fair	169000.0
Participant	255	1	19-Sep-97	16.0	37049.0	37049	175.99	1.09	0.69	0.63	Good	370490.0
Participant	257.1	1	19-Aug-97	101.0	1861.6	0	45.70	1.10	0.86	0.78	Good	0.0
Participant	257.1	2	19-Aug-97	114.9	1731.2	0	47.13	1.14	0.88	0.80	Good	0.0
Participant	257.1	3	19-Aug-97	121.8	1645.4	1490	47.89	1.16	0.87	0.79	Good	0.0
Participant	257.1	4	19-Aug-97	128.7	1544.7	1400	48.37	1.17	0.86	0.77	Good	0.0
Participant	257.2	1	19-Aug-97	76.9	1007.5	950	22.76	0.91	0.72	0.64	Good	0.0
Participant	257.2	2	19-Aug-97	86.2	967.1	860	23.19	0.93	0.76	0.68	Good	0.0
Participant	257.2	3	19-Aug-97	95.4	949.8	810	23.82	0.95	0.80	0.72	Good	0.0
Participant	257.2	4	19-Aug-97	118.5	842.5	750	24.45	0.98	0.86	0.77	Good	0.0
Participant	257.3	1	19-Aug-97	107.0	1670.1	1550	47.53	1.15	0.79	0.71	Good	0.0
Participant	257.3	2	19-Aug-97	117.3	1544.7	1460	48.33	1.17	0.78	0.71	Good	0.0
Participant	257.3	3	19-Aug-97	130.1	1430.8	1330	48.73	1.18	0.80	0.72	Good	0.0
Participant	257.3	4	19-Aug-97	139.3	1282.3	1160	47.94	1.16	0.78	0.70	Good	0.0
Participant	258.1	1	19-Aug-97	88.8	1919.9	1710	44.23	1.07	0.81	0.73	Good	0.0
Participant	258.1	2	19-Aug-97	105.0	1765.5	1510	45.82	1.11	0.85	0.76	Good	0.0
Participant	258.1	3	19-Aug-97	121.1	1586.4	1220	47.70	1.15	0.84	0.76	Good	0.0
Participant	258.1	4	19-Aug-97	141.9	1282.3	1140	47.08	1.14	0.81	0.73	Good	0.0
Participant	258.2	1	19-Aug-97	79.5	1074.9	1000	23.58	0.94	0.76	0.68	Good	0.0
Participant	258.2	2	19-Aug-97	91.1	1017.1	900	23.90	0.95	0.82	0.73	Good	0.0
Participant	258.2	3	19-Aug-97	111.9	938.2	850	24.92	0.99	0.89	0.79	Good	0.0
Participant	258.2	4	19-Aug-97	128.1	854.5	750	25.29	1.01	0.91	0.82	Good	0.0
Participant	258.3	1	19-Aug-97	88.8	1973.0	1800	43.88	1.06	0.83	0.75	Good	0.0
Participant	258.3	2	19-Aug-97	102.6	1773.8	1650	45.12	1.09	0.84	0.76	Good	0.0
Participant	258.3	3	19-Aug-97	116.5	1643.0	1480	46.29	1.12	0.86	0.78	Good	0.0
Participant	258.3	4	19-Aug-97	135.0	1383.7	1300	46.97	1.13	0.83	0.75	Good	0.0
Participant	259.1	1	20-Aug-97	125.7	1469.6	1425	45.20	1.09	0.85	0.77	Good	0.0
Participant	259.1	2	20-Aug-97	132.7	1401.9	1350	45.16	1.09	0.86	0.78	Good	0.0
Participant	259.1	3	20-Aug-97	139.6	1275.7	1205	44.44	1.07	0.84	0.76	Good	0.0
Participant	259.1	4	20-Aug-97	150.0	1076.8	1025	42.47	1.03	0.80	0.72	Good	0.0

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Participant	259.2	1	20-Aug-97	118.8	1595.9	1450	47.49	0.96	0.83	0.75	Good	0.0
Participant	259.2	2	20-Aug-97	128.1	1518.3	1375	48.51	0.98	0.83	0.76	Good	0.0
Participant	259.2	3	20-Aug-97	137.3	1413.5	1250	48.98	0.99	0.82	0.75	Good	0.0
Participant	259.2	4	20-Aug-97	146.5	1282.3	1150	48.42	0.98	0.81	0.73	Good	0.0
Participant	260.1	1	20-Aug-97	89.8	1961.2	0	45.24	1.09	0.81	0.73	Good	0.0
Participant	260.1	2	20-Aug-97	101.3	1848.0	0	45.92	1.11	0.85	0.77	Good	0.0
Participant	260.1	3	20-Aug-97	110.6	1705.4	0	46.91	1.13	0.84	0.76	Good	0.0
Participant	260.1	4	20-Aug-97	129.1	1586.4	0	48.04	1.16	0.89	0.80	Good	0.0
Participant	260.2	1	20-Aug-97	73.6	921.7	0	20.19	0.81	0.71	0.63	Good	0.0
Participant	260.2	2	20-Aug-97	99.0	776.7	725	21.16	0.84	0.77	0.68	Good	0.0
Participant	260.2	3	20-Aug-97	112.9	714.2	650	21.40	0.85	0.79	0.71	Good	0.0
Participant	260.2	4	20-Aug-97	129.1	668.3	600	21.68	0.87	0.84	0.75	Good	0.0
Participant	260.2	5	20-Aug-97	142.9	619.9	550	21.56	0.86	0.87	0.77	Good	0.0
Participant	262	1	11-Aug-97	125.3	476.2	481.7729	22.36	0.89	0.56	0.50	Poor	0.0
Participant	262	2	11-Aug-97	121.1	604.9	553.4204	25.86	1.03	0.60	0.53	Fair	0.0
Participant	262	3	11-Aug-97	117.9	675.7	738.1209	27.60	1.10	0.61	0.54	Fair	0.0
Participant	263	1	02-Sep-97	4.6	2109.1	0	230.83	1.14	0.01	0.00	Poor	-7.9
Participant	263	2	02-Sep-97	23.1	2019.2	0	230.83	1.14	0.04	0.00	Poor	-7.6
Participant	263	3	02-Sep-97	53.1	1999.4	0	231.07	1.14	0.09	0.00	Poor	-7.5
Participant	265	1	19-Sep-97	15.4	40635.0	40635	286.49	1.01	0.45	0.41	Poor	0.0
Participant	268	1	02-Sep-97	284.0	1378.8	0	110.23	1.09	0.73	0.67	Fair	30.6
Participant	270	1	30-Sep-97	235.4	28588.0	28588	1419.91	0.88	0.97	0.89	Good	0.0
Participant	271	1	30-Sep-97	118.1	15797.0	15797	474.28	0.96	0.82	0.74	Good	0.0
Participant	273	1	08-Aug-97	21.6	4839.5	0	30.32	1.21	0.73	0.65	Good	0.0
Participant	275	1	08-Aug-97	207.1	221.6	0	15.26	0.73	0.64	0.57	Fair	44.3
Participant	275	2	08-Aug-97	189.0	415.2	0	20.53	0.98	0.81	0.72	Good	41.5
Participant	275	3	08-Aug-97	160.9	514.9	0	21.73	1.03	0.81	0.72	Good	42.9
Participant	276	1	22-Aug-97	363.7	169.3	0	26.81	0.65	0.48	0.43	Poor	0.0
Participant	276	2	22-Aug-97	341.7	317.4	0	35.66	0.86	0.64	0.57	Fair	0.0
Participant	276	3	22-Aug-97	323.2	360.6	0	42.53	1.03	0.57	0.52	Poor	0.0
Participant	280	1	12-Aug-97	240.0	1469.6	0	95.33	1.17	0.76	0.70	Good	58.8
Participant	282	1	04-Sep-97	127.2	1529.6	0	47.90	0.97	0.85	0.76	Good	139.1
Participant	283	1	10-Sep-97	158.1	461.1	0	22.85	0.91	0.67	0.60	Fair	9222.6
Participant	283	2	10-Sep-97	135.0	508.1	0	23.51	0.94	0.62	0.55	Fair	10162.8

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Participant	283	3	10-Sep-97	144.2	495.8	0	23.32	0.93	0.65	0.58	Fair	9916.5
Participant	287	1	10-Sep-97	181.3	732.9	0	40.00	0.97	0.69	0.63	Fair	0.0
Participant	287	2	10-Sep-97	209.0	618.0	0	36.30	0.88	0.74	0.67	Good	0.0
Participant	287	3	10-Sep-97	233.4	415.4	0	30.50	0.74	0.66	0.60	Fair	0.0
Participant	288	1	24-Sep-97	319.2	1467.2	0	126.58	1.04	0.76	0.70	Good	0.0
Participant	288	2	24-Sep-97	344.5	1415.7	0	125.78	1.03	0.79	0.73	Good	0.0
Participant	288	3	24-Sep-97	374.5	1277.4	0	125.53	1.03	0.78	0.72	Good	0.0
Participant	289	1	04-Sep-97	255.5	113.2	0	16.20	0.72	0.41	0.34	Poor	37.7
Participant	289	2	04-Sep-97	232.1	146.3	0	16.40	0.72	0.47	0.39	Poor	29.3
Participant	289	3	04-Sep-97	194.8	190.4	0	16.50	0.73	0.51	0.42	Poor	27.2
Participant	290	1	14-Jul-97	187.2	2085.0	0	115.11	1.13	0.69	0.64	Fair	0.0
Participant	290	2	14-Jul-97	205.1	1808.3	0	116.51	1.15	0.65	0.60	Fair	0.0
Participant	290	3	14-Jul-97	216.0	1731.0	0	115.11	1.13	0.67	0.61	Fair	0.0
Participant	291	1	29-Jul-97	231.2	1304.6	0	66.34	1.08	0.94	0.86	Good	28.0
Participant	291	2	29-Jul-97	262.2	872.8	0	56.76	0.92	0.83	0.76	Good	30.0
Participant	291	3	29-Jul-97	273.9	502.2	0	50.36	0.82	0.56	0.51	Poor	32.6
Participant	292	1	18-Sep-97	1.0	1023.2	0	106.11	1.30	0.00	0.00	Poor	0.0
Participant	292	2	18-Sep-97	16.2	991.8	0	106.17	1.30	0.03	0.00	Poor	0.0
Participant	292	3	18-Sep-97	27.7	967.1	0	105.62	1.29	0.05	0.00	Poor	0.0
Participant	292	4	18-Sep-97	39.3	915.1	0	103.63	1.27	0.07	0.00	Poor	0.0
Participant	293	1	03-Sep-97	544.0	912.5	0	144.35	1.19	0.70	0.65	Fair	5.4
Participant	293	2	03-Sep-97	550.8	886.6	0	143.64	1.18	0.70	0.64	Fair	5.4
Participant	293	3	03-Sep-97	560.1	871.1	0	143.83	1.18	0.70	0.64	Fair	5.4
Participant	293	4	03-Sep-97	571.6	843.6	0	140.33	1.15	0.70	0.65	Fair	5.3
Participant	297	1	20-Aug-97	407.0	1595.9	0	183.61	1.13	0.72	0.67	Fair	63.8
Participant	301	1	07-Aug-97	23.5	2701.5	0	21.69	1.03	0.62	0.55	Fair	27014.6
Nonparticipant	305	1	30-Sep-97	243.7	101.7	0	10.72	1.14	0.55	0.44	Fair	4.1
Nonparticipant	319	1	12-Aug-97	254.2	967.1	0	73.08	1.19	0.70	0.63	Fair	0.0
Nonparticipant	320	1	29-Aug-97	140.5	136.7	0	10.36	0.81	0.40	0.35	Poor	54.7
Nonparticipant	320	2	29-Aug-97	143.0	54.8	0	8.87	0.69	0.19	0.17	Poor	36.5
Nonparticipant	320	3	29-Aug-97	141.3	143.5	0	10.40	0.81	0.42	0.37	Poor	41.0
Nonparticipant	328	1	29-Aug-97	20.8	868.2	0	22.87	1.09	0.17	0.00	Poor	0.0
Nonparticipant	328	2	29-Aug-97	30.0	742.6	0	21.79	1.04	0.22	0.00	Poor	0.0
Nonparticipant	328	3	29-Aug-97	39.3	629.8	0	20.35	0.97	0.26	0.00	Poor	0.0

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Nonparticipant	328	4	29-Aug-97	48.5	417.2	0	16.42	0.78	0.26	0.00	Poor	0.0
Nonparticipant	329	1	12-Aug-97	95.6	2458.2	0	75.28	1.23	0.65	0.59	Poor	144.6
Nonparticipant	329	2	12-Aug-97	107.0	2341.0	0	75.47	1.23	0.69	0.63	Fair	161.4
Nonparticipant	329	3	12-Aug-97	117.0	2066.2	0	75.58	1.23	0.66	0.60	Fair	158.9
Nonparticipant	335	1	20-Aug-97	243.7	346.0	346	24.77	0.50	0.71	0.64	Fair	33.0
Nonparticipant	335	2	20-Aug-97	252.5	315.0	315	24.51	0.50	0.68	0.61	Fair	31.5
Nonparticipant	335	3	20-Aug-97	265.8	305.0	305	24.24	0.49	0.70	0.63	Fair	32.1
Nonparticipant	335	4	20-Aug-97	278.7	295.0	295	23.86	0.48	0.72	0.65	Good	34.7
Nonparticipant	338	1	21-Aug-97	228.1	1779.3	0	105.89	1.04	0.79	0.72	Good	177.9
Nonparticipant	338	2	21-Aug-97	206.0	1904.8	0	104.30	1.03	0.77	0.71	Good	173.2
Nonparticipant	338	3	21-Aug-97	165.1	2178.3	0	100.15	0.99	0.74	0.68	Fair	155.6
Nonparticipant	341	1	10-Sep-97	414.9	45.1	0	13.64	0.98	0.32	0.26	Poor	5.0
Nonparticipant	341	2	10-Sep-97	380.6	85.6	0	14.24	1.02	0.54	0.43	Poor	6.1
Nonparticipant	341	3	10-Sep-97	347.3	107.2	0	17.95	1.29	0.49	0.39	Poor	5.4
Nonparticipant	341	4	10-Sep-97	302.7	124.2	0	16.74	1.20	0.53	0.42	Poor	5.0
Nonparticipant	347	1	21-Aug-97	229.8	353.7	0	26.81	0.81	0.64	0.57	Fair	70.7
Nonparticipant	349	1	21-Aug-97	183.9	1053.5	0	51.25	1.04	0.79	0.71	Good	526.7
Nonparticipant	349	2	21-Aug-97	140.7	1249.5	0	50.61	1.02	0.72	0.65	Good	249.9
Nonparticipant	349	3	21-Aug-97	130.2	1396.5	0	49.73	1.01	0.76	0.69	Good	232.8
Nonparticipant	350	1	22-Aug-97	277.9	101.3	100	13.44	0.97	0.49	0.39	Poor	11.3
Nonparticipant	350	2	22-Aug-97	257.4	103.5	107	13.84	1.00	0.45	0.36	Poor	14.8
Nonparticipant	357	1	18-Sep-97	66.2	557.7	0	27.54	2.14	0.29	0.25	Poor	50.7
Nonparticipant	362.1	1	19-Sep-97	15.0	5320.0	5320	27.66	0.67	0.60	0.54	Good	0.0
Nonparticipant	362.2	1	19-Sep-97	16.0	24969.0	24969	96.22	0.79	0.85	0.78	Good	0.0
Nonparticipant	362.3	1	19-Sep-97	16.0	14167.0	14167	63.66	0.78	0.73	0.67	Good	0.0
Nonparticipant	362.4	1	19-Sep-97	16.0	13034.0	13034	62.31	0.76	0.69	0.63	Good	0.0
Nonparticipant	366	1	04-Sep-97	291.8	421.7	0	36.45	1.09	0.71	0.64	Good	84.3
Nonparticipant	375	1	04-Sep-97	124.2	72.9	0	8.44	1.19	0.26	0.20	Poor	0.0
Nonparticipant	377	1	05-Sep-97	28.3	5956.5	0	45.02	1.09	0.78	0.71	Good	0.0
Nonparticipant	381	1	05-Sep-97	7.5	5973.3	0	23.06	1.36	0.42	0.37	Poor	0.0
Nonparticipant	383	1	04-Sep-97	211.9	759.8	0	56.24	0.92	0.59	0.54	Poor	152.0
Nonparticipant	389	1	10-Sep-97	234.8	368.3	380	35.14	0.85	0.51	0.46	Poor	22.3
Nonparticipant	389	2	10-Sep-97	247.6	317.6	340	33.44	0.81	0.49	0.44	Poor	20.5
Nonparticipant	389	3	10-Sep-97	258.2	295.8	300	30.53	0.74	0.52	0.47	Poor	20.4

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Nonparticipant	389	4	10-Sep-97	265.7	226.0	220	21.69	0.52	0.58	0.52	Poor	21.5
Nonparticipant	394	1	11-Sep-97	205.1	2037.2	0	114.40	0.71	0.75	0.69	Fair	40.9
Nonparticipant	395	1	22-Aug-97	97.6	1301.6	0	40.58	1.22	0.66	0.59	Fair	276.9
Nonparticipant	395	2	22-Aug-97	136.2	845.2	0	38.61	1.16	0.63	0.56	Fair	497.2
Nonparticipant	396	1	20-Aug-97	147.0	746.1	0	40.94	1.23	0.56	0.50	Poor	93.3
Nonparticipant	397	1	20-Aug-97	202.5	1194.1	0	68.27	1.11	0.73	0.67	Fair	53.1
Nonparticipant	399	1	05-Sep-97	179.6	716.9	0	35.43	1.06	0.76	0.68	Good	37.7
Nonparticipant	399	2	05-Sep-97	141.7	868.1	0	37.49	1.13	0.69	0.62	Good	34.7
Nonparticipant	400	1	05-Sep-97	165.6	539.8	0	34.64	0.84	0.54	0.49	Poor	0.0
Nonparticipant	401	1	04-Sep-97	156.2	75.8	0	8.52	1.20	0.33	0.26	Poor	7.6
Nonparticipant	402	1	09-Sep-97	81.0	464.8	0	18.69	1.10	0.43	0.38	Poor	35.8
Nonparticipant	403	1	09-Sep-97	126.7	464.0	0	23.27	0.93	0.53	0.48	Poor	6.4
Nonparticipant	403	2	09-Sep-97	126.2	317.3	0	22.45	0.90	0.38	0.34	Poor	5.5
Nonparticipant	403	3	09-Sep-97	131.8	298.1	0	21.71	0.87	0.38	0.34	Poor	6.9
Nonparticipant	404	1	25-Sep-97	95.9	1076.8	0	29.03	1.16	0.75	0.67	Good	71.8
Nonparticipant	404	2	25-Sep-97	104.3	997.3	0	29.37	1.17	0.75	0.67	Good	76.7
Nonparticipant	404	3	25-Sep-97	112.5	924.3	0	31.13	1.24	0.70	0.63	Good	77.0
Nonparticipant	404	4	25-Sep-97	117.8	854.2	0	31.61	1.26	0.67	0.60	Fair	74.3
Nonparticipant	405	1	09-Sep-97	69.6	1439.6	0	25.06	1.00	0.84	0.75	Good	40.6
Nonparticipant	406	1	08-Oct-97	180.5	2190.9	0	108.75	1.07	0.75	0.69	Fair	54.1
Nonparticipant	408	1	03-Sep-97	175.7	326.7	0	28.63	1.06	0.46	0.38	Poor	40.8
Nonparticipant	409	1	08-Oct-97	3.0	729.5	0	15.92	1.24	0.03	0.00	Poor	0.0
Nonparticipant	410	1	10-Sep-97	124.2	1962.2	0	69.82	1.14	0.72	0.66	Fair	327.0
Nonparticipant	411	1	09-Sep-97	102.9	75.4	0	7.35	0.78	0.25	0.20	Poor	15.1
Nonparticipant	412	1	08-Oct-97	71.0	334.8	0	9.95	1.40	0.57	0.45	Fair	41.9
Nonparticipant	412	2	08-Oct-97	112.9	266.0	0	10.30	1.45	0.70	0.55	Good	38.0
Nonparticipant	412	3	08-Oct-97	148.9	237.8	0	10.25	1.44	0.83	0.65	Good	39.6
Nonparticipant	412	4	08-Oct-97	157.6	215.9	0	10.12	1.42	0.81	0.63	Good	39.3
Nonparticipant	414	1	25-Sep-97	55.8	221.5	0	9.02	0.96	0.32	0.26	Poor	18.5
Nonparticipant	414	2	25-Sep-97	82.2	205.0	0	9.44	1.01	0.42	0.34	Poor	15.8
Nonparticipant	414	3	25-Sep-97	114.5	182.1	0	9.76	1.04	0.51	0.40	Poor	14.0
Nonparticipant	414	4	25-Sep-97	174.9	108.2	0	9.45	1.01	0.47	0.38	Poor	9.8
Nonparticipant	415	1	25-Sep-97	147.0	2074.5	0	85.15	1.39	0.74	0.67	Fair	31.4
Nonparticipant	416	1	25-Sep-97	113.0	939.0	0	37.30	1.12	0.60	0.54	Fair	34.8

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Nonparticipant	417	1	19-Sep-97	80.9	10.4	0	2.17	0.33	0.09	0.00	Poor	0.0
Nonparticipant	418	1	17-Sep-97	19.2	1911.4	0	10.08	0.78	0.79	0.68	Good	0.0
Nonparticipant	420	1	23-Sep-97	82.0	2416.4	2388.278	59.10	0.96	0.69	0.63	Fair	62.0
Nonparticipant	420	2	23-Sep-97	93.2	2233.0	2235.429	59.80	0.97	0.72	0.66	Fair	65.7
Nonparticipant	420	3	23-Sep-97	111.3	2030.3	1973.764	60.11	0.98	0.78	0.71	Good	70.0
Nonparticipant	421	1	23-Sep-97	109.3	2471.1	1997.957	123.32	2.01	0.45	0.41	Poor	0.0
Nonparticipant	422	1	24-Sep-97	37.3	2020.6	0	44.01	1.06	0.36	0.00	Poor	0.0
Nonparticipant	422	2	24-Sep-97	60.4	1512.2	0	41.12	0.99	0.46	0.00	Poor	0.0
Nonparticipant	422	3	24-Sep-97	78.9	1100.4	0	39.37	0.95	0.46	0.00	Poor	0.0
Nonparticipant	423	1	24-Sep-97	28.7	1827.6	0	39.43	0.95	0.28	0.00	Poor	0.0
Nonparticipant	423	2	24-Sep-97	47.2	1518.7	0	37.77	0.91	0.40	0.00	Poor	0.0
Nonparticipant	423	3	24-Sep-97	70.3	971.7	0	37.06	0.90	0.39	0.00	Poor	0.0
Nonparticipant	424	1	24-Sep-97	29.7	2068.9	0	38.08	0.92	0.34	0.00	Poor	0.0
Nonparticipant	424	2	24-Sep-97	48.2	1660.3	0	36.00	0.87	0.46	0.00	Poor	0.0
Nonparticipant	424	3	24-Sep-97	71.3	1113.3	0	33.97	0.82	0.49	0.00	Poor	0.0
Nonparticipant	425	1	23-Sep-97	164.5	523.3	0	34.41	0.83	0.52	0.47	Poor	19.0
Nonparticipant	425	2	23-Sep-97	174.6	517.7	0	34.66	0.84	0.55	0.49	Poor	19.9
Nonparticipant	425	3	23-Sep-97	185.6	508.0	0	35.13	0.85	0.56	0.51	Poor	19.9
Nonparticipant	425	4	23-Sep-97	198.5	498.3	0	35.39	0.85	0.58	0.53	Poor	20.3
Nonparticipant	426	1	23-Sep-97	116.0	1307.1	0	70.95	1.16	0.44	0.40	Poor	54.0
Nonparticipant	427	1	23-Sep-97	356.5	1518.3	0	153.74	1.26	0.72	0.66	Fair	138.0
Nonparticipant	429	1	24-Sep-97	756.1	933.3	0	176.39	0.87	0.82	0.75	Good	103.7
Nonparticipant	429	2	24-Sep-97	764.7	729.4	0	159.96	0.79	0.71	0.66	Fair	121.6
Nonparticipant	429	3	24-Sep-97	784.8	609.0	0	136.08	0.67	0.72	0.66	Fair	203.0
Nonparticipant	430	1	24-Sep-97	554.2	181.0	0	38.39	0.87	0.58	0.49	Fair	15.1
Nonparticipant	430	2	24-Sep-97	571.7	172.2	0	37.83	0.86	0.58	0.49	Fair	15.7
Nonparticipant	430	3	24-Sep-97	582.7	169.6	0	37.56	0.86	0.58	0.50	Fair	16.2
Nonparticipant	430	4	24-Sep-97	593.8	162.1	0	37.30	0.85	0.57	0.49	Fair	16.2
Nonparticipant	431	1	17-Sep-97	12.7	1809.4	0	9.39	0.73	0.53	0.46	Fair	0.0
Nonparticipant	432	1	17-Sep-97	26.8	817.7	0	15.07	1.17	0.31	0.27	Poor	0.0
Nonparticipant	433	1	17-Sep-97	27.3	976.0	0	15.45	1.20	0.37	0.32	Poor	0.0
Nonparticipant	434	1	17-Sep-97	54.6	4029.7	0	69.34	0.85	0.65	0.60	Poor	0.0
Nonparticipant	434	2	17-Sep-97	63.8	3649.7	0	67.10	0.82	0.72	0.65	Fair	0.0
Nonparticipant	434	3	17-Sep-97	70.8	2332.1	0	59.30	0.73	0.57	0.52	Poor	0.0

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	Run	Date of Test	Total Load (Ft)	Gallons Per Minute	Field Measured GPM	KW Input	MtrLoad	PumpEff	OPE	OPE Rating	Yield
Nonparticipant	435	1	23-Sep-97	371.7	1355.7	0	144.88	1.19	0.71	0.66	Fair	65.2
Nonparticipant	435	2	23-Sep-97	385.6	1343.4	0	145.19	1.19	0.73	0.67	Fair	72.6
Nonparticipant	435	3	23-Sep-97	394.9	1325.2	0	145.41	1.19	0.74	0.68	Fair	81.8
Nonparticipant	436	1	23-Sep-97	359.0	1518.3	0	153.74	1.26	0.73	0.67	Fair	126.5
Nonparticipant	437	1	01-Oct-97	330.9	1879.5	0	226.60	1.12	0.56	0.52	Poor	47.0
Nonparticipant	438	1	30-Sep-97	300.0	1786.5	0	164.83	1.02	0.67	0.61	Fair	55.8
Nonparticipant	438	2	30-Sep-97	316.5	1745.2	0	165.05	1.02	0.69	0.63	Fair	54.5
Nonparticipant	438	3	30-Sep-97	335.0	1684.2	0	166.07	1.02	0.70	0.64	Fair	52.6
Nonparticipant	439	1	30-Sep-97	352.5	949.8	0	217.41	0.89	0.32	0.29	Poor	63.3
Nonparticipant	440	1	30-Sep-97	115.8	5340.0	5340	154.31	0.95	0.82	0.75	Good	0.0
Nonparticipant	441	1	08-Oct-97	217.0	1004.3	0	63.80	1.04	0.71	0.64	Fair	12.5
Nonparticipant	442	1	08-Oct-97	54.5	993.4	0	18.11	1.07	0.64	0.56	Fair	94.6
Nonparticipant	442	2	08-Oct-97	59.9	909.4	0	17.14	1.01	0.68	0.60	Good	109.6
Nonparticipant	442	3	08-Oct-97	71.4	635.7	0	15.40	0.91	0.63	0.56	Fair	105.9
Nonparticipant	442	4	08-Oct-97	80.0	464.0	0	13.56	0.80	0.59	0.52	Fair	154.7
Nonparticipant	443	1	18-Sep-97	166.9	289.6	0	19.51	1.15	0.53	0.47	Poor	19.4
Nonparticipant	444	1	18-Sep-97	11.6	442.3	0	17.08	1.01	0.06	0.00	Poor	0.0

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Participant	202	1750.1	570.5	41.8	37.3	21.0	Poor
Participant	203	1705.7	556.1	276.0	254.5	228.8	Fair
Participant	205	685.4	223.5	27.1	23.8	14.6	Fair
Participant	206	753.3	245.6	47.7	42.7	29.6	Poor
Participant	207	784.2	255.7	80.0	72.4	46.3	Good
Participant	207	771.9	251.6	81.5	73.8	44.8	Good
Participant	207	744.6	242.7	81.8	74.1	43.4	Good
Participant	208	493.5	160.9	48.5	43.5	4.3	Good
Participant	209	1310.7	427.3	38.0	34.1	10.7	Poor
Participant	212	1729.5	563.8	50.9	43.3	26.0	Good
Participant	213	2017.6	657.7	150.5	132.3	95.9	Fair
Participant	213	1857.1	605.4	152.2	133.8	96.9	Fair
Participant	213	1794.9	585.1	151.9	133.5	97.2	Fair
Participant	216	1029.7	335.7	38.0	33.9	7.4	Poor
Participant	216	987.7	322.0	38.4	34.3	6.1	Poor
Participant	216	943.4	307.5	38.6	34.5	5.3	Poor
Participant	221	512.5	167.1	40.9	36.5	26.6	Good
Participant	222	487.9	159.0	38.0	33.9	23.1	Good
Participant	229	885.5	288.7	95.4	87.2	53.7	Good
Participant	230	962.0	313.6	119.7	110.0	67.2	Good
Participant	231	1165.4	379.9	192.6	177.0	135.4	Fair
Participant	231	1200.6	391.4	193.4	177.8	138.0	Fair
Participant	231	1234.6	402.5	193.0	177.3	139.9	Fair
Participant	231	1334.1	434.9	193.2	177.6	137.2	Fair
Participant	232	105.1	34.2	209.5	192.7	168.8	Poor
Participant	232	122.2	39.8	229.6	211.3	193.2	Poor
Participant	232	145.1	47.3	248.0	228.2	200.6	Poor
Participant	233	189.4	61.8	288.2	265.1	210.4	Poor
Participant	233	212.5	69.3	298.9	275.0	209.9	Poor
Participant	233	225.7	73.6	301.5	277.4	218.7	Poor
Participant	235	1886.7	615.1	90.1	82.1	45.9	Poor
Participant	235	1457.5	475.2	91.0	82.9	58.1	Poor
Participant	235	1357.5	442.6	92.2	84.0	56.8	Poor
Participant	236	1415.1	461.3	19.5	17.0	10.2	Good

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Participant	236	1269.3	413.8	19.7	17.1	10.5	Good
Participant	236	1117.3	364.2	20.3	17.6	10.0	Good
Participant	237	655.0	213.5	68.8	62.7	43.3	Good
Participant	238	852.6	277.9	308.7	284.0	214.2	CustMeter
Participant	238	920.3	300.0	316.6	291.3	219.7	CustMeter
Participant	238	940.7	306.7	309.9	285.2	223.6	CustMeter
Participant	238	973.6	317.4	303.2	278.9	220.3	CustMeter
Participant	240	130.5	42.5	28.0	24.8	14.5	Good
Participant	241	1512.7	493.2	194.3	178.5	91.1	Poor
Participant	242.1	691.0	225.3	76.9	70.1	44.6	Fair
Participant	242.1	791.8	258.1	76.2	69.4	50.4	Fair
Participant	242.1	909.7	296.6	73.3	66.8	51.6	Fair
Participant	242.2	1003.9	327.3	74.4	67.4	46.9	Fair
Participant	242.2	858.8	280.0	75.3	68.1	52.2	Fair
Participant	242.2	781.1	254.7	76.7	69.5	52.2	Fair
Participant	243	752.1	245.2	160.3	147.3	95.7	CustMeter
Participant	243	833.1	271.6	165.5	152.1	110.8	CustMeter
Participant	243	965.1	314.6	156.9	144.2	103.6	CustMeter
Participant	244	681.4	222.2	78.7	71.7	47.3	CustMeter
Participant	244	1104.0	359.9	95.7	87.2	47.4	CustMeter
Participant	244	1119.8	365.1	72.8	66.3	41.7	CustMeter
Participant	245.1	577.9	188.4	21.2	18.4	11.8	Fair
Participant	245.1	620.7	202.4	21.0	18.3	12.1	Fair
Participant	245.1	679.2	221.4	20.6	17.9	11.8	Fair
Participant	245.1	746.1	243.2	19.1	16.6	10.8	Fair
Participant	245.2	860.7	280.6	11.2	9.6	5.8	Fair
Participant	245.2	868.3	283.1	10.0	8.6	5.5	Fair
Participant	245.2	2974.1	969.6	9.9	8.5	1.8	Fair
Participant	247	436.2	142.2	21.5	18.9	13.5	Poor
Participant	247	483.5	157.6	21.9	19.3	14.1	Poor
Participant	247	564.0	183.9	21.6	19.0	13.6	Poor
Participant	247	705.6	230.0	20.9	18.4	11.6	Poor
Participant	248.1	503.9	164.3	25.5	22.4	11.7	Fair
Participant	248.1	507.0	165.3	25.6	22.5	13.2	Fair

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Participant	248.1	557.0	181.6	25.8	22.7	14.1	Fair
Participant	248.2	357.4	116.5	83.2	75.0	63.2	Fair
Participant	250	1594.0	519.7	82.1	75.0	17.8	Poor
Participant	250	1459.2	475.7	83.5	76.4	24.3	Poor
Participant	252	105.3	34.3	143.2	131.6	73.2	Fair
Participant	255	79.1	25.8	235.9	217.0	149.7	Poor
Participant	257.1	409.0	133.3	61.3	55.2	47.5	Fair
Participant	257.1	453.5	147.8	63.2	56.9	50.2	Fair
Participant	257.1	484.9	158.1	64.2	57.8	50.6	Fair
Participant	257.1	521.7	170.1	64.8	58.4	50.2	Fair
Participant	257.2	376.4	122.7	30.5	27.2	19.6	Fair
Participant	257.2	399.6	130.3	31.1	27.8	21.0	Fair
Participant	257.2	417.9	136.2	31.9	28.5	22.9	Fair
Participant	257.2	483.5	157.6	32.8	29.3	25.2	Fair
Participant	257.3	474.1	154.6	63.7	57.4	45.1	Fair
Participant	257.3	521.2	169.9	64.8	58.4	45.8	Fair
Participant	257.3	567.4	185.0	65.3	58.9	47.0	Fair
Participant	257.3	622.8	203.0	64.3	57.9	45.1	Fair
Participant	258.1	383.8	125.1	59.3	53.4	43.0	Fair
Participant	258.1	432.4	141.0	61.4	55.3	46.8	Fair
Participant	258.1	501.0	163.3	63.9	57.6	48.5	Fair
Participant	258.1	611.7	199.4	63.1	56.9	46.0	Fair
Participant	258.2	365.5	119.2	31.6	28.2	21.6	Fair
Participant	258.2	391.4	127.6	32.0	28.6	23.4	Fair
Participant	258.2	442.5	144.3	33.4	29.8	26.5	Fair
Participant	258.2	493.0	160.7	33.9	30.3	27.6	Fair
Participant	258.3	370.5	120.8	58.8	53.0	44.2	Fair
Participant	258.3	423.7	138.1	60.5	54.5	46.0	Fair
Participant	258.3	469.3	153.0	62.0	55.9	48.3	Fair
Participant	258.3	565.5	184.4	63.0	56.7	47.2	Fair
Participant	259.1	512.3	167.0	60.6	54.6	46.7	Fair
Participant	259.1	536.6	174.9	60.5	54.5	47.0	Fair
Participant	259.1	580.3	189.2	59.6	53.7	45.0	Fair
Participant	259.1	657.1	214.2	56.9	51.3	40.8	Fair

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Participant	259.2	495.7	161.6	63.7	57.6	47.9	Fair
Participant	259.2	532.2	173.5	65.0	58.8	49.1	Fair
Participant	259.2	577.3	188.2	65.7	59.4	49.0	Fair
Participant	259.2	629.0	205.1	64.9	58.7	47.4	Fair
Participant	260.1	384.3	125.3	60.6	54.6	44.5	Fair
Participant	260.1	413.9	134.9	61.6	55.5	47.3	Fair
Participant	260.1	458.3	149.4	62.9	56.7	47.6	Fair
Participant	260.1	504.5	164.5	64.4	58.0	51.7	Fair
Participant	260.2	364.9	119.0	27.1	24.2	17.1	Fair
Participant	260.2	453.8	147.9	28.4	25.3	19.4	Fair
Participant	260.2	499.2	162.8	28.7	25.6	20.4	Fair
Participant	260.2	540.4	176.2	29.1	26.0	21.8	Fair
Participant	260.2	579.3	188.9	28.9	25.8	22.4	Fair
Participant	262	782.4	255.1	30.0	26.8	15.1	Poor
Participant	262	712.1	232.2	34.7	31.0	18.5	Good
Participant	262	680.5	221.8	37.0	33.0	20.1	Good
Participant	263	1823.3	594.4	309.4	285.3	2.5	Poor
Participant	263	1904.5	620.9	309.4	285.3	11.8	Poor
Participant	263	1925.3	627.7	309.7	285.6	26.8	Poor
Participant	265	117.5	38.3	384.0	354.1	158.0	CustMeter
Participant	268	1331.8	434.2	147.8	135.8	98.9	Fair
Participant	270	827.4	269.7	1903.4	1751.1	1699.3	Poor (OPE High)
Participant	271	500.2	163.1	635.8	575.4	471.0	CustMeter
Participant	273	104.4	34.0	40.6	36.3	26.3	Poor
Participant	275	1147.2	374.0	20.5	18.2	11.6	Poor
Participant	275	823.5	268.5	27.5	24.4	19.8	Good
Participant	275	703.0	229.2	29.1	25.9	20.9	Good
Participant	276	2638.9	860.3	35.9	32.4	15.5	Fair
Participant	276	1871.7	610.2	47.8	43.1	27.4	Fair
Participant	276	1964.6	640.5	57.0	51.4	29.4	Fair
Participant	280	1080.7	352.3	127.8	116.8	89.1	Fair
Participant	282	521.7	170.1	64.2	58.1	49.1	Fair
Participant	283	825.7	269.2	30.6	27.4	18.4	Fair
Participant	283	770.9	251.3	31.5	28.1	17.3	Fair

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Participant	283	783.4	255.4	31.3	27.9	18.1	Fair
Participant	287	909.4	296.5	53.6	48.3	33.6	Good
Participant	287	978.5	319.0	48.7	43.8	32.6	Good
Participant	287	1222.9	398.7	40.9	36.8	24.5	Good
Participant	288	1437.2	468.5	169.7	155.9	118.3	Fair
Participant	288	1480.1	482.5	168.6	155.0	123.2	Fair
Participant	288	1637.2	533.7	168.3	154.6	120.8	Fair
Participant	289	2384.8	777.5	21.7	17.9	7.3	Good
Participant	289	1867.6	608.8	22.0	18.1	8.6	Good
Participant	289	1443.4	470.6	22.1	18.2	9.4	Good
Participant	290	919.8	299.8	154.3	141.8	98.5	Good
Participant	290	1073.4	349.9	156.2	143.5	93.7	Good
Participant	290	1107.8	361.1	154.3	141.8	94.4	Good
Participant	291	847.1	276.2	88.9	81.0	76.2	Poor
Participant	291	1083.4	353.2	76.1	69.3	57.8	Poor
Participant	291	1670.3	544.5	67.5	61.5	34.7	Poor
Participant	292	1727.6	563.2	142.2	130.0	0.3	Poor
Participant	292	1783.3	581.4	142.3	130.1	4.1	Poor
Participant	292	1819.4	593.1	141.6	129.4	6.8	Poor
Participant	292	1886.5	615.0	138.9	127.0	9.1	Poor
Participant	293	2635.3	859.1	193.5	177.8	125.3	Fair
Participant	293	2699.0	879.9	192.5	177.0	123.3	Fair
Participant	293	2750.7	896.8	192.8	177.2	123.2	Fair
Participant	293	2771.2	903.4	188.1	172.9	121.8	Fair
Participant	297	1916.7	624.9	246.1	226.4	164.0	Fair
Participant	301	133.7	43.6	29.1	25.8	16.0	Good
Nonparticipant	305	1755.3	572.2	14.4	11.4	6.3	Fair
Nonparticipant	319	1258.9	410.4	98.0	89.2	62.1	Fair
Nonparticipant	320	1262.0	411.4	13.9	12.1	4.9	Poor
Nonparticipant	320	2696.8	879.2	11.9	10.3	2.0	Poor
Nonparticipant	320	1207.6	393.7	13.9	12.1	5.1	Poor
Nonparticipant	328	438.8	143.0	30.7	27.2	4.6	Poor
Nonparticipant	328	488.9	159.4	29.2	25.9	5.6	Poor
Nonparticipant	328	538.2	175.5	27.3	24.2	6.2	Poor

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Nonparticipant	328	655.9	213.8	22.0	19.6	5.1	Poor
Nonparticipant	329	510.2	166.3	100.9	91.9	59.4	Fair
Nonparticipant	329	537.1	175.1	101.2	92.2	63.2	Fair
Nonparticipant	329	609.4	198.7	101.3	92.3	61.1	Fair
Nonparticipant	335	1192.5	388.7	33.2	30.0	21.3	CustMeter
Nonparticipant	335	1296.2	422.6	32.9	29.7	20.1	CustMeter
Nonparticipant	335	1324.0	431.6	32.5	29.4	20.5	CustMeter
Nonparticipant	335	1347.2	439.2	32.0	28.9	20.8	CustMeter
Nonparticipant	338	991.4	323.2	141.9	130.4	102.5	Good
Nonparticipant	338	912.2	297.4	139.8	128.5	99.1	Good
Nonparticipant	338	765.9	249.7	134.2	123.4	90.8	Good
Nonparticipant	341	5039.3	1642.8	18.3	14.7	4.7	Poor
Nonparticipant	341	2773.3	904.1	19.1	15.4	8.2	Fair
Nonparticipant	341	2790.6	909.7	24.1	19.4	9.4	Fair
Nonparticipant	341	2245.0	731.9	22.4	18.1	9.5	Fair
Nonparticipant	347	1263.0	411.8	35.9	32.2	20.5	Good
Nonparticipant	349	810.4	264.2	68.7	62.2	48.9	Fair
Nonparticipant	349	674.7	220.0	67.8	61.4	44.4	Fair
Nonparticipant	349	593.3	193.4	66.7	60.3	45.9	Fair
Nonparticipant	350	2211.2	720.9	18.0	14.5	7.1	Fair
Nonparticipant	350	2226.1	725.7	18.5	14.9	6.7	Fair
Nonparticipant	357	822.6	268.2	36.9	32.1	9.3	Good
Nonparticipant	362.1	86.6	28.2	37.1	33.4	20.2	Fair
Nonparticipant	362.2	64.2	20.9	129.0	118.5	100.9	Fair
Nonparticipant	362.3	74.9	24.4	85.3	78.0	57.2	Fair
Nonparticipant	362.4	79.6	26.0	83.5	76.3	52.7	Fair
Nonparticipant	366	1440.2	469.5	48.9	43.8	31.1	Poor
Nonparticipant	375	1928.0	628.5	11.3	8.9	2.3	Fair
Nonparticipant	377	125.9	41.0	60.3	54.4	42.6	Good
Nonparticipant	381	64.3	21.0	30.9	27.2	11.3	Fair
Nonparticipant	383	1233.3	402.1	75.4	68.7	40.7	Good
Nonparticipant	389	1589.2	518.1	47.1	42.4	21.8	Fair
Nonparticipant	389	1753.7	571.7	44.8	40.4	19.9	Fair
Nonparticipant	389	1719.3	560.5	40.9	36.9	19.3	Fair

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Nonparticipant	389	1598.6	521.2	29.1	26.2	15.2	Fair
Nonparticipant	394	935.5	305.0	153.4	141.1	105.5	Poor
Nonparticipant	395	519.4	169.3	54.4	48.7	32.1	Poor
Nonparticipant	395	761.0	248.1	51.8	46.4	29.1	Poor
Nonparticipant	396	914.0	298.0	54.9	49.2	27.7	Fair
Nonparticipant	397	952.5	310.5	91.5	83.4	61.1	Fair
Nonparticipant	399	823.3	268.4	47.5	42.6	32.5	Good
Nonparticipant	399	719.5	234.5	50.3	45.0	31.1	Good
Nonparticipant	400	1069.1	348.5	46.4	41.8	22.6	Good
Nonparticipant	401	1872.2	610.4	11.4	9.0	3.0	Good
Nonparticipant	402	669.9	218.4	25.1	22.0	9.5	Fair
Nonparticipant	403	835.4	272.3	31.2	27.9	14.8	Fair
Nonparticipant	403	1178.8	384.3	30.1	26.9	10.1	Fair
Nonparticipant	403	1213.5	395.6	29.1	26.0	9.9	Fair
Nonparticipant	404	449.1	146.4	38.9	34.8	26.1	Poor
Nonparticipant	404	490.6	159.9	39.4	35.2	26.3	Poor
Nonparticipant	404	561.1	182.9	41.7	37.3	26.3	Poor
Nonparticipant	404	616.5	201.0	42.4	37.8	25.4	Poor
Nonparticipant	405	290.0	94.5	33.6	30.0	25.3	Poor
Nonparticipant	406	826.9	269.6	145.8	134.0	99.9	Fair
Nonparticipant	408	1459.7	475.9	38.4	31.7	14.5	Poor
Nonparticipant	409	363.6	118.5	21.3	18.6	0.6	Poor
Nonparticipant	410	592.8	193.3	93.6	85.3	61.5	Omit Test
Nonparticipant	411	1623.3	529.2	9.8	7.8	2.0	Fair
Nonparticipant	412	495.1	161.4	13.3	10.5	6.0	Fair
Nonparticipant	412	645.3	210.4	13.8	10.9	7.6	Fair
Nonparticipant	412	718.1	234.1	13.7	10.8	8.9	Fair
Nonparticipant	412	781.2	254.7	13.6	10.7	8.6	Fair
Nonparticipant	414	678.0	221.0	12.1	9.6	3.1	Fair
Nonparticipant	414	767.5	250.2	12.7	10.1	4.3	Fair
Nonparticipant	414	892.6	291.0	13.1	10.4	5.3	Fair
Nonparticipant	414	1455.2	474.4	12.7	10.1	4.8	Fair
Nonparticipant	415	683.8	222.9	114.1	104.0	77.0	Fair
Nonparticipant	416	661.8	215.7	50.0	44.8	26.8	Fair

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Nonparticipant	417	3474.3	1132.6	2.9	2.5	0.2	Poor
Nonparticipant	418	87.9	28.6	13.5	11.8	9.2	Poor
Nonparticipant	420	407.4	132.8	79.2	72.2	50.1	Poor
Nonparticipant	420	446.2	145.5	80.2	73.0	52.6	Poor
Nonparticipant	420	493.2	160.8	80.6	73.4	57.1	Poor
Nonparticipant	421	831.4	271.0	165.3	150.6	68.2	Poor
Nonparticipant	422	362.8	118.3	59.0	53.2	19.1	Poor
Nonparticipant	422	452.9	147.7	55.1	49.7	23.1	Poor
Nonparticipant	422	596.0	194.3	52.8	47.5	21.9	Poor
Nonparticipant	423	359.4	117.2	52.9	47.6	13.3	Poor
Nonparticipant	423	414.4	135.1	50.6	45.6	18.1	Poor
Nonparticipant	423	635.4	207.1	49.7	44.8	17.3	Poor
Nonparticipant	424	306.6	100.0	51.0	46.0	15.5	Poor
Nonparticipant	424	361.2	117.8	48.3	43.5	20.2	Poor
Nonparticipant	424	508.3	165.7	45.5	41.0	20.0	Poor
Nonparticipant	425	1095.4	357.1	46.1	41.6	21.7	Fair
Nonparticipant	425	1115.3	363.6	46.5	41.9	22.8	Fair
Nonparticipant	425	1152.1	375.6	47.1	42.4	23.8	Fair
Nonparticipant	425	1183.4	385.8	47.4	42.7	25.0	Fair
Nonparticipant	426	904.4	294.8	95.1	86.6	38.3	Poor
Nonparticipant	427	1686.8	549.9	206.1	189.4	136.7	Poor
Nonparticipant	429	3148.7	1026.5	236.5	218.0	178.2	Fair
Nonparticipant	429	3653.1	1190.9	214.4	197.7	140.9	Fair
Nonparticipant	429	3722.6	1213.6	182.4	168.2	120.7	Fair
Nonparticipant	430	3534.5	1152.3	51.5	43.7	25.3	Fair
Nonparticipant	430	3660.9	1193.5	50.7	43.1	24.9	Fair
Nonparticipant	430	3688.3	1202.4	50.3	42.8	25.0	Fair
Nonparticipant	430	3833.5	1249.7	50.0	42.5	24.3	Fair
Nonparticipant	431	86.5	28.2	12.6	11.0	5.8	Fair
Nonparticipant	432	307.0	100.1	20.2	17.6	5.5	Fair
Nonparticipant	433	263.8	86.0	20.7	18.0	6.7	Fair
Nonparticipant	434	286.7	93.5	93.0	85.0	55.6	Poor
Nonparticipant	434	306.3	99.9	89.9	82.2	58.8	Poor
Nonparticipant	434	423.6	138.1	79.5	72.7	41.7	Poor

Appendix H
Pump Test Data Summary

Pump Runs

Participant Type	On-site Audit ID	kWhr/MG	kWhr/AF	Horsepower Input	Brake Horsepower	Water Horsepower	Quality Rating
Nonparticipant	435	1780.3	580.4	194.2	178.5	127.3	Poor
Nonparticipant	435	1800.5	587.0	194.6	178.9	130.8	Poor
Nonparticipant	435	1828.0	595.9	194.9	179.1	132.1	Poor
Nonparticipant	436	1686.8	549.9	206.1	189.4	137.6	Fair
Nonparticipant	437	2008.6	654.8	303.8	280.1	157.1	Poor
Nonparticipant	438	1537.1	501.1	221.0	203.3	135.3	Fair
Nonparticipant	438	1575.6	513.6	221.3	203.6	139.5	Fair
Nonparticipant	438	1642.8	535.5	222.6	204.8	142.5	Fair
Nonparticipant	439	3813.6	1243.2	291.4	268.1	84.5	Fair
Nonparticipant	440	481.4	156.9	206.8	190.3	156.1	CustMeter
Nonparticipant	441	1058.3	345.0	85.5	77.9	55.0	Fair
Nonparticipant	442	303.7	99.0	24.3	21.4	13.7	Fair
Nonparticipant	442	313.9	102.3	23.0	20.2	13.7	Fair
Nonparticipant	442	403.6	131.6	20.6	18.2	11.5	Fair
Nonparticipant	442	487.0	158.8	18.2	16.0	9.4	Fair
Nonparticipant	443	1122.2	365.8	26.1	23.0	12.2	Poor
Nonparticipant	444	643.5	209.8	22.9	20.2	1.3	Poor