

CONSULTANT REPORT

CALIFORNIA COMMERCIAL END-USE SURVEY

Chapter 11

Prepared For:
California Energy Commission

CALMAC Study ID: CEC0023.07

Prepared By:
Itron, Inc.



March 2006
CEC-400-2006-005

This report is dedicated to the memory of Alan Fields, who served as the project manager until his death on February 3, 2004. Alan was a valued colleague and dear friend. He will be missed by his associates at Itron, the California Energy Commission, and the energy industry.

Prepared By:

Itron, Inc.

Subcontractors:

KEMA

ADM Associates

James J. Hirsch & Associates

Contract No. 300-00-002

Prepared For:

California Energy Commission

Peg A. Pigeon-Bergmann

Contract Manager

Mohsen Abrishami

Mark Ciminelli

Project Managers

Sylvia Bender

Manager

Demand Analysis Office

Valerie Hall

Deputy Director

Energy Efficiency & Demand Analysis Division

B.B. Blevins

Executive Director

DISCLAIMER

This report was prepared as the result of work sponsored by the California Energy Commission. It does not necessarily represent the views of the Energy Commission, its employees or the State of California. The Energy Commission, the State of California, its employees, contractors and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the uses of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the California Energy Commission nor has the California Energy Commission passed upon the accuracy or adequacy of the information in this report.

TABLE OF CONTENTS

Executive Summary	1
E.1 Introduction	1
Overview	1
Background	1
Project Objectives	1
E.2 Summary of the Project Scope and Methods	2
Survey Design	2
Collection of On-Site Survey Data	2
Collection of Information on Energy Usage for Sampled Sites	2
Development of Demand Analysis System	3
Analysis of Hourly End-Use Energy Consumption at the Premise Level	3
Analysis of Segment-Level End-Use Energy Consumption	4
E.3 Overview of Statewide Energy Usage	5
Definitions	5
Results	7
E.4 Recommendations	14
Lessons Learned	14
Recommendations for Additional Commercial Sector Research	15
 Chapter 1: Introduction	 17
1.1 Overview	17
1.2 Background	17
1.3 Project Objectives	17
1.4 Summary of the Study	18
Survey Design	18
Collection of On-Site Survey Data	18
Development of Energy Consumption Data for Sampled Sites.....	19
Development of Demand Analysis System.....	19
Analysis of Premise-Level End-Use Energy Consumption	20
Analysis of Segment-Level End-Use Energy Consumption	21
1.5 Organization of the Report	22
CEUS Report Structure.....	22
CEUS Report Appendices	22
Affiliated Reports from the CEUS Project	23
 Chapter 2: Sample Design	 25
2.1 Overview	25
2.2 Sampling Unit	25
2.3 Sample Frame for IOU Survey	26
2.4 Sample Frame Stratification	28
2.5 Sample Size and Sample Allocation	31
Sample Size.....	31

Sample Allocation	31
2.6 Development of Final Sample Design for IOU Survey	33
Allocation Methods	33
Alternative Stratification Approaches	34
Final Sample Design.....	36
2.7 SMUD Sample Design.....	41
Sample Frame	41
SMUD Sample Design.....	42
Chapter 3: Survey Design and Implementation.....	45
3.1 Overview	45
3.2 Survey Instrument Design	45
Non-HVAC Equipment End-use Mapping	46
Energy Efficiency Measure Detail	46
eQUEST Design Development Wizard Features	47
3.3 Customer Recruitment Protocols	48
Introduction	48
Recruitment Letter	49
Recruitment Phone Calls	49
Recruitment Disposition Report Requirements	51
3.4 Survey Protocols	54
Introduction	54
Premise as the Unit of Analysis	55
Protocols for Linking Meters to Premises.....	55
Defining Component Survey Areas.....	55
Protocols for Determining Business Type	57
Protocols for Dealing with Large Sites and Limited Access	57
Describing HVAC Zoning, Mechanical Systems and Equipment for HVAC and non HVAC End Uses	60
Site Physical Characteristics.....	61
Recording Technical Information	62
Supplemental Information	63
Key Elements of Business Operations.....	63
Interview Techniques	64
Quality-Control Procedures for Field Surveyors.....	65
3.5 Short-Term Metering Protocols.....	66
Overall STM Objectives	66
STM Targets	66
General Issues/Protocols	70
3.6 Surveyor Training.....	71
Day 1	71
Day 2-3	72
Day 4	72
3.7 Survey Pretests	72
3.8 Survey Implementation Process	73
Overall Process	73

Initial Sample	74
Recruiting Protocol	75
Site Information Sheets.....	75
Weekly Disposition Reports	75
Quality Control Procedures.....	76
Data Entry.....	76
Data Cleaning	79
On-Site Survey Form Delivery	79
Inventory Reports	79
3.9 Completed Samples	79
On-Site Survey Sample Targets and Actual Counts	80
Premises with Interval-Metered Data Available	81
Premises with Short-Term Metering Data	82
Chapter 4: Electric and Natural Gas Consumption Data	85
4.1 Overview	85
4.2 Validation and Analysis of Billing Data	86
4.3 Calendarization of Consumption Data.....	87
4.4 Developing Sample Recruitment Pools.....	88
4.5 Gas Consumption for SCE and SMUD Premises.....	89
4.6 Customer Information Sheet (CIS).....	90
4.7 Meter Reconciliation Issues	92
4.8 Mapping Interval-Metered Data to Premises	92
4.9 Post-Survey Meter Reconciliation	93
Chapter 5: Simulation Modeling Software	95
5.1 Introduction	95
5.2 DrCEUS System Design Overview	95
5.3 Site Processing Mode	97
Site Processor Structure	97
Site Processor Results.....	98
Energy Efficiency Measure Analysis in the Site Processor	101
Utility Billing Analysis in the Site Processor	103
5.4 Segment Processing Mode.....	104
5.5 Applications of the CEUS Database and DrCEUS	106
Chapter 6: The DRCEUS Energy Simulation And Calibration Process	109
6.1 Overview	109
6.2 Simulation Weather Data	109
6.3 Calibration Data Sources.....	111
Electric and Gas Consumption Data	111
Interval-Metered Electricity Data.....	112
Short-Term Metered (STM) Data	112
6.4 DrCEUS Simulation and Calibration Process	114
Overview of the Simulation/Calibration Process	114

Figure 6-4: Overview of the DrCEUS Simulation/Calibration Process	114
6.5 Judgmental Calibration.....	115
6.6 Calibration Special Issues	120
Complex Building Systems	120
Billed Demand Data	121
Interval-Metered Data	122
Short-Term Metered (STM) Data	122
Propane and Non-IOU Commercial Natural Gas	123
Chapter 7: Analysis of Commercial Segments—Key Concepts	125
7.1 Overview	125
7.2 Expansion (Case) Weights	125
7.3 Definitions and Concepts	140
7.4 Presentation of Results	145
Chapter 8: Statewide Results by Segment	149
8.1 Introduction	149
8.2 Overview of Statewide Energy Usage	149
8.3 Segment-Level Fuel Shares, EUIs, and Energy Intensities.....	156
All Commercial.....	156
Small Offices.....	157
Large Offices	158
Restaurants	159
Retail.....	160
Food Stores	161
Refrigerated Warehouses	162
Unrefrigerated Warehouses.....	163
Schools	164
Colleges	165
Health	166
Lodging	167
Miscellaneous	168
8.4 Segment-Level Hourly End-Use Electric Shapes	169
Chapter 9: PG&E Results by Segment.....	183
9.1 Introduction	183
9.2 Overview of Energy Usage in the PG&E Electric Service Area	183
9.3 Segment-Level Fuel Shares, EUIs, and Energy Intensities.....	190
All Commercial.....	190
Small Offices.....	191
Large Offices	192
Restaurants	193
Retail.....	194
Food Stores	195
Refrigerated Warehouses	196

Unrefrigerated Warehouses	197
Schools	198
Colleges	199
Health	200
Lodging	201
Miscellaneous	202
9.4 Segment-Level Hourly End-Use Electric Shapes	203
Chapter 10: SCE Results by Segment.....	217
 10.1 Introduction	217
 10.2 Overview of Energy Usage in the SCE Electric Service Area.....	217
 10.3 Segment-Level Fuel Shares, EUIs, and Energy Intensities.....	224
All Commercial.....	224
Small Offices.....	225
Large Offices	226
Restaurants	227
Retail.....	228
Food Stores	229
Refrigerated Warehouses	230
Unrefrigerated Warehouses	231
Schools	232
Colleges	233
Health	234
Lodging	235
Miscellaneous	236
 10.4 Segment-Level Hourly End-Use Electric Shapes	237
Chapter 11: SDG&E Results by Segment	251
 11.1 Introduction	251
 11.2 Overview of Energy Usage in the SDG&E Electric Service Area	251
 11.3 Segment-Level Fuel Shares, EUIs, and Energy Intensities.....	258
All Commercial.....	258
Small Offices.....	259
Large Offices	260
Restaurants	261
Retail.....	262
Food Stores	263
Refrigerated Warehouses	264
Unrefrigerated Warehouses	265
Schools	266
Colleges	267
Health	268
Lodging	269
Miscellaneous	270
 11.4 Segment-Level Hourly End-Use Electric Shapes	271

Chapter 12: SMUD Results by Segment	285
12.1 Introduction	285
12.2 Overview of Energy Usage in the SMUD Electric Service Area.....	285
12.3 Segment-Level Fuel Shares, EUIs, and Energy Intensities.....	292
All Commercial.....	292
Small Offices.....	293
Large Offices	294
Restaurants	295
Retail.....	296
Food Stores	297
Refrigerated Warehouses	298
Unrefrigerated Warehouses.....	299
Schools	300
Colleges.....	301
Health	302
Lodging	303
Miscellaneous	304
12.4 Segment-Level Hourly End Use Electric Shapes.....	305
Chapter 13: Summary and Recommendations.....	319
13.1 Summary of Project Scope and Methods.....	319
Survey Design	319
Collection of On-Site Survey Data	319
Collection of Information on Energy Usage for Sampled Sites	320
Development of Demand Analysis System	320
Analysis of Premise-Level Hourly End-Use Energy	320
Analysis of Segment-Level End-Use Energy Consumption	321
13.2 Recommendations	322
Lessons Learned	322
Recommendations for Additional Commercial Sector Research	324

Publication CEC-400-2006-005APA contains the following 10 appendices that accompany this report:

Appendix A: Basic Survey Instrument

Appendix B: Annotated Survey Instrument

Appendix C: End-Use Mappings

Appendix D: Recruitment Letter

Appendix E: Recruitment Script

Appendix F: Short-Term Metering Protocols

Appendix G: Survey Database Layout

Appendix H: Non-HVAC End-Use Algorithms

Appendix I: Description of Forecasting Climate Zone Results Database

Appendix J: SIC Code to CEUS Building Type Mapping Table

CHAPTER 11: SDG&E RESULTS BY SEGMENT

11.1 Introduction

This chapter summarizes the results of the CEUS analysis for the SDG&E service area. As noted in Chapter 7, *gas estimates relate to natural gas usage by customers in SDG&E's electric service area*. As such, they include some gas provided to these customers by other gas utilities, and exclude SDG&E gas served to customers in other electric service areas. Section 11.2 provides an overview of the composition of energy usage in the SDG&E electric service area by building type and end use. Section 11.3 presents electric and gas fuel shares, energy-use indices (EUIs), and energy intensities at the end-use level by building type. Section 11.4 provides 16-day hourly end-use electric shapes by building type. For all results presented in this chapter, the end uses and building types are as described in Chapter 7 of this report.

Additional results for the California Energy Commission Forecasting Climate Zones within the SDG&E service area (13) were also generated.¹ The database containing these results is described in Appendix I.

11.2 Overview of Energy Usage in the SDG&E Electric Service Area

Table 11-1, Figure 11-1, and Figure 11-2 depict the estimates of floor stock, whole-building energy intensities, and energy usage by building type for the SDG&E service area. Energy intensities and annual usage are weather-normalized. As noted in Chapter 7, these estimates refer to end-use consumption rather than necessarily purchases from utilities or other vendors. Estimates are based on the analysis year of 2002.

As shown, total commercial floor stock in the SDG&E electric service area is estimated to be just over 500 million square feet. The building types accounting for the largest percentage of total commercial floor stock are Miscellaneous (with approximately 21% of the total), Large Offices (16%) and Retail (12%).

Total commercial electric consumption is 8,491 GWh annually. The building types accounting for the largest percentage of total electricity consumption are Large Offices (20%), Miscellaneous (14%), and retail (13%). Natural gas usage is roughly 153 million therms (Mtherms) per year. Two building types account for over 41% of natural gas usage: Large Offices (23%) and Restaurants (18%).

¹ For the CEUS study, the single SDG&E FCZ was analyzed as “coastal” and “inland” sub-zones, designated as “S07” and “S10” respectively. The S07 sub-group included all premises located in Standards climate zones 6, 7 and 8, while the S10 sub-zone included premises located in Standards climate zones 10, 14, and 15. This approach was used in recognition of the varying climate regions within the SDG&E service territory.

Figure 11-3 and Figure 11-4 depict estimates of SDG&E service area electric and gas usage percentages by end use. The primary electric end uses are interior lighting (28%), cooling (16%), refrigeration (12%), and ventilation (11%). The primary natural gas end uses are water heating (32%) and space heating (30%).

Electric and gas usage and energy intensities by end use and building type are presented in Table 11-2 through Table 11-5. As indicated in Table 11-3, the highest overall electric end-use energy intensities are interior lighting (4.16 kWh per square foot), followed by cooling (2.38), refrigeration (1.79), and ventilation (1.66). According to Table 11-5, the highest natural gas end-use energy intensities are water heating (8.6 kBtu per square foot), space heating (7.9), and cooking (5.6).

EUIs by building type and end use are presented in Section 11-3.

Table 11-1: Overview of Energy Usage in the SDG&E Electric Service Area

Building Type	Floor Stock (kft ²)	Annual Energy Intensities			Total Annual Usage	
		Electricity (kWh/ft ²)	Natural Gas (therms/ft ²)	Natural Gas (kBtu/ft ²)	Electricity (GWh)	Natural Gas (Mtherms)
All Commercial	580,041	14.64	0.26	26.45	8,491	153.40
Small Office (<30k ft ²)	59,429	12.13	0.02	2.07	721	1.20
Large Office (>=30k ft ²)	89,827	19.23	0.39	38.86	1,727	34.90
Restaurant	15,604	43.73	1.77	176.82	682	27.60
Retail	72,428	15.49	0.02	2.44	1,122	1.80
Food Store	19,010	38.79	0.27	26.53	737	5.00
Refrigerated Warehouse	1,933	35.31	0.07	7.12	68	0.10
Unrefrigerated Warehouse	28,451	4.54	0.02	2.08	129	0.60
School	54,671	6.69	0.07	7.03	366	3.80
College	48,504	11.32	0.43	42.97	549	20.80
Health	35,163	18.92	0.61	61.02	665	21.50
Lodging	34,019	16.10	0.62	61.75	548	21.00
Miscellaneous	121,002	9.72	0.12	12.41	1,176	15.00
All Offices	149,257	16.40	0.24	24.21	2,448	36.10
All Warehouses	30,384	6.50	0.02	2.40	197	0.70

Figure 11-1: Electricity Use by Building Type




Figure 11-2: Natural Gas Usage by Building Type




Figure 11-3: Electric Usage by End Use




Figure 11-4: Natural Gas Usage by End Use




Table 11-2: Electric Usage (GWh) by Building Type and End Use

Building Type	Heat	Cool	Vent.	Refrig.	WH	Cook	Int. Ltg.	Ext. Ltg.	Office Equip.	Misc.	Air Comp.	Motors	Proc.	Total
All Commercial	162.10	1,380.50	965.60	1,041.00	93.60	304.70	2,411.60	520.50	597.50	452.30	6.60	477.30	77.40	8490.60
Small Office	18.00	134.20	63.40	45.30	21.70	10.60	234.10	47.60	132.30	10.80	0.00	0.40	2.30	720.60
Large Office	43.40	382.60	294.80	64.10	15.00	13.10	399.90	51.20	265.50	94.10	1.20	92.10	10.30	1727.10
Restaurant	2.30	100.30	65.90	161.60	8.10	157.40	105.80	30.20	11.60	37.90	0.00	0.80	0.30	682.30
Retail	6.30	174.90	117.30	103.10	18.60	18.50	486.80	89.00	41.80	39.90	0.00	15.70	10.10	1121.90
Food Store	0.40	40.90	41.60	433.40	1.50	27.00	148.50	19.00	7.50	14.90	0.00	2.80	0.00	737.40
Refrigerated Warehouse	0.20	1.30	3.60	43.90	0.30	0.20	8.10	0.90	0.70	0.70	0.00	8.20	0.20	68.30
Unrefrigerated Warehouse	0.70	18.40	12.70	9.80	2.60	3.40	56.20	6.80	8.70	4.60	0.80	3.80	0.80	129.10
School	12.00	53.90	46.40	22.30	5.60	4.60	145.20	37.70	27.60	6.40	0.00	2.40	1.60	365.70
College	38.50	116.20	37.10	28.60	1.00	17.30	157.70	67.90	25.50	11.60	0.00	42.60	5.10	549.10
Health	16.00	147.90	101.80	21.40	3.80	7.60	172.80	16.20	28.20	108.60	0.40	35.30	5.30	665.30
Lodging	13.80	114.10	99.40	35.10	0.10	30.90	175.80	19.70	3.70	36.30	0.00	18.10	0.90	547.80
Miscellaneous	10.70	95.80	81.60	72.20	15.50	14.20	320.80	134.20	44.30	86.70	4.20	255.20	40.70	1176.00
All Offices	61.30	516.80	358.20	109.50	36.60	23.60	633.90	98.80	397.80	104.80	1.20	92.50	12.60	2447.70
All Warehouses	0.80	19.70	16.30	53.70	2.90	3.60	64.20	7.70	9.30	5.30	0.80	12.00	1.00	197.40

Table 11-3: Electric Energy Intensities (kWh/ft²-yr) by Building Type and End Use

Building Type	Total	Heat	Cool	Vent.	Refrig.	WH	Cook	Int. Ltg.	Ext. Ltg.	Office Equip.	Misc.	Air Comp.	Motors	Proc.
All Commercial	14.64	0.28	2.38	1.66	1.79	0.16	0.53	4.16	0.90	1.03	0.78	0.01	0.82	0.13
Small Office	12.13	0.30	2.26	1.07	0.76	0.37	0.18	3.94	0.80	2.23	0.18	0.00	0.01	0.04
Large Office	19.23	0.48	4.26	3.28	0.71	0.17	0.15	4.45	0.57	2.96	1.05	0.01	1.03	0.11
Restaurant	43.73	0.15	6.43	4.22	10.36	0.52	10.08	6.78	1.94	0.75	2.43	0.00	0.05	0.02
Retail	15.49	0.09	2.42	1.62	1.42	0.26	0.26	6.72	1.23	0.58	0.55	0.00	0.22	0.14
Food Store	38.79	0.02	2.15	2.19	22.80	0.08	1.42	7.81	1.00	0.40	0.78	0.00	0.14	0.00
Refrigerated Warehouse	35.31	0.09	0.68	1.86	22.72	0.16	0.12	4.18	0.46	0.36	0.34	0.00	4.25	0.09
Unrefrigerated Warehouse	4.54	0.02	0.65	0.45	0.34	0.09	0.12	1.97	0.24	0.30	0.16	0.03	0.13	0.03
School	6.69	0.22	0.99	0.85	0.41	0.10	0.08	2.66	0.69	0.50	0.12	0.00	0.04	0.03
College	11.32	0.79	2.40	0.77	0.59	0.02	0.36	3.25	1.40	0.53	0.24	0.00	0.88	0.10
Health	18.92	0.45	4.21	2.89	0.61	0.11	0.22	4.92	0.46	0.80	3.09	0.01	1.00	0.15
Lodging	16.10	0.41	3.35	2.92	1.03	0.00	0.91	5.17	0.58	0.11	1.07	0.00	0.53	0.03
Miscellaneous	9.72	0.09	0.79	0.67	0.60	0.13	0.12	2.65	1.11	0.37	0.72	0.03	2.11	0.34
All Offices	16.40	0.41	3.46	2.40	0.73	0.25	0.16	4.25	0.66	2.67	0.70	0.01	0.62	0.08
All Warehouses	6.50	0.03	0.65	0.54	1.77	0.09	0.12	2.11	0.25	0.31	0.17	0.03	0.39	0.03

Table 11-4: Natural Gas Usage (Mtherms) by Building Type and End Use

Building Type	Heat	Cool	WH	Cook	Misc.	Proc.	Total
All Commercial	45.80	8.50	49.70	32.40	4.00	12.90	153.40
Small Office	0.40	0.00	0.50	0.00	0.00	0.30	1.20
Large Office	22.70	2.40	3.80	0.20	0.10	5.60	34.90
Restaurant	0.50	0.00	5.50	21.60	0.00	0.00	27.60
Retail	0.60	0.00	0.40	0.70	0.00	0.10	1.80
Food Store	0.90	0.00	1.20	2.90	0.00	0.00	5.00
Refrigerated Warehouse	0.00	0.00	0.10	0.00	0.00	0.00	0.10
Unrefrigerated Warehouse	0.50	0.00	0.10	0.00	0.00	0.00	0.60
School	2.40	0.00	1.10	0.30	0.00	0.00	3.80
College	7.20	5.80	5.30	1.90	0.70	0.00	20.80
Health	4.90	0.30	13.70	1.60	0.50	0.30	21.50
Lodging	1.60	0.00	15.60	2.50	1.10	0.10	21.00
Miscellaneous	4.00	0.00	2.30	0.70	1.60	6.40	15.00
All Offices	23.10	2.40	4.30	0.20	0.20	5.90	36.10
All Warehouses	0.50	0.00	0.20	0.00	0.00	0.00	0.70

Table 11-5: Natural Gas Usage Intensities (kBtu/ft²-yr) by Building Type and End Use

Building Type	Total	Heat	Cool	WH	Cook	Misc.	Proc.
All Commercial	26.5	7.9	1.5	8.6	5.6	0.7	2.2
Small Office	2.1	0.7	0.0	0.9	0.0	0.0	0.4
Large Office	38.9	25.3	2.7	4.2	0.2	0.2	6.3
Restaurant	176.8	3.0	0.0	35.4	138.4	0.0	0.0
Retail	2.4	0.8	0.0	0.6	0.9	0.0	0.2
Food Store	26.5	4.8	0.0	6.3	15.4	0.0	0.0
Refrigerated Warehouse	7.1	2.2	0.0	4.9	0.0	0.0	0.0
Unrefrigerated Warehouse	2.1	1.7	0.0	0.2	0.0	0.1	0.0
School	7.0	4.5	0.0	2.1	0.5	0.0	0.0
College	43.0	14.9	11.9	11.0	3.8	1.3	0.0
Health	61.0	14.1	0.9	39.1	4.7	1.3	1.0
Lodging	61.7	4.8	0.0	45.8	7.5	3.2	0.4
Miscellaneous	12.4	3.3	0.0	1.9	0.6	1.3	5.3
All Offices	24.2	15.5	1.6	2.9	0.1	0.1	4.0
All Warehouses	2.4	1.8	0.0	0.5	0.0	0.1	0.0

11.3 Segment-Level Fuel Shares, EUIs, and Energy Intensities

This section provides EUIs, fuel shares, and energy intensities for the building types and end uses defined in Chapter 7. Results are not presented in this section for the “All Offices” and “All Warehouses” building types.

All Commercial

Estimated total floor stock for all commercial buildings in the SDG&E service area is just over 580 million square feet. Electric and natural gas EUIs, fuel shares and energy intensities for the overall SDG&E commercial sector are presented in Table 11-6 and Table 11-7.

Table 11-6: All Commercial Electric EUIs, Fuel Shares, and EIIs

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.52	53.90	0.28
Cooling	3.37	70.60	2.38
Ventilation	2.20	75.60	1.66
Water Heating	0.31	52.90	0.16
Cooking	0.56	94.60	0.53
Refrigeration	1.85	97.20	1.79
Interior Lighting	4.16	100.00	4.16
Office Equipment	1.03	99.70	1.03
Exterior Lighting	0.97	92.30	0.90
Miscellaneous	1.02	76.10	0.78
Process	0.44	2.60	0.01
Motors	1.40	58.80	0.82
Air Compressors	0.37	36.40	0.13
All End Uses			14.64

Table 11-7: All Commercial Natural Gas EUIs, Fuel Shares, and EIIs

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	16.72	47.20	7.90
Cooling	20.76	7.10	1.47
Water Heating	14.80	57.90	8.57
Cooking	15.24	36.70	5.59
Miscellaneous	3.62	19.20	0.69
Process	55.48	4.00	2.23
All End Uses			26.45

Small Offices

Estimated total floor stock in small office buildings (defined as premises with total floor area less than 30,000 square feet) is just over 59 million square feet. Based on the electric intensities in Table 11-8, the largest electric end uses in this building type are interior lighting, cooling and office equipment. As shown in Table 11-9, the largest gas end use is water heating, followed fairly closely by space heating.

Table 11-8: Small Office Electric EUIs, Fuel Shares, and EIIs

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.38	80.00	0.30
Cooling	2.44	92.60	2.26
Ventilation	1.14	93.40	1.07
Water Heating	0.52	70.30	0.37
Cooking	0.19	92.20	0.18
Refrigeration	0.87	87.20	0.76
Interior Lighting	3.94	100.00	3.94
Office Equipment	2.23	100.00	2.23
Exterior Lighting	1.46	54.70	0.80
Miscellaneous	0.54	33.80	0.18
Process	0.00	0.00	0.00
Motors	0.70	0.90	0.01
Air Compressors	0.44	8.90	0.04
All End Uses	-	-	12.13

Table 11-9: Small Office Natural Gas EUIs, Fuel Shares, and EIIs

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	10.18	6.70	0.68
Cooling	0.00	0.00	0.00
Water Heating	18.08	5.10	0.92
Cooking	0.00	0.00	0.00
Miscellaneous	0.29	10.90	0.03
Process	215.01	0.20	0.44
All End Uses			2.07

Large Offices

Estimated total floor stock in large office buildings (defined as premises with total floor area of 30,000 square feet or more) is almost 90 million square feet. As indicated by Table 11-10, the largest electric end uses in this building type are interior lighting, cooling and ventilation. As shown in Table 11-11, the predominant gas end use is space heating.

Table 11-10: Large Office Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.69	70.40	0.48
Cooling	4.76	89.50	4.26
Ventilation	3.56	92.10	3.28
Water Heating	0.27	62.80	0.17
Cooking	0.15	96.00	0.15
Refrigeration	0.73	97.70	0.71
Interior Lighting	4.45	100.00	4.45
Office Equipment	2.96	100.00	2.96
Exterior Lighting	0.57	100.00	0.57
Miscellaneous	1.64	64.00	1.05
Process	0.40	3.40	0.01
Motors	1.11	92.50	1.03
Air Compressors	0.25	45.90	0.11
All End Uses			19.23

Table 11-11: Large Office Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	37.72	67.10	25.31
Cooling	54.22	4.90	2.67
Water Heating	6.86	61.20	4.20
Cooking	1.26	18.10	0.23
Miscellaneous	0.77	21.30	0.16
Process	50.56	12.40	6.29
All End Uses			38.86

Restaurants

Estimated total floor stock in large restaurants just over 15.6 million square feet. As indicated by Table 11-12, the largest electric end uses in this building type are refrigeration, cooking, and interior lighting. As shown in Table 11-13, the predominant gas end use is cooking.

Table 11-12: Restaurant Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.53	28.30	0.15
Cooling	9.33	68.90	6.43
Ventilation	5.69	74.30	4.22
Water Heating	1.73	30.00	0.52
Cooking	10.59	95.20	10.08
Refrigeration	10.36	100.00	10.36
Interior Lighting	6.78	100.00	6.78
Office Equipment	0.78	95.60	0.75
Exterior Lighting	2.24	86.50	1.94
Miscellaneous	3.99	60.80	2.43
Process	0.00	0.00	0.00
Motors	0.39	13.60	0.05
Air Compressors	0.46	4.80	0.02
All End Uses			43.73

Table 11-13: Restaurant Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	6.77	44.20	2.99
Cooling	0.00	0.00	0.00
Water Heating	46.12	76.70	35.36
Cooking	173.65	79.70	138.43
Miscellaneous	1.40	2.70	0.04
Process	0.00	0.00	0.00
All End Uses			176.82

Retail

Estimated total floor stock in retail is just over 72 million square feet. As indicated by Table 11-14, the largest electric end uses in this building type are interior lighting, cooling, and ventilation. As shown in Table 11-15, cooking and space heating account for most of the gas usage, although the overall gas energy intensity is low in this building type.

Table 11-14: Retail Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.34	25.30	0.09
Cooling	3.88	62.30	2.42
Ventilation	2.40	67.60	1.62
Water Heating	0.48	53.30	0.26
Cooking	0.29	89.40	0.26
Refrigeration	1.52	93.30	1.42
Interior Lighting	6.72	100.00	6.72
Office Equipment	0.58	100.00	0.58
Exterior Lighting	1.37	89.50	1.23
Miscellaneous	0.97	56.70	0.55
Process	0.00	0.00	0.00
Motors	0.77	28.20	0.22
Air Compressors	0.47	29.50	0.14
All End Uses			15.49

Table 11-15: Retail Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	2.30	33.10	0.76
Cooling	0.00	0.00	0.00
Water Heating	2.71	21.70	0.59
Cooking	10.59	8.80	0.93
Miscellaneous	0.02	1.30	0.00
Process	6.53	2.50	0.16
All End Uses			2.44

Food Stores

Estimated total floor stock in retail is just over 19 million square feet. As indicated by Table 11-16, the predominant electric end use in this building type is refrigeration. As shown in Table 11-17, cooking and water heating account for most of the gas usage.

Table 11-16: Food Store Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.16	12.20	0.02
Cooling	3.93	54.80	2.15
Ventilation	3.99	54.80	2.19
Water Heating	0.56	14.00	0.08
Cooking	1.54	92.30	1.42
Refrigeration	22.80	100.00	22.80
Interior Lighting	7.81	100.00	7.81
Office Equipment	0.40	100.00	0.40
Exterior Lighting	1.13	88.00	1.00
Miscellaneous	0.82	95.90	0.78
Process	0.00	0.00	0.00
Motors	0.50	28.60	0.14
Air Compressors	0.00	0.00	0.00
All End Uses			38.79

Table 11-17: Food Store Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	18.12	26.60	4.82
Cooling	0.00	0.00	0.00
Water Heating	9.09	69.10	6.28
Cooking	27.68	55.70	15.41
Miscellaneous	0.14	14.80	0.02
Process	0.00	0.00	0.00
All End Uses			26.53

Refrigerated Warehouses

Estimated total floor stock in refrigerated warehouses is just under 2 million square feet. As indicated by Table 11-18, the predominant electric end use in this building type is refrigeration. As shown in Table 11-19, water heating and space heating account for virtually all of this sector's gas usage.

Table 11-18: Refrigerated Warehouse Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	1.84	4.70	0.09
Cooling	4.65	14.60	0.68
Ventilation	4.58	40.60	1.86
Water Heating	0.41	39.60	0.16
Cooking	0.12	100.00	0.12
Refrigeration	22.72	100.00	22.72
Interior Lighting	4.18	100.00	4.18
Office Equipment	0.36	100.00	0.36
Exterior Lighting	0.46	100.00	0.46
Miscellaneous	0.41	83.80	0.34
Process	0.00	0.00	0.00
Motors	7.04	60.40	4.25
Air Compressors	2.32	3.90	0.09
All End Uses			35.31

Table 11-19: Refrigerated Warehouse Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	5.47	40.60	2.22
Cooling	0.00	0.00	0.00
Water Heating	8.07	60.40	4.88
Cooking	0.04	56.50	0.02
Miscellaneous	0.00	0.00	0.00
Process	0.00	0.00	0.00
All End Uses			7.12

Unrefrigerated Warehouses

Estimated total floor stock in unrefrigerated warehouses is just over 28 million square feet. As indicated by Table 11-20, the major electric end use in this building type is interior lighting, followed by cooling and ventilation. As shown in Table 11-21, space heating accounts for most of this sector's gas usage.

Table 11-20: Unrefrigerated Warehouse Electric EUIs, Fuel Shares, and EIs

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.20	11.70	0.02
Cooling	2.59	25.00	0.65
Ventilation	1.79	25.00	0.45
Water Heating	0.12	74.70	0.09
Cooking	0.12	100.00	0.12
Refrigeration	0.35	99.30	0.34
Interior Lighting	1.97	100.00	1.97
Office Equipment	0.31	99.30	0.30
Exterior Lighting	0.25	97.80	0.24
Miscellaneous	0.21	76.20	0.16
Process	0.81	3.60	0.03
Motors	0.20	65.60	0.13
Air Compressors	0.10	27.40	0.03
All End Uses			4.54

Table 11-21: Unrefrigerated Warehouse Natural Gas EUIs, Fuel Shares, and EIs

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	8.44	20.60	1.73
Cooling	0.00	0.00	0.00
Water Heating	0.66	35.00	0.23
Cooking	0.00	0.00	0.00
Miscellaneous	7.62	1.60	0.12
Process	0.00	0.00	0.00
All End Uses			2.08

Schools

Estimated total floor stock in schools unrefrigerated warehouses is over 54 million square feet. As indicated by Table 11-22, the major electric end use in this building type is interior lighting, followed by cooling and ventilation. As shown in Table 11-23, space heating accounts for most of this sector's gas usage.

Table 11-22: School Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.27	80.70	0.22
Cooling	1.17	84.10	0.99
Ventilation	0.96	88.80	0.85
Water Heating	0.13	80.10	0.10
Cooking	0.08	100.00	0.08
Refrigeration	0.41	100.00	0.41
Interior Lighting	2.66	100.00	2.66
Office Equipment	0.50	100.00	0.50
Exterior Lighting	0.69	100.00	0.69
Miscellaneous	0.12	100.00	0.12
Process	0.00	0.00	0.00
Motors	0.08	55.10	0.04
Air Compressors	0.13	23.10	0.03
All End Uses			6.69

Table 11-23: School Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	6.84	65.10	4.45
Cooling	0.00	0.00	0.00
Water Heating	2.61	80.20	2.09
Cooking	0.66	73.40	0.49
Miscellaneous	0.00	0.00	0.00
Process	0.00	0.00	0.00
All End Uses			7.03

Colleges

Estimated total floor stock in colleges is just over 48 million square feet. As indicated by Table 11-24, the major electric end use in this building type is interior lighting, followed by cooling and exterior lighting. As shown in Table 11-25, this sector's gas usage is split fairly evenly among space heating, water heating and cooling.

Table 11-24: College Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.97	81.90	0.79
Cooling	2.96	80.90	2.40
Ventilation	0.93	81.90	0.77
Water Heating	0.02	97.70	0.02
Cooking	0.36	100.00	0.36
Refrigeration	0.59	100.00	0.59
Interior Lighting	3.25	100.00	3.25
Office Equipment	0.53	100.00	0.53
Exterior Lighting	1.41	99.60	1.40
Miscellaneous	0.25	95.90	0.24
Process	0.05	0.70	0.00
Motors	0.90	97.30	0.88
Air Compressors	0.11	94.30	0.10
All End Uses			11.32

Table 11-25: College Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	18.62	79.90	14.88
Cooling	15.99	74.70	11.94
Water Heating	11.56	95.00	10.98
Cooking	4.06	94.30	3.82
Miscellaneous	1.42	94.30	1.34
Process	0.00	0.00	0.00
All End Uses			42.96

Health

Estimated total floor stock in health is just over 35 million square feet. As indicated by Table 11-26, the major electric end use in this building type is interior lighting, followed by cooling miscellaneous (mostly medical equipment). As shown in Table 11-27, water heating accounts for most of this sector's gas usage.

Table 11-26: Health Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.66	69.10	0.45
Cooling	4.54	92.70	4.21
Ventilation	3.05	95.00	2.89
Water Heating	0.47	23.10	0.11
Cooking	0.22	100.00	0.22
Refrigeration	0.61	100.00	0.61
Interior Lighting	4.92	100.00	4.92
Office Equipment	0.80	100.00	0.80
Exterior Lighting	0.46	99.60	0.46
Miscellaneous	3.21	96.30	3.09
Process	0.10	9.80	0.01
Motors	1.19	84.50	1.00
Air Compressors	0.37	40.50	0.15
All End Uses			18.92

Table 11-27: Health Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	16.54	85.10	14.07
Cooling	83.29	1.10	0.93
Water Heating	42.07	92.90	39.10
Cooking	5.48	85.50	4.68
Miscellaneous	5.97	21.50	1.28
Process	12.31	7.80	0.96
All End Uses			61.02

Lodging

Estimated total floor stock in lodging is just over 34 million square feet. As indicated by Table 11-28, the major electric end use in this building type is interior lighting, followed by cooling and ventilation. As shown in Table 11-29, water heating account for most of this sector's gas usage.

Table 11-28: Lodging Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.47	85.70	0.41
Cooling	3.73	89.90	3.35
Ventilation	3.21	91.00	2.92
Water Heating	0.05	5.40	0.00
Cooking	0.92	99.10	0.91
Refrigeration	1.03	100.00	1.03
Interior Lighting	5.17	100.00	5.17
Office Equipment	0.11	98.10	0.11
Exterior Lighting	0.58	100.00	0.58
Miscellaneous	1.07	100.00	1.07
Process	0.00	0.00	0.00
Motors	0.58	91.70	0.53
Air Compressors	0.08	33.60	0.03
All End Uses			16.10

Table 11-29: Lodging Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	8.62	56.10	4.83
Cooling	0.00	0.00	0.00
Water Heating	50.09	91.50	45.81
Cooking	11.34	65.80	7.46
Miscellaneous	6.19	52.00	3.22
Process	5.35	8.00	0.43
All End Uses			61.75

Miscellaneous

Estimated total floor stock in the miscellaneous building type is 121 million square feet. As indicated by Table 11-30, the major electric end use in this building type is interior lighting, followed motors and exterior lighting. As shown in Table 11-31, process and space heating account for most of this sector's gas usage.

Table 11-30: Miscellaneous Electric EUIs, Fuel Shares, and EI

End Use	Electric EUI (kWh/End-Use ft ²)	Electric Fuel Share	Electric EI (kWh/ft ²)
Heating	0.30	29.60	0.09
Cooling	1.84	43.00	0.79
Ventilation	1.19	56.70	0.67
Water Heating	0.39	32.60	0.13
Cooking	0.13	89.20	0.12
Refrigeration	0.60	98.80	0.60
Interior Lighting	2.65	100.00	2.65
Office Equipment	0.37	100.00	0.37
Exterior Lighting	1.16	95.90	1.11
Miscellaneous	0.84	84.90	0.72
Process	0.58	6.00	0.03
Motors	3.58	58.90	2.11
Air Compressors	0.80	41.80	0.34
All End Uses			9.72

Table 11-31: Miscellaneous Natural Gas EUIs, Fuel Shares, and EI

End Use	Natural Gas EUI (kBtu/End-Use ft ²)	Natural Gas Fuel Share	Natural Gas EI (kBtu/ft ²)
Heating	9.05	36.20	3.28
Cooling	0.00	0.00	0.00
Water Heating	3.14	59.60	1.87
Cooking	2.60	23.00	0.60
Miscellaneous	16.17	8.30	1.34
Process	133.80	4.00	5.32
All End Uses			12.41

11.4 Segment-Level Hourly End-Use Electric Shapes


This section presents 16-day hourly stacked end-use graphs from DrCEUS for the basic set of building types (that is, excluding “All Offices” and “All Warehouses”). The 16-day type basis (4 day types X 4 seasons), as defined in Chapter 7, are as follows:

- **Four Day Types.** Typical Day (weekday), Hot Day (weekday), Cold Day (weekday) and Weekend (Saturday, Sunday, and holidays). Note that the Hot and Cold day types are the hottest\coldest² *single* days during a season, whereas the Typical and Weekend day types are an *average* of all days of those respective types during the season.
- **Four Seasons.** Winter (December through February), Spring (March through May), Summer (June through September), Fall (October through November).

Only electric hourly end-use shapes are presented here, although gas end-use hourly shapes are also available from DrCEUS.

² The hottest/coldest days are determined as the first weekday during a season that has the highest or lowest hourly temperature.

Figure 11-5: All Commercial 16-Day Hourly End-Use Shapes



California Commercial End-Use Survey

Figure 11-6: Small Office 16-Day Hourly End-Use Shapes






Figure 11-7: Large Office 16-Day Hourly End-Use Shapes




California Commercial End-Use Survey

Figure 11-8: Restaurant 16-Day Hourly End-Use Shapes



California Commercial End-Use Survey

Figure 11-9: Retail 16-Day Hourly End-Use Shapes



California Commercial End-Use Survey

Figure 11-10: Food Store 16-Day Hourly End-Use Shapes




Figure 11-11: Refrigerated Warehouse 16-Day Hourly End-Use Shapes






Figure 11-12: Unrefrigerated Warehouse 16-Day Hourly End-Use Shapes




California Commercial End-Use Survey

Figure 11-13: School 16-Day Hourly End-Use Shapes




California Commercial End-Use Survey

Figure 11-14: College 16-Day Hourly End-Use Shapes




California Commercial End-Use Survey

Figure 11-15: Health 16-Day Hourly End-Use Shapes



California Commercial End-Use Survey

Figure 11-16: Lodging 16-Day Hourly End-Use Shapes



California Commercial End-Use Survey

Figure 11-17: Miscellaneous 16-Day Hourly End-Use Shapes

