

**1994 COMMERCIAL RETROFIT PROGRAM
EVALUATION OF LIGHTING TECHNOLOGIES**

FINAL IMPACT EVALUATION REPORT

Submitted to

**Elsia Galawish
Market Planning & Research
Pacific Gas & Electric Company
123 Mission Street, Room 2437
San Francisco, CA 94177**

Prepared by

**QUANTUM CONSULTING INC.
2030 Addison Street
Berkeley, CA 94704**

P696.321

February 1996

**1994 COMMERCIAL RETROFIT PROGRAM
EVALUATION OF LIGHTING TECHNOLOGIES**

FINAL IMPACT EVALUATION REPORT

Prepared by

**QUANTUM CONSULTING INC.
2030 Addison Street
Berkeley, CA 94704**

Principal Investigators

**Robert Uhlener
Timothy Caulfield
Joan Mancuso
Bing Xiao
Kris Bradley
Sam Shrauger
Michael Oing**

February 1996

CONTENTS

| Section | Page |
|---|------------|
| 1 Executive Summary..... | 1-1 |
| 1.1 Evaluation Summary..... | 1-1 |
| 1.2 Major Findings | 1-5 |
| 1.3 Major Recommendations..... | 1-5 |
| 2 Introduction..... | 2-1 |
| 2.1 The Retrofit Express Program | 2-1 |
| 2.2 The Customized Incentives Program..... | 2-2 |
| 2.3 Evaluation Overview | 2-2 |
| 2.4 Report Layout | 2-4 |
| 3 Methodology..... | 3-1 |
| 3.1 Integrated Evaluation Approach | 3-1 |
| 3.2 Engineering Analysis | 3-9 |
| 3.3 Billing Regression Analysis..... | 3-21 |
| 3.4 Net-to-Gross Analysis..... | 3-35 |
| 4 Evaluation Results Summaries | 4-1 |
| 4.1 Gross Energy Impact Results | 4-1 |
| 4.2 Net to Gross Adjustments..... | 4-4 |
| 4.3 Net Impacts..... | 4-6 |
| 4.4 Realization Rates..... | 4-9 |
| 4.5 Overview of Realization Rates..... | 4-19 |
| 4.6 Overview of Realization Rates..... | 4-20 |
| 5 Recommendations..... | 5-1 |
| 5.1 Evaluation Methods | 5-1 |
| 5.2 Program Design..... | 5-2 |
| 5.3 Protocols..... | 5-3 |

LIST OF APPENDICES

Appendix

- A Sample Design Protocols**
- B Engineering Detailed Computational Methods**
- C Detailed Statistical Impact Analysis Approach and Results**
- D Final Participants Telephone Survey**
- E Final Nonparticipants Telephone Survey**
- F Final Participants On-site Instrument**
- G Final Nonparticipants On-site Instrument**
- H Participants Telephone Survey Response Frequencies**
- I Nonparticipants Telephone Survey Response Frequencies**
- J Purchase Decision Logistic Regression Model**
- K Gross Energy and Demand Impacts by Costing Period**
- L Ex Ante Net-to-Gross Ratios**
- M Commercial Refusal Comments**
- N Nonparticipant Refusal Comments**

LIST OF EXHIBITS

| Exhibit | Page |
|---|-------------|
| 1-1 Summary of Gross Evaluation Results Commercial Indoor and Outdoor Lighting Applications..... | 1-3 |
| 1-2 Summary of Net Evaluation Results Commercial Indoor and Outdoor Lighting Applications..... | 1-4 |
| 3-1 Nested Sample Design Approach..... | 3-4 |
| 3-2 Method for Estimating Demand Impacts..... | 3-5 |
| 3-3 Method for Estimating Energy Impacts | 3-7 |
| 3-4 Derivation of Engineering Estimates for Use in Billing Regression Analysis..... | 3-10 |
| 3-5 Engineering Estimates of Gross Demand Impacts | 3-11 |
| 3-6 Engineering Estimates of Gross Energy Impacts | 3-13 |
| 3-7 Comparison of Segmentation by Technology | 3-15 |
| 3-8 Operating Hours and Operating Factors for Engineering Models (Sources Used to Determine Each Estimate) | 3-17 |
| 3-9 Estimate of Cooling Benefit | 3-19 |
| 3-10 Estimate of Heating Increase Penalty (Electric Heating Only) | 3-20 |
| 3-11 Telephone Survey Sample Distribution by Program, End Use and Business Type | 3-26 |
| 3-12 Telephone Survey Sample Distribution by Technology | 3-27 |
| 3-13 Billing Regression Analysis Final Model Outputs..... | 3-32 |

| Exhibit | Page |
|----------------|---|
| 3-14 | Relative Precision Calculation 3-34 |
| 3-15 | Self-Reported Free Ridership: Superset of Model Variables 3-37 |
| 3-16 | Example: Spillover Effects Used for Compact Fluorescent Lamps..... 3-41 |
| 3-17 | Representation of Nonparticipant Spillover Effects..... 3-42 |
| 3-18 | Net Energy Impact Summary 3-45 |
| 3-19 | Net Demand Impact Summary 3-46 |
| 4-1 | Gross Energy Impacts By Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-2 |
| 4-2 | Gross Demand Impacts By Business Group and Technology Type Commercial Indoor and Outdoor Lighting Applications..... 4-3 |
| 4-3 | NTG Adjustments by Technology Type 4-5 |
| 4-4 | Net Energy Impacts By Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-7 |
| 4-5 | Net Demand Impacts By Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-8 |
| 4-6 | Gross Energy Impact Realization Rates By Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-10 |
| 4-7 | Gross Demand Impact Realization Rates by Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-13 |
| 4-8 | Net Energy Impact Realization Rates By Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-16 |
| 4-9 | Net Demand Impact Realization Rates By Business Type and Technology Group Commercial Indoor and Outdoor Lighting Applications..... 4-18 |
| 4-10 | Full Load Hours by Business Type 4-20 |

4-11 CDOFs by Business Type..... 4-21

Section 1

EXECUTIVE SUMMARY

This section presents a summary of the impact results for the commercial lighting technologies offered under the Pacific Gas & Electric Company (PG&E) 1994 Nonresidential Retrofit Programs. This evaluation covered both indoor and outdoor lighting technologies for the Retrofit Express (RE) and the Customized Incentives (Customized) programs. The results are presented in three sections: evaluation results summary (covering the numerical results of the study), major findings, and major recommendations.

1.1 Evaluation Summary

The evaluation results are summarized in terms of energy savings (MWh), demand savings (kW), and realization rates, the ratio of the evaluation results (ex post) to the program design estimates (ex ante). These results are presented on a gross and net basis (i.e., before and after accounting for free riders and spillover). Exhibit 1-1 presents the gross energy and demand savings results, together with the gross realization rates.

Exhibit 1-1
Summary of GROSS Evaluation Results
Commercial Indoor and Outdoor Lighting Applications

| Program and Technology Group | Number of Units Paid | Gross Impacts | | | |
|---------------------------------|----------------------|----------------|------------------|---------------|------------------|
| | | Energy | | Demand | |
| | | (MWh) | Realization Rate | (kW) | Realization Rate |
| Indoor Total | 2,826,393 | 277,688 | 0.99 | 62,389 | 1.19 |
| Outdoor Total | 16,363 | 18,058 | 0.87 | 782 | 6.31 |
| Indoor and Outdoor Total | 2,842,756 | 295,746 | 0.98 | 63,172 | 1.20 |

These results illustrate the following key points about the gross commercial lighting impacts:

- The vast majority of the savings are from indoor lighting applications.
- The ex post gross impacts equaled the ex ante gross estimate for energy, and exceeded it for demand. This is primarily the result of higher operating factors (as determined by field inspections), in conjunction with the inclusion of the HVAC savings due to the more efficient lights, in the ex post impacts.

Exhibits 1-2 and 1-3 present the net energy and demand impact results, together with the net realization rates, at the same levels presented in Exhibit 1-1.

The net ex post energy impacts exceed the net ex ante design estimates by 39 percent for energy, and 73 percent for demand. To a certain extent, these results reflect the high gross realization rates, but they are really driven by the ex ante and ex post net-to-gross (NTG) ratios. The net to gross adjustments apply equally to energy and demand impacts, since they represent behavioral affects on the decision to purchase energy-efficient equipment. Thus the following points apply equally to Exhibits 1-2 and 1-3.

- The ex ante NTG ratio was between 0.70 and 0.77, depending upon the business segment and technology, averaging about 0.76.
- The ex post NTG ratio for combined indoor and outdoor lighting averaged 1.08.
- When 1.08 is divided by 0.77, it results in an average 40 percent increase in realized savings.
- Free ridership rates were low for these programs, contributing a 17 percent overall reduction in energy and demand impacts.
- Participant spillover rates offset the free ridership to a small extent, contributing an average of 3 percent increase in impacts
- Nonparticipant spillover effects were detected in this evaluation, contributing a an average 18 percent increase in estimated savings for the combined indoor and outdoor impacts measured for the combined lighting programs.

Exhibit 1-2
 Summary of NET Evaluation ENERGY Results
 Commercial Indoor and Outdoor Lighting Applications

| Technology Group | Gross | NTG Adjustments | | | Net | |
|--|--------------|----------------------------------|----------------------------------|-------------------------------------|--|---|
| | Gross Impact | Free Ridership Adjustment (1-FR) | Participant Spillover Adjustment | Nonparticipant Spillover Adjustment | Net Impact without NP Spillover Adjustment | Net Impact with NP Spillover Adjustment |
| | (MWh) | (Unitless) | (Unitless) | (Unitless) | (MWh) | (MWh) |
| Ex Ante | | | | | | |
| Indoor Lighting | 280,014 | 0.67 | | 0.10 | 215,858 | |
| Outdoor Lighting | 20,738 | 0.67 | | 0.10 | 15,958 | |
| Indoor & Outdoor Lighting | 300,752 | 0.67 | | 0.10 | 230,783 | |
| Ex Post | | | | | | |
| Indoor Lighting | 277,688 | 0.87 | 0.03 | 0.18 | 250,058 | 300,043 |
| Outdoor Lighting | 18,058 | 0.82 | 0.06 | 0.27 | 15,891 | 20,745 |
| Indoor & Outdoor Lighting | 295,746 | 0.87 | 0.03 | 0.18 | 267,059 | 320,778 |
| Realization Rates (ex post/ex ante) | | | | | | |
| Indoor Lighting | 0.99 | NA | NA | NA | 1.16 | 1.39 |
| Outdoor Lighting | 0.87 | NA | NA | NA | 1.00 | 1.30 |
| Indoor & Outdoor Lighting | 0.98 | NA | NA | NA | 1.16 | 1.39 |

Exhibit 1-2 illustrates the following key points about the net commercial lighting energy impact results:

- The ex post net energy impact exceeded the ex ante net impact by 39 percent.
- A significant factor in the high ex post NTG ratio is nonparticipant spillover, which increased the NTG ratio by 18 percentage points. While this spillover effect is documented and believed to be appropriate, net realization rates without nonparticipant spillover are still 1.16.

Exhibit 1-3 presents the net demand savings results, together with the net realization rates, at the same levels presented in Exhibit 1-1.

Exhibit 1-3
 Summary of NET Evaluation DEMAND Results
 Commercial Indoor and Outdoor Lighting Applications

| Technology Group | Gross | NTG Adjustments | | | Net | |
|--|--------------|----------------------------------|----------------------------------|-------------------------------------|--|---|
| | Gross Impact | Free Ridership Adjustment (1-FR) | Participant Spillover Adjustment | Nonparticipant Spillover Adjustment | Net Impact without NP Spillover Adjustment | Net Impact with NP Spillover Adjustment |
| | (kW) | (Unitless) | (Unitless) | (Unitless) | (kW) | (kW) |
| Ex Ante | | | | | | |
| Indoor Lighting | 52,416 | 0.67 | | 0.10 | 40,351 | |
| Outdoor Lighting | 124 | 0.67 | | 0.10 | 92 | |
| Indoor & Outdoor Lighting | 52,540 | 0.67 | | 0.10 | 40,443 | |
| Ex Post | | | | | | |
| Indoor Lighting | 62,389 | 0.87 | 0.03 | 0.19 | 56,181 | 69,000 |
| Outdoor Lighting | 782 | 0.83 | 0.06 | 0.27 | 696 | 884 |
| Indoor & Outdoor Lighting | 63,172 | 0.87 | 0.03 | 0.18 | 57,044 | 69,884 |
| Realization Rates (ex post/ex ante) | | | | | | |
| Indoor Lighting | 1.19 | NA | NA | NA | 1.39 | 1.71 |
| Outdoor Lighting | 6.31 | NA | NA | NA | 7.53 | 9.56 |
| Indoor & Outdoor Lighting | 1.20 | NA | NA | NA | 1.41 | 1.73 |

These results illustrate the following key points about the net commercial lighting demand impact results:

- The net ex post energy impacts exceed the net ex ante design estimates 73 percent for demand. Like the energy estimates, a significant factor in the high ex post NTG ratio is nonparticipant spillover, which increased the NTG ratio by 18 percentage points.
- These high savings estimates reflect not only the high NTG ratios, but the conservative ex ante design estimates. The high operating factors that the evaluation identified in the commercial sector, and the inclusion of the HVAC savings in the ex post evaluation impacts, contributed to the high net demand savings.
- The high realization rates for outdoor lighting demand are a result of the on-site inspections identifying outdoor lighting that was operating during the day, and thus

on-peak. The ex ante projections assumed very little outdoor fixture on-peak operation, and thus claimed very small on-peak impact. This resulted in division of the small impact found during the evaluation by a very much smaller ex ante value, yielding high realization rates.

Detailed presentation and discussion of this data can be found in *Section 4*.

1.2 Major Findings

The key findings are best summarized as follows:

- Overall, PG&E's ex ante estimates for the commercial lighting technologies paid under the 1994 programs were conservative, resulting in net realization rates exceeding one.
- For many of the business types and technologies, hours of operation and operating factors exceeded the ex ante estimated values by a significant margin. This was the main factor contributing to many high gross realization rates.
- High NTG ratios combined with low program design NTG estimates to significantly increase net realized savings. This finding resulted from relatively low free ridership rates, in conjunction with significant participant and nonparticipant spillover.
- The high participation technologies of T8/electronic ballast, optical reflectors with delamping, and HID replacement of less efficient technologies yielded strong realized savings.

1.3 Major Recommendations

Trade on Established Information in Future Evaluations - This evaluation developed extensive observed and measured operating factor and operating hours information on the highest participation segments. There is no reason to believe that the operating factor and operating hours information developed in this evaluation will change significantly from year to year. QC recommends that PG&E develop an understanding with the California Public Utilities Commission (CPUC) on the validity and use of this information in subsequent evaluations, thus minimizing the need to replicate operating hours and operating factor data for sectors where this information is unlikely to change. This will allow PG&E and the CPUC to maximize return on money invested in future evaluations, resulting in better estimates for sectors that have yet to be definitively documented.

Other detailed recommendations concerning measures offered and the CPUC Protocols are covered in detail in *Section 5*.

Section 2

INTRODUCTION

This report covers the impact evaluation of the commercial lighting technologies offered under the Pacific Gas & Electric Company (PG&E) 1994 Nonresidential Retrofit Programs. These technologies are covered by two separate program options, the Retrofit Express (RE) Program and the Customized Incentive (Customized) Program. These programs are summarized below.

2.1 The Retrofit Express Program

The RE program offered fixed rebates to customers who installed specific gas or electric energy-efficiency equipment in their facilities. The program covered the most common energy saving measures, and spans lighting, air-conditioning, refrigeration, motors, agricultural applications, and food service. Customers were required to submit proof of purchase with these applications, in order to receive rebates. The program was marketed primarily to small- and medium-sized commercial, industrial, and agricultural customers. The maximum rebate amount, including all measure types, was \$300,000 per account. No minimum amount was required to qualify for a rebate.

In the lighting end use , the program offered rebates on the following technologies:

- Halogen lamps replacing existing lamps
- Compact fluorescent lamps replacing incandescent lamps
- Compact fluorescent and LED lamps replacing incandescent lamps in exit signs
- Electronic ballasts replacing electromagnetic ballasts
- T8 lamps and electronic ballasts replacing T12 lamps and electromagnetic ballasts in various lengths and configurations
- High-intensity discharge (HID) fixtures replacing incandescent or mercury vapor fixtures
- Installation of occupancy sensors, bypass or delay timers, photocells, and time clock controls for lighting applications

2.2 The Customized Incentives Program

The Customized program offered financial incentives to customers who undertook large or complex projects that save gas or electricity. These customers were required to submit calculations for projected first-year energy savings with their applications and prior to installation of the project. The maximum incentive amount for the Customized program was \$500,000 per account, and minimum qualifying incentive was \$2,500 per project. The total incentive payment for kW, kWh, and therm savings was limited to 50% of direct project cost for retrofit of existing systems. Since the program also applied to expansion projects, the new systems incentive was limited to 100% of the incremental cost to make new processes or added systems energy efficient. Customers were paid 4 cents per kWh, and 20 cents per therm for first-year annual energy savings. A \$200 per peak kW incentive, and a \$50 per peak kW early completion (October 31, 1994) bonus for peak demand savings required that savings be achieved during the hours PG&E experiences high power demand.

As a result of program design, many of the measures installed were similar to or the same as those for the RE program, but were installed in larger and more complex projects.

2.3 Evaluation Overview

The impact evaluation described in this report covers all lighting measures installed at commercial accounts, as determined by the program participant database—Management Decision Support System (MDSS)—sector code, which were included under the RE and Customized programs, and for which rebates were paid during calendar year 1994.

The impact evaluation results in both gross and net impacts, and compares these estimates to the program earnings claims¹.

2.3.1 Objectives

The objectives of the evaluation were originally stated in the Request for Proposals (RFP), refined during the project initiation meeting, and documented in the evaluation research plan. These research objectives are as follows:

- Determine first-year gross energy and demand impacts for RE and Customized lighting technologies paid in 1994, by technology and business type, and overall impacts for the commercial sector

¹ PG&E Annual Summary Report on DSM Programs in 1994 and 1995.

- Investigate and explain differences between evaluation and program design estimates
- Assess free ridership rates, and investigate and explain differences between evaluation and program design estimates
- Assess spillover rates, and investigate and explain differences between evaluation and program design estimates
- Provide recommendations to strengthen the realized impact of the RE program
- Create a panel of participants for future monitoring of equipment retention in the commercial sector

This report covers the methodology and the gross and net impacts for the sector, divided into indoor and outdoor lighting effects.

Results are segmented by technology and building type. Technologies are defined by measures offered by the RE and Customized programs. Building segments for the commercial market sector, as defined by PG&E, are office, retail, college and university, schools, grocery, restaurant, health care, hotel/motel, and warehouse.

The difference between gross and net impacts is the behavior that affected customers' participation. Adjustments were made to the gross estimate of savings for customers that would have installed energy-efficient measures anyway, despite the program (free riders), and customers that installed energy efficient measures as a result of the presence of the program, resulting in savings that were beyond the program-related gross savings of the participants (spillover).

The evaluation investigated and, where possible, explains differences between program design estimates and evaluation results. This analysis resulted in recommendations for improving program design estimates (ex ante), which should, in turn, result in post-implementation evaluation savings (ex post) that are closer to ex ante estimated savings.

2.3.2 Timing

The 1994 Commercial Lighting Impact Evaluation began in December 1994, completed the planning stage in March 1995, executed data collection between late May and October 1995, and completed the analysis and reporting phase in January and February 1996. Analysis is based upon the post-installation period from September 1994 through September 1995. The pre-installation period varied depending upon the installation date, but ranges between October 1991 and September 1993.

2.3.3 Role of Protocols

This evaluation was conducted under the rules specified in the “Protocols and Procedures for the Verification of Cost, Benefits, and Shareholder Earnings from Demand Side Management Programs” (the Protocols), as adopted by California Public Utility Commission (CPUC) Decision 93-05-063, Revised January 1995 Pursuant to Decisions 94-10-063, 94-10-059, and 94-12-021. To the extent it was possible during an ongoing evaluation, many of the changes included in CPUC Decision 95-12-054² were incorporated into the evaluation.

The Protocols control most aspects of the evaluation. They specify the minimum sample sizes, the required precision, data collection techniques, certain minimum analysis approaches, and formats for documenting and reporting results to the CPUC. This evaluation has endeavored to meet all Protocol requirements, and where possible, enhance evaluation techniques or results to supply added value to the developed estimates.

2.4 Report Layout

This report presents the results of the above evaluation. It is divided into five sections, plus appendices. *Sections 1 and 2* are the *Executive Summary* and the *Introduction*. *Section 3* presents the *Methodology* of the evaluation. It is supported in detail by *Appendices A, B, C, and J*. *Section 4* presents detailed results and discussion and is supported by *Appendices K and L*. *Section 5* discusses and presents recommendations for improving the evaluation, the program measures, the program tracking, and the CPUC Protocols. The remainder of the appendices document the data collection efforts undertaken during the evaluation.

² California Public Utilities Commission Decision 93-05-063, Revised January 1995 Pursuant to Decisions 94-05-063, 94-10-059, 9412-021, and 95-12-054.

Section 3

METHODOLOGY

This methodology section begins with an overview of the evaluation approach. This is followed by a more detailed discussion of the specific engineering, billing regression, and net-to-gross (NTG) analysis approaches used in the evaluation. Additional detail on these three approaches is supplied in *Appendices B, C and J*, respectively.

3.1 Integrated Evaluation Approach

This overview of the integrated evaluation approach begins by presenting the data sources and sample design approach used for the evaluation of the 1994 Pacific Gas and Electric Company (PG&E) Commercial Lighting Technologies Evaluation. It is followed by an overview of how the engineering, billing, and NTG estimates are used together to derive the gross and net energy and demand impacts.

3.1.1 Existing Data

The PG&E Commercial Lighting Evaluation approach used all the data currently available, in particular PG&E's historical billing data, program participation data, or the Management Decision Support System (MDSS), paper copies of Retrofit Express (RE) and Customized Incentive (Customized) applications, other program-related data, and industry standards information.

- **Program Participant Tracking System** - The participant tracking system data, maintained in the PG&E MDSS, contains program project information, and technical information about measure installation. It also provides expected impact estimates based upon the ex ante engineering algorithms. This information is used to create sample designs for data collection and to leverage calibrated impact estimates from the telephone sample to the entire participant population.
- **Program Marketing Data** - PG&E program marketing data contain detailed descriptions of program marketing and application procedures, together with details on the measures offered. This data source also provides a general description of measures accepted by the program.
- **PG&E Billing Data** - The PG&E nonresidential billing database contains monthly energy-consumption information for all commercial customers in PG&E's service

territory. It also contains demographic data for all customers, and the on-peak and off-peak monthly energy usage for customers who receive services on demand or time-of-use (TOU) rates. This information is used to calibrate the engineering estimates to actual pre- and post-installation energy usage.

- **Annual Summary Report on Demand Side Management Programs in 1994 and 1995¹ (Forecast Filing)** - This report documents the ex ante earnings claims, including specific information on the derivation of per-unit ex ante savings estimates and the assumptions that go into those estimates. This documentation often includes assumptions such as operating hours and operating factors, by fixture type. This document supplies the best information available on ex ante estimates and assumptions, thus facilitating knowledge-based comparisons to ex post estimates.
- **Industry Standards/Information** - In order to establish baseline levels and new equipment performance levels, industry standards information from organizations such as the American Society of Heating, Refrigeration and Air-conditioning Engineers (ASHRAE) and American National Standards Institute (ANSI) was used, together with information from manufacturers.
- **Copies of RE and Customized Paper Application Files** - QC requested and received complete copies of application files for a random 100 RE participants and all Customized participants. The RE files were used to verify the entries in the MDSS electronic files and to identify additional information that could be extracted from the file to improve the analysis. The Customized files were used to classify these participants into categories similar to the RE program, where possible, thus allowing maximum use of the statistical billing regression analysis.

3.1.2 Evaluation Surveys and Metered Data


For lighting in the RE and Customized programs, the impact analysis plan is based upon a nested sample design, with a core of lighting logged sites supplying calibration for the on-site sample, and the on-site audit sample being leveraged with a larger, less expensive, telephone survey. Data between these samples are leveraged through “overlapping items” between the telephone and on-site instruments. The MDSS database program application information is used to leverage results to the entire participant population. This approach, as shown in Exhibit 3-1, results in the efficient use of all information to contribute to the final impact results².

¹ Advice Filing 1800-G-A/1446-E-A.

² For a detailed description of the allocation of each of these sample types by technology and building type refer to Appendix A, pages A-1-A-18.

- The lighting logger data (represented by the innermost circle in Exhibit 3-1) supply the most accurate source of data for calibration of the engineering estimates. This metering, which uses lighting loggers, registers the time and date the monitored fixture is turned on or off, for periods up to two months in length. This information allows calibration of self-reported operating schedules collected during the telephone survey. In addition, it supplies operating information related to hours when facilities are closed, which cannot be collected during the on-site audit. When the lighting loggers are placed, one-time fixture operating wattage measurements (spot watt) are taken to confirm power consumption estimates of the operating fixtures. Loggers were placed in 92 commercial sites with an average of 2.60 loggers per site. Loggers were placed in every participant site where on-site inspections were completed and it was practical to place loggers and obtain reliable data.
- A relatively small on-site auditing sample (represented by the band around the innermost circle in Exhibit 3-1), is designed to support the telephone sample for the largest participation segments. This sample contributes equipment details that are site-specific, and better estimates of operating hours, operating factors, equipment efficiency, lamp burn-out rates, missed opportunities, and other technical factors that are difficult to collect over the telephone. The on-site sample itself is not designed to be statistically representative, but rather to support the estimate of detailed engineering parameters collected within the highest projected impact.
- A significantly larger telephone survey sample (represented in Exhibit 3-1 by the second band from the center), is designed to be representative of the participant population in terms of technology and business type. The telephone survey supplies information on participant decision-making, energy-related changes at each site for the billing period covered by the billing analysis, and data for estimating the NTG adjustments. The comparison group telephone surveys supply information on trends in baseline equipment changes, including lighting retrofits outside the program, changes in square footage, and other trends.
- The participant population (represented by the outermost circle in Exhibit 3-1), is based upon information in the MDSS, and provides information needed to generalize estimated per-unit impact estimates for the telephone-surveyed sample to the entire population of program participants. Using the population to leverage impact estimates corrects for potential bias in the sample selection process, especially in terms of the actual distribution of installed measures.


Exhibit 3-1
Nested Sample Design Approach



3.1.3 Demand Estimates

Demand estimates for the 1994 Commercial Lighting Evaluation are based upon engineering models calibrated to on-site data, metered data, and industry standards. As illustrated in Exhibit 3-2, the demand estimate method contains the following elements:

Exhibit 3-2
Method for Estimating Demand Impacts




- The program application and design data are used to create the data collection plan, which guides the data collection efforts of the evaluation (*Appendix A*, pages A1-A18).
- Post-Installation data collection efforts are targeted in a manner to produce the most efficient estimates.
 - The sample design begins with the development of participation matrices that indicate the larger and, therefore, more important segments.
 - Operating factors derived from lighting logger data and weekday operating factors, collected based upon the number of lamps operating at the time of each on-site audit, are inputs to the engineering calibration. In addition, data collected from the comparison group on-site audit sample, including burned-out lamp rates and existing equipment saturation, are used to calibrate engineering savings estimates (*Appendix B*, page 12).
 - Smaller impact segments do not justify the collection of independent samples of primary data. For these segments, estimates are transferred from a similar segment, or industry standard test results—reported by the manufacturer—are used.
- Estimates of gross demand impacts are the product of the engineering analysis by technology and segment. These impact estimates are based upon the assumption that single fixtures operate according to observed operating factors for installed equipment and each building schedule.
- Program impacts are estimated by combining per-unit demand with the number of units installed, according to the participation matrices, to form the evaluation demand estimates for each segment. These results yield the estimated gross peak-demand impact for the program. They are presented as first-year impacts, accounting for the short-term effect of relamping burned-out lamps.
- The NTG adjustments for behavioral effects of participants and nonparticipants account for free riders (participants who would have adopted similar program measures anyway), and spillover (reductions in energy consumption or demand caused by the presence of the program) (*Appendix J*).

3.1.4 Energy Estimates

The energy impact estimates for the 1994 Commercial Lighting Evaluation are derived using engineering methods and statistically adjusted engineering (SAE) estimates. As illustrated in Exhibit 3-3, the energy impact method is comprised of the following elements:

- The post-installation inspection data supply crucial lighting logger and spot kW data used to develop segment operating hours and operating factors, which are used with the participation data to create engineering estimates.

Exhibit 3-3
Method for Estimating Energy Impacts



- The per-unit engineering estimates are derived by analyzing the change in fixture connected loads in conjunction with customer operating schedules and fixture operating factors. Lighting logger data, instantaneous post-installation demand measurements, and on-site audit data are used to calibrate the engineering estimates. Additional data collected during comparison group on-site audits concerning burned-out/nonoperating lamps and operating factors (percentage of lights operating at any time) are used to adjust the engineering per-unit savings estimates (*Appendix B*, pages B-25 through B-31).
- The per-unit engineering energy impacts are developed for each program segment. These represent savings that will be achieved, assuming that single fixtures operate according to observed on-site operating factors and calibrated operating schedules established during evaluation data collection.
 - The per-unit engineering energy impacts, combined with the units installed, form the input to the billing regression analysis for segments with sufficient participation (high-participation segments in Exhibit 3-3), or SAE analysis. In the SAE analysis, the engineering estimates are compared to billing data using regression analyses, in order to adjust for behavioral factors of occupants and other unaccounted for effects. The output for these segments are SAE estimates of savings.
 - For segments with participation levels too small to support statistical analysis (low-participation segments in Exhibit 3-3), the calibrated engineering estimates are used as the evaluation estimate. These results are presented as first-year impacts, accounting for the short-term effect of relamping burned-out lamps. Calibrated engineering estimates were used in outdoor lighting estimates and the other (miscellaneous) measures because regression analysis could not identify a statistically significant effect.
 - The two sets of results described above are combined to represent the evaluation estimate of program savings.
- Two approaches are used to calculate program net effects. One approach attempts to measure net effects directly in the SAE analysis, while the second approach models customers' decisions in the lighting market. The NTG adjustments compensate for free riders (participants who would have adopted similar program measures anyway), and spillover (reductions in energy consumption or demand caused by the presence of the program).

3.2 Engineering Analysis


The engineering analysis combines information from telephone surveys with detailed on-site audit data to supply reliable engineering estimates. These estimates are used as “proxies” for actual building energy consumption, verified using statistical analysis. The primary value of good engineering proxies is that they reduce the standard error of billing regression estimates. Exhibit 3-4 provides an overview of the entire engineering estimation process.

Exhibit 3-4 illustrates the following features of the integrated impact analysis:

- Lighting logger data are used to:
 - Calibrate self reported building operating schedules
 - Determine whether buildings are operating at the peak hour
 - Estimate operating factors for “off” and weekend periods, since direct count information is not available from on-site audits
- On-site data and telephone surveys allow calibration of initial engineering estimates of savings by adjusting post-kW, operating hours, and operating factors to reflect actual operation for the surveyed sample.
- Calibrated per-unit engineering estimates are used in conjunction with the number of fixtures installed from the program application to estimate the impact for each site included in the telephone survey sample.
- Finally, engineering estimates either serve as input to the statistical models or as final results from the calibrated models.

The details of all of the above steps are described in *Appendix B, Engineering Detailed Computational Methods*.

Exhibit 3-4
Derivation of Engineering Estimates for Use in Billing Regression Analysis



3.2.1 Engineering Demand Model³

The data described earlier are used to develop the inputs to the "load decomposition" demand impact algorithm presented in Exhibit 3-5. The strength of this model is that the key factors affecting gross demand impacts—impacts for operating hours, operating factor, HVAC adjustment factor, and diversity factor—are estimated separately, then combined to estimate overall demand impacts for each action taken by each program participant. This allows clear identification of factors controlling differences in consumption between segments, or between program design and evaluation estimates.

Exhibit 3-5
Engineering Estimates of Gross Demand Impacts

| | | |
|----------------|---|--|
| $kW_{sav,j}$ | = | $(\Delta UOL_j * U * OF_p * 0.001) + AC_{sav}$ |
| where | | |
| $kW_{sav,j}$ | = | Peak demand savings for action "j" (kW) |
| ΔUOL_j | = | Estimated per-unit gross demand impact for action j |
| U | = | Number of units installed |
| OF_p | = | Operating at time of system peak, which is $[(OF_o * DF) + ((OF_c * (1-DF)))]$ |
| AC_{sav} | = | Air conditioning savings at time of system peak resulting from lighting reduction |
| OF_o | = | Operating factor when the facility is open |
| OF_c | = | Operating factor when the facility is closed |
| DF | = | Diversity factor at time of system peak |

Each of the parameters listed in Exhibit 3-5 are developed as follows:

- The change in Unit Operating Load (ΔUOL_j) is derived by calibrating manufacturers' data with pre- and post-installation spot kW data collected during on-site audits. These data, collected by technology type, are gathered in fixture groups large enough to minimize measurement error. Differences between various

³ The energy and demand engineering models are discussed in more detail in Appendix B, pages B-1-B-25.

manufacturers of ballasts and lamps are averaged to develop measure-specific UOLs.

- The number of units (U) of each measure type installed is verified during the post-installation on-site audit. The on-site audits also include random inspections of fixtures to confirm that newly-installed ballasts meet program specifications.
- The facility open operating factor (OF_o) is derived from lamp counts and questions asked during on-site audits. It compensates for partial operation of retrofitted lighting at sites when the facility is open. The OF, which measures the percentage of lamps operating, should not be confused with the diversity factor discussed below, which compensates for whether a site is operating at peak.
- The facility closed operating factor (OF_c) is derived from logger data, representing the percentage of fixtures operating during the hours that a facility is closed.
- Air-conditioning savings (AC_{sav}) are the credit for reduced heat load resulting from the installation of more efficient lighting. Cooling credits and heating debits are computed using an approach that compensates for changes in lighting load based upon local heating and cooling degree days.⁴ Note that heating is not an issue in estimating peak demand impacts, since PG&E's peak occurs during the summer.
- The diversity factor (DF) is the percentage of participants in any one segment operating at the time of system peak. This factor compensates for non-operating facilities at the time of system peak.

The engineering model for energy, which is based upon the same decomposition of load concept, is described below. The approach that is described in this next section illustrates a generalized approach to estimating annual lighting impacts. Actual energy impacts were generated in a fashion that is related more closely to the approach described above for demand impacts: on an hourly basis, for all hours in a year.

3.2.2 Engineering Energy Model

The model used to calculate annual energy impacts is similar to the demand impact model presented in Exhibit 3-5, except that operating factors and operating hours are incorporated for each distinct operating period. Additionally, an adjustment is made for heating usage and cooling usage. The model used, and definitions of each element of the equation, are presented in Exhibit 3-6.

⁴ Robert A Rundquist, Karl Johnson, and Donald Aumann. "Calculating Lighting and HVAC Interactions," *ASHRAE Journal*, November 1993.

Exhibit 3-6
Engineering Estimates of Gross Energy Impacts

| | | |
|----------------|---|--|
| $kWh_{sav,j}$ | = | $\Delta UOL_j * U * \{(OFWK_i * YWKHO_j) + (OFWE_i * YWEHO_j) + (OFBN_i * YBNO_j)\} * 0.001 + AC_{sav} - Heat_{pen}$ |
| where | | |
| $kWh_{sav,j}$ | = | Annual energy impact for action "j" (kWh/yr.) |
| ΔUOL_j | = | Estimated per-unit gross demand impact for action j |
| U | = | Number of units installed |
| $OFWK_i$ | = | Annual weekday operating factor for segment i |
| $YWKHO_j$ | = | Annual weekday operating hours |
| $OFWE_i$ | = | Annual weekends (Saturday and Sunday separately) operating factor for segment i |
| $YWEHO_j$ | = | Annual weekends (Saturday and Sunday separately) operating hours |
| $OFBN_i$ | = | Annual operating factor for segment i when building is closed |
| $YBNO_j$ | = | Annual hours when building is closed |
| AC_{sav} | = | Air conditioning savings resulting from lighting impacts |
| $Heat_{pen}$ | = | Heating penalty resulting from lighting impacts |

Each of the parameters listed in Exhibit 3-6 are developed as follows:

- The change in Unit Operating Load (ΔUOL_j) and the number of units (U) of each measure type installed are the same as those used in the demand model (Exhibit 3-5).
- Operating factors (percentage of retrofitted lighting units operating during a specified time - OFWK, OFWE, OFBN) are derived from lamp counts, lighting logger records, and questions asked during on-site audits and telephone surveys. They compensate for partial operation of the retrofitted lighting.

- Annual operating hours for each period (YWKHO for weekdays, YWEHO for weekends, and YBNO for all building closed periods) are developed from a combination of lighting logger measurements conducted during the post-installation period, and interview questions that address seasonal variations in retrofitted lighting usage.
- Cooling credits are computed using an approach that compensates for changes in HVAC load based upon both the lighting only impacts and local heating and cooling degree days.
- The heating penalty from energy-efficient lighting installation was estimated for those customers that heat with electricity. Using the ASHRAE method⁵, the heating penalty for customers with electric resistance space heat is less than 5% of the lighting impact for any customer in PG&E's service territory.

3.2.3 RE and Customized Measure Segmentation

Measures are grouped in order to develop segments representing common technologies. This approach, while establishing estimates at the measure level, maximizes leveraging of data in the statistical analysis. The comparisons made at the individual measure level are listed in Exhibit 3-7.

Since lighting technologies are generally the same in both the RE and Customized programs, the most common technology groupings can be used as common categories for both programs. For the Customized program, a thorough review of the paper files was performed in order to confirm technology types, or reassign the allocation of measures to categories that matched the RE segmentation. During this review, many of the controlling engineering parameters were extracted from the applications and entered into an electronic dataset to facilitate analysis. Exhibit 3-7 illustrates the overlap of technology categories for the RE and Customized programs.⁶

When the measure code was received from PG&E, many of the measures with clearly defined action codes were allocated to the "Lighting Other" category, so that this category represented 35% of the total population. To facilitate evaluation, QC reallocated these measures to an appropriate technology group category. As a result, The "Lighting Other" category represents only about 5% of total participation in the Customized program.

⁵Ibid.

⁶ The "PG&E Measure Code" used to define measures for both programs is also known as the "Action Code" in the MDSS system.

Exhibit 3-7
Comparison of Segmentation by Technology

| RE Program | | Customized Program | |
|---|-------------------|--|-------------------|
| Technology Segment Descriptions | PG&E Measure Code | Technology Segment Descriptions | PG&E Measure Code |
| Halogen | | Halogen | |
| All wattages | L1 | Low Voltage Halogen | 182 |
| < 45 watts | L60 | Halogen Lamp Conversion | 156 |
| > 50 watts | L61 | | |
| Compact Fluorescent Lamps | | Compact Fluorescent Lamps | 102 |
| Screw In CF | | | |
| All wattages | L2, L56 | | |
| 5-13 watts | L62 | | |
| 14-26 watts | L63 | | |
| Screw In CF- Reusable ballast | | | |
| All wattages | L3, L58, L59 | | |
| 5-13 watts | L64 | | |
| 14-26 watts | L65 | | |
| Hard Wired CF | | | |
| All wattages | L4 | | |
| 5-13 watts | L66 | | |
| 14-26 watts | L67 | | |
| 27-50 watts | L68 | | |
| Incandescent to Fluorescent Fixture | | Incandescent to Fluorescent Fixture | |
| With Energy Saving Ballast & T12 Lamps | L7 | Incandescent to Fluorescent - Indoor | 101 |
| With Electronic Ballast & T8 Lamps | L8 | Incandescent to Fluorescent - Outdoor | 120 |
| Exit Signs | | Exit Signs | 155 |
| Incand. to Compact Fluorescents | L5 | Incand. to LED | 155 |
| Incand. to LED or Electroluminescent Retrofit | L6 | | |
| Efficient Ballasts Changeouts | | Efficient Ballasts Changeouts | |
| Electronic Ballasts | | Modified Electromagnetic Ballasts | |
| 2 Lamp Electronic Ballast | L14 | Hybrid Ballasts | 147 |
| 3 Lamp Electronic Ballast | L15 | Primum Ballast (Core & Coil) | 148 |
| 4 Lamp Electronic Ballast | L16 | Electronic Ballasts | 149 |
| T8 Lamps and Electronic Ballasts | | T8 Lamps and Electronic Ballasts | |
| New Fixtures | | | |
| One-Lamp Fixture | L9, L117, L121 | | |
| Two-Lamp Fixture | L10, L118, L122 | | |
| Three-Lamp Fixture | L11, L123 | | |
| Four-Lamp Fixture | L12, L120, L124 | | |
| 2'-1 U Tube or 2 lamps | L69 | | |
| 2'-2 U Tubes or 4 lamps | L70 | | |
| 2'-3 U Tubes or 6 lamps | L71 | | |
| 4'-1 lamp | L72 | | |
| 4'-2 lamps | L73 | | |
| 4'-3 lamps | L74 | | |
| 4'-4 lamps or 8'-2 lamps | L75 | | |
| Fixture Modif.- Replace Lamps and Ballasts | | Fixture Modif.- Replace Lamps and Ballasts | |
| Replace Lamps & Ballasts - 2' Fixture | L21 | Replace Lamps & Ballasts - 2' Fixture | 146 |
| Replace Lamps & Ballasts - 3' Fixture | L22 | | |
| Replace Lamps & Ballasts - 4' Fixture | L23 | | |
| Replace Lamps & Ballasts - 8' Fixture | L24 | | |
| Delamp Fluorescent Fixtures | | Delamp Fluorescent Fixtures | |
| Fixture Modif.- Delamp and Reflector | | Fixture Modif.- Delamp and Reflector | |
| Removal - 2' Lamps & Ballasts | L17 | 1-F96T12 (60W) w/EE Magnetic Ballast | 181 |
| Removal - 3' Lamps | L18 | Remove Lamps Reduce Lights | 150 |
| Removal - 4' Lamps | L19 | | |
| Removal - 8' Lamps | L20 | | |
| High Output T8 & T10 Conversion w/ Delamp | | | |
| T10 & Energy Saving Ballast | L76 | | |
| T10 or T8 & Electronic Ballast | L77 | | |
| High Intensity Discharge | | High Intensity Discharge | |
| Interior Compact HPS from Incand. | | Metal Halide Fixtures - Interior | 104 |
| 0-100 watts HPS | L25 | HPS/LPS - Exterior | 123 |
| 0-35 watts HPS | L78 | | |
| 36-70 watts HPS | L79 | | |
| 71-100 watts HPS | L80 | | |
| Interior Standard MH from Merc. Vapor | | | |
| 101-175 watts MH | L26 | | |
| 176-250 watts MH | L27, L37 | | |
| 251-400 watts MH | L81 | | |
| Exterior HPS from Merc. Vapor | | | |
| 0-100 watts | L28 | | |
| 101-175 watts | L29 | | |
| 176 watts & greater | L30 | | |
| Reduced Wattage Lighting | | Reduced Wattage Lighting | |
| T8 (32 watt) Fluorescent Lamp | L13 | 4' Energy Saver Fluorescent Lamps | 142 |
| | | 8' Energy Saver Fluorescent Lamps | 143 |
| | | T8 Fluorescent Lamps | 144 |
| | | Lower Wattage Incandescent Lamps | 152 |
| | | Current Limiters | 153 |
| Controls | | Controls | |
| Time Clocks | L31 | Lighting Controls | 160 |
| Occupancy Sensors | | Lighting EMS | 164 |
| 72-350 watts controlled | L32 | Motion/Occupancy Sensors | 166 |
| 351-1000 watts controlled | L33 | Photocell | 168 |
| 1000 watts and greater controlled | L34 | Bypass/Delay | 169 |
| Wall Mounted | L82 | | |
| Ceiling Mounted | L83 | | |
| Bypass/Delay | L35 | | |
| Photocell | L36 | | |
| | | Lighting Other | |
| | | Daylighting | 191 |
| | | Optical Reflectors | 193 |
| | | Lighting Other | 199 |

As part of the process of matching the action and measure codes, and of understanding the original calculations so that differences between the final evaluation results and the ex ante estimates could be explained, QC performed a review of the ex ante estimates and the parameters that went into them. *Appendix L* summarizes the distribution of NTG ratios that were applied, by technology and building type. These factors, plus the detailed understanding of the ex ante algorithms, allowed the clear identification of reasons for ex post differences, which are presented in *Section 4* of this report.

3.2.4 Engineering Connected Load Estimates

The basis of both engineering estimates and program design estimates is the per-unit connected load computation. In both cases, estimates are created by subtracting the estimate of “on” consumption of the average new fixture from the “on” consumption of the average original fixture. The documentation and comparison of evaluation estimates to program design estimates are the first steps to understanding reasons for differences between evaluation and program estimates.

The per-unit consumption estimates for the engineering analysis are from manufacturers' literature. Values for program design estimates were taken from the 1994 RE program estimates, as supplied with the October 1993 Forecast Filing.⁷ Manufacturers' estimates were then reviewed and noted as a way to explain differences between evaluation results and program design estimates.

3.2.5 Engineering Operating Hour and Operating Factor Estimates

One of the primary differences between evaluation engineering estimates and program estimates is that evaluation estimates are based upon program participant-specific operating hours and operating factors (the percentage of retrofitted lights operating at a specified time). Program design estimates, because they are created before the program is conducted, are based upon expectations or standards for typical buildings, rather than the direct measurement of program participant energy use.

The source of operating hours assumptions for the program design estimates is an Operating Hours Study conducted in 1992 by HBRS. The operating hours are calculated as full load operating hours, thus defining an “on” operating factor of 1.0. The peak load diversity factor came from the October 1993 Forecast Filing referenced above. The value of 0.67 is based upon an analysis of 50 end-use metered points, according to a study that was performed by Regional Economic Research (RER).

⁷ *Annual Summary Report on Demand Side Management Programs in 1994 and 1995*, Advice Filing 1800-G-A/1446-E-A.

The sources of premise-specific operating hours for evaluation estimates are displayed in Exhibit 3-8. Nesting of the samples (lighting logger data within on-site audits, within telephone surveys) allows calibration of less expensive data collection methods to those that are more costly.

Exhibit 3-8
 Operating Hours and Operating Factors for Engineering Models
 (Sources Used to Determine Each Estimate)

| Parameter Source | | Operating Hours | Operating Factors |
|-----------------------------------|----------------|--|--|
| Program Design | Peak kW | NA | Peak Load Diversity = 0.67 |
| | kWh | Specified by Building Type from Operating Hours Study | Assumed to Be = 1.0 |
| Evaluation | | | |
| Telephone Survey | Peak kW | NA | Determined by Premise from Customer Self-Report, Calibrated to On-Site Findings |
| | kWh | Determined by Premise from Customer Self-Report, Calibrated by Audit Data and/or Run-Time Meter Data | Determined by Premise from Customer Self-Report, Calibrated to On-Site Findings |
| On-Site Audits | Peak kW | NA | Determined by Actual Count at Time of Audit and Extrapolated to Peak Hour Based upon Customer Self-Reports |
| | kWh | Determined by Premise and Schedule Zone, Calibrated to Run-Time Meter Data for Metered Sites | Determined by Actual Count at Time of Audit and Extrapolated to Remaining Operating Hours Based upon Customer Self-Reports of Use Patterns |
| Lighting Loggers | Peak kW | NA | Determined by Actual Count During On-Site Audit |
| | kWh | Determined by Run-Time Meters by Schedule Zone | Determined by Actual Count During On-Site Audit |

While lighting loggers supply information about whether the building is operating at the time of peak demand, for the peak demand estimate, the operating factor is actually estimated by extrapolation of the operating factor observed during the on-site audit, and is based upon actual lamp and fixture counts.

3.2.6 Engineering Cooling Benefit Estimates

Cooling savings resulting from reduced internal heat gains (caused by the installation of more energy-efficient lighting) are a function of the contribution of lighting internal gains to cooling load, in combination with the efficiency of the cooling system.

A modified version of the approach presented in a recent issue of the *ASHRAE Journal*⁸ was used in this analysis. Equations for the demand and energy adjustments used in this evaluation are presented in Exhibit 3-9, together with definitions of the elements that compose the estimates.

Exhibit 3-9
Estimate of Cooling Benefit

| | | |
|-----------------|---|---|
| $AC_{SAVj,kW}$ | = | $kW_{LSAV,j}/MCOP$ |
| $AC_{SAVj,kWh}$ | = | $kWh_{LSAV,j} * RCF / MCOP$ |
| Where | | |
| $AC_{SAVj,kW}$ | = | Additional kW savings attributed to reduced demand from lighting action "j" (kW) |
| $kW_{LSAV,j}$ | = | Demand savings directly attributable to action "j" (kW) |
| MCOP | = | Marginal coefficient of performance for cooling system, including auxiliaries and supply and returning fans (unitless) |
| $AC_{SAVj,kWh}$ | = | Additional savings attributed to reduced cooling load from lighting action "j" (kWh/yr) |
| $kWh_{LSAV,j}$ | = | Energy savings directly attributable to action "j" (kWh/yr) |
| RCF | = | Regional Cooling Factor—fraction of annual lighting energy that is rejected as heat and thus requires cooling. Value is dependent upon local cooling degree days, and is supplied by reference table (unitless) |

⁸ Robert A Rundquist, Karl Johnson, and Donald Aumann. "Calculating Lighting and HVAC Interactions," *ASHRAE Journal*, November 1993.

The features of the ASHRAE method are as follows:

- The cooling *demand* savings are calculated by dividing the lighting energy saved ($kW_{LSAV,j}$) by the efficiency of the HVAC system (its marginal coefficient of performance – MCOP). The computation assumes that all energy saved during the peak period results in a reduction in peak demand. This methodology has the potential to increase lighting program peak demand impacts by approximately 33 percent.
- In calculating cooling *energy* savings, the lighting energy saved ($kW_{LSAV,j}$) is first multiplied by a regional correction factor (RCF) to reflect interregional differences in the percentage of lighting energy savings that affects air-conditioning energy usage over the entire cooling season.⁹ The resulting adjusted energy savings are then divided by the MCOP to determine estimated HVAC system energy savings. Using this approach, it is estimated that, in the PG&E service area, cooling energy savings add approximately 12 percent to lighting energy savings.

The summer cooling energy savings that result from the installation of more efficient lighting fixtures is offset by a winter heating penalty caused by reduced heat contribution during the heating season.

3.2.7 Engineering Heating Penalty Estimates

The increase in winter heating energy requirements resulting from reduced internal gains (caused by the installation of energy-efficient lighting) is computed using a method similar to that used to calculate cooling benefits. In summary, the cooling credit and heating debit together should increase peak demand impacts by approximately 33 percent, and annual energy consumption by 8 to 10 percent. The heating algorithm and its elements are described in Exhibit 3-10.

⁹ In the *ASHRAE Journal* article referenced above, the regional cooling factor (RCF) is supplied in a table for selected major cities in the United States. The table reflects the number of annual cooling degree days in each region.

Exhibit 3-10
Estimate of Heating Increase Penalty
(Electric Heating Only)

| | | |
|-----------------------|---|---|
| Heat pen,j,kWh | = | (kWh _{LSAV,j} *RHF* PERIM•FRACTION)/HPCOP |
| Where | | |
| Heat pen,j,kWh | = | Additional heating energy required because of the lower heat rejection of new lights (kWh/yr) |
| kWh _{LSAV,j} | = | Energy savings directly attributable to installation of lighting measure "j" (kWh/yr) |
| RHF | = | Regional Heating Factor – fraction of annual lighting energy savings that would have been rejected as heat, thus requiring additional heating. The value is dependent upon local heating degree days, and is supplied by a reference table (unitless) |
| HPCOP | = | Efficiency of the electric heating system -- default of 1.0 for electric resistance heat or 2.0 for heat pumps (unitless) |
| PERIM•FRACTION | = | Fraction of the floor area that is within 15 feet of the perimeter wall (unitless) |

The *ASHRAE Journal* method for calculating increases in heating energy savings entails multiplying the lighting energy saved (kWh_{LSAV,j}) by a regional correction factor (RCF) for heating to reflect interregional differences in the percentage of lighting energy savings that result in increases in heating energy requirements.¹⁰ This product is then multiplied by the fraction of building floor area within 15 feet of the perimeter of the building, as this is where most heat loss occurs. Finally, the mechanical system efficiency parameter, HPCOP is applied to adjust for a conversion from building heat load to heating system energy use. In addition, three considerations are reflected in this model.

- The electric heating energy debit is smaller than the cooling credit, and is less than 1 percent of the lighting energy savings, depending upon the perimeter fraction.
- The heating *demand* savings is not addressed because PG&E is a summer peaking utility, and no heating occurs during the summer peak period.
- The heating penalty is only a factor if heating is electric.

¹⁰ As is the case for cooling, the regional heating factor is supplied in a table in the *ASHRAE Journal* article for selected major cities in the United States. The table reflects the number of annual heating degree days in each region.

3.3 Billing Regression Analysis

The billing regression analysis of PG&E's Commercial Lighting Evaluation is an integrated part of the overall gross and net impact evaluation. The key objective of the analysis is to determine the first-year program energy impacts. Statistical analysis is employed to model the differences of customers' energy usage between pre- and post-installation periods. The model is specified using actual customer billing data, and independent variables that explain changes in customers' energy usage, including engineering estimates of program participation. This SAE analysis is consistent with the requirements of the Load Impact Regression Model (LIRM) defined in the CPUC Protocols. The analysis employed in this evaluation used all of the telephone survey points, with the exception of two sites. These two points disproportionately skew the performance of the model in the direction of increasing the impact.

The results of the billing regression analysis are estimated as ratios, termed "realization rates," of realized impacts to engineering impact estimates. Realized impacts represent the fractions of the engineering estimates actually observed or detected in the statistical analysis of actual billing data. The realization rates estimated as coefficients in the SAE regression models are relative to the results of the evaluation-based engineering estimates, not the PG&E program ex ante estimates. The SAE realization rates, the estimation of which is the topic of this subsection, are then used to estimate program impacts and realization rates relative to the ex ante estimates. Program realization rates are the topic of *Section 4*.

This subsection presents the approach and findings of the billing regression analysis. It begins with a discussion of analysis periods and data sources used in the billing regression analysis, and then presents the telephone sample design and final sample allocation. Next, the regression model specification and SAE realization rate results are presented. The presentation of a final specification used to estimate net impacts directly, termed "Approach A" is presented in the next subsection, (*Section 3.4.1*) NTG analysis. The "Approach A" billing regression analysis supports the direct estimation of net program impacts as a consequence on the energy analysis. The key assumption underlying this approach is that equipment purchases outside the program represent a baseline for what would have happened in the absence of the program. Appendices A, C and K detail implementation of the specific methods described below.

3.3.1 Use of Data Sources

The billing regression analysis for the 1994 Commercial Lighting Evaluation uses data from four primary data sources: the MDSS tracking database, the billing database, the telephone survey data, and the engineering estimates of changes of usage between the pre- and post-installation periods. It also utilizes the weather data tape from PG&E's load research weather sites. A summary of the data elements used in the regression analysis are presented below, and a more detailed discussion can be found in Appendices A and C.

- **Program Participant Tracking System** - The participant tracking system for the RE and Customized programs was maintained as part of the PG&E MDSS. It contains program application, rebate, and technical information about installed measures, including measure description, quantity, rebate amount, and ex ante demand, energy, and therm saving estimates. The MDSS database is linked to the billing database and other program databases through PG&E's customer control numbers.
- **PG&E Billing Data** - For this evaluation, the PG&E billing data were obtained from two PG&E data sources. The original nonresidential billing dataset contains monthly energy usage for all nonresidential accounts in PG&E's service territory, and was used in the sample design as described in *Appendix A*. The second billing dataset, which consists only of customer accounts in the surveyed dataset, was later obtained from PG&E's Load Data Services.¹¹ Since the second billing dataset has many useful fields not included in the first dataset, a decision was made to use the second billing dataset to conduct the statistical analysis. The billing series used in the analysis is PG&E's prorated monthly usage data, a series calculated by PG&E for each calendar month, from January 1991 to September 1995.
- **Weather Data** - The hourly dry bulb temperature collected for 25 PG&E load research weather sites is used in the billing regression analysis to calculate total monthly cooling and heating degree days for each month in the analysis period. For each customer in the analysis dataset, the appropriate weather site is linked to that customer by using the PG&E-defined weather site mapped to PG&E's local office.

In addition to the data sources discussed above, another key input to the regression analysis is the telephone survey data collected as part of this evaluation effort. The sample design and final sample allocation achieved from the telephone survey are discussed below.

3.3.2 Sample Design and Segmentation

The sample design for the PG&E Commercial Lighting Evaluation was based upon analysis of 1994 program participation data and PG&E billing data. The goal of the sample design was to achieve the most efficient utilization of project resources in order to estimate the first-year gross and net impacts in a manner that met the sample size and evaluation accuracy requirements defined by the Protocols. A detailed discussion of the sample design and sampling plan is presented in *Appendix A*.

The lighting evaluation is based upon a nested sample design approach. The main feature of this approach is that it consists of four groups of customers segmented according to the type of information available. The largest customer group included all

¹¹ A preliminary analysis has concluded that the monthly usage and bill read date information in these two datasets is consistent.

of the commercial customers who received rebates for eligible lighting technologies in 1994 (the "participant population") with monthly PG&E billing data and participant tracking data. The smallest group included the logged participants with the most comprehensive information available: lighting logger data, on-site audit data, telephone survey data, participant tracking data, and billing data. A similar nested sample design was also implemented for the comparison group, with the exception that the logger data was not collected for the comparison group. The advantage of a nested sample design is that it yields overlapping samples. These are used to compute dual estimates from the engineering and statistical analysis for the same group of customers, and therefore yield robust and accurate estimates of the SAE realization rates.

The telephone survey sample was selected based upon the stratified random sampling techniques for both participant and comparison group. The objective of stratification is to improve the overall reliability of estimates by restricting the sample to reasonably homogeneous segments, while at the same time ensuring that sufficient representation of the population is preserved. The sample segmentation is developed across two dimensions: business types and technologies.

- The customer segment is defined primarily by the business types, which were determined based upon the MDSS database (for participants), and the Second Standard Industrial Classification (SIC2) code—which represents building activity—from the billing dataset (for the comparison group). Within each business type, the annual energy consumptions are used as proxies to group customers into usage bins, and sample points are selected to reflect the underlying distribution of the participant population.
- Technology segmentation is important because the use of electricity, and therefore the program impacts, varies by program measure. Therefore, by grouping together common technologies, the variation in impacts is reduced, which, in turn, results in more accurate estimates of the SAE realization rates. For example, all T12 to T8 retrofit measures are grouped together, despite the fact that some installations are new fixtures, while others are retrofits, and different measures have different levels of projected energy impacts. These factors are directly accounted for in the engineering estimates. That is, the engineering estimates account for interparticipant variation so that what is assumed is that the fraction of the expected impact is stable within a segment, rather than the level of the impact. This assumption is the basis for SAE models.

Ten business segments and 11 technology groups were defined and used in the sample design and sample allocation for the RE program. For each business and technology combination, the sample was allocated in proportion to avoided costs. The purpose of this weighting scheme is to identify which technologies and/or business types account for the greatest impact on the program's resource and shareholder values. Avoided costs, by business type and technology group, for the RE program are presented in

Exhibit A-2 of *Appendix A*. Three business types: offices, retail, and schools, account for more than 70 percent of the projected (ex ante) program-avoided costs in 1994; the office segment alone accounts for approximately 37 percent of the avoided costs.

Given the low participation in the Customized program (only about 120 participants in 1994), all hard copy application forms were reviewed and a census was attempted for all eligible participants. The Customized program total avoided costs account for approximately 6 percent of the total commercial sector.

3.3.3 Selection of Participant and Comparison Group

Participants in the lighting program are defined as those PG&E commercial customers who received rebates from PG&E in the 1994 calendar year for installing at least one lighting measure under the rebate programs.

The comparison group for this study is defined as PG&E commercial customers who did not receive rebates for lighting technologies in the 1994 calendar year under the nonresidential rebate programs, and who share many characteristics with the commercial sector participant group in terms of annual usage and business type distribution. Customers who were program participants in prior years are eligible for the comparison group. In order to avoid over surveying of PG&E's commercial customer base (i.e., calling the same customer twice for similar information), comparison group samples were coordinated with the HVAC end use evaluation effort.

The sampling unit for both participant and comparison groups was defined as customer premise. A premise is defined as all billing accounts that correspond to the same location and customer. The final participant sample frame consists of 1,675 premises drawn from the eligible population of 6,037 lighting program participants who were paid in 1994 from both the RE and Customized programs.

The comparison group sample frame consists of 4,039 customers drawn from the eligible population of 26,435 commercial customers that satisfied all of the screening criteria used in construction of the sample frame. In drawing the sample frame, targets are established for each business type and usage segment, so that the sample frame distribution, by building type and usage segment, is the same as that of the participant population.

The process of reduction to the eligible sample involved the elimination of customers that had 1) moved during the period of interest; or 2) had billing records with significant missing data. Customers were further screened to identify those who had high-quality data for each month, for all three years of the analysis window.

Appendix A (pages A19-A-26) details the reduction of the eligible population to a sample frame suitable for estimating realization rates and not confounded with uncertainty in the billing series itself. None of the criteria used to screen the sample are correlated

with the SAE realization rate; therefore, the screening criteria preserve the transferability of the model results to the population. Moreover, since all the installation information pertaining to the entire participant population is used to develop the expected program impacts, this step introduces no bias in calculating unadjusted expected impacts.

3.3.4 Analysis Sample Size and Distribution

Two analysis samples of 480 participant and 458 nonparticipant commercial customers were collected for the evaluation. The data collected in the telephone survey supplies information on energy-related changes at each site for the billing period covered by the statistical billing data analysis.

As discussed earlier, this evaluation utilizes a nested sample design approach. The on-site audit sample and the lighting logger sample are collected as part of the telephone survey, with the exception of a few customers who completed an on-site audit and later declined to be telephone surveyed. The final analysis sample size of 480 commercial participant customers represents 325 customers who were surveyed only by telephone; 154 customers who were surveyed by telephone and on-site audited; and one customer who was on-site audited, but later refused to complete a telephone survey. This sample includes a total of 432 RE program indoor lighting participants; 20 Customized program indoor lighting participants; and 28 participants who installed only outdoor lighting measures under the RE or Customized programs. The final sample distribution by building type, program, and indoor/outdoor measures is presented in Exhibit 3-11.

Exhibit 3-11
Analysis Sample Distribution
By Program, End Use and Business Type

| Building Type* | Participants | | | Comparison Group | Total |
|------------------|--------------|------------|---------------|------------------|------------|
| | Indoor | | Outdoor | | |
| | RE | Customized | RE/Customized | | |
| Office | 106 | 2 | 6 | 138 | 252 |
| Retail | 105 | 3 | 14 | 104 | 226 |
| Coll/Univ | 1 | 0 | 0 | 3 | 4 |
| School | 61 | 1 | 3 | 33 | 98 |
| Grocery | 27 | 11 | 0 | 30 | 68 |
| Restaurant | 20 | 0 | 2 | 29 | 51 |
| Health Care | 33 | 0 | 1 | 20 | 54 |
| Hotel/Motel | 14 | 1 | 0 | 36 | 51 |
| Warehouse | 32 | 1 | 1 | 32 | 66 |
| Commercial Misc. | 33 | 1 | 1 | 33 | 68 |
| TOTAL | 432 | 20 | 28 | 458 | 938 |

* Defined based upon survey responses—may differ from MDSS.

In order to estimate independent realization rates at the business type and technology level, the lighting technologies were further grouped into seven categories, as shown in Exhibit 3-12. Among those technology categories, the standard-efficiency fluorescent group accounts for the largest share of impact, with approximately 65 percent of the total engineering impact estimate for energy. The second largest technology group is the interior HID and halogen group, which accounts for about 11 percent of the impacts, followed by the Customized measures (7 percent), and the compact fluorescent lamps (7 percent). The outdoor lighting measures account for approximately 5.6 percent of the total impacts.

Exhibit 3-12
Telephone Survey Sample Distribution by Technology

| Lighting Technology | Description of Technology | Sample Size * |
|--|--|----------------------|
| RE Program: Interior HID and Halogen | All Halogen Wattages, All Indoor HID Measures | 65 |
| RE Program: Compact Fluorescent Lamps | All Compact Fluorescent Measures | 175 |
| RE Program: Exit Signs | All Exit Sign Retrofit Measures | 59 |
| RE Program: Standard-Efficiency Fluorescent | Incandescent to Fluorescent Fixtures, Efficient Ballast Changeouts, T-8 Lamps and Electronic Ballasts, Delamp Fluorescent Fixtures, Reduced Wattage Lighting | 351 |
| RE Program: All Other Indoor Lighting Measures | All Controls, All Other Misc. Indoor Lighting Measures | 57 |
| Customized Program: All Indoor Measures | All CI Lighting Measures | 20 |
| Outdoor Lighting: All Outdoor RE and Customized Measures | Exterior HPS from Mercury Vapor, Outdoor Incandescent to Fluorescent, Exterior HPS/LPS | 94 |

*Sum may exceed the total sample size because there were multiple measure installations.

3.3.5 Analysis Periods

According to the Protocols, participants are defined by the “paid date” instead of the “installation date.” Most customers actually installed measures in 1993 or 1994, with 1994 installations accounting for approximately 75 percent of total installations.¹²

¹² Accurate determination of the installation dates is very difficult because information in the MDSS database is inadequate. However, a best-effort estimate was implemented based upon the analysis of the inspection dates and check issue dates from the MDSS database, in combination with customers’ self-reported installation dates.

When the billing regression analysis is used to model the change of consumption attributable to the program measures, the first step is to isolate the pre- and post-installation periods for each customer in the analysis database, so that the impact of these measures can be verified.

Two comparison periods are specified so that pre-installation data from both 1992 and 1993 can be used. Two sets of analysis periods support the joint estimation of changes relative to two years of pre-installation data using a simultaneous equation approach described later in this section. Estimation occurs in a two stage least square (2SLS) model as defined in the next section, using the following two analysis periods:

- The primary analysis periods are defined in a way that maximizes the inclusion of a majority of the sample with high-quality data. Because the installation dates cannot be determined accurately for all customers in the analysis database, the pre-installation period (October 1991 - September 1992) and a post-installation period (October 1994 - September 1995) are defined for the entire participant sample. This definition creates a window so that billing data excluded from the analysis is wide enough to ensure that all participants have the effects of program measures isolated from the pre- and post-installation periods. In this way, realization rates are not biased by errors in estimating dates of installation.
- A second analysis period is used to estimate the first stage of the 2SLS model. The first-stage model is only used to estimate customer-specific inter-year correlations, and is less sensitive to errors that may be introduced by estimation of the installation dates. The second pair of pre- and post-installation periods compares 1993 (October 1992 - September 1993) to 1995 (October 1994 - September 1995). For these customers, prorated estimates of program impacts are computed to account for when the installation likely occurred, if it is estimated that installation took place during a portion of the pre-installation period.

For a more complete discussion of these analysis periods, and the model specification, see *Appendix C, Model Specification and Results* on pages C-9-C-12.

The specification of two analysis periods allows for the analysis of pre-installation periods in a manner that, through the use of the earlier pre-installation period, minimizes measurement error in the identification of installation, and retains the information of value contributed by the more recent pre-installation period. As discussed below, these analyses periods support seasonal billing data regression models. Seasonal models produced more stable results without artificially deflating the parameter standard errors that would be induced by autocorrelated monthly observations.

3.3.6 Model Specification and Results

The billing regression analysis for the lighting program uses two different multivariate regression models under an integrated framework of providing unbiased and robust model estimates in the commercial sector. The key feature of our approach is that it employs a simultaneous equation approach to account for both the year-to-year and cross-sectional variations in a manner that consistently and efficiently isolates program impacts.

A baseline model is initially estimated using only the comparison group sample. This model estimates a relationship that is then used to forecast the post-installation-year energy consumption for both participants and the comparison group, as a function of pre-installation-year usage. In this way, baseline energy usage is forecasted for participants by assuming that their usage will change, on average, in the same way that usage did for the comparison group.

The SAE impact model used in this evaluation is specified as a two-stage ordinary least squares (2SLS) model that allows for the utilization of all billing and sample data from two pre-installation periods (as described above). The estimated SAE realization rates are used to adjust the engineering estimates of expected annual energy impacts for the entire participant population. These impacts are presented in *Section 4*, and were used to compute program realization rates.

Baseline Model - The baseline model explains post-installation energy usage as a function of the pre-installation energy usage, weather changes, and customer self-reports of factors that could affect energy usage. In order to isolate the program impact from the energy usage changes, only the comparison group is used to fit this model. The baseline model has the following functional form:

$$kWh_{post,i} = \sum_j \alpha_j + \beta kWh_{pre,i} + \gamma (\Delta CDD_i) * kWh_{pre,i} + \sum_k \eta_k Chg_{i,k} + \varepsilon$$

Where

$kWh_{post,i}$ and $kWh_{pre,i}$ are customer i 's annualized energy usage for the post- and pre-installation periods, respectively;

ΔCDD_i is the annual change of cooling degree days (base 65°F) between post-installation year and pre-installation year;

$Chg_{i,k}$ are the customer self-reported change variables from the survey data, including adding, replacing, or removing equipment associated with major end uses, changes in number of employees, and square footage;

α_j is the indicator variable (0/1) for the j th business type. It equals 1 if the customer is in that business type, and 0 otherwise;

β and γ are the estimated slopes on their respective independent variables; and,

ε is the random error term of the model

For each customer in the analysis dataset, two predicted usage values are calculated using the parameters of the baseline models estimated independently for the 1993 to 1995, and 1992 to 1995 analysis periods. They both take the same functional form, with different segment-level intercept series (α_j) and slopes (β and γ):

$$\widehat{kWh}_{post,i} = F_{pre}(kWh_{pre}) = \sum_j \alpha_j + \beta kWh_{pre,i} + \gamma(\Delta CDD_i) * kWh_{pre,i}$$

SAE Model - Using the predicted post-installation usage values estimated in the baseline models, a simultaneous equation model is specified to estimate the SAE realization rates. This approach employs a 2SLS model that incorporates billing data and engineering estimates from 1993¹³ and 1995 to fit the first (stage 1) model. The 1992 and 1995 data are used in the final (stage 2) model. The first stage contributes an estimate of customer-specific inter-year correlation that is used as an independent variable in the final model. The SAE simultaneous system can be described as follows:

$$\text{Stage 1:} \quad kWh_{95,i} - F_{93}(kWh_{93}, \Delta CDD_{93}) = \sum_m \beta_m Eng_m + \sum_k \eta_k Chg_{i,k} + \mu_{93}$$

$$\text{Stage 2:} \quad kWh_{95,i} - F_{92}(kWh_{92}, \Delta CDD_{92}) = \sum_m \beta'_m Eng_m + \sum_k \eta'_k Chg_{i,k} + \mu_{92}$$

$$\text{with} \quad \mu_{92} = \lambda \mu_{93} + \sigma$$

The last equation represents the assumption that there is correlation in usage between the two years. By including the estimated residual from the stage 1 model¹⁴ as an independent variable in the stage 2 model, the error term in the stage 2 model simplifies to a random error term σ and results in the estimation of a more accurate and stable final SAE model.

3.3.7 Billing Regression Analysis Results

This section presents the results of the billing regression analysis. *Appendix C*, pages C-12- C-14, presents a more complete discussion of the results of the regression analysis.

¹³ All years mentioned in the SAE analysis refer to a period covering the last quarter of the previous year, and the first nine months of the current year.

¹⁴ This procedure is the econometric solution to this type of simultaneous equation system.

The coefficients of the engineering impacts in the stage 2 model are the SAE realization rates. Independent realization rates are estimated to provide PG&E with results by business type and technology group. Exhibit 3-13 summarizes the final SAE model results estimated using 936 customers out of a total sample of 938 customers. Two customers—one hospital participant and one college/university nonparticipant—were excluded from the final model because they introduced great influence over the parameter estimates (toward increased impacts). In addition, these two customers have the highest annual usage among all customers in the analysis dataset. Exhibit 3-13 summarizes the independent variables used in the final stage 2 model, along with the t-statistics and sample sizes available for each parameter estimate.

Exhibit 3-13
Billing Regression Analysis Final Model
Outputs

| Parameter Description | Parameter Estimate | 90% Confident Bounds | | t-statistic | Sample Sizes |
|--|--------------------|----------------------|-------|-------------|--------------|
| | | Lower | Upper | | |
| Customer Specific Intercept from Stage 1 | 0.95 | 0.89 | 1.01 | 25.7 | 936 |
| Estimates Realization Rates | | | | | |
| RE Program Standard Fluorescence | | | | | |
| Offices | -0.94 | -1.10 | -0.78 | 10.1 | 90 |
| Retails | -0.82 | -1.14 | -0.50 | 5.2 | 84 |
| Others | -0.70 | -0.94 | -0.46 | 6.9 | 177 |
| RE Program HIDs | | | | | |
| Offices | -0.94 | -1.21 | -0.67 | 6.1 | 10 |
| Retails | -0.75 | -1.17 | -0.33 | 3.9 | 28 |
| Others | -1.60 | -1.87 | -1.33 | 6.1 | 27 |
| RE Program Compact Fluorescence | -0.62 | -1.33 | 0.09 | 2.3 | 175 |
| RE Program Other Indoor Measures | -0.40 | -2.63 | 1.83 | 0.7 | 105 |
| Customized Program Indoor Measures | -1.57 | -1.71 | -1.43 | 12.0 | 20 |
| RE/Customized Outdoor Measures | -0.54 | -1.61 | 0.53 | 1.5 | 94 |
| Change Variables (Multiplied by Pre-Usage) | | | | | |
| Add Lighting | 0.131 | -0.122 | 0.384 | 6.5 | 80 |
| Replace Lighting (Outside Program) | -0.027 | -1.124 | 1.070 | 1.5 | 38 |
| Remove Lighting | -0.171 | -1.119 | 0.777 | 1.7 | 6 |
| Replace HVAC | -0.031 | -0.689 | 0.627 | 2.5 | 60 |
| Replace Other Equipment | -0.057 | -1.142 | 1.028 | 1.5 | 52 |
| Add Employee | 0.038 | -0.819 | 0.895 | 1.9 | 103 |
| Reduce Employee | -0.053 | -0.484 | 0.378 | 3.8 | 90 |
| Installed Non-Lighting Program Measures | -0.055 | -0.534 | 0.424 | 3.4 | 18 |

| | Baseline Model | SAE Model |
|------------------------|----------------|-----------|
| Number of Observation: | 457 | 936 |
| R-squared: | 0.98 | 0.63 |

- The dependent variable is the difference between the actual and predicted 1995 usage using the 1992 baseline model.
- Customer-specific inter-year correlation is the residual term from the stage 1 model. The large t-statistics on this term suggest strong correlation between customers' usage from one year to another. Inclusion of this term contributes to a more stable model in the sense that there is very low correlation between all parameter estimates in the final model, especially the SAE realization rate parameters.

- Ten different realization rates are estimated, corresponding to business type and technology group segments. Only those measures with broad participation and relative high expected impacts can support a separate realization rate estimate. While all the realization rates have the right signs, some business types and technologies have much higher estimated impacts than others. All realization rate estimates are significant at the 95% confidence level (t-statistics greater than 2) except RE program other indoor lighting measures and RE/Customized outdoor measures, since these segments have high variation and relatively low impacts. This means that results from the billing regression analysis were used in the final evaluations results for all measures *except RE program other indoor lighting measures and RE/Customized outdoor measures. Engineering model estimates were used for these two measure categories.*
- All change variables have the expected signs. Only those change variables with a significant level greater than 0.15 are kept in the final model, through a stepwise regression procedure. Variables excluded from the model include changes in facility square footage, removal of HVAC equipment, and participation in the 1993 programs.

While QC investigated the use of TOU and load research demand data to support a similar SAE demand model, load information is not available in sufficient quantity to support such an analysis. The demand analysis conducted during this evaluation is based upon engineering models calibrated to on-site audit, spot-watt measurements, lamp counts, and lighting logger data. The spot-watt data are used to calibrate new equipment manufacturers' cut sheet data based upon actual measurements. The lamp counts are used to determine operating factors and burned-out lamp rates, pre- and post-installation. The lighting loggers are used to determine whether sites are actually operating in the "open" mode at the time of system peak. This is necessary, since many of the audits were conducted in the morning, and the lighting loggers confirmed self-reports that the facility was open or closed at the time of system peak.

3.3.8 Relative Precision Calculation

Relative precision at 90 percent and 80 percent confidence levels for the adjusted gross energy impact estimates are calculated at each of the SAE analysis segments. As mentioned above, a total of ten analysis segments were explicitly modeled, and the relative precision estimates based upon the model output are presented in Exhibit 3-14 below. In order to calculate the total program level adjusted gross impact and relative precision, the segment level results are weighted by their unadjusted engineering energy impact estimates in the following equations, and the results are presented in Exhibit 3-14.

- Analysis segment level relative precisions at the 90 percent confidence level were calculated using the following formula:

$$RP_i = (1.645 * StdErr_i) / RR_i$$

where

RP_i = the relative precision at analysis level

$StdErr_i$ = the standard error of the realization rate for each analysis level

RR_i = the realization rate for each analysis level

- From the analysis level relative precisions, the program level relative precision was determined by the following equation:

$$RP = \sqrt{\sum(PR * M_i)^2 / \sum(RR * M_i)} = 16\%$$

where

M_i = the gross impact estimate at each analysis level

Exhibit 3-14
Relative Precision Calculation

| SAE Analysis Level | Engineering Gross Impact Estimate (MWh) | SAE Realization Rate | Relative Precision at 90% | Relative Precision at 80% |
|---|---|----------------------|---------------------------|---------------------------|
| RE Program Standard Fluorescents | | | | |
| Offices | 93,822 | 94% | 16% | 13% |
| Retails | 30,756 | 82% | 32% | 25% |
| Others | 83,607 | 70% | 24% | 18% |
| RE Program HIDs | | | | |
| Offices | 8,611 | 94% | 27% | 21% |
| Retails | 10,810 | 75% | 42% | 32% |
| Others | 15,302 | 160% | 27% | 21% |
| RE Program Compact Fluorescents | 23,719 | 62% | 71% | 55% |
| RE Program Other Indoor Measures | 15,635 | 40% | 224% | 175% |
| Customized Program Indoor Measures | 22,117 | 157% | 14% | 11% |
| RE/Customized Program Outdoor Measures | 18,058 | 54% | 107% | 84% |
| TOTALS | 322,437 | 86% | 16% | 12% |

Note: Shaded rows indicate statistically insignificant results at the 90% confidence level.

The realization rates presented in Exhibit 3-14 above are the gross SAE realization rates, that is the gross realized impacts as compared to the gross *evaluation engineering estimates*. In order to compute the final gross realization rates, the gross evaluation estimates compared to the gross ex ante estimates, three steps need to occur. First, the gross evaluation engineering estimates presented in Exhibit 3-14 are multiplied by the SAE realization rates in Exhibit 3-14. Second, for the segments for which the 90 percent confidence level was not achieved (outdoor lighting and other indoor measures), the evaluation calibrated model engineering estimates of impact are to be assumed as the evaluation estimates (this is the same as assuming a realization rate of 1.0 in the previous step). When these two steps have been carried out, a total gross evaluation energy impact of 295,746 MWh is achieved (see Exhibit 4-1). Third, the evaluation estimate is divided by the gross ex ante estimate of impact (300,752 MWh total), resulting in the overall gross evaluation realization rate (gross evaluation estimates compared to the gross ex ante estimates) of 0.98. These steps are carried out by segment in *Section 4, Evaluation Results Summaries*, of this report.

3.4 Net-to-Gross Analysis

Two methods are employed to estimate program net impacts. The first method estimates net effects through an analysis of energy impacts for lighting actions conducted outside the program; this approach is termed the “net billing model.” The second method, a market analysis, involves the development of a model analyzing customer decisions in the lighting market. The market analysis models how participants first decided to purchase lighting equipment, and then, how they decided to purchase measures that correspond to those promoted by PG&E’s program.

The approach used to calculate program net effects uses self-reported responses from telephone survey data to estimate free ridership and spillover for lighting program participants, and spillover effects for nonparticipants. Results from each separate subanalysis are combined to generate NTG ratios.

First, the results from the net billing regression analysis are discussed.

3.4.1 Net Billing Regression Analysis

The net billing model produces results that support the estimates derived in the market analysis for two reasons. First, since some of the customers in the comparison group who replaced lighting outside of the program could have been free drivers, the net model produces an NTGs ratio that represents a lower bound of net impacts.¹⁵

¹⁵In fact, 22 of the 84 customers who had lighting actions outside the program were classified as free drivers in the market analysis. The net billing data model was run with and without these customers

Alternatively, the market analysis directly models spillover by analyzing reasons for equipment adoptions among both participants and nonparticipants. The confidence associated with this structural model for estimating spillover leads to a more supportable estimate of NTG. Finally, the market analysis produced results by technology group, whereas the net billing model only produced one overall estimate of NTG.

The specification of the SAE model includes a term that directly accounts for the impacts of equipment purchases made by customers in the comparison group. That is, the billing regression analysis supports the direct estimation of net program impacts as a consequence of the energy analysis. (This method has been termed “Approach A” in the work plan for this evaluation.) The key assumption underlying this approach is that equipment purchases outside the program represent a baseline for what would have happened in the absence of the program.

The specification of the net billing model includes an additional term that estimates the percentage of pre-installation usage that is saved if a customer in the comparison group implements a lighting retrofit. This parameter was estimated to be 2.7 percent based upon 38 customers (see Exhibit 3-13); and, it is interpreted as the natural savings that would have occurred in the absence of the program if participants had completed retrofits (i.e., a rate of natural conservation). Since participants saved an average of 11.7 percent of pre-installation usage,¹⁶ this translates into an NTG of $(11.7-2.7)/11.7$ or 77 percent. This parameter is measured with low precision—a t-statistic of only 1.5—which means that the 90 percent confidence interval around the 2.7 percent is from -0.7 percent to 6.1 percent, resulting in a range for the NTG ratio of 48 percent (lower) to 106 percent.

3.4.2 Free Ridership

A logistic regression model predicting free ridership was developed using self-report data in a pooled model incorporating data from all surveyed lighting program participants.¹⁷ The multivariate purchase decision model attempts to estimate the probability that a customers’ revealed choices are consistent with those of a free rider or net participant.

resulting in similar parameter estimates in both cases.

¹⁶ An average impact of 11.7 percent is calculated as the ratio between unadjusted engineering estimates and the annualized 1992 actual usage for all 480 participants in the analysis dataset.

¹⁷ Given the number of variables planned to be included in the initial models, we felt the logistic regressions would be under-powered if they were run separately for each measure group. Using a rule of thumb of 20 observations per model variable, only the T-8 group (N=144) could have supported its own logistic regression. Additionally, we believed that the behavioral model should hold for all purchase decisions, regardless of technology, since decision-making processes should be consistent across technologies.

Exhibit 3-15
Self-Reported Free Ridership: Superset of Model Variables

| Model Variable | Wording of Question | Predicted Direction | | In Final Model |
|---|---|------------------------------|---|----------------|
| | | Net Participant | Free Rider | |
| TIMING OF PLANS | | | | |
| PERIOD_BEFORE_AWARE | How long were you considering <the measure> before you heard about the program? | short-moderate period | longer period | |
| NO_PLANS | Wasn't planning on purchase until approached | yes | no | x |
| PERIOD_AFTER_AWARE | How long did you take to decide to participate after becoming aware of the program? | longer period | shorter period | x |
| WAIT_NO_PGM | How long would you have waited to <take the measure> without the program? | longer period | shorter period | x |
| WAIT_FOR_PGM | Did you delay a retrofit in order to participate? | no | yes | |
| OPTIONS | | | | |
| QUOTES | How many estimates or quotes did you obtain before purchasing your new equipment? | few | many | |
| STD_EQUIP | Did you consider purchasing standard-efficiency equipment? | yes | no | x |
| BROKEN | (Did the customer mention broken equipment?) | yes | no | |
| PROGRAM INFORMATION AND BENEFITS | | | | |
| PGE_CONTA | How many times a year do you have contact with your PG&E rep? | few | many | |
| REBATE | (Did the customer mention the rebate?) | yes | no | |
| BILL_SAVINGS | (Did the customer mention bill savings?) | yes | no | |
| FREE_RIDE | Before you knew about the program, which of the following statements best describes your company's plans to <take the measure>? | had considered, but no plans | planning to do it within the next 12 months | |

The dependent variable in the model is based upon customer-reported plans in the absence of the program. A customer is coded as a net participant if reported plans indicate that the retrofit would not have been completed in the absence of the program, or would have occurred at a later date.¹⁸

Independent variables included in the initial model are also shown, along with their predicted effects, in Exhibit 3-15. Three categories of variables are used to explain free ridership. The first category consists of variables that involve the timing of a customer's plans for completing a retrofit, and the timing of their awareness of PG&E's programs. The second category captures variables that characterize the choices customers faced in considering a retrofit. Finally, the third category describes some of the benefits provided by PG&E's program and how they relate to a customer's purchase behavior. Exhibit 3-15 lists the variables that were considered for the free rider model and indicates those variables included in its final specification.

Timing of Plans - Four questions addressing the decision-making process and the length of time spent in various decision-making stages were included in the telephone survey. A question addressing length of time spent considering various equipment options, before becoming aware of the program, `PERIOD_BEFORE_AWARE`, was included in the model. Customers spending less time researching equipment before becoming aware of the program can be distinguished from free riders who had researched and chosen products before becoming aware of the program. While risk-averse customers may also have spent considerable time considering options, net participants (as a group) should spend less time seeking information than free riders. Contractor-driven net participants were expected to have spent no time shopping for lighting equipment before becoming aware of the program (`NO_PLANS`).

A second question addressing the length of time the customer spent considering the benefits provided by the program was also included in the model (`PERIOD_AFTER_AWARE`). Free riders, because they have essentially already made up their minds, should spend a short period of time assessing the benefits provided by the program. When presented with the option to install equipment or take some other efficiency action through the program, they are eager to do so. Contractor-driven net participants may also spend a relatively short period of time reaching a decision, but taken as a whole, net participants are expected to take more time to reach a decision to participate than free riders.

¹⁸ Customers who accelerated a decision to retrofit were considered net participants.

The third decision-making question included in the model addressed the number of years a customer would have delayed the equipment retrofit had the program not existed (WAIT_NO_PROGRAM). This question is intended to differentiate decision-accelerated net participants from free riders.

A final question, WAIT_FOR_PROGRAM, was intended to serve as a flag identifying free riders based on prior purchase plans.

Options - In programs with aggressive target marketing by contractors and division representatives, participants may obtain few quotes for their prospective lighting purchases. Many customers will only obtain one quote from their initial program contact (often a lighting contractor) and then stay with one contractor. The number of quotes obtained (QUOTES) should discriminate between those customers who were driven into the program by tactical program marketing efforts versus those who were already active in the marketplace.

Customers who never considered standard-efficiency lighting measures prior to their purchase (STD_EQUIP) are likely free riders since the program was not a prime driver in their purchase of high-efficiency lighting equipment. Customers with older, failing equipment (BROKEN) may be driven into the market by the condition of their equipment, but once in the market, their equipment selection can be greatly affected by the program's contribution to the increased supply of energy-efficient lighting.

Program Information and Benefits - Customers in close contact with their division representatives have increased access to information about the benefits of participating (PGE_CONTACT). Customers in frequent communication with representatives may be "repeat" program participants whose likelihood of free ridership increases over time.

Program marketing efforts create a market for lighting retrofits and influence customer plans. Many customers indicated that they were drawn into the market by program marketing efforts. Program participants, more so than nonparticipants who also made lighting purchases, were more likely to echo program marketing messages such as a desire for bill savings (BILL_SAVINGS) or the program rebate (REBATE). These customers were drawn into the program by key program benefits, which provide the necessary motivation for customers who might not otherwise adopt program qualifying measures. These variables should be associated with decreasing likelihood of free ridership.

Details of the model-building process and final model selection appear in *Appendix J*. Pooled model results (the regression coefficients) were used to generate average free ridership rates for each technology group.

3.4.3 Spillover

The program spillover estimate contains two main components: a contribution from program participants and a contribution from nonparticipants.

Participants - Participant spillover effects were measured through simple self-report questions such as, "Since participating in the program, have you adopted any additional energy-efficiency recommendations?" Customers were asked about specific program-qualifying technologies such as T-8 lamps with electronic ballasts. Responses were tallied, and the rates of the actions in the participant population were calculated and multiplied by ex post estimates of measure savings (average percentage reductions in usage per account). These were then credited to the RE program as additional program kWh savings. This was done for each lighting technology group and the program as a whole.

Nonparticipants - The nonparticipant, free drivership analysis focused on the extent to which program-aware nonparticipants adopted the same program-qualifying measures. These estimates provide a lower bound on program educational effects. Because the survey was written to probe for changes since January 1992, and was conducted during the summer of 1995, the rates of implementation were reduced to reflect an average, typical year's worth of installations. Implementation rates were then multiplied by the nonparticipant market size, or approximately 278,000 accounts.

General Methods. All intermediate effects were expressed as percentage reductions in annual usage. These were multiplied by each groups' average annual account size¹⁹, and the impacts (in kWh) were summed to yield a final net kWh. This was then divided by the ex post gross kWh estimate to yield the final NTG ratio. Exhibit 3-16 shows an example of the spillover effects included for compact fluorescent lamps. Percentages shown in the exhibit are annual usage reductions used in the net energy calculations. Note the participant spillover effects (in this case for compact fluorescent lamps) apply to the NTG for the technology under which a customer participated.²⁰

¹⁹ Participant spillover effects were calculated as percentage reductions multiplied times the average *post-program* annual usage.

²⁰ Customers who installed multiple measures were categorized based on the measure that supplied the greatest impact on avoided cost.


Exhibit 3-16

Example: Spillover Effects Used for Compact Fluorescent Lamps

| Technology | Spillover Effects | | |
|-------------------------------------|--|---------------------------------------|----------------------------|
| | Participants' Within Measure Spillover | Participants' Other Measure Spillover | Nonparticipants' Spillover |
| Compact Fluorescent | 2% | | 2% |
| Incandescent to Fluorescent | | 6% | |
| Efficient Ballast | | 1% | |
| T8 Lamps and Electronic Ballasts | | 3% | |
| Optical Reflectors w/ Fluor. Delamp | | 11% | |
| High Intensity Discharge | | 5% | |
| Halogen | | 5% | |
| Exit Signs | | 1% | |
| Controls | | 2% | |

Caveats. By basing the program's market movement effects on the self-reports of aware nonparticipants we are both underestimating natural conservation among aware nonparticipant adopters and overestimating it among unaware nonparticipant adopters. Exhibit 3-17 shows how purchases outside the program can be divided into those reflecting the program's market movement effects and those reflecting natural conservation. These are shown alongside assumptions made in this analysis.

Exhibit 3-17
Representation of Nonparticipant Spillover Effects



In order to accurately measure the program's market effects, data from additional sources, in addition to self-reports, would be required. This stems from a major drawback of self-report data: namely, that there is no reason to believe that customers who made program qualifying retrofits outside the program would be able to accurately gauge the program's effect on structuring their choices. In other words, nonparticipants who make a program-qualifying purchase²¹ may have no idea of the

²¹regardless of their program awareness

program's effect on the pricing and availability of equipment they purchase outside the program. The same can be said of nonparticipants or participants who report that they “would have adopted the measure without the program.” This is a common dilemma in measuring program net effects when relying solely on self-reports. The solution to the problem does not lie in increasingly detailed probes of participants and nonparticipants. Rather, the solution lies in looking elsewhere for data and in adopting multi-level models or approaches that capture the program's macro-level effects on the distribution, availability, and pricing of energy efficiency options.

3.4.4 Integrated Estimate of NTG Adjustments

The final step in constructing the NTG ratio is to sum up all contributing effects into one index. Program gross impacts are adjusted for free ridership and spillover to produce the combined best-estimate of program net impacts. These net impacts are estimated by adding together the net effect of program participants,²² program participant spillover effects, and nonparticipant spillover effects, as follows:

$$\text{NTG} = \frac{\text{GI} * (1 - \text{FR}) + \text{Spillover}_{\text{Part}} + \text{Spillover}_{\text{NonPart}}}{\text{GI}}$$

where,

| | | |
|------------------------------|---|---|
| NTG | = | the Net-to-Gross Ratio |
| GI | = | the Program Gross Impact |
| FR | = | the Free Ridership Rate |
| Spillover _{Part} | = | the estimated impact of participants' nonprogram energy conservation actions |
| Spillover _{NonPart} | = | the estimated impact of nonparticipants' program-influenced energy conservation actions |

Because of the size of the remaining market (approximately 278,000 accounts) and its effect on NTG ratios, results shown in *Section 4* are given for four separate estimates of the nonparticipant contribution. First NTG ratios excluding nonparticipant contributions²³ are given. These are followed by NTG estimates that include the lower-bound estimate of nonparticipant contributions, the midpoint, and the 90 percent upper-bound nonparticipant spillover contribution. Summary tables in *Section 1* show the decomposition of the final program NTG ratio into the following components:

²² Taking free ridership into consideration

²³ but including participant spillover

- 1-FR
- Participant Spillover Effects
- Nonparticipant Spillover Effects

The process of applying the NTG adjustments to the gross energy and demand impacts is illustrated in Exhibits 3-18 and 3-19 below. The second column presents a summary of the gross ex ante impacts, and the gross ex post (evaluation) impacts. These impacts are then adjusted, on a row-by-row basis, by summing the appropriate free rider, participant spillover, or nonparticipant spillover adjustments and multiplying the sum times the gross impacts, to derive the net impacts in the two net columns. The realization rates, in the bottom section, are then generated by dividing the ex post impact by the ex ante impact.

While Exhibits 3-18 and 3-19 present results by end-use elements, the same method is used to estimate gross and net impact estimates that are presented by technology group in *Section 4, Evaluation Results Summaries*.

Exhibit 3-18
Net Energy Impact Summary

| Technology Group | Gross | NTG Adjustments | | | Net | |
|--|--------------|----------------------------------|----------------------------------|-------------------------------------|--|---|
| | Gross Impact | Free Ridership Adjustment (1-FR) | Participant Spillover Adjustment | Nonparticipant Spillover Adjustment | Net Impact without NP Spillover Adjustment | Net Impact with NP Spillover Adjustment |
| | (MWh) | (Unitless) | (Unitless) | (Unitless) | (MWh) | (MWh) |
| Ex Ante | | | | | | |
| Indoor Lighting | 280,014 | 0.67 | | 0.10 | 215,858 | |
| Outdoor Lighting | 20,738 | 0.67 | | 0.10 | 15,958 | |
| Indoor & Outdoor Lighting | 300,752 | 0.67 | | 0.10 | 230,783 | |
| Ex Post | | | | | | |
| Indoor Lighting | 277,688 | 0.87 | 0.03 | 0.18 | 250,058 | 300,043 |
| Outdoor Lighting | 18,058 | 0.82 | 0.06 | 0.27 | 15,891 | 20,745 |
| Indoor & Outdoor Lighting | 295,746 | 0.87 | 0.03 | 0.18 | 267,059 | 320,778 |
| Realization Rates (ex post/ex ante) | | | | | | |
| Indoor Lighting | 0.99 | NA | NA | NA | 1.16 | 1.39 |
| Outdoor Lighting | 0.87 | NA | NA | NA | 1.00 | 1.30 |
| Indoor & Outdoor Lighting | 0.98 | NA | NA | NA | 1.16 | 1.39 |

Exhibit 3-19
Net Demand Impact Summary

| Technology Group | Gross | NTG Adjustments | | | Net | |
|--|--------------|----------------------------------|----------------------------------|-------------------------------------|--|---|
| | Gross Impact | Free Ridership Adjustment (1-FR) | Participant Spillover Adjustment | Nonparticipant Spillover Adjustment | Net Impact without NP Spillover Adjustment | Net Impact with NP Spillover Adjustment |
| | (kW) | (Unitless) | (Unitless) | (Unitless) | (kW) | (kW) |
| Ex Ante | | | | | | |
| Indoor Lighting | 52,416 | 0.67 | | 0.10 | | 40,351 |
| Outdoor Lighting | 124 | 0.67 | | 0.10 | | 92 |
| Indoor & Outdoor Lighting | 52,540 | 0.67 | | 0.10 | | 40,443 |
| Ex Post | | | | | | |
| Indoor Lighting | 62,389 | 0.87 | 0.03 | 0.19 | 56,181 | 69,000 |
| Outdoor Lighting | 782 | 0.83 | 0.06 | 0.27 | 696 | 884 |
| Indoor & Outdoor Lighting | 63,172 | 0.87 | 0.03 | 0.18 | 57,044 | 69,884 |
| Realization Rates (ex post/ex ante) | | | | | | |
| Indoor Lighting | 1.19 | NA | NA | NA | 1.39 | 1.71 |
| Outdoor Lighting | 6.31 | NA | NA | NA | 7.53 | 9.56 |
| Indoor & Outdoor Lighting | 1.20 | NA | NA | NA | 1.41 | 1.73 |

Section 4

EVALUATION RESULTS SUMMARIES

This section summarizes the results of this evaluation, starting with the gross impact results, then discussing the net-to-gross (NTG) adjustments, and concluding with the program realization rates (ratio of evaluation findings to the ex ante program design estimates) for both gross and a net basis. Reasons for the deviations from the preconceived ex ante estimates are discussed in the presentation of program realization.

Where segment analysis could be supported, results are presented by technology and building segment. All results are segmented by program, Retrofit Express (RE) and Customized Incentives (Customized), and by indoor and outdoor applications. All results are aggregated to the entire program.

4.1 Gross Energy Impact Results

Exhibits 4-1 and 4-2 present the gross energy and demand impacts, respectively, from the evaluation for the RE and Customized programs for indoor and outdoor applications. The gross evaluation impacts for energy and demand by PG&E costing period are covered in *Appendix K*.

Exhibit 4-1
 Gross ENERGY IMPACTS
 By Business Type and Technology Group
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector First Year ENERGY IMPACTS (MWh) | | | | | | | | | | |
|---|---|---------------|---------------|---------------|---------------|--------------|---------------|---------------|---------------|---------------|----------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 3,068 | 675 | 773 | 1,046 | 150 | 805 | 1,235 | 6,627 | 55 | 272 | 14,706 |
| Incandescent to Fluorescent | 1,297 | 484 | 59 | 435 | 86 | 122 | 297 | 513 | 78 | 35 | 3,407 |
| Efficient Ballast | 1,182 | 292 | 463 | 425 | 972 | 24 | 144 | 11 | 55 | 226 | 3,795 |
| T8 Lamps and Electronic Ballasts | 40,380 | 15,483 | 3,838 | 8,505 | 5,309 | 383 | 8,039 | 1,557 | 2,142 | 2,139 | 87,775 |
| Optical Reflectors w/ Fluor. Delamp | 45,335 | 8,960 | 3,702 | 4,925 | 3,592 | 411 | 5,020 | 1,145 | 1,782 | 2,089 | 76,961 |
| High Intensity Discharge | 7,090 | 6,704 | 1,667 | 5,080 | 787 | 79 | 830 | 296 | 8,928 | 3,097 | 34,557 |
| Halogen | 1,005 | 1,403 | 410 | 105 | 109 | 427 | 621 | 1,773 | 107 | 167 | 6,128 |
| Exit Signs | 1,858 | 253 | 344 | 687 | 24 | 31 | 750 | 204 | 88 | 244 | 4,482 |
| Controls | 6,261 | 711 | 691 | 1,161 | 27 | 33 | 1,363 | 368 | 216 | 306 | 11,136 |
| Other | ---- | 17 | ---- | ---- | 1 | ---- | ---- | ---- | ---- | ---- | 17 |
| RE Program Indoor Total | 107,475 | 34,983 | 11,947 | 22,369 | 11,056 | 2,315 | 18,299 | 12,494 | 13,451 | 8,575 | 242,965 |
| Customized Program | | | | | | | | | | | |
| Compact Fluorescent | 378 | 82 | ---- | ---- | 96 | ---- | 33 | 95 | ---- | ---- | 684 |
| Standard Fluorescent | 6,371 | 3,923 | 3,354 | 680 | 10,382 | 85 | 341 | 92 | 79 | 49 | 25,356 |
| High Intensity Discharge | ---- | 388 | ---- | ---- | 89 | ---- | ---- | ---- | 1,332 | ---- | 1,808 |
| Exit Signs | 40 | 4 | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- | 45 |
| Controls | 510 | 795 | ---- | ---- | 2,595 | ---- | ---- | ---- | ---- | ---- | 3,901 |
| Other | 1,090 | 163 | ---- | ---- | 1,675 | ---- | ---- | ---- | ---- | ---- | 2,929 |
| Customized Program Indoor Total | 8,390 | 5,356 | 3,354 | 680 | 14,838 | 85 | 374 | 187 | 1,411 | 49 | 34,723 |
| Indoor Total | 115,865 | 40,338 | 15,301 | 23,049 | 25,895 | 2,400 | 18,673 | 12,681 | 14,862 | 8,625 | 277,688 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HID | 2,923 | 4,679 | 580 | 3,132 | 463 | 698 | 607 | 1,933 | 916 | 1,281 | 17,211 |
| Customized Program Exterior HID | 86 | ---- | ---- | ---- | ---- | ---- | ---- | ---- | 268 | ---- | 354 |
| Customized Program Traffic Lights | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- | 493 | 493 |
| Outdoor Total | 3,009 | 4,679 | 580 | 3,132 | 463 | 698 | 607 | 1,933 | 1,184 | 1,774 | 18,058 |
| Indoor and Outdoor Total | 118,874 | 45,018 | 15,881 | 26,181 | 26,357 | 3,098 | 19,280 | 14,614 | 16,046 | 10,398 | 295,746 |

Exhibit 4-2
 Gross DEMAND* IMPACTS
 By Business Group and Technology Type
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector First Year DEMAND IMPACTS (kW) | | | | | | | | | | |
|---|--|---------------|--------------|--------------|--------------|------------|--------------|--------------|--------------|--------------|---------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 1,036 | 225 | 210 | 414 | 32 | 201 | 324 | 1,379 | 23 | 65 | 3,909 |
| Incandescent to Fluorescent | 299 | 136 | 16 | 159 | 18 | 29 | 75 | 95 | 29 | 8 | 865 |
| Efficient Ballast | 274 | 83 | 121 | 163 | 199 | 6 | 36 | 2 | 21 | 50 | 956 |
| T8 Lamps and Electronic Ballasts | 9,348 | 4,423 | 1,004 | 3,115 | 1,110 | 92 | 2,029 | 289 | 812 | 478 | 22,700 |
| Optical Reflectors w/ Fluor. Delamp | 10,505 | 2,578 | 968 | 1,778 | 753 | 98 | 1,260 | 213 | 671 | 467 | 19,291 |
| High Intensity Discharge | 1,644 | 2,041 | 194 | 838 | 71 | 8 | 94 | 24 | 1,494 | 306 | 6,714 |
| Halogen | 236 | 432 | 48 | 18 | 10 | 45 | 71 | 144 | 18 | 16 | 1,038 |
| Exit Signs | 231 | 31 | 43 | 86 | 3 | 4 | 93 | 25 | 11 | 30 | 556 |
| Controls | 1,551 | 160 | 130 | 245 | 1 | 5 | 222 | 44 | 36 | 46 | 2,441 |
| Other | ----- | 2 | ----- | ----- | 0 | ----- | ----- | ----- | ----- | ----- | 2 |
| RE Program Indoor Total | 25,125 | 10,110 | 2,734 | 6,816 | 2,197 | 489 | 4,204 | 2,216 | 3,115 | 1,465 | 58,471 |
| Customized Program | | | | | | | | | | | |
| Compact Fluorescent | 51 | 13 | ----- | ----- | 8 | ----- | 3 | 8 | ----- | ----- | 82 |
| Standard Fluorescent | 879 | 584 | 391 | 118 | 962 | 9 | 38 | 7 | 13 | 6 | 3,008 |
| High Intensity Discharge | ----- | 53 | ----- | ----- | 8 | ----- | ----- | ----- | 226 | ----- | 287 |
| Exit Signs | 3 | 0 | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 4 |
| Controls | 40 | 62 | ----- | ----- | 201 | ----- | ----- | ----- | ----- | ----- | 304 |
| Other | 86 | 13 | ----- | ----- | 134 | ----- | ----- | ----- | ----- | ----- | 233 |
| Customized Program Indoor Total | 1,059 | 726 | 391 | 118 | 1,312 | 9 | 42 | 15 | 239 | 6 | 3,918 |
| Indoor Total | 26,184 | 10,836 | 3,126 | 6,934 | 3,509 | 498 | 4,246 | 2,231 | 3,355 | 1,471 | 62,389 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HID | 121 | 193 | 24 | 129 | 19 | 29 | 25 | 80 | 38 | 53 | 712 |
| Customized Program Exterior HID | 4 | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 11 | ----- | 15 |
| Customized Program Traffic Lights | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 56 | 56 |
| Outdoor Total | 124 | 193 | 24 | 129 | 19 | 29 | 25 | 80 | 49 | 109 | 782 |
| Indoor and Outdoor Total | 26,309 | 11,029 | 3,149 | 7,063 | 3,528 | 527 | 4,271 | 2,311 | 3,404 | 1,580 | 63,172 |

*Summer On-Peak demand impacts are defined for weekdays during the hour 3:00-4:00 PM, May 1-October 31.

The results in Exhibits 4-1 and 4-2 illustrate the following findings:

- RE indoor technologies represented more than 80 percent and 90 percent of the energy and demand impacts, respectively.
- Office and retail business types represent more than 55 percent of the impacts, with office being the largest single segment accounting for about 40 percent.

- The three technologies that made the largest contributions to impacts were the replacement of standard-efficiency fluorescent lamps and ballasts with modern T-8 lamps and electronic ballasts; the installation of optical reflectors in combination with delamping in fluorescent fixtures; and the installation of high-intensity discharge (HID) lamps and ballasts for less efficient technologies. These three technologies represented more than 70 percent of the program energy and demand savings.
- The lowest energy impacts were contributed by the restaurant building type, because of low participation in the program. Lighting quality requirements within this segment have been an explanation for the predominance of incandescent installations that overcome the limitations of dimming capability in energy-efficient technologies.
- The Customized program plays a small role in the overall impact, with just over 10 percent of the energy savings and approximately 6 percent of the demand savings being attributable to this program.
- Similarly, outdoor lighting is a small contributor, with just about 6 percent of the energy savings and approximately 1 percent of the demand savings.

4.2 Net-to-Gross Adjustments

The NTG results account for all of the market spillover effects (free ridership, participant spillover, and nonparticipant spillover) into estimates by measure, and an overall estimate for the program. The market analysis NTG approach discussed in *Section 3* is the method that produced these results because of their higher reliability, and the fact that they could support measure-level analysis.

Exhibit 4-3 presents the NTG values by technology, along with the 90 percent confidence intervals, without nonparticipant spillover and with nonparticipant spillover. The estimates are presented this way because of the large effect that nonparticipant spillover can have on the NTG values.

Nonparticipant spillover accounts for the percentage of customers who were not participants but installed high-efficiency measures because of the presence of the program. This effect is determined by assessing the percentage of the nonparticipant population who installed high-efficiency measures because of the presence of the program, then multiplying this percentage by the nonparticipant population. Since the nonparticipant population is large, a small percentage of nonparticipant actions can create a large spillover effect relative to the program impact.

While QC computed and presents NTG estimates without and with nonparticipant spillover, we are convinced that nonparticipant spillover exists, and that the values

presented including nonparticipant spillover are the best estimates of the NTG adjustments.

Exhibit 4-3
NTG Adjustments by Technology Type

| Technology | Without NP Spillover | | |
|-------------------------------------|-----------------------------|-----------------|------------------|
| | Lower 90% | Midpoint | Upper 90% |
| Compact Fluorescent | 1.00 | 1.01 | 1.02 |
| Incandescent to Fluorescent | 0.83 | 0.89 | 0.95 |
| Efficient Ballast | 0.92 | 0.93 | 0.94 |
| T8 Lamps and Electronic Ballasts | 0.91 | 0.92 | 0.94 |
| Optical Reflectors w/ Fluor. Delamp | 0.95 | 0.96 | 0.96 |
| High Intensity Discharge | 0.86 | 0.88 | 0.90 |
| Halogen | 0.83 | 0.89 | 0.95 |
| Exit Signs | 1.02 | 1.08 | 1.14 |
| Controls | 0.89 | 0.93 | 0.96 |
| Other | 0.83 | 0.89 | 0.95 |
| RE Program | 0.92 | 0.93 | 0.93 |
| Customized Program | 0.70 | 0.73 | 0.76 |

| Technology | With NP Spillover | | |
|-------------------------------------|--------------------------|-----------------|------------------|
| | Lower 90% | Midpoint | Upper 90% |
| Compact Fluorescent | 1.01 | 1.45 | 1.99 |
| Incandescent to Fluorescent | NA | 0.89 | NA |
| Efficient Ballast | 0.93 | 2.00 | 2.00 |
| T8 Lamps and Electronic Ballasts | 0.92 | 1.19 | 1.50 |
| Optical Reflectors w/ Fluor. Delamp | 0.96 | 0.98 | 1.02 |
| High Intensity Discharge | 0.88 | 1.17 | 1.51 |
| Halogen | NA | 0.89 | NA |
| Exit Signs | 1.08 | 1.45 | 1.88 |
| Controls | NA | 0.93 | NA |
| Other | NA | 0.89 | NA |
| RE Program | 0.93 | 1.13 | 1.34 |
| Customized Program | NA | 0.73 | NA |

Several of the technology-specific estimates deserve individual discussion.

- **Compact Fluorescents** - Net estimates for compact fluorescent lighting were increased by two major contributions. First, program participants who installed compact fluorescent lighting through the program also reported installing T-8 lamps *after* participating. Additionally, 0.1 percent of nonparticipants surveyed also reported installing compact fluorescent lighting. Because the size of the nonparticipant market exceeds 270,000 accounts, the nonparticipant contribution drives the final NTG estimate to 1.45.
- **Exit Signs** - Ten percent of the customers who installed exit signs through the program were also estimated to have installed compact fluorescent lighting outside the program after participating. Nonparticipant spillover contributions further increased the NTG for LED exit lighting.
- **Electronic Ballasts** - More free driver nonparticipants installed electronic ballasts outside the program than customers within the program. This effect caused the NTG for electronic ballasts to exceed 2.0.

4.3 Net Impacts

Exhibits 4-4 and 4-5 present the net energy and demand impacts, respectively, from the evaluation for the RE and Customized programs for indoor and outdoor applications.

Exhibit 4-4
 Net ENERGY IMPACTS
 By Business Type and Technology Group
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector First Year ENERGY IMPACTS (MWh) | | | | | | | | | | |
|---|---|---------------|---------------|---------------|---------------|--------------|---------------|---------------|---------------|---------------|----------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 4,461 | 981 | 1,124 | 1,520 | 218 | 1,171 | 1,795 | 9,637 | 81 | 396 | 21,384 |
| Incandescent to Fluorescent | 1,161 | 433 | 53 | 389 | 77 | 110 | 265 | 459 | 70 | 32 | 3,048 |
| Efficient Ballast | 2,364 | 585 | 927 | 850 | 1,943 | 48 | 289 | 22 | 110 | 451 | 7,589 |
| T8 Lamps and Electronic Ballasts | 47,926 | 18,377 | 4,555 | 10,095 | 6,301 | 455 | 9,542 | 1,848 | 2,542 | 2,539 | 104,179 |
| Optical Reflectors w/ Fluor. Delamp | 44,585 | 8,812 | 3,641 | 4,844 | 3,533 | 404 | 4,937 | 1,126 | 1,753 | 2,055 | 75,689 |
| High Intensity Discharge | 8,290 | 7,839 | 1,949 | 5,940 | 920 | 92 | 971 | 346 | 10,438 | 3,621 | 40,405 |
| Halogen | 899 | 1,256 | 367 | 94 | 98 | 382 | 556 | 1,586 | 96 | 149 | 5,483 |
| Exit Signs | 2,688 | 366 | 497 | 994 | 35 | 44 | 1,085 | 296 | 128 | 353 | 6,486 |
| Controls | 5,792 | 658 | 639 | 1,074 | 25 | 30 | 1,261 | 340 | 200 | 283 | 10,302 |
| Other | ----- | 15 | ----- | ----- | 1 | ----- | ----- | ----- | ----- | ----- | 16 |
| RE Program Indoor Total | 118,165 | 39,321 | 13,752 | 25,800 | 13,150 | 2,737 | 20,701 | 15,660 | 15,416 | 9,879 | 274,581 |
| Customized Program | | | | | | | | | | | |
| Compact Fluorescent | 277 | 60 | ----- | ----- | 70 | ----- | 24 | 69 | ----- | ----- | 501 |
| Standard Fluorescent | 4,672 | 2,877 | 2,459 | 498 | 7,613 | 62 | 250 | 67 | 58 | 36 | 18,594 |
| High Intensity Discharge | ----- | 284 | ----- | ----- | 65 | ----- | ----- | ----- | 976 | ----- | 1,326 |
| Exit Signs | 30 | 3 | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 33 |
| Controls | 374 | 583 | ----- | ----- | 1,903 | ----- | ----- | ----- | ----- | ----- | 2,861 |
| Other | 800 | 120 | ----- | ----- | 1,229 | ----- | ----- | ----- | ----- | ----- | 2,148 |
| Customized Program Indoor Total | 6,153 | 3,927 | 2,459 | 498 | 10,881 | 62 | 274 | 137 | 1,035 | 36 | 25,462 |
| Indoor Total | 124,318 | 43,248 | 16,211 | 26,298 | 24,031 | 2,799 | 20,975 | 15,797 | 16,451 | 9,915 | 300,043 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HID | 3,418 | 5,471 | 678 | 3,662 | 541 | 816 | 709 | 2,260 | 1,071 | 1,497 | 20,124 |
| Customized Program Exterior HID | 63 | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 197 | ----- | 260 |
| Customized Program Traffic Lights | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 361 | 361 |
| Outdoor Total | 3,481 | 5,471 | 678 | 3,662 | 541 | 816 | 709 | 2,260 | 1,268 | 1,859 | 20,745 |
| Indoor and Outdoor Total | 127,799 | 48,719 | 16,889 | 29,960 | 24,572 | 3,615 | 21,684 | 18,057 | 17,719 | 11,774 | 320,788 |

Exhibit 4-5
 Net DEMAND* IMPACTS
 By Business Type and Technology Group
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector First Year DEMAND IMPACTS (kW) | | | | | | | | | | |
|---|--|---------------|--------------|--------------|--------------|------------|--------------|--------------|--------------|--------------|---------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 1,507 | 327 | 305 | 602 | 46 | 293 | 471 | 2,005 | 33 | 94 | 5,683 |
| Incandescent to Fluorescent | 268 | 121 | 14 | 142 | 16 | 26 | 67 | 85 | 26 | 7 | 774 |
| Efficient Ballast | 547 | 166 | 242 | 326 | 399 | 12 | 73 | 4 | 42 | 101 | 1,912 |
| T8 Lamps and Electronic Ballasts | 11,095 | 5,250 | 1,192 | 3,697 | 1,317 | 109 | 2,408 | 343 | 964 | 567 | 26,942 |
| Optical Reflectors w/ Fluor. Delamp | 10,332 | 2,535 | 952 | 1,749 | 740 | 97 | 1,239 | 209 | 660 | 459 | 18,972 |
| High Intensity Discharge | 1,922 | 2,386 | 226 | 980 | 83 | 10 | 110 | 28 | 1,747 | 358 | 7,850 |
| Halogen | 211 | 387 | 43 | 16 | 9 | 40 | 63 | 129 | 16 | 15 | 929 |
| Exit Signs | 334 | 45 | 63 | 124 | 4 | 6 | 135 | 37 | 15 | 43 | 805 |
| Controls | 1,435 | 148 | 121 | 226 | 1 | 4 | 206 | 41 | 34 | 43 | 2,259 |
| Other | ----- | 2 | ----- | ----- | 0 | ----- | ----- | ----- | ----- | ----- | 2 |
| RE Program Indoor Total | 27,651 | 11,367 | 3,158 | 7,863 | 2,616 | 597 | 4,772 | 2,882 | 3,537 | 1,685 | 66,127 |
| Customized Program | | | | | | | | | | | |
| Compact Fluorescent | 37 | 9 | ----- | ----- | 6 | ----- | 3 | 6 | ----- | ----- | 60 |
| Standard Fluorescent | 644 | 429 | 287 | 86 | 705 | 7 | 28 | 5 | 10 | 4 | 2,206 |
| High Intensity Discharge | ----- | 39 | ----- | ----- | 6 | ----- | ----- | ----- | 166 | ----- | 211 |
| Exit Signs | 2 | 0 | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 3 |
| Controls | 30 | 46 | ----- | ----- | 147 | ----- | ----- | ----- | ----- | ----- | 223 |
| Other | 63 | 9 | ----- | ----- | 98 | ----- | ----- | ----- | ----- | ----- | 171 |
| Customized Program Indoor Total | 777 | 532 | 287 | 86 | 962 | 7 | 31 | 11 | 176 | 4 | 2,873 |
| Indoor Total | 28,428 | 11,899 | 3,445 | 7,949 | 3,578 | 603 | 4,802 | 2,893 | 3,713 | 1,689 | 69,000 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HID | 141 | 226 | 28 | 151 | 22 | 34 | 29 | 93 | 44 | 62 | 832 |
| Customized Program Exterior HID | 3 | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 8 | ----- | 11 |
| Customized Program Traffic Lights | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | ----- | 41 | 41 |
| Outdoor Total | 144 | 226 | 28 | 151 | 22 | 34 | 29 | 93 | 52 | 103 | 884 |
| Indoor and Outdoor Total | 28,572 | 12,125 | 3,473 | 8,100 | 3,601 | 637 | 4,832 | 2,986 | 3,765 | 1,793 | 69,884 |

*Summer On-Peak demand impacts are defined for weekdays during the hour 3:00-4:00 PM, May 1-October 31.

Overall, Exhibits 4-4 and 4-5 show an 8.5 percent increase in ex-post program energy savings, and a 10.6 percent increase in demand savings (when compared to Exhibits 4-1 and 4-2, gross impacts), as a result of the application of the NTG adjustments presented in Exhibit 4-3. The NTG adjustments modified the general impact picture very little. T-8/electronic ballast, optical reflectors with decamp, and HID replacements for less efficient lamps still dominate the savings representing more than two thirds of the energy and demand impacts. On a building basis, office and retail segments still dominate impacts with more than 55 percent of the total impact for both energy and demand.

Close examination of these results identifies the following findings:

- **Efficient Ballasts** - The impact doubled, as predicted by the NTG adjustment, but this had little effect on the overall impact because it represents only 2 to 3 percent of the total impact.
- **Hotel/motel** - The hotel/motel business type showed a 24 percent increase in energy, and a 29 percent increase in demand impact due primarily to the high proportion of savings represented by compact fluorescent technology in this building segment.
- **Grocery** - The grocery business type showed a decreased in energy impact and an increase in demand impact because of the low NTG on custom measures. The grocery building segment had large estimated impacts in standard fluorescent custom measures. This measure had a substantial energy impact but a small demand impact.

4.4 Realization Rates

Exhibits 4-6 through 4-9 present the gross and net realization rates for energy and demand impacts for the RE and Customized program indoor and outdoor lighting applications. The four realization rate exhibits are analyzed in order, so that factors that contributed to the results can be discussed in order of impact, followed by market analysis results.

4.4.1 Gross Realization Rates for Energy Impacts

The gross energy realization rates are presented in Exhibit 4-6. These values represent, by segment, the ratio of gross impact evaluation findings to the gross ex ante program design estimate of savings. These realization rates illustrate how well the ex ante estimates predicted energy savings, before taking into account customer behavioral effects, both inside and outside the program.

Exhibit 4-6
 Gross ENERGY Impact REALIZATION RATES
 By Business Type and Technology Group
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector ENERGY Impact REALIZATION RATES# | | | | | | | | | | |
|---|--|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|---------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Average |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 0.60 | 0.41 | 0.72 | 0.52 | 0.45 | 0.56 | 0.60 | 0.69 | 0.31 | 0.52 | 0.61 |
| Incandescent to Fluorescent | 1.11 | 0.90 | 0.87 | 0.70 | 0.75 | 0.84 | 0.94 | 1.29 | 0.53 | 2.62 | 0.97 |
| Efficient Ballast | 0.57 | 0.40 | 0.60 | 0.40 | 0.55 | 0.29 | 0.46 | 0.79 | 0.28 | 0.56 | 0.51 |
| T8 Lamps and Electronic Ballasts | 1.05 | 0.74 | 0.94 | 0.64 | 0.69 | 0.73 | 0.86 | 1.18 | 0.47 | 1.02 | 0.86 |
| Optical Reflectors w/ Fluor. Delamp | 1.18 | 0.83 | 1.09 | 0.69 | 0.74 | 0.84 | 0.97 | 1.30 | 0.59 | 1.36 | 1.02 |
| High Intensity Discharge | 1.15 | 0.70 | 4.46 | 1.94 | 1.60 | 1.82 | 2.15 | 2.99 | 1.22 | 2.10 | 1.21 |
| Halogen | 1.91 | 1.45 | 3.84 | 2.27 | 4.20 | 4.56 | 3.65 | 5.64 | 2.12 | 5.01 | 2.63 |
| Exit Signs | 1.07 | 1.00 | 1.39 | 1.06 | 1.06 | 1.06 | 1.05 | 1.09 | 0.98 | 1.04 | 1.08 |
| Controls | 0.92 | 0.96 | 1.45 | 0.63 | 0.71 | 1.23 | 1.35 | 1.56 | 0.95 | 1.03 | 0.96 |
| Other | ----- | 1.08 | ----- | ----- | 1.12 | ----- | ----- | ----- | ----- | ----- | 1.08 |
| RE Program Indoor Average | 1.07 | 0.76 | 1.13 | 0.76 | 0.72 | 0.80 | 0.94 | 0.95 | 0.85 | 1.30 | 0.94 |
| Customized Program | | | | | | | | | | | |
| Compact Fluorescent¥ | | | | | | | | | | | |
| Standard Fluorescent¥ | | | | | | | | | | | |
| High Intensity Discharge¥ | | | | | | | | | | | |
| Exit Signs¥ | | | | | | | | | | | |
| Controls¥ | | | | | | | | | | | |
| Other¥ | | | | | | | | | | | |
| Customized Program Indoor Average | | | | | | | | | | | 1.69 |
| Indoor Average | | | | | | | | | | | 0.99 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HID | 0.87 | 0.87 | 1.07 | 0.87 | 0.87 | 0.87 | 0.87 | 0.85 | 0.86 | 0.93 | 0.88 |
| Customized Program Exterior HID | | | | | | | | | | | 0.85 |
| Customized Program Traffic Lights | | | | | | | | | | | 0.71 |
| Outdoor Average | | | | | | | | | | | 0.87 |
| Indoor and Outdoor Average | | | | | | | | | | | 0.98 |

The program design gross impact realization rates are defined as the ratio of evaluation impact to MDSS impact.

¥ Customized Incentives Program results are not reported by technology group because measure classifications are not carefully tracked in the MDSS.

Overall, Exhibit 4-6 shows that the ex ante estimates are close to the gross impact estimates. The average realization rate for RE indoor applications is 0.94, while Customized is 1.69, resulting in a program realization rate of 0.99 for indoor lighting applications. When this is combined with the 0.87 realization rate for outdoor lighting, a weighted overall program realization rate of 0.98 results.

Segment level realization rates were not possible for Customized because the MDSS did not track ex ante estimates by measure technology.

The results presented in Exhibit 4-6 can be explained using information from the review of the ex ante estimates in conjunction with the impact analysis results. Explanations of the results by technology are as follows:

- **Compact Fluorescents** - The low program realization rates for compact fluorescent technology are a product of the billing regression analysis yielding a 62 percent realization on the engineering estimates. These results were significant at greater than the 90 percent confidence level. The primary segments for compact fluorescents were hotel/motel and office, representing 45 percent and 21 percent of the gross energy savings, respectively.
 - The operating factors for this technology were estimated only for the office segment and were lower than expected. This adjustment was made in the engineering estimates for the office segment alone. The hotel/motel segment, a segment that was not included in the on-site sample because it represented only about 5 percent of the total ex ante impacts, was based upon ex ante estimates. The sample did not support independent analyses of the hotel/motel and office segments; therefore, the low average SAE realization rate for this must be attributed primarily to the hotel/motel segment.
 - QC's experience has been that compact fluorescents in the hotel/motel segment are either placed in hallways that have 24-hour operation, or in guest rooms, where operation is erratic, and inspection and monitoring are not viable. The low realization rate results, therefore, because a significant number of the compact fluorescent lamps installed in the hotel/motel building segment were installed in guest rooms. Even for the other building types, lower operating factors than expected are likely, since compact fluorescents typically replace incandescent lamps in locations where occupancy is inconsistent.
- **Efficient Ballast** - The low gross program realization rates for the efficient ballast technology is a result of an error in the MDSS. The MDSS applied the per-fixture ex ante savings value to lamp counts for a portion (1993 program applicants) of the measures tracked. This resulted in ex ante estimates in the MDSS that were approximately 100 percent higher than they should have been.
- **Halogen** - The high realization rates for the halogen technologies are a result of the ex ante estimates for this technology assuming a short lamp life, with the lamp being replaced with a conventional light at the end of the original lamp life. No evidence of this practice was found in the field nor detected in the billing regression analysis. These high realization rates have a small effect on the overall realization rates because the energy impact of this technology accounts for only 2 percent of the total.
- **Fluorescent Technologies, Low Billing Regression Realization Rates** - The low realization rates for retail, school, grocery, and restaurant business types are a direct

result of low realized impacts detected in the billing regression analysis for fluorescent technologies. Other than that ex ante estimates for this technology may have been derived from unrealistic assumptions, no specific reasons explaining this result could be found.

- **High-Intensity Discharge** - The high realization rates reported for many building types under the HID technology type are the result of inexplicably low MDSS figures. An attempt to reproduce the MDSS estimates, based upon the ex ante input values and participation numbers, resulted in considerably higher values than those reported in the MDSS.

4.4.2 Gross Realization Rates for Demand Impacts

The gross demand realization rates are presented in Exhibit 4-7. These values represent, by segment, the ratio of gross impact evaluation findings to the gross ex ante program design estimate of savings. These realization rates illustrate how well the ex ante estimates predicted demand savings, before taking into account customers' actions within the lighting market.

Exhibit 4-7
 Gross DEMAND* Impact REALIZATION RATES
 By Business Type and Technology Group
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector DEMAND Impact REALIZATION RATES# | | | | | | | | | | |
|---|--|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|---------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Average |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 1.07 | 0.90 | 1.03 | 0.65 | 1.00 | 1.00 | 0.94 | 0.86 | 0.77 | 0.74 | 0.90 |
| Incandescent to Fluorescent | 1.38 | 1.63 | 1.19 | 0.81 | 1.64 | 1.45 | 1.43 | 1.43 | 1.21 | 3.49 | 1.26 |
| Efficient Ballast | 0.68 | 0.76 | 0.82 | 0.47 | 1.17 | 0.50 | 0.68 | 0.87 | 0.63 | 0.74 | 0.71 |
| T8 Lamps and Electronic Ballasts | 1.28 | 1.45 | 1.29 | 0.74 | 1.52 | 1.24 | 1.29 | 1.31 | 1.06 | 1.38 | 1.19 |
| Optical Reflectors w/ Fluor. Delamp | 1.39 | 1.54 | 1.49 | 0.78 | 1.63 | 1.44 | 1.42 | 1.42 | 1.13 | 1.79 | 1.32 |
| High Intensity Discharge | 1.45 | 1.38 | 2.71 | 1.01 | 1.51 | 1.38 | 1.45 | 1.45 | 1.22 | 1.24 | 1.31 |
| Halogen | 1.80 | 1.76 | 1.69 | 1.38 | 1.62 | 1.88 | 1.69 | 1.82 | 1.46 | 1.78 | 1.76 |
| Exit Signs | 1.16 | 1.07 | 1.54 | 1.15 | 1.16 | 1.18 | 1.15 | 1.19 | 1.03 | 1.10 | 1.17 |
| Controls | 0.95 | 0.92 | 1.18 | 0.61 | 0.17 | 0.99 | 0.91 | 1.33 | 0.72 | 0.88 | 0.90 |
| Other | ----- | 0.54 | ----- | ----- | 0.59 | ----- | ----- | ----- | ----- | ----- | 0.54 |
| RE Program Indoor Average | 1.28 | 1.42 | 1.34 | 0.76 | 1.50 | 1.18 | 1.26 | 1.01 | 1.14 | 1.33 | 1.19 |
| CI Program | | | | | | | | | | | |
| Compact Fluorescent¥ | | | | | | | | | | | |
| Standard Fluorescent¥ | | | | | | | | | | | |
| High Intensity Discharge¥ | | | | | | | | | | | |
| Exit Signs¥ | | | | | | | | | | | |
| Controls¥ | | | | | | | | | | | |
| Other¥ | | | | | | | | | | | |
| CI Program Indoor Average | | | | | | | | | | | 1.13 |
| Indoor Average | | | | | | | | | | | 1.19 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HIDS | ----- | ----- | ----- | 11.56 | ----- | ----- | ----- | 235.09 | ----- | ----- | 61.66 |
| CI Program Exterior HIDS | | | | | | | | | | | ----- |
| CI Program Traffic Lights | | | | | | | | | | | 0.50 |
| Outdoor Average | | | | | | | | | | | 6.31 |
| Indoor and Outdoor Average | | | | | | | | | | | 1.20 |

* Summer On-Peak demand impacts are defined for weekdays during the hour 3:00-4:00 PM, May 1-October 31.

The program design gross impact realization rates are defined as the ratio of evaluation impact to MDSS impact.

¥ Customized Incentives Program results are not reported by technology group because measure classifications are not carefully tracked in the MDSS.

§ In general, MDSS impacts for exterior lighting systems are zero, with only limited exceptions to this rule.

Overall, the gross demand estimates presented in Exhibit 4-7 are 20 percent higher than the ex ante values. The two primary reasons for this difference are higher operating factors (through lamp counts) than the operating factors used in the ex ante estimates were observed; and the evaluation estimates include HVAC interaction, which was not accounted for in the ex ante values.

Some of the results presented in Exhibit 4-7 can be explained using information from review of the ex ante estimates and the evaluation engineering and billing regression analyses. Specific comments and justifications for the results presented in Exhibit 4-7 are as follows:

- **Compact Fluorescents** - The lower realization rates are due to lower operating factors observed for this technology during field inspections. These operating factors are closer to the operating factors used in the ex ante estimates.
- **Efficient Ballast** - The low gross realization rates reported for the efficient ballast technology is a result of an error in the MDSS. The MDSS applied the per-fixture ex ante savings value to lamp counts for a portion (1993 program applicants) of the measures tracked. This resulted in ex ante estimates in the MDSS that were approximately 100 percent higher than they should have been.
- **High-Intensity Discharge** - The high realization rates reported for many building types under the HID technology type are a result of mistakes in the MDSS figures for this technology, as described above.
- **Halogen** - As previously discussed, the high realization rate for the halogen technologies results from ex ante estimates for this technology, which are based on a short lamp life, with the lamp being replaced with a conventional light at the end of the original lamp life.
- **Grocery** - The high realization rate on grocery building type is due to high operating factors (as observed during inspections through lamp counts), and high diversity factor (high percentage of stores open at peak hour).
- **Schools** - The low realization rate is a result of low diversity factor for schools (a high percentage of schools closed at summer peak hour).
- **Hotel/motel** - The low realization rate is a result of the low realization rate for compact fluorescent technology, which represents more than half of the demand impact in this building type.
- **Exterior HIDs** - The wildly high realization rates for this technology are a result of the ex ante peak demand impact estimates being zero for most applications of this technology. While this is reasonable in theory, field inspections found that many exterior lighting applications are on during peak hours. The extremely high realization rates result from the extremely conservative impacts entered in the MDSS for this application.
- **Traffic Lights (red only)** - The MDSS value for traffic lights does not account for the fact that red traffic lights are on less than 100 percent of the time. The engineering estimates used a conservative diversity factor of 50 percent, resulting in the 0.50 realization rate. Alternatively, the energy estimate reflects the somewhat higher diversity factor (66 percent), based upon a Department of Transportation study.

- **Controls** - The estimated impacts for controls are low because QC could not develop a good demand estimate based upon the data available. As a result, QC assumed a conservative ex post demand value for this extremely small segment impact.

4.4.3 Net Realization Rates for Energy Impacts

The difference between the gross and net realization rates is substantial. This is because of the differences between the ex ante and the ex post estimates of the NTG adjustment. The ex ante estimate varied between 0.72 and 0.78, depending upon the segment. As can be seen from Exhibit 4-3 above, the NTG estimates vary between 0.73 and 2.0, depending upon the technology, resulting in an overall estimate of 1.13 for RE and 0.73 for Customized. As Exhibit 4-1 and 4-2 show, RE represents about 90 percent of the lighting impact for both energy and demand. These NTG adjustment differences result in a 42 percent increase in energy and a 44 percent increase in demand impact.

The net energy realization rates are presented in Exhibit 4-8. These values represent, by segment, the ratio of net impact evaluation findings to the net ex ante program design estimate of savings. The realization rates illustrate how well the ex ante estimates predicted energy savings, after taking into account customers' actions within the lighting market.

Exhibit 4-8
 Net ENERGY Impact REALIZATION RATES
 By Business Type and Technology Group
 Commercial Indoor and Outdoor Lighting Applications

| Business Type Program and Technology Group | Commercial Sector ENERGY Impact REALIZATION RATES# | | | | | | | | | | |
|---|--|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|---------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Average |
| Indoor Lighting | | | | | | | | | | | |
| RE Program | | | | | | | | | | | |
| Compact Fluorescent | 1.13 | 0.77 | 1.36 | 0.98 | 0.86 | 1.05 | 1.14 | 1.30 | 0.59 | 0.98 | 1.15 |
| Incandescent to Fluorescent | 1.28 | 1.04 | 1.02 | 0.82 | 0.87 | 0.98 | 1.10 | 1.50 | 0.62 | 3.04 | 1.12 |
| Efficient Ballast | 1.48 | 1.04 | 1.55 | 1.03 | 1.44 | 0.76 | 1.18 | 2.04 | 0.72 | 1.46 | 1.33 |
| T8 Lamps and Electronic Ballasts | 1.62 | 1.15 | 1.45 | 0.98 | 1.07 | 1.12 | 1.32 | 1.81 | 0.72 | 1.58 | 1.32 |
| Optical Reflectors w/ Fluor. Delamp | 1.50 | 1.07 | 1.39 | 0.88 | 0.95 | 1.07 | 1.23 | 1.66 | 0.76 | 1.73 | 1.30 |
| High Intensity Discharge | 1.74 | 1.07 | 6.77 | 2.95 | 2.43 | 2.76 | 3.26 | 4.54 | 1.86 | 3.19 | 1.84 |
| Halogen | 2.22 | 1.69 | 4.46 | 2.63 | 4.88 | 5.30 | 4.25 | 6.55 | 2.47 | 5.82 | 3.05 |
| Exit Signs | 2.01 | 1.87 | 2.62 | 1.99 | 1.98 | 2.00 | 1.98 | 2.05 | 1.84 | 1.95 | 2.02 |
| Controls | 1.11 | 1.15 | 1.74 | 0.76 | 0.86 | 1.48 | 1.62 | 1.87 | 1.14 | 1.24 | 1.15 |
| Other | ----- | 1.38 | ----- | ----- | 1.43 | ----- | ----- | ----- | ----- | ----- | 1.38 |
| RE Program Indoor Average | 1.53 | 1.11 | 1.69 | 1.14 | 1.12 | 1.23 | 1.38 | 1.55 | 1.27 | 1.94 | 1.37 |
| Customized Program | | | | | | | | | | | |
| Compact Fluorescent¥ | | | | | | | | | | | |
| Standard Fluorescent¥ | | | | | | | | | | | |
| High Intensity Discharge¥ | | | | | | | | | | | |
| Exit Signs¥ | | | | | | | | | | | |
| Controls¥ | | | | | | | | | | | |
| Other¥ | | | | | | | | | | | |
| Customized Program Indoor Average | | | | | | | | | | | 1.66 |
| Indoor Average | | | | | | | | | | | 1.39 |
| Exterior Lighting | | | | | | | | | | | |
| RE Program Exterior HID | 1.32 | 1.32 | 1.62 | 1.32 | 1.32 | 1.32 | 1.33 | 1.29 | 1.30 | 1.41 | 1.33 |
| Customized Program Exterior HID | | | | | | | | | | | 0.84 |
| Customized Program Traffic Lights | | | | | | | | | | | 0.70 |
| Outdoor Average | | | | | | | | | | | 1.30 |
| Indoor and Outdoor Average | | | | | | | | | | | 1.39 |

The program design gross impact realization rates are defined as the ratio of evaluation impact to MDSS impact.

¥ Customized Incentives Program results are not reported by technology group because measure classifications are not carefully tracked in the MDSS.

Overall, given the large difference between the NTG adjustment factors discussed above, and the generally high gross realization rates discussed earlier, it is not surprising that all technology and building segment average realization rates are above 1.0. Additionally, even though the realization rate for the Customized program was 0.73, this was virtually the same realization rate as the ex ante estimate, resulting in only a minor decrease in impact estimate for the Customized program elements.

As discussed previously, some of the results presented in Exhibit 4-8 can be explained using information from the review of the ex ante estimates and the evaluation engineering, billing regression, and NTG analyses. Most of the comments discussed in relation to the gross realization rate estimates apply to the net realization rates. Some are repeated here for thoroughness. Specific comments and justifications for the net realization rates presented in Exhibit 4-8 are as follows:

- **Compact Fluorescents and Efficient Ballast** - The low gross realization rates discussed earlier for compact fluorescent and efficient ballast technologies have been more than offset by the difference between the ex ante and ex post NTG adjustments. It must be remembered that the low gross realization rates reported for the efficient ballast technology is a result of an error in the MDSS. The MDSS applied the per fixture ex ante savings value to lamp counts for a portion (1993 program applicants) of the measures tracked.
- **Halogen** - The high realization rates for the halogen technologies are driven by the gross impact results.
- **Fluorescent Technologies, Low Billing Regression Realization Rates** - The relatively low realization rates for retail, school, grocery, and restaurant businesses are still driven by the gross impact results.
- **High Intensity Discharge** - As noted before, these ex ante estimates are the result of MDSS data or calculation errors.
- **Main Realization Rates Reasonable** - The realization rates that represent the largest proportion (84 percent) of the total net energy savings (compact fluorescents, T-8/electronic ballasts, optical reflectors with delamp, HID for less efficient technologies, and controls) all have realization rates between 1.15 and 1.33 with the exception of HIDs, where incorrect entry of data in the MDSS has caused artificially high realization rates.

supportable set of results than the net billing analysis model that is derived exclusively from energy data.

As with the net energy estimates discussed above, the overall effect of the NTG adjustments results in high realization rates, especially since some gross realization rate estimates were already greater than 1.0.

Most of the specific comments applied to the net energy and gross realization rate discussions apply to the net realization rates as well. Those reasons not summarized in the previous section are listed below.

- **Schools** - The gross demand realization rate still drives the results for this business type, since the lower than average realization rate is due to low diversity factor for schools (a high percentage of schools are closed during summer peak hour).
- **Exterior HIDs** - As noted above, the wildly high realization rates for this technology are a result of the ex ante peak demand impact estimates being zero for most applications in this technology.
- **Controls** - The estimated impacts for controls are low because QC could not develop a good demand estimate based upon the data available. As a result, QC assumed a conservative ex post demand value for this extremely small segment impact.

4.5 Overview of Realization Rates

Overall, the net energy and demand impacts and realization rates are higher than predicted by the ex ante impact estimates. However, these high realization rates are well documented and supportable based upon the information developed during the evaluation. The ex post estimates are higher than the ex ante values because of the following:

- The evaluation field data collection established generally higher operating factors and longer operating hours than were assumed in the ex ante estimates.
- The billing regression analysis established solid (0.94 to 0.70) SAE realization rates (billing regression estimate divided by the evaluation engineering estimates) for the highest participation segments.
- The NTG adjustment estimation resulted in a mean estimate 40 to 45 percent higher than the conservative estimates use in the ex ante values.

In summary, PG&E's ex ante estimate of energy savings was 39 percent below the ex post estimate of net energy savings, and the ex ante estimate of demand savings was 73 percent below the ex post estimate of net demand.

4.6 Program Design Estimates

The evaluation team offers the following comments and recommendations regarding the methods used to generate program design estimates (further details are available in *Appendix B*, pages B-25 through B-32):

- An extensive review of the program design algorithms and collected field data on building segment-specific operating hours and operating factors provided insights into these parameters. These full load hours account only for lighting system operation, not total impact -- thus isolating the lighting technology impacts from the HVAC program impact contributions. This information should be incorporated into the PG&E design estimates by substituting the following adjusted full load hours into the current design algorithm by business type:

Exhibit 4-10
Full Load Hours by Business Type

| Industry Group | Indoor Lighting Annual Hours of Operation | |
|----------------------|---|-------------------------|
| | Evaluation Estimate | Program Design Estimate |
| Office | 3,900 | 3,400 |
| Retail | 4,200 | 4,700 |
| College/University | 3,700 | 3,500 |
| School | 2,000 | 2,100 |
| Grocery | 6,800 | 7,000 |
| Restaurant | 4,800 | 4,800 |
| Health Care/Hospital | 4,900 | 4,000 |
| Hotel/Motel | 5,400 | 4,000 |
| Warehouse | 3,100 | 4,000 |
| Miscellaneous | 4,800 | 4,000 |

- The coincident diversified operating factors (CDOFs) generated by business type—for use in predicting demand during the on-peak season at the system peak hour—should be incorporated into the PG&E design estimates. That is, these estimates should be substituted for applicable measures that currently have a coincident diversity factor (CDF) of 0.67. The following are recommended CDOFs by business type:

Exhibit 4-11
CDOFs by Business Type

| Industry Group | Indoor Lighting Peak Hour CDOF | |
|----------------------|--------------------------------|-------------------------|
| | Evaluation Estimate | Program Design Estimate |
| Office | 0.78 | 0.67 |
| Retail | 0.90 | 0.67 |
| College/University | 0.61 | 0.67 |
| School | 0.46 | 0.67 |
| Grocery | 0.91 | 0.67 |
| Restaurant | 0.70 | 0.67 |
| Health Care/Hospital | 0.78 | 0.67 |
| Hotel/Motel | 0.64 | 0.67 |
| Warehouse | 0.78 | 0.67 |
| Miscellaneous | 0.71 | 0.67 |

- Program design first-year energy impact estimates for halogen lamps are generated under the assumption that these fixtures will burn out within the first year, and then either remain out or be replaced by another technology. On-site audit results have clearly shown that the burn-out rates in halogen lamps are small (less than 1 percent of the halogen lamps inspected were burned out), leading to the conclusion that halogen lamp failure rates are not abnormally prevalent one year after the initial installation. We recommend that retention studies carefully record the fate of halogen retrofit technologies, and that, based upon these results, consideration should be given to analyzing program design estimates using hours of operation that extend beyond the life of a halogen lamp.
- Program design demand impact estimates for exterior lighting systems assume no operation during daylight hours, and thus generally predict zero demand during the summer on-peak hour. Both on-site audit schedules and on-site lamp counts have discounted this hypothesis, showing that exterior lights do occasionally operate during daylight hours. Data supporting or discounting these findings should continue to be gathered, in order to better define the probability of exterior fixture operation during daylight hours.
- Program design demand impact estimates recorded in the MDSS (for customers participating in the Customized program indoor lighting measures) were typically found to contain the difference in connected load between the retrofit and existing system. This record of demand impact is inconsistent with the indoor lighting demand recorded for RE customers, where the difference in connected load is adjusted by a coincident diversity factor (typical CDF adjustment for applicable measures is 0.67). We recommend that demand impacts for applicable Customized program measures be adjusted in a similar fashion to ensure consistency in these MDSS records.

Section 5

RECOMMENDATIONS

Recommendations that would enhance future program performance and evaluation are presented in this section. Recommendations regarding evaluation methods are followed by those affecting the program's design. Finally, recommendations regarding the Protocols are offered.

5.1 Evaluation Methods

The evaluation team offers the following comments and recommendations regarding methods used in the 1994 evaluation:

- **General Issues for Quantifying Spillover Effects** - Because the nonparticipant market size is so large, including nonparticipant spillover effects in net-to-gross (NTG) calculations has a profound impact on the final NTG ratios. With the inclusion of nonparticipant effects, the NTG ratios can exceed 2.0. Therefore, the evaluation team recommends collecting additional data (such as trade ally surveys) every second or third year to gauge the program's market movement effects. This second source of data will help support the program's cost recovery claims for spillover effects.
- **Trade on Established Information in Future Evaluations** - This evaluation developed extensive observed and measured operating factor and operating hours information on the highest participation segments, in order to obtain the best estimates of savings for the largest contributors to savings. Less robust information was developed on medium- and low- participation segments. There is no reason to believe that the operating factor and operating hours information developed in this evaluation will change from year to year. QC recommends that PG&E develop an understanding with the CPUC on the validity and use of this information in subsequent evaluations, so that the resources dedicated to subsequent evaluations can be used to improve information on the medium- and low- participation segments, or to develop information on other parameters, rather than just measuring the same parameters over again.

5.2 Measures Offered

The realization rate estimates in *Section 4* (ratio of the evaluation estimated savings to the ex ante savings on a gross and net basis), allow for the identification of technologies or building types that either exceed or fall below expectations.

In general, the commercial lighting technologies offered exceeded program design expectations on both a gross and net basis. This is primarily a result of the ex ante estimates being based upon hours of operation shorter than those measured during the evaluation, and the application of ex ante NTG adjustments that were lower than the values established by the evaluation.

These exhibits allow identification of technologies or building types that should be reassessed in terms of their viability as technologies. This does not imply that these technologies are not valuable, but rather that the original estimate of design savings was higher than that actually achieved. The following segments should be reviewed for viability as part of the overall assessment.

- **Schools** showed low realization rates on both a gross and net basis for most technologies. Those technologies that showed realization rates above 1.0 were generally low- participation/low-impact measures for the schools segment. The evaluation impacts were low because both the hours of operation and the operating factors for the school building segment were substantially below those anticipated. In addition, schools tend not to operate during system peak (summer), and are less likely to be air-conditioned than other commercial buildings. We realize that eliminating schools may not be viable for other reasons.
- **Compact Fluorescents** showed low energy realization rates across all business segments. This is primarily a result of low, but significant, realized savings estimates in the billing regression analysis for all compact fluorescents, which were analyzed as a group. The primary segments for compact fluorescents were hotel/motel and office, representing 45 percent and 21 percent of the gross energy savings, respectively. Compact fluorescents are generally installed in fixtures that have traditionally used incandescent lamps, and as such, are more likely to be switched off when not needed (e.g., in bathrooms, closets, store rooms, etc.). The hotel/motel segment was not subject to on-site inspections because it represented only approximately 5 percent of the savings (energy and demand), and because our experience indicated that compact fluorescents in the hotel/motel segment are either placed in hallways that have 24-hour operation, or in guest rooms, where operation is erratic, and inspection and monitoring are not viable. The realization rate for this technology is low because a significant number of the compact fluorescent lamps installed in the hotel/motel building segment were probably installed in guest rooms. If feasible, PG&E should consider limiting rebates in the hotel/motel building type to common area applications.

All other technologies or building segments with low realization rates are discussed and explained in *Section 4, Evaluation Results Summaries*.

5.3 Protocols

After working with the ex post application of the Protocols for over a year, QC would like to offer the following recommendations:

- **Clarify the Sample Size for the Retention Panel - Table 9A** - Table 9A states as part of the footnote that “The utility should select the top ten measures ranked by net resource value or the number of measures that constitute the first 50% of the estimated resource value, whichever number of measures is less.” The Protocols do not specify the size of the sample required to satisfy this “top ten or 50%” requirement. PG&E has specified a retention panel size of 150 sites (probably based upon the number of on-sites that are being executed). Without a Protocol-based sample size, it is always a guessing game between the consultant and PG&E as to what will satisfy the Protocol requirements for Table 9A.
- **Coordinate Table 11 and Table 6** - The new Table 6 and Table 11 are inconsistent in their application in that Table 11 does not include the footnote indicating the optional nature of some of the inclusions. Tables 6 and 11 should be made consistent with the rest of the Protocols.
- **Clarify Basis, Meaning, and Purpose for Square Footage Estimates (Table 6, C-4, C-5)** - Tables C-4 and C-5 request reporting of results in “Designated Unit(s) of Measurement” for lighting of “load impacts per square foot per 1000 hours of operation.” Under Participant Group, point 4 the square footage estimates is defined as “Square footage estimates (conditioned space and lighted area) used in the end use model(s) to produce estimates of pre installation usage, base year usage, and first year impacts must be based on (a) premise-specific data collected and used for purposes of establishing the terms and conditions of financial assistance, or, if not available; (b) premise-specific data collected on-site from all remaining customers in the participant group evaluation sample.” This definition does not identify whether the square footage to be used in the computation is the retrofitted square footage, or the total facility square footage. In consultation with the PG&E project manager, the total rather than retrofitted square footage, based upon on-site data collection, was applied. It may well be that other contractors are basing computations on retrofitted facility square footage, in which case they will develop totally different estimates. The definition and purpose of the square footage estimates should be clarified to assist the utilities and contractors in developing useful, meaningful Protocol- compliance estimates.

- **Identify Meaningful Designated Units for Controls Measures** - Designated units of load impact per square foot per 1000 hours of operation have no meaning for controls measures where the connected load does not change. These measures include time clocks, photo-cell controls, energy management systems, occupancy sensors, and any other control-oriented measures. While these represent a small portion of the program, it is unclear how the results should be reported. Modifications to the Protocols should be made to clarify how they should be reported.

**1994 COMMERCIAL RETROFIT PROGRAM
EVALUATION OF LIGHTING TECHNOLOGIES**

**FINAL IMPACT EVALUATION REPORT
APPENDICES**

Submitted to

**Elsia Galawish
Market Planning & Research
Pacific Gas & Electric Company
123 Mission Street, Room 2437
San Francisco, CA 94177**

Prepared by

**QUANTUM CONSULTING INC.
2030 Addison Street
Berkeley, CA 94704**

P696.321

February 1996

**1994 COMMERCIAL RETROFIT PROGRAM
EVALUATION OF LIGHTING TECHNOLOGIES**

**FINAL IMPACT EVALUATION REPORT
APPENDICES**

Prepared by

**QUANTUM CONSULTING INC.
2030 Addison Street
Berkeley, CA 94704**

Principal Investigators

**Robert Uhlener
Timothy Caulfield
Joan Mancuso
Bing Xiao
Kris Bradley
Sam Shrauger
Michael Oing**

February 1996

LIST OF APPENDICES

Appendix

- A Sample Design Protocols**
- B Engineering Detailed Computational Methods**
- C Detailed Statistical Impact Analysis Approach and Results**
- D Final Participants Telephone Survey**
- E Final Nonparticipants Telephone Survey**
- F Final Participants On-site Instrument**
- G Final Nonparticipants On-site Instrument**
- H Participants Telephone Survey Response Frequencies**
- I Nonparticipants Telephone Survey Response Frequencies**
- J Purchase Decision Logistic Regression Model**
- K Gross Energy and Demand Impacts by Costing Period**
- L Ex Ante Net-to-Gross Ratios**
- M Commercial Refusal Comments**
- N Nonparticipant Refusal Comments**

Appendix A

SAMPLE DESIGN PROTOCOLS

Appendix A

SAMPLE DESIGN

This appendix presents the existing data sources and sample design approach used for the evaluation of Pacific Gas and Electric Company's (PG&E's) 1994 Commercial Lighting Technologies Evaluation. It begins with a discussion of data sources used in the sample design, followed by detailed descriptions of the steps undertaken to design the telephone survey, on-site audit, and lighting logger samples for the impact and process evaluation. This appendix concludes with a discussion of the California Public Utilities Commission (CPUC) Evaluation and Measurement Protocols (the Protocols) requirements, and how those requirements are met in the current sample design.

A.1 Existing Data Sources for Sample Design

A.1.1 Program Participant Tracking System

The participant tracking system for the Retrofit Express (RE) and Customized Incentives (Customized) Programs is maintained as part of the PG&E Management Decision Support System (MDSS). It contains program application, rebate, and technical information regarding installed measures, including measure descriptions, quantities, rebate amounts, and ex ante demand, energy and therm saving estimates. The MDSS extract used in this evaluation is consistent with data used in the PG&E March 31 Annual Earning Assessment Proceedings (AEAP) Report.

For the RE/Customized programs, participation was tracked at both application and measure levels, and stored in two separate databases, linked by application code and program year. Each application can cover multiple measures and accounts, and each measure is linked to a PG&E electrical or gas service location where the measures are supposed to be installed. The account location is identified by its account number, or a unique seven-digit identification number (PG&E's control number). Because they are not reassigned or changed, like the customer account numbers may be, control numbers are used to identify customer service locations and serve as key fields to link different datasets.

A.1.2 PG&E Billing Data

Two installments of billing data were received for the evaluation. The first, received in March 1995, covers the period between January 1992 and February 1995. The second dataset was received in late November 1995, covering the period from September 1994

through September 1995. Depending upon the time period, the number of unique control numbers in the billing dataset ranged from 723k in 1992, to 758k in 1995. The billing dataset contains monthly energy-consumption information for all nonresidential electric accounts in the PG&E service territory, as well as other billing-related information, such as customer name, service location, rate schedule, and Standard Industrial Classification (SIC) code. The final integrated multi-year billing dataset contains a total of 761,669 unique control numbers.

Preparation of the billing data for selection of participant and comparison group samples is discussed in greater detail in the sample frame sections that follow.

A.2 Sample Design Overview

The sampling plan for the Commercial Lighting Evaluation is based upon analysis of 1994 program participation data and the PG&E billing data. The goal of the design approach is to achieve the most efficient utilization of project resources, in order to meet the following objectives:

- Determine least-cost optimal sample allocation for first-year gross impact analysis, based upon sample size and evaluation accuracy requirements of the Protocols
- Allocate sufficient sample points to meet net-to-gross (NTG) and process evaluation objectives
- Reallocate available resources, wherever feasible, to focus on measures and/or program features deemed most important by PG&E staff for future program design

The lighting evaluation sample design is based upon a nested sample design approach. This approach consists of four groups of customers in subsets, according to the type of information available. The largest customer group includes all of the commercial customers with monthly PG&E billing data and participant tracking data who were rebated for eligible lighting technologies in 1994 (the "participant population"). The smallest group is the metered participants, who have the most comprehensive information available. These participants have lighting logger data, on-site audit data, telephone survey data, participant tracking data, and billing data. A similar nested sample design was also implemented for the comparison group, with the exception that logger data was not collected for that group. The advantage of a nested sample design is that it yields overlapping samples, which are used to compute dual estimates from the engineering and statistical analysis for the same group of customers, and therefore yields meaningful estimates of the realization rates.

A.3 Sample Frame


The first step in sample design is to determine the sampling frame. In general, the sampling frame includes only those customers who are program participants, or likely targets of the program, rather than all customers in the population. It sets the stage for all data collection activities that follow, and determines the availability of billing and demand data for the remainder of the analysis. In addition, it prevents drawing samples outside the sampling frame.

In this evaluation, different analyses (e.g., impact analysis, free rider analysis, and spillover analysis) use different sampling frames, which are defined by analyzing what possible actions a customer in PG&E's service territory could have taken during the study period. This classification provides the basis for the sample design. Without this kind of control, the SAE analysis change model cannot be estimated, since nonprogram-induced changes cannot be separated from changes between periods attributable to other factors, such as weather and economic trends.

Exhibit A-1 illustrates a decision-tree analysis of possible program-related customer actions. The bottom-most groupings on the diagram illustrate the application of each type of action.

- Group A and B accelerated their decision to retrofit and purchased high-efficiency lighting, and all count as net program participants.
- Participants (Groups A, C, E) and nonparticipants unaware of the program (in Groups D, G, and, if any, in Groups B and F) will be used in the free ridership analysis.
- Spillover/free drivership will be analyzed by attempting to identify and assess reasons for adoption among customers in Groups B and F.
- The gross impact analysis will be best controlled for by customers in Groups J and I, since these are customers (both in and out of the market) who possess equipment similar to participants' pre-existing systems.

Exhibit A-1
Possible Customer Actions Related to Program Measures



A.4 Sample Segmentation

Evaluation of the Commercial lighting program at the participant segment level allows more precise, and insightful, evaluation analyses than those undertaken at the aggregate PG&E system level. A participant segmentation scheme was developed to provide some homogeneous segments for analysis; it is, however, sufficiently aggregated for statistical analysis.

The program segmentation consists of two components: participant segmentation and technology segmentation. Based upon the available MDSS database, Exhibits A-2 through A-4 that follow present the final participant and technology segments used in the sample design, data collection, and program analysis and reporting.

The first step in the participant segmentation process grouped firms by business type, as defined in the MDSS. There are a total of 11 business types in the MDSS database; however, approximately 35 percent of the program projects were assigned to two miscellaneous categories, named ALL and Other (OTR). Participants in these two groups were redistributed on the basis of their Second Standard Industrial Classification (SIC2) code, and put into the existing nine business types, and a new, smaller miscellaneous group. The final data distribution, by business type, is presented in Exhibit A-2.

Exhibit A-2
Commercial Lighting Technology Participant Segmentation and Data Distribution in 1994

| Business Type Data Distribution | Commercial | | | | | | | | | | |
|--|------------|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|---------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| RE Program | | | | | | | | | | | |
| Expected Net kW Impacts (kW) | 10,590 | 5,181 | 1,242 | 4,452 | 1,036 | 380 | 1,707 | 1,512 | 1,847 | 631 | 28,578 |
| % kW Impacts | 30.1% | 14.7% | 3.5% | 12.7% | 2.9% | 1.1% | 4.9% | 4.3% | 5.2% | 1.8% | 81.2% |
| Expected Net MWh Impacts (MWh) | 57,387 | 37,494 | 6,573 | 17,279 | 11,229 | 3,260 | 10,810 | 11,325 | 11,664 | 5,045 | 172,068 |
| % MWh Impacts | 27.2% | 17.8% | 3.1% | 8.2% | 5.3% | 1.5% | 5.1% | 5.4% | 5.5% | 2.4% | 81.6% |
| Avoided Cost in 1994 (\$1,000) | 37,108 | 23,665 | 4,047 | 12,540 | 6,687 | 1,515 | 6,556 | 6,534 | 7,991 | 3,087 | 109,729 |
| % Avoided Cost | 27.6% | 17.6% | 3.0% | 9.3% | 5.0% | 1.1% | 4.9% | 4.9% | 5.9% | 2.3% | 81.5% |
| # of Paid Items in 1994 | 3,896 | 2,817 | 351 | 1,464 | 649 | 487 | 1,034 | 713 | 678 | 475 | 12,564 |
| # of Paid Projects in 1994 | 1,467 | 1,256 | 111 | 449 | 279 | 229 | 381 | 251 | 308 | 95 | 4,826 |
| # of Unique Master Accounts | 1,260 | 1,150 | 39 | 383 | 260 | 216 | 293 | 206 | 282 | 78 | 4,167 |
| Customized Program | | | | | | | | | | | |
| Expected Net kW Impacts (kW) | 473 | 456 | 225 | 34 | 731 | 2 | 44 | 10 | 215 | 117 | 2,307 |
| % kW Impacts | 20.0% | 19.3% | 9.5% | 1.4% | 30.9% | 0.1% | 1.9% | 0.4% | 9.1% | 5.0% | 97.5% |
| Expected Net MWh Impacts (MWh) | 2,229 | 2,788 | 819 | 68 | 7,147 | 8 | 247 | 77 | 1,163 | 737 | 15,283 |
| % MWh Impacts | 14.3% | 17.9% | 5.3% | 0.4% | 45.9% | 0.1% | 1.6% | 0.5% | 7.5% | 4.7% | 98.1% |
| Avoided Cost in 1994 (\$1,000) | 1,477 | 1,364 | 538 | 77 | 3,072 | 5 | 115 | 32 | 540 | 520 | 7,740 |
| % Avoided Cost | 18.8% | 17.3% | 6.8% | 1.0% | 39.0% | 0.1% | 1.5% | 0.4% | 6.9% | 6.6% | 98.3% |
| # of Paid Items in 1994 | 23 | 19 | 2 | 1 | 51 | 1 | 3 | 4 | 7 | 81 | 192 |
| # of Paid Projects in 1994 | 20 | 16 | 2 | 1 | 48 | 1 | 3 | 2 | 5 | 4 | 102 |
| # of Unique Master Accounts | 20 | 14 | 2 | 1 | 47 | 1 | 3 | 2 | 4 | 4 | 98 |

Another segmentation element was the size of the firm. The annual energy consumption values were used to group customers into three usage/size categories; small, medium, and large. The comparison group customers are then selected to mirror the underlying distribution of the participant target population. For a given business type, the lighting use area or schedule zone was used to obtain consistent estimates of operating hours and operating factors, as discussed earlier.

As shown in Exhibit A-2, three business types, office, retail, and school, account for more than 70 percent of the projected (ex ante) program avoided cost in 1994. The avoided cost of the Customized program is only about 6 percent of the avoided cost of the RE program.

A.5 Technology Segmentation (RE Program)

For this evaluation, program measures have been reorganized into technology groups, combining technologies with similar energy reduction responses. This grouping strengthens the analysis by increasing the number of points and decreasing the variation per group.

Grouping by technology is important because the use of electricity, and therefore the program impacts, varies widely across technologies. Grouping common technologies reduces variation in the results.

The three elements of the technology segmentation are as follows:

- **Technology Groups**, presented in bold in Exhibit A-3, encompass all measures offered by the RE Program, which are expected to have similar energy saving responses. For example, all T12 to T8 retrofit measures are grouped together, despite the fact that 1) some are new fixtures, and some retrofitted fixture; and 2) different measures have different levels of projected energy savings. The projected energy savings differences will be accounted for in the engineering estimates, yielding similar per-unit responses.
- **Measure Group**, the second level of segmentation, groups measures by the PG&E RE program measure description.
- **Measure**, the highest level of segmentation presented, is the actual measure offered by the PG&E RE program.

In some instances, the measure-level descriptions appear repetitive or overlapping, because measures from both the 1993 and 1994 RE programs are included in the evaluation of measures paid in calendar year 1994.

The RE technology segmentation presented in Exhibit A-3 shows the highest level of segmentation, at the measure level for the commercial sector. While evaluation engineering estimates were developed at this level, final billing regression analysis results were only significant at selected technology-group levels.

T12 to T8 fluorescent technology retrofits, and mercury vapor lamp replacement with high-intensity discharge lamps accounted for more than 70 percent of the program design (ex ante) kW and kWh saving for the RE program.

A.6 Technology Segmentation (Customized Program)

In general, the same technologies are used in custom applications or configurations in the Customized program. The same technology groups applied to the RE program are

Sample Design

also used in the Customized program. The measure groups and measures are, however, specific to the Customized program.

The diversity of measures and applications make segmentation much less important to the analysis of savings for the Customized program. The evaluation of savings for the Customized program relies heavily upon 1) comprehensive review of the paper documentation for the 102 program applicants; (2) grouping of similar projects into common technology groups, when possible; and 3) engineering estimation of savings based upon application information and data collected during on-site audits.

Review of the distribution of energy and demand savings across the measures listed in Exhibit A-4 reveals a much broader distribution of saving across measures. For example, T8/energy-efficient ballasts represent approximately 16 percent of the program design savings, as compared to approximately 30 percent for the RE program. This is not surprising for a customized incentive program accompanied by a comprehensive prescriptive program.

Exhibit A-3 Commercial Lighting Technology Segmentation – RE Program

| Technology Segment Descriptions | PG&E Measure Code | # of Measures | Expected Impacts | | |
|--|-------------------|---------------|------------------|---------------|----------------|
| | | | kW | MWh | |
| Halogen | | | | | |
| All wattages | L1 | 8,647 | 171 | 514 | |
| < 45 watts | L60 | 1,117 | 22 | 67 | |
| > 50 watts | L61 | 11,682 | 397 | 1,752 | |
| Compact Fluorescent Lamps | | | | | |
| Screw In CF | | | | | |
| All wattages | L2, L56 | 8,665 | 293 | 1,623 | |
| 5-13 watts | L62 | 2,173 | 65 | 360 | |
| 14-26 watts | L63 | 8,007 | 238 | 1,329 | |
| Screw In CF- Reusable ballast | | | | | |
| All wattages | L3, L58, L59 | 18,812 | 561 | 3,330 | |
| 5-13 watts | L64 | 20,932 | 628 | 3,278 | |
| 14-26 watts | L65 | 16,092 | 482 | 2,528 | |
| Hard Wired CF | | | | | |
| All wattages | L4 | 20,862 | 1,209 | 6,879 | |
| 5-13 watts | L66 | 10,310 | 309 | 1,689 | |
| 14-26 watts | L67 | 15,635 | 468 | 2,487 | |
| 27-50 watts | L68 | 3,003 | 105 | 550 | |
| Incandescent to Fluorescent Fixture | | | | | |
| With Energy Saving Ballast & T12 Lamps | L7 | 2,634 | 370 | 2,007 | |
| With Electronic Ballast & T8 Lamps | L8 | 1,973 | 318 | 1,522 | |
| Exit Signs | | | | | |
| Incand. to Compact Fluorescents | L5 | 10,249 | 295 | 2,581 | |
| Incand. to LED or Electroluminescent Retrofit | L6 | 5,607 | 181 | 1,583 | |
| Efficient Ballasts Changeouts | | | | | |
| Electronic Ballasts | | | | | |
| 2 Lamp Electronic Ballast | L14 | 74,834 | 942 | 5,311 | |
| 3 Lamp Electronic Ballast | L15 | 3,780 | 58 | 313 | |
| 4 Lamp Electronic Ballast | L16 | 17,528 | 340 | 1,794 | |
| T8 Lamps and Electronic Ballasts | | | | | |
| New Fixtures | | | | | |
| One-Lamp Fixture | L9, L117, L121 | 1,467 | 22 | 107 | |
| Two-Lamp Fixture | L10, L118, L122 | 20,538 | 265 | 1,345 | |
| Three-Lamp Fixture | L11, L123 | 15,221 | 337 | 1,576 | |
| Four-Lamp Fixture | L12, L120, L124 | 17,177 | 452 | 2,619 | |
| 2'-1 U Tube or 2 lamps | L69 | 710 | 10 | 57 | |
| 2'-2 U Tubes or 4 lamps | L70 | 2,022 | 52 | 305 | |
| 2'-3 U Tubes or 6 lamps | L71 | 599 | 31 | 189 | |
| 4'-1 lamp | L72 | 2,606 | 39 | 229 | |
| 4'-2 lamps | L73 | 32,639 | 485 | 2,484 | |
| 4'-3 lamps | L74 | 27,042 | 676 | 3,476 | |
| 4'-4 lamps or 8'-2 lamps | L75 | 30,784 | 923 | 6,214 | |
| Fixture Modif. - Replace Lamps and Ballasts | | | | | |
| Replace Lamps & Ballasts - 2' Fixture | L21 | 46,675 | 327 | 1,897 | |
| Replace Lamps & Ballasts - 3' Fixture | L22 | 24,503 | 189 | 1,048 | |
| Replace Lamps & Ballasts - 4' Fixture | L23 | 1,701,262 | 13,420 | 70,720 | |
| Replace Lamps & Ballasts - 8' Fixture | L24 | 67,921 | 1,019 | 5,844 | |
| Delamp Fluorescent Fixtures | | | | | |
| Fixture Modif. - Delamp and Reflector | | | | | |
| Removal - 2' Lamps & Ballasts | L17 | 4,750 | 100 | 559 | |
| Removal - 3' Lamps | L18 | 4,641 | 69 | 355 | |
| Removal - 4' Lamps | L19 | 404,236 | 12,306 | 62,410 | |
| Removal - 8' Lamps | L20 | 32,283 | 2,059 | 12,152 | |
| High Output T8 & T10 Conversion w/ Delamp | | | | | |
| T10 & Energy Saving Ballast | L76 | 317 | 7 | 42 | |
| T10 or T8 & Electronic Ballast | L77 | 1,308 | 39 | 199 | |
| High Intensity Discharge | | | | | |
| Interior Compact HPS from Incand. | | | | | |
| 0-100 watts HPS | L25 | 651 | 74 | 412 | |
| 0-35 watts HPS | L78 | 53 | 4 | 19 | |
| 36-70 watts HPS | L79 | 664 | 50 | 292 | |
| 71-100 watts HPS | L80 | 473 | 49 | 240 | |
| Interior Standard MH from Merc. Vapor | | | | | |
| 101-175 watts MH | L26 | 2,254 | 283 | 1,498 | |
| 176-250 watts MH | L27, L37 | 5,977 | 2,552 | 13,997 | |
| 251-400 watts MH | L81 | 5,084 | 2,107 | 12,036 | |
| Exterior HPS from Merc. Vapor | | | | | |
| 0-100 watts | L28 | 7,840 | 0 | 3,615 | |
| 101-175 watts | L29 | 3,418 | 0 | 3,362 | |
| 176 watts & greater | L30 | 5,105 | 11 | 12,652 | |
| Reduced Wattage Lighting | | | | | |
| Controls | | | | | |
| Time Clocks | L31 | 713 | 0 | 312 | |
| Occupancy Sensors | | | | | |
| 72-350 watts controlled | L32 | 3,287 | 195 | 870 | |
| 351-1000 watts controlled | L33 | 2,907 | 588 | 2,286 | |
| 1000 watts and greater controlled | L34 | 769 | 209 | 1,053 | |
| Wall Mounted | L82 | 7,587 | 466 | 2,082 | |
| Ceiling Mounted | L83 | 5,704 | 1,181 | 4,589 | |
| Bypass/Delay | L35 | 694 | 72 | 280 | |
| Photocell | L36 | 1,882 | 0 | 185 | |
| Other Lighting | | | | | |
| | L114 - L116 | 154 | 4 | 16 | |
| RE Program Total | | ALL | 2,894,643 | 48,971 | 279,149 |

Exhibit A-4
Commercial Lighting Technology Segmentation – Customized Program

| Technology Segment Descriptions | PG&E Measure Code | # of Items | Expected Impacts | |
|--|----------------------|---------------|------------------|---------------|
| | | | kW | MWh |
| Halogen | | | | |
| Low Voltage Halogen | 182 | 0 | 0 | 0 |
| Halogen Lamp Conversion | 156 | 2 | 4 | 18 |
| Compact Fluorescent Lamps | 102 | 4 | 26 | 130 |
| Incandescent to Fluorescent Fixture | | | | |
| Incandescent to Fluorescent - Indoor | 101 | 1 | 5 | 42 |
| Incandescent to Fluorescent - Outdoor | 120 | 4 | 0 | 314 |
| Exit Signs | 155 | 2 | 1 | 12 |
| Efficient Ballasts Changeouts | | | | |
| Modified Electromagnetic Ballasts | | | | |
| Hybrid Ballasts | 147 | 6 | 165 | 1,258 |
| Primium Ballast (Core & Coil) | 148 | 2 | 56 | 387 |
| Electronic Ballasts | 149 | 4 | 677 | 2,937 |
| T8 Lamps and Electronic Ballasts | 146 | 20 | 407 | 2,624 |
| Delamp Fluorescent Fixtures | | | | |
| Fixture Modif.- Delamp and Reflector | 181 | 1 | 16 | 181 |
| Remove Lamps Reduce Lights | 150 | 1 | 13 | 100 |
| High Intensity Discharge | | | | |
| Metal Halide Fixtures - Interior | 104 | 1 | 2 | 10 |
| HPS/LPS - Interior | 105 | 2 | 98 | 563 |
| HPS/LPS - Exterior | 123 | 1 | 0 | 105 |
| Reduced Wattage Lighting | | | | |
| 4' Energy Saver Fluorescent Lamps | 142 | 0 | 0 | 0 |
| 8' Energy Saver Fluorescent Lamps | 143 | 8 | 124 | 1,128 |
| T8 Fluorescent Lamps | 144 | 3 | 119 | 442 |
| Lower Wattage Incandescent Lamps | 152 | 1 | 2 | 5 |
| Current Limiters | 153 | 1 | 22 | 168 |
| Controls | | | | |
| Lighting Controls | 160 | 4 | 47 | 896 |
| Lighting EMS | 164 | 13 | 0 | 1,156 |
| Motion/Occupancy Sensors | 166 | 1 | 30 | 118 |
| Photocell | 168 | 1 | 0 | 115 |
| Bypass/Delay | 169 | 1 | 0 | 11 |
| Lighting Other | | | | |
| Daylighting | 191 | 0 | 0 | 0 |
| Optical Reflectors | 193 | 5 | 12 | 50 |
| Lighting Other | 151,195,199 | 131 | 1,743 | 8,826 |
| Customized Program Total | ALL | 220 | 3,568 | 21,596 |

The column titled “# of Items” in Exhibit A-4 refers to the number of times that type of measure appeared on an application form. Because each application is different, the total number of measures is not a relevant index.

The distribution of measures reflects the allotment of these applications after reallocation based upon a review of the paper application files. As originally allocated in the MDSS, the “other lighting” category represented approximately 50 percent of the energy and load ex ante estimates of savings. Reallocation of these applications was important in order to include the maximum number of measures into the billing regression analysis, and maximize the transfer of realization rates from the billing analysis to similar measures in the Customized program.

A.7 Sample Weighting Techniques

The 1994 Commercial Lighting Evaluation sample design allocated sample sizes in proportion to the program segment-level avoided cost, which served as the primary segment-level sample weights in the subsequent sample allocation.

A key step in developing the sampling plan is to calculate appropriate weights by the segments mentioned above. The purpose of this weighting scheme is to identify which technologies and/or business types in the RE and Customized programs account for the greatest impact on the program resource and shareholder values. For this evaluation, the primary prioritization relies upon program segment-level avoided cost reported in the MDSS database, which is a combination of expected program demand and energy savings weighted by PG&E system marginal costs.

Another consideration in designing the sample is compliance with the Protocols. The sample allocation was designed to meet the sample size and relative precision requirements of the Protocols, as established in Table 5.

Finally, the sample allocation also reflects feedback from PG&E program staff regarding future design of the program and the uncertainty of the current program estimates.

Exhibit A-5 presents the avoided cost, by business type and measure group, for the RE program.

Exhibit A-5
Commercial Lighting Technologies – RE Program
Percentage of Avoided Cost by Business Type and Measure Group

| Business Type \ Measure Group | Commercial | | | | | | | | | | |
|---|------------|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|--------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Halogen | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| Compact Fluorescent Lamps | | | | | | | | | | | |
| Screw In CF | 0.1% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.2% |
| Screw In CF- Reusable ballast | 0.2% | 0.1% | 0.0% | 0.2% | 0.0% | 0.1% | 0.1% | 0.4% | 0.0% | 0.0% | 1.1% |
| Hard Wired CF | 1.0% | 0.2% | 0.2% | 0.4% | 0.0% | 0.2% | 0.4% | 2.4% | 0.0% | 0.1% | 5.0% |
| Incandescent to Fluorescent Fixture | | | | | | | | | | | |
| With Energy Saving Ballast & T12 Lamps | 0.2% | 0.1% | 0.0% | 0.1% | 0.0% | 0.0% | 0.1% | 0.1% | 0.0% | 0.0% | 0.8% |
| With Electronic Ballast & T8 Lamps | 0.2% | 0.1% | 0.0% | 0.2% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.6% |
| Exit Signs | | | | | | | | | | | |
| Incand. to Compact Fluorescents | 0.4% | 0.1% | 0.0% | 0.2% | 0.0% | 0.0% | 0.1% | 0.0% | 0.0% | 0.1% | 0.9% |
| Incand. to LED or Electroluminescent Retrofit | 0.2% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.2% | 0.0% | 0.0% | 0.0% | 0.6% |
| Efficient Ballasts Changeouts | | | | | | | | | | | |
| Electronic Ballasts | 0.8% | 0.3% | 0.3% | 0.5% | 0.6% | 0.0% | 0.1% | 0.0% | 0.1% | 0.2% | 2.8% |
| T8 Lamps and Electronic Ballasts | | | | | | | | | | | |
| New Fixtures | 2.0% | 1.6% | 0.2% | 1.3% | 1.4% | 0.0% | 0.2% | 0.2% | 0.5% | 0.1% | 7.5% |
| Fixture Modif.- Replace Lamps and Ballasts | 12.4% | 5.9% | 1.2% | 4.4% | 1.2% | 0.1% | 3.2% | 0.3% | 1.1% | 0.6% | 30.5% |
| Delamp Fluorescent Fixtures | | | | | | | | | | | |
| Fixture Modif.- Delamp and Reflector | 14.9% | 3.9% | 1.3% | 3.2% | 1.6% | 0.2% | 2.0% | 0.3% | 1.2% | 0.6% | 29.1% |
| High Output T8 & T10 Conversion w/ Delamp | 0.1% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.1% |
| High Intensity Discharge | | | | | | | | | | | |
| Interior Compact HPS from Incand. | 0.1% | 0.2% | 0.0% | 0.1% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.4% |
| Interior Standard MH from Merc. Vapor | 2.4% | 3.6% | 0.1% | 1.2% | 0.2% | 0.0% | 0.2% | 0.0% | 3.0% | 0.6% | 11.3% |
| Exterior HPS from Merc. Vapor | 1.0% | 1.6% | 0.2% | 1.1% | 0.2% | 0.2% | 0.2% | 0.7% | 0.3% | 0.4% | 5.7% |
| Reduced Wattage Lighting | 0.2% | 0.1% | 0.1% | 0.2% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.6% |
| Controls | | | | | | | | | | | |
| Time Clocks | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| Occupancy Sensors | 1.5% | 0.2% | 0.1% | 0.4% | 0.0% | 0.0% | 0.2% | 0.0% | 0.0% | 0.1% | 2.5% |
| Bypass/Delay | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.1% |
| Photocell | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| Other Lighting | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| Program Total | 37.7% | 17.9% | 3.9% | 13.5% | 5.2% | 1.0% | 7.0% | 4.6% | 6.4% | 2.8% | 100.0% |

A.8 Sample Sizes

The PG&E C/I Lighting Program Evaluation sampling plan consists of a telephone sample of 900 customers (450 participants and 450 comparison group customers), an on-site audit sample of 300 customers (150 participants and 150 comparison group customers), and a lighting logger sample of 150 participants. The sample design complies with the Protocols and meets the program evaluation objectives. In this evaluation, the sampling unit is the PG&E control number, which defines a unique service address. Applications in the MDSS database can cover more than one control number. The distribution of these sample points is presented in Exhibit A-6.

Exhibits A-7 through A-9 present the detailed RE program sampling for the telephone survey, on-site audit, and lighting logger samples, respectively. Because of the

relatively large number of measures, sample size and allocation will only be shown at the measure-group level.

Telephone Survey Sample Allocation by Segment - For each segment, the RE program sample design allocated the sample in proportion to the program-avoided cost by segment. This sample design (Exhibit A-7) concentrates sample points to segments that represent highest impact, in order to obtain the best estimate of impact for the largest portion of the population. This sample allocation, combined with the random sampling techniques within each segment, produces a stratified random telephone survey sample representing the RE lighting program-participant population (paid in 1994). In addition, the same process also generates a nonparticipant sample that is used as a comparison group for the evaluation.

On-site Audit Sample Allocation by Segment - Exhibit A-8 presents the RE program sample allocation for the on-site audit sample. Similar to the telephone survey sample, this sample was also structured to be approximately proportional to the program segment-level avoided cost estimates.

Lighting Logger Sample Allocation by Segment - The sample allocation for the lighting logger sample is presented in Exhibit A-9. This sample is not intended to be a random sample, nor strictly proportional to the program-avoided cost. The sample allocations were manipulated in order to assure adequate sample sizes for calibration of engineering models (see *Appendix B*).

Exhibit A-6
Commercial Lighting Evaluation Sample Allocation

| Program | Sample Frame | Telephone Survey | | On-Site Audit | Lighting Logger |
|------------------|--------------|------------------|---------------------|---------------|-----------------|
| | | Lighting | HVAC Process Survey | | |
| Participant | 2,193 | 450 | 80 | 150 | 150 |
| Comparison Group | 4,039 | 450 | 0 | 150 | 0 |
| TOTAL | 6,232 | 900 | 80 | 300 | 150 |

*Based upon a preliminary analysis of the incomplete 1994 MDSS database.

†Actual numbers will be determined when the billing data becomes available.

Exhibit A-7
Retrofit Express Program – Commercial Lighting Technologies
Telephone Survey Sample Allocation

| Business Type Measure Group | Commercial Sector | | | | | | | | | | |
|---|-------------------|-----------|--------------|-----------|-----------|------------|-------------|-------------|-----------|----------|------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Halogen | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Compact Fluorescent Lamps | | | | | | | | | | | |
| Screw In CF | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Screw In CF- Reusable ballast | 1 | 0 | 0 | 1 | 0 | 0 | 0 | 2 | 0 | 0 | 4 |
| Hard Wired CF | 4 | 1 | 1 | 2 | 0 | 3 | 2 | 11 | 0 | 0 | 24 |
| Incandescent to Fluorescent Fixture | | | | | | | | | | | |
| With Energy Saving Ballast & T12 Lamps | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 2 |
| With Electronic Ballast & T8 Lamps | 1 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 2 |
| Exit Signs | | | | | | | | | | | |
| Incand. to Compact Fluorescents | 2 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 3 |
| Incand. to LED or Electroluminescent Retrofit | 1 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 2 |
| Efficient Ballasts Changeouts | | | | | | | | | | | |
| Electronic Ballasts | 4 | 1 | 1 | 2 | 3 | 1 | 1 | 0 | 0 | 0 | 13 |
| T8 Lamps and Electronic Ballasts | | | | | | | | | | | |
| New Fixtures | 9 | 7 | 1 | 6 | 6 | 0 | 1 | 1 | 2 | 0 | 33 |
| Fixture Modif.- Replace Lamps and Ballasts | 57 | 27 | 5 | 20 | 5 | 4 | 15 | 1 | 5 | 0 | 139 |
| Delamp Fluorescent Fixtures | | | | | | | | | | | |
| Fixture Modif.- Delamp and Reflector | 68 | 18 | 7 | 14 | 7 | 5 | 9 | 3 | 5 | 0 | 136 |
| High Output T8 & T10 Conversion w/ Delamp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| High Intensity Discharge | | | | | | | | | | | |
| Interior Compact HPS from Incand. | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 |
| Interior Standard MH from Merc. Vapor | 11 | 16 | 1 | 5 | 1 | 3 | 1 | 0 | 13 | 0 | 51 |
| Exterior HPS from Merc. Vapor | 4 | 7 | 1 | 5 | 1 | 3 | 1 | 3 | 1 | 0 | 26 |
| Reduced Wattage Lighting | 1 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 2 |
| Controls | | | | | | | | | | | |
| Time Clocks | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Occupancy Sensors | 7 | 1 | 0 | 2 | 0 | 0 | 1 | 0 | 0 | 0 | 11 |
| Bypass/Delay | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Photocell | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Other Lighting | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Program Participant | 172 | 79 | 17 | 60 | 23 | 19 | 32 | 22 | 26 | 0 | 450 |
| Comparison Group | 172 | 79 | 17 | 60 | 23 | 19 | 32 | 22 | 26 | 0 | 450 |

Exhibit A-8
 Retrofit Express Program – Commercial Lighting Technologies
 On-Site Audit Sample Allocation

| Business Type Measure Group | Commercial Sector | | | | | | | | | | |
|---|-------------------|-----------|--------------|-----------|-----------|------------|-------------|-------------|-----------|----------|------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Halogen | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Compact Fluorescent Lamps | | | | | | | | | | | |
| Screw In CF | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Screw In CF- Reusable ballast | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 |
| Hard Wired CF | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 |
| Incandescent to Fluorescent Fixture | | | | | | | | | | | |
| With Energy Saving Ballast & T12 Lamps | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| With Electronic Ballast & T8 Lamps | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Exit Signs | | | | | | | | | | | |
| Incand. to Compact Fluorescents | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 |
| Incand. to LED or Electroluminescent Retrofit | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Efficient Ballasts Changeouts | | | | | | | | | | | |
| Electronic Ballasts | 3 | 0 | 0 | 0 | 4 | 0 | 0 | 0 | 0 | 0 | 7 |
| T8 Lamps and Electronic Ballasts | | | | | | | | | | | |
| New Fixtures | 4 | 2 | 0 | 2 | 4 | 0 | 0 | 0 | 3 | 0 | 15 |
| Fixture Modif.- Replace Lamps and Ballasts | 20 | 11 | 0 | 7 | 4 | 0 | 0 | 0 | 4 | 0 | 46 |
| Delamp Fluorescent Fixtures | | | | | | | | | | | |
| Fixture Modif.- Delamp and Reflector | 23 | 9 | 0 | 5 | 4 | 0 | 0 | 0 | 5 | 0 | 46 |
| High Output T8 & T10 Conversion w/ Delamp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| High Intensity Discharge | | | | | | | | | | | |
| Interior Compact HPS from Incand. | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Interior Standard MH from Merc. Vapor | 5 | 5 | 0 | 2 | 0 | 0 | 0 | 0 | 4 | 0 | 16 |
| Exterior HPS from Merc. Vapor | 3 | 2 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 7 |
| Reduced Wattage Lighting | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Controls | | | | | | | | | | | |
| Time Clocks | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Occupancy Sensors | 2 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 4 |
| Bypass/Delay | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Photocell | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Program Participant | 69 | 29 | 0 | 20 | 16 | 0 | 0 | 0 | 16 | 0 | 150 |
| Comparison Group | 69 | 29 | 0 | 20 | 16 | 0 | 0 | 0 | 16 | 0 | 150 |

Exhibit A-9
Retrofit Express Program – Commercial Lighting Technologies
Lighting Logger Sample Allocation

| Business Type Measure Group | Commercial Sector | | | | | | | | | | |
|---|-------------------|-----------|--------------|-----------|----------|------------|-------------|-------------|-----------|----------|------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total |
| Halogen | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Compact Fluorescent Lamps | | | | | | | | | | | |
| Screw In CF | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Screw In CF- Reusable ballast | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 1 |
| Hard Wired CF | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 4 | 0 | 0 | 6 |
| Incandescent to Fluorescent Fixture | | | | | | | | | | | |
| With Energy Saving Ballast & T12 Lamps | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| With Electronic Ballast & T8 Lamps | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Exit Signs | | | | | | | | | | | |
| Incand. to Compact Fluorescents | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 |
| Incand. to LED or Electroluminescent Retrofit | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Efficient Ballasts Changeouts | | | | | | | | | | | |
| Electronic Ballasts | 3 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 5 |
| T8 Lamps and Electronic Ballasts | | | | | | | | | | | |
| New Fixtures | 3 | 2 | 0 | 2 | 2 | 0 | 0 | 0 | 1 | 0 | 10 |
| Fixture Modif.- Replace Lamps and Ballasts | 19 | 9 | 3 | 7 | 3 | 0 | 5 | 0 | 4 | 1 | 51 |
| Delamp Fluorescent Fixtures | | | | | | | | | | | |
| Fixture Modif.- Delamp and Reflector | 22 | 6 | 4 | 5 | 2 | 0 | 4 | 0 | 3 | 0 | 46 |
| High Output T8 & T10 Conversion w/ Delamp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| High Intensity Discharge | | | | | | | | | | | |
| Interior Compact HPS from Incand. | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Interior Standard MH from Merc. Vapor | 4 | 5 | 0 | 3 | 0 | 0 | 0 | 0 | 4 | 0 | 16 |
| Exterior HPS from Merc. Vapor | 1 | 2 | 0 | 2 | 0 | 0 | 0 | 2 | 1 | 0 | 8 |
| Reduced Wattage Lighting | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Controls | | | | | | | | | | | |
| Time Clocks | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Occupancy Sensors | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 6 |
| Bypass/Delay | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Photocell | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Program Participant | 61 | 26 | 7 | 19 | 7 | 0 | 9 | 7 | 13 | 1 | 150 |
| Comparison Group | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

A.9 Billing Data Preparation

Once the sampling approach and segmentation scheme are determined, the next step is the preparation of the billing and tracking system data for sample selection. A final analysis dataset of billing data was created, consisting of all 6,037 lighting program participants paid in 1994, and 104,052 1994 nonparticipants. All unique lighting program control numbers, representing participants paid in 1994 and identified from PG&E's MDSS, were retained in the final dataset, regardless of the quality of customer billing data. However, the nonparticipant control numbers that were retained were identified as eligible nonparticipants and screened for data quality using a number of criteria.

As noted above, the entire PG&E nonresidential population was initially identified as the 754,928 accounts with PG&E control numbers that were not in the set of 6,037 control numbers of lighting program participants paid in 1994. From this group of

754,928 accounts, potential nonparticipant accounts were identified as the 278,073 accounts with SIC codes matching any of the 589 unique SIC codes represented in the 1994 lighting program participant population. Of these 278,073 customers, 104,052 were identified as eligible for the final analysis dataset based upon the quality of their billing data. Criteria considered in the assessment of the quality of customer billing data quality are as follows:

- Presence of a billing rate schedule for the customer: Customers are required to have a rate schedule code for all years spanned by the billing data. There were 53,582 accounts rejected for failing to satisfy this criterion.
- Quality of usage readings for the customer for the period of January 1993 through February 1995: Customers are required to have non-missing, non-zero usage values for all months spanned by the billing data. Customers are also required to have realistic PG&E revenues for the period. Realistic revenues are defined as revenues of at least \$0.03 per kWh, but no greater than \$0.25 per kWh. A total of 42,552 accounts were eliminated from eligibility for the final analysis database based upon this criterion.
- Cohesion of billing data across years: The original billing data was received by year ,i.e., the billing data for each calendar year was stored on a separate data tape. Data from different billing tapes were checked to ensure that the first month on each tape was immediately after the last month of the previous year's tape. A total of 52,667 accounts have mismatched billing data across tapes.
- Presence of multiple billing records for the customer in the 1993, 1994, or 1995 billing data: Customers with multiple records in any of the three billing years were ineligible for the final analysis dataset. This criterion removed 16,124 accounts from the final analysis database.
- Quality of read dates for the customer: Read dates are required to be monotonic, and within 180 days of the expected date range for the read date. Expected date ranges are determined from the year of the tape from which the date was read, as well as the order of the variable in that particular year's data. Based upon this requirement, 539 accounts were considered ineligible for the final analysis database.
- Absence of changes in key elements of the customer's billing data over the billing data period: Customers were selected only if the following remained constant over the entire January 1993 - February 1995 period:
 - Corporation identification number
 - Date on premises
 - Date on system
 - Meter number
 - Rate schedule
 - Premise identification number

- Second SIC Code (SIC2)
- There were 8,557 accounts eliminated from eligibility for the final analysis database as a result of this screening requirement.

The final billing data analysis database, created using the methods detailed above, consisted of a total of 6,037 participant and 104,052 nonparticipant accounts. This analysis database is used in the generation of participant and comparison group telephone survey and on-site survey sample frames. The methods and stages of data attrition used in the generation of these sample frames are described below.

A.10 Participant Sample Frame

This section details the reduction of the eligible participant population to a sample frame suitable for impact analysis. None of the criteria used to screen the sample are believed to have adverse impacts on the sample representativeness; therefore, the screening criteria preserve the transferability of the impact results to the population.

Unlike nonparticipant accounts, for which data attrition is a prerequisite for inclusion in the final billing data analysis dataset, all 6,037 lighting program accounts paid in 1994 were included in the analysis dataset, regardless of the quality of their data. For these accounts, all aspects of data attrition and screening are undertaken at the sample frame construction stage, using criteria similar to those used in the screening of nonparticipant accounts, together with several additional criteria. The final participant sample frame consists of 1,625 commercial customers drawn from the eligible population of 6,741 lighting program participants paid in 1994. Criteria considered in the assessment of the quality of participant account billing data are as follows:

- Presence of a billing rate schedule for the customer: Customers are required to have a rate schedule code for all years spanned by the billing data. Fifty-six customers were rejected for failing to satisfy this criterion.
- Quality of usage readings for the customer for the period of January 1993 through February 1995: Customers are required to have non-missing, non-zero usage values for all months spanned by the billing data. Customers are also required to have realistic PG&E revenues for the period. Realistic revenues are defined as revenues of at least \$0.03 per kWh, but no greater than \$0.25 per kWh. There were 1,236 customers rejected for failing to satisfy this criterion.
- Cohesion of billing data across years: The original billing data was received by year, i.e., the billing data for each calendar year was stored on a separate data tape. Data from different billing tapes was checked to ensure that the first month on each tape was immediately after the last month of the previous year's tape. A total of thirteen accounts have mismatched billing data across tapes.

- Presence of multiple billing records for the customer in the 1993, 1994, or 1995 billing data: Customers with multiple records in any of the three billing years were ineligible for the final analysis dataset. No customers were rejected for failing to satisfy this criterion.
- Quality of read dates for the customer: Read dates are required to be monotonic, and within 180 days of the expected date range for the read date. Expected date ranges are determined from the year of the tape from which the date was read, as well as the order of the variable in that particular year's data. There were 213 customers rejected for failing to satisfy this criterion.
- Absence of changes in key elements of the customer's billing data over the billing data period: Customers were selected only if the following remained constant over the entire January 1993 - February 1995 period:
 - Corporation identification number
 - Date on premises
 - Date on system
 - Meter number
 - Rate schedule
 - Premise identification number
 - Second SIC Code (SIC2)
- There were 779 customers rejected for failing to satisfy this criterion.
- Nonparticipation in the 1993 lighting program: Accounts included in the sample frame for the 1994 lighting program could not have participated in the 1993 program. There were 596 accounts eliminated from sample frame eligibility for this reason. However, this group of nonparticipants was later added back to the sample frame near the end of the survey data collection, based upon the participant definition in the Protocols, *Appendix A*. The sample selection procedure for this group of customers was designed to match the probability of selection for the rest of the customers in the sample frame, so that the combined sample will still be a random sample in each of the sample stratum.
- Participation in other incentive programs: Accounts that participated in other incentive programs in 1994 were excluded from eligibility for the lighting program sample frame. There were 176 accounts eliminated for this reason.

- PG&E division representative deletion requests: Lists of customers in the sample frame were sent to the appropriate PG&E division representative for approval. Based upon responses from the representatives, customers were deleted from the sample frame. These deletions removed 172 customers from eligibility for the sample frame.
- Reasonable usage across years and populated telephone numbers: Accounts are screened to ensure that the mean usage on the account for 1994 is no more than twice the mean usage on the account for 1993. Accounts are also screened to ensure they have reasonable phone numbers, and any accounts with no telephone number, or zeros in place of a number, are rejected from the sample frame. There were 1,171 accounts eliminated from eligibility for failing to meet this criterion.

The 1,625 participant accounts remaining following this screening process comprise the final participant sample frame used in the collection of telephone and on-site survey data.

A.11 Comparison Group Sample Frame

The comparison group sample frame consists of 4,039 commercial customers drawn from the eligible population of 104,052 nonparticipants in the 1994 lighting program. Since comparison group surveys were conducted only for customers in the commercial sector, the first step in creation of the sample frame is to limit eligibility to only those accounts having SIC codes representing commercial business activities. Further screening, based upon several factors, of the remaining 87,450 eligible accounts was undertaken to arrive at the final comparison group sample frame. The screening criteria used, and the number of customers eliminated as a result of each criterion, are detailed below.

- Excessive changes in usage between 1993 and 1994 billing years: Accounts are screened to ensure that the mean usage on the account for 1994 is no more than twice the mean usage on the account for 1993. There were 2,868 accounts eliminated for failing to meet this criterion.
- Geographic location of customers: Accounts are screened to insure that they fall within the geographic regions targeted for comparison group telephone survey and on-site survey data collection. There were 55,052 accounts eliminated for failing to meet this criterion.
- Customer presence in other survey samples: Accounts sharing PG&E corporation identification numbers with any accounts in the sample frame for the HVAC program evaluation survey conducted by SBW, Inc., the lighting program evaluation participant survey sample frame, and the lighting program evaluation comparison group survey pretest sample frame were eliminated from eligibility for the lighting program evaluation comparison group sample frame. There were 3,095 accounts eliminated for this reason.

Following the data screening, the comparison group survey sample frame of 4,039 customers is randomly drawn from the 26,435 accounts that satisfied all of the screening criteria used in construction of the sample frame. In drawing the sample frame, targets are established for each business type and usage segment, so that the sample frame distribution, by business type and usage segment, is the same as that of the surveyed lighting program participant population. The drawing is conducted in this manner to ensure sufficient representation of each business type/usage segment combination in the sample frame and allow survey data collection in accordance with the sample design.

A.12 Final Sample Sizes

The final sample sizes for the telephone, on-site, and lighting logger samples collected for the evaluation are presented in this section. Exhibit A-10 details the commercial sector telephone and on-site survey distributions by program (RE or Customized), and an indoor/outdoor technology classification.

Exhibit A-10

Telephone and On-Site Survey Data Collected by Program and End Use

| Program | Total Surveys | On-Site Audits | On-Site Without Surveys | Analysis Dataset |
|-------------------------------|----------------------|-----------------------|--------------------------------|-------------------------|
| Indoor Lighting (RE) | 432 | 134 | 0 | 432 |
| Indoor Lighting (Customized) | 19 | 17 | 1 | 20 |
| Outdoor Lighting (RE) | 28 | 4 | 0 | 28 |
| Outdoor Lighting (Customized) | 0 | 0 | 0 | 0 |
| Commercial Participant Total | 479 | 155 | 1 | 480 |
| Commercial Comparison Group | 458 | 143 | 0 | 458 |

A.12.1 Telephone Survey Sample

Telephone surveys were collected for a total of 937 customers, 479 of which are participants, (451 indoor lighting participants, and 28 outdoor lighting measure participants) and the remaining 458 are in the comparison group. The telephone survey data is designed to provide insight into changes in the quantity and usage patterns of electrical equipment present at an account. The final sample allocation of the telephone survey sample, by technology and business type, is detailed in Exhibit A-11.

Exhibit A-11
Telephone Survey Sample Sizes by Business Type and Technology

| Business Type ** | Commercial Sector | | | | | | | | | | |
|---------------------------------------|-------------------|------------|--------------|-----------|-----------|------------|-------------|-------------|-----------|-----------|------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total * |
| Lighting Technology | | | | | | | | | | | |
| RE Indoor Measures | | | | | | | | | | | |
| Halogen | 5 | 6 | 0 | 0 | 0 | 0 | 2 | 1 | 1 | 3 | 18 |
| Compact Fluorescent Lamps | 60 | 24 | 0 | 68 | 7 | 20 | 24 | 21 | 6 | 23 | 253 |
| Incandescent to Fluorescent Fixture | 6 | 5 | 0 | 4 | 0 | 0 | 3 | 0 | 0 | 3 | 21 |
| Exit Signs | 16 | 5 | 0 | 17 | 3 | 1 | 5 | 1 | 3 | 8 | 59 |
| Efficient Ballasts Changeouts | 21 | 11 | 0 | 17 | 22 | 0 | 8 | 0 | 3 | 6 | 88 |
| T8 Lamps and Electronic Ballasts | 105 | 102 | 2 | 97 | 22 | 8 | 40 | 3 | 26 | 32 | 437 |
| Delamp Fluorescent Fixtures | 53 | 57 | 1 | 28 | 11 | 5 | 17 | 0 | 13 | 13 | 198 |
| High-Intensity Discharge | 22 | 41 | 0 | 24 | 8 | 3 | 0 | 3 | 14 | 20 | 135 |
| Reduced Wattage Lighting | 13 | 7 | 0 | 10 | 4 | 0 | 4 | 0 | 2 | 3 | 43 |
| Controls | 11 | 16 | 0 | 10 | 4 | 0 | 5 | 5 | 8 | 11 | 70 |
| Other Lighting | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Customized Indoor Measures | 3 | 6 | 0 | 1 | 16 | 1 | 1 | 1 | 1 | 2 | 32 |
| RE/Customized Outdoor Measures | 6 | 16 | 3 | 2 | 0 | 2 | 2 | 0 | 1 | 1 | 33 |
| Participant Total | 114 | 122 | 1 | 65 | 38 | 22 | 34 | 15 | 33 | 35 | 479 |
| Comparison Group Sample | 138 | 104 | 3 | 33 | 30 | 29 | 20 | 36 | 32 | 33 | 458 |

* Sum may exceed the total sample size because of participation in multiple measures.

** Survey self-report business type.

A.12.2 On-Site Survey Sample

A total of 291 on-site surveys were conducted for the commercial sector, with 155 participants and 143 comparison group customers. In accordance with the nested sample approach, 290 of these 291 surveys were conducted with customers who also completed a telephone survey. One customer completed the on-site survey, but did not complete the telephone survey. Distribution of the on-site survey sample, by business and technology type, is presented in Exhibit A-12 below.

Exhibit A-12
On-Site Survey Sample Sizes by Business Type and Technology

| Lighting Technology | Commercial Sector | | | | | | | | | | |
|---------------------------------------|-------------------|-----------|--------------|-----------|-----------|------------|-------------|-------------|-----------|-----------|------------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. | Total * |
| RE Indoor Measures | | | | | | | | | | | |
| Halogen | 3 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 6 |
| Compact Fluorescent Lamps | 27 | 4 | 0 | 11 | 6 | 3 | 1 | 0 | 4 | 7 | 63 |
| Incandescent to Fluorescent Fixture | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 |
| Exit Signs | 7 | 0 | 0 | 2 | 2 | 0 | 0 | 0 | 1 | 3 | 15 |
| Efficient Ballasts Changeouts | 4 | 0 | 0 | 8 | 20 | 0 | 0 | 0 | 0 | 3 | 35 |
| T8 Lamps and Electronic Ballasts | 43 | 18 | 0 | 25 | 17 | 4 | 3 | 0 | 9 | 15 | 134 |
| Delamp Fluorescent Fixtures | 27 | 10 | 0 | 3 | 4 | 1 | 1 | 0 | 6 | 4 | 56 |
| High-Intensity Discharge | 8 | 13 | 0 | 6 | 2 | 0 | 0 | 0 | 4 | 6 | 39 |
| Reduced Wattage Lighting | 3 | 0 | 0 | 5 | 3 | 0 | 0 | 0 | 0 | 2 | 13 |
| Controls | 6 | 3 | 0 | 2 | 0 | 0 | 0 | 0 | 1 | 8 | 20 |
| Other Lighting | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Customized Indoor Measures | 3 | 1 | 0 | 1 | 14 | 0 | 0 | 0 | 1 | 1 | 21 |
| RE/Customized Outdoor Measures | 0 | 2 | 0 | 2 | 0 | 0 | 0 | 0 | 1 | 0 | 5 |
| Participant Total | 43 | 30 | 0 | 20 | 26 | 5 | 3 | 0 | 14 | 14 | 155 |
| Comparison Group Sample | 57 | 31 | 0 | 12 | 12 | 5 | 0 | 6 | 10 | 10 | 143 |

* Sum may exceed the total sample size because of participation in multiple measures.

** Survey self-report business type.

A.12.3 Logger Sample

A total of 236 loggers were installed within the sample of 155 on-site surveyed customers. Among them, 69 were installed at office sites, 54 in groceries, 42 in schools, 24 in retails, with the remaining 47 installed in other business types.

A.13 Relative Precision

Given a sample design, the relative precision, based upon total annual energy use, reflects the uncertainty regarding the extent to which the allocated sample sizes are large enough to control for the population variance in terms of annual energy usage. The final achieved telephone survey sample (indoor lighting technology) is expected to yield an overall relative precision of 8.4 percent in terms of annual energy consumption.

Precision for the telephone sample is calculated using the following procedure:

- First, the 1994 annual energy consumption is computed for all participants in the analysis dataset. Since the Protocols' requirement for relative precision of samples is only applicable to the indoor lighting end use, only telephone surveyed or on-site audited indoor lighting participants (a total of 452 customers) were used in the calculation.
- Next, four strata are constructed based on customers' annual usage. Customers with annual usage in 0-40, 40-70, 70-90, and 90+ percentiles of the sample population are grouped into different strata. Exhibit A-13 presents the stratum-level sample size, sample weight, sample mean, and estimated standard errors.
- Then, the program level mean and standard error are calculated using classic stratified sample techniques.¹The functional relation can be best described in the following equations:

$$\bar{m} = \sum_i w_i * \bar{m}_i = 344,316 \text{ kWh} \quad \text{with } w_i = \frac{n_i}{n}$$

$$\text{StdErr} = \sum_i (w_i)^2 * \frac{\text{StdErr}_i}{n_i} = 17,480 \text{ kWh}$$

- Finally, the relative precision at 90 percent confidence level is calculated as

$$\text{RP} = \frac{1.645 * \text{StdErr}}{\bar{m}} = 8.4\%$$

Exhibit A-13

Telephone Sample - Relative Precision Levels

| Stratum | Sample Size | Segment Weight | Mean 1994 Usage | Sample Estimated Standard Error |
|--------------|-------------|----------------|-----------------|---------------------------------|
| 1 | 180 | 0.40 | 29,027 | 1,304 |
| 2 | 136 | 0.30 | 126,145 | 3,506 |
| 3 | 90 | 0.20 | 483,877 | 22,950 |
| 4 | 46 | 0.10 | 1,950,032 | 165,383 |
| Total | 452 | 1.00 | 344,316 | 17,480 |

¹ Cochran, W.G., *Sampling Techniques*, Third Edition, John Wiley & Sons, 1977. pp 91-95.

The same calculation for the 458 comparison group customers yields a relative precision of 9.4 percent in terms of their 1994 annual energy consumption. This ensures that the sample design meets the requirement of a 10 percent relative precision in the Protocols for the commercial sectors, indoor lighting end use. However, it is important to note that this expected precision is based upon the *annual energy usage*, and does not imply the same level of precision for the final *end-use impact* evaluation results.

A.14 Demonstration of Protocol Compliance

A.14.1 Sampling Procedures Adopted

The sample design used to evaluate the 1994 Commercial Lighting Program follows the rules established by the CPUC in the January 1995 revisions to the "Protocols and Procedures for the Verification of Costs, Benefits and Shareholder Earning from Demand Side Management Programs." Recent revisions to the Protocols—a draft dated 6/27/95—were incorporated wherever appropriate. The purpose of this section of the report is to identify compliance with these Protocols, with respect to the 1994 Commercial Lighting Program Evaluation activities.

A.14.2 Sample Definitions

The following definitions are provided to introduce the primary segments targeted—both a participant sample and a comparison group—to ensure experiment control:

- **Participants** - According to Table 5, part C, paragraph 1 of the Protocols, participants are defined as "those who received utility financial assistance to install a measure or group of measures during the program year."
- **Comparison Group** - A control group is defined as a group of customers that represents what would have happened in the absence of the program. According to Table 5, part D, paragraphs 3 & 4, the comparison groups include both "customers who installed applicable measures" and "customers who did not install applicable measures," with no preference for either group (i.e., random or stratified random sample). This sample is therefore representative of the population, excluding only program participants during the evaluation year.

A.14.3 Overall Sampling Procedures

The commercial customer samples are driven by a primary data collection activity; in this case, the telephone surveys serve as the primary site-specific data collection elements that contribute to the analysis dataset. The commercial telephone sample was drawn to achieve a stratified random sample and optimally distribute the allocated sample points.

A.14.4 Detailed Protocol Sample Requirement

The commercial participant and comparison group samples are designed to meet the Protocol requirements in terms of analysis dataset sample size, precision of the results, availability of pre- and post-billing data contributing to the analysis dataset, and in ensuring cost-effective use of measured data.

- *Analysis Dataset Sample for Commercial Participants:* The Protocols require that a program with more than 450 participants has a randomly drawn sample sufficiently large to achieve minimum energy use precision of $\pm 10\%$ at the 90% confidence level, and at least 450 contributing points in the analysis dataset.
 - The 480 analysis dataset points, 452 of which were for customers with indoor lighting measures, were supplemented with 155 nested on-site points to ensure sample size compliance with Protocol requirements in Table 5, part C, paragraph 3. Data collection protocols are also met regarding minimum analysis dataset size, if primary site-specific data are collected on-site, as per Table 5, part C, paragraph 4 of the Protocols.
 - Data collection efforts are further strengthened during on-site activities through the installation of lighting loggers. These devices record specific fixture operating profiles during the monitoring period, and serve to calibrate self-reported lighting operating schedules. Data collected in this way follows the participant protocol recommendations set forth in Table C-4, paragraph 1 of the Protocols.
 - As discussed earlier, the sample collected for the commercial section, indoor lighting end use achieves a relative precision of 8.4 percent at a 90 percent confidence level, as required by the Protocols, Table 5, part C, paragraph 4.
 - All 480 participant sample points were screened for bad billing or MDSS data to ensure each point eventually contributed to the analysis dataset. In addition, each participant chosen for the telephone sample is required to have at least nine months of post-installation billing data, and 12 months of pre-installation data, as per the Protocols, Table 5, part D, paragraphs 2 and 1, respectively.
- **Analysis Dataset Sample for Commercial Comparison Group** - The Protocols require that the comparison group sample "be drawn using the same criteria for participants," as per Table 5, part C, paragraph 6.
 - The 458 analysis dataset points meet the sample size requirement in Table 5, part C, paragraph 3. The calculated relative precision of 9.4 percent at a 90 percent confidence level meets the precision requirement in Table 5, part C, paragraph 4.

- The commercial comparison group telephone sample is drawn based upon the similar distribution of participant sample, in terms of their business types and annual usage. Since lighting equipment characteristics are unknown for nonparticipants, no stratification was included for lighting equipment groups.
- To ensure compliance with comparison group protocols, the telephone survey sample frame is drawn to meet the billing data requirements of Table 5, part D, paragraphs 3 and 4 of the Protocols. All customers in the analysis dataset have billing data from January 1991 to September 1995, which ensures an adequate pre- and post-installation billing periods for customers who installed applicable measures between 1993 and 1994.

Appendix B

ENGINEERING DETAILED COMPUTATIONAL METHODS

Appendix B

ENGINEERING DETAILED COMPUTATIONAL METHODS

The technical approach and intermediate engineering results that support realized gross impacts in the 1994 Pacific Gas and Electric Company (PG&E) Commercial Lighting Technologies Evaluation (Commercial Lighting Evaluation) are presented in this section. The purpose of a presentation of the engineering computations is to provide detailed intermediate results that either compliment or dispel significantly the current methods used to generate program design demand and energy impact estimates. Results are presented to ensure that future program design and evaluation activities will benefit from the engineering parameters generated during the 1994 program evaluation effort.

B.1 Appendix B Structure

This appendix is structured as follows:

- The appendix begins with a presentation of the general approach used to generate both evaluation results and program design estimates. The purpose of a presentation of the engineering approach is to:
 - Summarize and define each of the lighting end-use impact components that were used to generate final impact results
 - Demonstrate key differences between the evaluation methods and those used to derive program design estimates
 - Provide intermediate engineering results and discuss the data sources and methods used to derive each parameter
- Next, program design estimate methods that were used to generate impacts for the majority of the 1994 program applications are introduced. This discussion focuses on the methods used to derive impacts for the Retrofit Express (RE) Program.
- The evaluation approach is then presented, incorporating both of the general methodologies from Section 3 of this report, but simplifying that approach by introducing an hourly impact model.

- Then, detailed derivations are presented for several key engineering parameters, including premise operating schedules, technology- and business type-dependent operating factors, and impacts caused by the interaction between lighting system heat gain, and heating and cooling system energy use.
- Next, engineering intermediate results that PG&E may elect to incorporate in future program design efforts are presented.
 - First, database estimates of fixture connected load are compared against measured fixture connected loads that were sampled during on-site audit activities. The purpose of this analysis was to determine if adjustments to database estimates of connected load were necessary, because of differences between field-measured fixture operating loads and those claimed in manufacturers' product literature.
 - Then, the frequency of observed lamp burn-out is explored to highlight the importance of including these adjustments in all future program design estimates.
 - Next, the existing fixture frequency is explored, both as observed during on-site data collection activities, and also according to assumed fixture replacement under program design guidelines.
 - Then, evaluation estimates of annual fixture hours of operation are compared against parameter estimate assumptions, yielding results by technology group.
 - Next, evaluation estimates of Summer On-peak coincident diversified operating factor (CDOF) are presented, yielding significant results by technology group.
 - Lastly, evaluation estimate results are presented for heating and cooling energy and demand impacts caused by the retrofit of standard-efficiency lighting systems with high efficiency systems offered under the program.
- Then, the methods are described that were used to both classify and analyze 1994 program impacts for lighting retrofits installed under the Customized Incentives (Customized) Program.
- Finally, to summarize the engineering effort, RE-selected hourly impact profiles are presented by daytype, business type, and time-of-use (TOU) costing period B.2 Engineering Gross Impact Evaluation Approach.

B.2 Overview of the Evaluation Approach

This overview of the engineering approach will address the generic methodology used to estimate impacts for the majority of the lighting retrofits covered under the RE and Customized programs, and the data sources contributing to these estimates of energy and demand impact. More specifically, the following are addressed as follows:

- Lighting end-use parameters, which contribute to energy and demand impact estimates, are introduced using the impact decomposition approach.
- Data sources that contributed to each component of impact are then discussed. This introduction focuses on the accuracy of these contributing data elements, and the concept of the nested sample design that was used to transfer accurate data elements.

B.2.1 Introduction to the Impact Decomposition Approach

The general lighting model used to estimate most of the impacts under the RE and Customized programs were founded on the decomposition of lighting impacts into manageable engineering parameters. The impact decomposition was used to estimate unadjusted engineering impacts (UEI's) over a specified period of time—by season/daytype/hour—and is defined as follows:

| | | |
|------------------|---|--|
| UEI _t | = | [(Ψ OL x U x OF _t) x T] x [1+HVAC], where |
| Ψ OL | = | the technology level maximum change in connected kW associated with a particular measure. |
| U | = | the number of measure units installed for a particular application. |
| OF _t | = | the operating factor which describes the percentage of full load used by a group of fixtures during a prescribed period of time, t. |
| T | = | the time interval for which an impact is estimated; for most measures, the OF term is the engineering parameter that changes significantly over time. Time intervals for lighting estimates were single hours, segmented by hours “on” (open operating factor) and hours “off” (closed operating factor) schedules. ¹ |
| HVAC | = | the component of impact associated with both a net energy savings due to cooling and a net energy increase due to heating. |

The process of analyzing each contributing element in this relationship with respect to time dependency is referred to in this approach as engineering model calibration.

¹Although there are periods of time when lights are generally considered off, many lights are either accidentally or purposely left on during these periods. The effective hours of lighting operation captured during these off periods were applied using the operating factor term (the probability that lights operate during a particular time interval).


Premise-specific estimates were calibrated to either premise self-reports, business type segment-level results, and/or technology group segment-level results. Calibration of the lighting end-use engineering parameters yielded typical lighting hourly load shapes by daytype and season. We recommend incorporating these calibrated results in all future lighting program evaluation activities, specifically the engineering-based program design calculations prepared for cost-recovery activities.

Note that neither program design demand nor energy impact estimates include claimed credits for the indirect HVAC impacts associated with a reduction in internal heat gain (as a result of an efficient lighting retrofit).

B.2.2 Data Sources and the Nested Sample Design

The impact approach used several data sources to collect similar engineering parameters. The purpose of gathering like information from several sources was to ensure calibration of engineering parameters using the most accurate data gathered. Exhibit B-1 depicts the nested sample design that was used to generate the most accurate estimate of engineering parameters, given certain constraints imposed by limited resources.

Exhibit B-1
Schematic of the Commercial Lighting Program
Data Collection Nested Sample Design



Resource constraints required that the most accurate, and therefore valuable, analytical data were gathered at a relatively small sample of sites, and that these data were then transferred to a larger samples of participants using leveraging techniques , whenever possible.

A good example of this calibration process using the nested sample design involves the use of logger information to calibrate on-site self-report lighting schedules, and likewise, the use of calibrated on-site self-report lighting schedules to calibrate the telephone sample self-report lighting schedules. The lighting logger sample provided information regarding typical daytype lighting profiles for fixtures operated within the on-site sample, by schedule group. Schedule groups are defined as groups of rooms and/or fixtures at a site that operate on a similar and unique schedule. Details

regarding the derivation of calibrated operating schedules is covered in detail on pages B-12 and B-13 of this appendix.

B.3 Program Design Impact Estimate Methods

B.3.1 Overview

The methods implemented to achieve 1994 RE program design impacts are introduced in this section². The gross program design impacts that were generated using these methods are recorded in the Management Decision Support System (MDSS) database. These methods are introduced at this early stage in the engineering approach to enable the direct comparisons between evaluation and program design engineering parameters that appear throughout the remainder of this section. In this section, engineering parameters that were used to generate program design impact estimates are defined, including the following:

- Measure-specific, per-unit noncoincident demand impacts (the difference in fixture connected load pre- and post-retrofit) were used as inputs to both the energy and demand impact estimates.
- A Coincident Diversity Factor (CDF) is described, a parameter applicable to demand impact estimates.
- Annual hours of operation, defined by business type, were used to generate annual energy impact estimates.

Results are presented based on an effort to regenerate program design estimates by applying the methods described in this section. Several important discrepancies were found between the intended application of these impact methods and the gross impacts stored in the MDSS.

B.3.2 Noncoincident Demand Impact Calculations

All lighting estimates require the use of pre- and post-retrofit fixture connected loads or more typically, the change in fixture connected. This engineering parameter represents the Δ UOL term in the impact decomposition approach. This change in lighting system connected load is referred to as the noncoincident demand impact, which is defined for each RE measure using the following formula:

$$kW_{NCP} = kW_E - kW_R \quad (1)$$

² These methodologies are described in a document titled "1994 Lighting Retrofit Express Program", submitted by Darrell Hall and Sam Cohen. They resulted in the values presented in the *Annual Summary Report on Demand Side Management Programs in 1994 and 1995*, Advice Filing 1800-G-A/1446-E-A.

Where:

kW_{NCP} = Per-unit noncoincident demand impact by measure

kW_E = Per-unit existing measure demand

kW_R = Per-unit retrofit measure demand

Exhibit B-2 provides a summary of the assumed change in connected load for the measures installed according to the 1994 RE document cited above. This difference in connected load is based upon both the measure definition specified under the RE program (and typical customer installations for each measure), and an assumed existing system that represents a typical customer configuration prior to retrofit. Each individual fixture connected load, both pre- and post-retrofit, was carefully scrutinized and compared with manufacturers' data for the technologies and lamp wattage specified. In all cases, manufacturers' data supported the pre- and post-retrofit connected load assumptions used to produce program design estimates. In addition, fixture connected loads were field tested using spot-watt metering devices to determine the accuracy of manufacturers' data for fixture connected loads. Spot metering results, which also support manufacturers' data for fixture connected loads, are provided on page B-26 of this appendix.

Exhibit B-2

Fixture Assumptions Used to Generate
Retrofit Express Commercial Lighting Program Design Estimates

| Generic Measure Group Descriptions | Code Application Year | Measure Code In the MDSS Database | 1994 Per-Unit NC Impact\$ (Watts) | Coincident Diversity Factor | Per-Unit Peak Demand MDSS Impact (Watts) | Per-Unit Annual Energy MDSS Impact‡ (kWh) |
|---|-----------------------|-----------------------------------|-----------------------------------|-----------------------------|--|---|
| Halogen | | | | | | |
| < 45 watts | 1994 | L60 | 30.0 | 0.67 | 20.1 | 60 |
| > 50 watts | 1994 | L61 | 50.0 | 0.67 | 33.5 | 150 / 105 |
| Compact Fluorescent Lamps | | | | | | |
| Screw In CF | | | | | | |
| 5-13 watts | 1994 | L62 | 45.0 | 0.67 | 30.2 | |
| 14-26 watts | 1994 | L63 | 45.0 | 0.67 | 30.2 | |
| Screw In CF- Reusable ballast | | | | | | |
| 5-13 watts | 1994 | L64 | 45.0 | 0.67 | 30.2 | |
| 14-26 watts | 1994 | L65 | 45.0 | 0.67 | 30.2 | |
| Hard Wired CF | | | | | | |
| 5-13 watts | 1994 | L66 | 45.0 | 0.67 | 30.2 | |
| 14-26 watts | 1994 | L67 | 45.0 | 0.67 | 30.2 | |
| 27-50 watts | 1994 | L68 | 52.0 | 0.67 | 34.8 | |
| Incandescent to Fluorescent Fixture | | | | | | |
| With Energy Saving Ballast & T12 Lamps | 1993&4 | L7 | 212.0 | 0.67 | 142.0 | |
| With Electronic Ballast & T8 Lamps | 1993&4 | L8 | 240.0 | 0.67 | 160.8 | |
| Exit Signs | | | | | | |
| Incand. to Compact Fluorescents | 1993&4 | L5 | 29.0 | 1.00 | 29.0 | 254 |
| Incand. to LED or Electroluminescent Retrofit | 1993&4 | L6 | 33.0 | 1.00 | 33.0 | 289 |
| Efficient Ballasts Changeouts | | | | | | |
| Electronic Ballasts | | | | | | |
| 2 Lamp Electronic Ballast | 1993&4 | L14 | 19.0 | 0.67 | 12.7 | |
| 3 Lamp Electronic Ballast | 1993&4 | L15 | 29.0 | 0.67 | 19.4 | |
| 4 Lamp Electronic Ballast | 1993&4 | L16 | 38.0 | 0.67 | 25.5 | |
| T8 Lamps and Electronic Ballasts | | | | | | |
| New Fixtures | | | | | | |
| 2'-1 U Tube or 2 lamps | 1994 | L69 | 21.0 | 0.67 | 14.1 | |
| 2'-2 U Tubes or 4 lamps | 1994 | L70 | 43.0 | 0.67 | 28.8 | |
| 2'-3 U Tubes or 6 lamps | 1994 | L71 | 78.0 | 0.67 | 52.3 | |
| 4'-1 lamp | 1994 | L72 | 22.0 | 0.67 | 14.7 | |
| 4'-2 lamps | 1994 | L73 | 22.0 | 0.67 | 14.7 | |
| 4'-3 lamps | 1994 | L74 | 37.0 | 0.67 | 24.8 | |
| 4'-4 lamps or 8'-2 lamps | 1994 | L75 | 45.0 | 0.67 | 30.2 | |
| Fixture Modif.- Replace Lamps and Ballasts | | | | | | |
| Replace Lamps & Ballasts - 2' Fixture | 1993&4 | L21 | 10.5 | 0.67 | 7.0 | |
| Replace Lamps & Ballasts - 3' Fixture | 1993&4 | L22 | 13.0 | 0.67 | 8.7 | |
| Replace Lamps & Ballasts - 4' Fixture | 1993&4 | L23 | 11.8 | 0.67 | 7.9 | |
| Replace Lamps & Ballasts - 8' Fixture | 1993&4 | L24 | 22.5 | 0.67 | 15.1 | |
| Delamp Fluorescent Fixtures | | | | | | |
| Fixture Modif.- Delamp and Reflector | | | | | | |
| Removal - 2' Lamps & Ballasts | 1993&4 | L17 | 32.0 | 0.67 | 21.4 | |
| Removal - 3' Lamps | 1993&4 | L18 | 43.0 | 0.67 | 28.8 | |
| Removal - 4' Lamps | 1993&4 | L19 | 46.0 | 0.67 | 30.8 | |
| Removal - 8' Lamps | 1993&4 | L20 | 96.0 | 0.67 | 64.3 | |
| High Output T8 & T10 Conversion w/ Delamp | | | | | | |
| T10 & Energy Saving Ballast | 1994 | L76 | 31.0 | 0.67 | 20.8 | |
| T10 or T8 & Electronic Ballast | 1994 | L77 | 45.0 | 0.67 | 30.2 | |
| High Intensity Discharge | | | | | | |
| Interior Compact HPS | | | | | | |
| 0-35 watts HPS | 1994 | L78 | 107.0 | 0.67 | 71.7 | |
| 36-70 watts HPS | 1994 | L79 | 112.0 | 0.67 | 75.0 | |
| 71-100 watts HPS | 1994 | L80 | 155.0 | 0.67 | 103.9 | |
| Interior Standard MH from Merc. Vapor | | | | | | |
| 101-175 watts MH | 1993&4 | L26 | 240.0 | 0.67 | 160.8 | |
| 176-250 watts MH | 1993&4 | L27 | 528.0 | 0.67 | 353.8 | |
| 251-400 watts MH | | L81 | 620.0 | 0.67 | 415.4 | |
| Exterior HPS from Merc. Vapor | | | | | | |
| 0-100 watts | 1993&4 | L28 | 113.0 | 0.00 | 0.0 | 463 |
| 101-175 watts | 1993&4 | L29 | 240.0 | 0.00 | 0.0 | 984 |
| 176 watts & greater | 1993&4 | L30 | 610.0 | 0.00 | 0.0 | 2,501 |
| Controls | | | | | | |
| Time Clocks | 1993&4 | L31 | N/A | N/A | 0.0 | 439 |
| Occupancy Sensors | | | N/A | N/A | | |
| 72-350 watts controlled | 1993 | L32 | N/A | N/A | 62.0 | 277 |
| 351-1000 watts controlled | 1993 | L33 | N/A | N/A | 212.0 | 824 |
| 1000 watts and greater controlled | 1993 | L34 | N/A | N/A | 280.0 | 1409 |
| Wall Mounted | 1994 | L82 | N/A | N/A | 62.0 | 277 |
| Ceiling Mounted | 1994 | L83 | N/A | N/A | 212.0 | 824 |
| Bypass/Delay | 1993&4 | L35 | N/A | N/A | 106.0 | 412 |
| Photocell | 1993&4 | L36 | N/A | N/A | 0.0 | 99 |

§ Non-coincident demand impact -- the difference between the non-coincident existing (assumed) measure and retrofit measure demand.
 ¥ Most program design (MDSS) energy impact estimates vary as a function of business type.

The Retrofit Express connected load figures were carried over into the evaluation analyses of program savings, though modified wherever possible for lamp burn-out rates in both the new and existing systems. Typical lamp burn-out rates were determined for specific technology groups, based upon data gathered during on-site

audit activities. Burned-out lamp rates and methodologies are presented in an upcoming section of this appendix.

The largest potential error in estimating noncoincident demand estimates is made in the assumptions regarding the existing lighting system prior to the adoption of retrofit measures. Technology group saturations for existing systems were gathered on-site that largely support the systems specified in these program assumptions. The results of these analyses are provided in an upcoming section of this appendix.

Also provided in Exhibit B-2 are the specific CDFs and nonsegment-specific annual energy savings estimates used in generating program design estimates. These terms are described in detail in the following two sections.

B.3.3 Coincident Demand Impact Calculations

Engineering estimates of noncoincident demand impact from equation (1) are multiplied by a CDF, which was developed based upon PG&E load research data, as part of the Commercial End-Use Metering Project performed by Regional Economic Research (RER). CDF is mathematically defined as:

$$\text{CDF} = \text{Coincidence Factor} \times \text{Diversity Factor}$$

where:

Coincidence Factor is the ratio of the measure demand reduction at system peak and the noncoincident demand impact

and

Diversity Factor is the probability that a given measure is on at the time of system peak

The value of CDF for most lighting end-use program design estimates is 0.67. Hence, coincident demand impacts are typically estimated as follows:

$$\text{Coincident Demand Impact} = 0.67 \times kW_{NCP}$$

As shown in Exhibit B-2, the CDF does vary for certain measures, specifically exit lights and exterior lights. Evaluation results did not use this CDF value to estimate impacts, using instead detailed evaluation methods. Evaluation methods used customer-specific schedules in conjunction with business type and technology group operating factors to generate program impacts at the hourly level, as discussed on page B-12 of this appendix.

B.3.4 Annual Energy Impact Calculations

Per-unit program design energy impacts are typically calculated based upon the product of the per-unit non-coincident demand impact and industry group annual hours of fixture operation, as shown in the following equation:

$$kWh_{ANNUAL} = kW_{NCP} \times hrs_z \quad (2)$$

Where:

kWh_{ANNUAL} = Per-unit annual energy impact by measure

hrs_z = Annual hours that a given measure operates in industry group z

B.3.5 Annual Hours of Operation by Business Type

Annual hours of fixture operation are based upon results from a PG&E study (HBRS and BCI 1992) and negotiations regarding impact estimates, according to a 1991 PG&E Advice Filing with the CPUC. Hours of operation vary by business type, except in cases where all sectors share identical estimates for hours of operation, such as exit lighting or exterior lighting. Exhibit B-3 provides assumed hours of operation for various business types, as specified in the majority of the program design estimates. Refer to Exhibit B-2 for additional information regarding measures that are assumed to have the same energy impacts, independent of business type.

Exhibit B-3

Annual Fixture Operating Assumptions Used to Generate Retrofit Express Commercial Lighting Program Design Estimates

| Business Type | Annual Operating Hours* |
|----------------------|-------------------------|
| Office | 3,400 |
| Retail | 4,700 |
| University | 3,500 |
| School | 2,100 |
| Grocery | 7,000 |
| Restaurant | 4,800 |
| Health Care/Hospital | 4,000 |
| Hotel/Motel | 4,000 |
| Warehouse | 4,000 |
| All Other | 4,000 |

* All exterior lights are assumed to operate 4,100 hours per year regardless of business type.

Exterior lights are assumed to have the same annual hours of operation across all business types, even across sectors. They are assumed to be controlled by a combined time clock and photocell system, resulting in 4,100 operating hours per year. This

figure assumes that lights operate 12 hours a day, except during summer, when the photocell reduces operation by another three hours per day.

The evaluation results do not use the operating hours specified in the program design methodology, yielding instead to customer schedules derived using self-reported telephone survey responses, on-site schedule group responses, and lighting logger data to calibrate those responses. Again, unique customer lighting profiles were generated at the hourly level by daytype and season, in order to accurately estimate impacts according to PG&E-specified TOU periods. This methodology ensured consistency between hourly impacts and energy impacts, where energy is derived by simply adding across specific hours.

B.3.6 Reproduction of Program Design Estimates

In an attempt to verify both the methods used to generate program design impacts and the impact estimates stored in the MDSS, RE program design impacts were reproduced. Although the methods were generally found to be applied correctly in the MDSS, in several instances, differences were found between the reproduced values and those stored in the MDSS. Further investigation showed that for specific cases, impact estimates in the MDSS were calculated incorrectly. Those particular instances are summarized below.

- L14-L16: Electronic ballast measure energy and demand impact estimates, that were applied for under the 1993 RE program application form, were inadvertently overestimated by two to four times, depending upon the measure installed. The unit of rebated measure under the 1993 program was lamps and not ballasts, causing this error in estimated impact.
- L21: Energy estimates for a subset of this 2' T8 lamp and ballast replacement measure were overestimated by approximately 40 percent. The cause of this error appears to be related to business type classification.
- L20: Energy estimates for a subset of this 8' reflector and lamp removal measure were underestimated by approximately 60 percent. The cause of this error appears to be related to business type classification.
- L61: Energy estimates for a small subset of this halogen retrofit measure were overestimated by approximately 40 percent. The cause of this error appears to be related to program design assumptions that should have been implemented for schools.

In addition, other spurious MDSS impact estimates were infrequently detected. The source of these other events could not be specifically isolated.

B.4 Evaluation Approach

To satisfy the requirements of PG&E for impact estimates by TOU costing periods, all impact estimates were generated at an hourly level. Engineering estimates that were used as inputs to the SAE were additionally estimated according to each particular customer's self-reported operating schedule.

To estimate impacts for each hour, customer operating schedules were developed by daytype, hour and season, and expressed as numeric values between zero and one, where one indicates that the probability of being open is 100 percent, and zero represents a closed premise. Impacts utilize distinct operating factors by daytype for both the closed periods and the open periods (operating factors are also dependent upon business type and technology group, but that is not important to this discussion). To estimate impacts for each hour, fixture noncoincident demand connected loads are used along with the applicable schedule and operating factors, according to the following equation:

$$UE_{lijzdhs} = \Delta UOL_i \times U_{ij} \times \left[(PO_{jdhs} \times OOF_{izd}) + ((1 - PO_{jdhs}) \times COF_{izd}) \right] \times [1 + HVAC_{ijs}]$$

Where:

$UE_{lijzdhs}$ is the unadjusted engineering impact for measure i , customer j , business type z , for daytype d , hour h and season s .

ΔUOL_i is the change in connected load for technology measure i .

U_{ij} is the number of units of technology type i installed by customer j .

PO_{jdhs} is the schedule defined probability that customer j will be open on daytype d during the hour h and season s .

OOF_{izd} is the open operating factor which describes the percentage of full load during normal business hours used by a group of fixtures of type i , in business type z , during daytype d .

COF_{izd} is the closed operating factor which describes the percentage of full load during non-business hours used by a group of fixtures of type i , in business type z , during daytype d .

$HVAC_{ijs}$ is the contribution of impact caused by both heating and cooling interaction for technology measure i , installed by customer j , during the season s .

Impacts for each measure/season/daytype/hour (and often by customer) were derived and applied to a 1994 calendar, yielding demand profiles for all 8760 hours in a year.

B.5 Detailed Engineering Derivations

B.5.1 Customer Operating Schedule Derivation

The calibration of customer lighting schedules was achieved using the following approach:

- Within the larger on-site sample, self-reported schedules (or profiles) were gathered at the schedule group level by daytype, allowing analysis of schedule group self-report accuracy using the lighting logger sample. The detected bias in customer self-reported hours of operation at the schedule group level was then applied to the larger sample of schedule group self-reports by business type, thus calibrating all schedule group lighting schedules. The following key points describe the details of the calibration process for schedule groups:
 - Self-reported schedule group profiles were generated that consist of hourly values generally consisting of one's and zero's, though "shoulder" hours (when a building transitions from on to off) may have intermediate values. These values represent the probability for any given hour of the day that lights are operating, according to the on-site contact. Schedule group hourly profiles were generated for each of three daytypes, Weekday, Saturday and Sunday.
 - Loggers that were installed within schedule groups at a selected number of audits, are placed with the intention of gathering a measured equivalent of the schedule group operating schedule. Each logger stores a continuous date and time-stamped transition record of lights being turned on or turned off during the monitoring period. The data from each logger was then transformed into a useful format for analytical purposes, specifically, each 15-minute interval during the monitoring period was assigned a value between one and zero that specifies the percentage of time during each interval that a particular light operated. Then, for each logger, hourly mean values were generated by daytype using aggregating hourly results across the entire monitoring period. This yielded an hourly/daytype operating factor for the fixture monitored, or the percentage of time that each monitored fixture operated during the course of the monitoring effort, or the probability of operation.
 - Lastly, logger and self-reported operating schedules were compared to each other at the business segment level to detect bias in the self report transitions from on to off. All loggers and schedule groups that contributed to a particular segment were independently combined using a weighted mean, where weights were applied based upon the total retrofit technology connected load within each particular schedule group. For logger data, the transition from on to off was set to be half the distance between the maximum hour-specific observation and the minimum hour-specific observation. All schedule group self-reports were then adjusted according to these results, by moving the periods of transition from on

to off, and the transitions from off to on, according to segment mean bias detected within the logger sample. In general the results of these analyses showed that customer self-reports were highly accurate. Therefore, in the absence of well behaved segment-specific results, unadjusted customer self-reports were used.

- Then, self-reported lighting schedules from the telephone sample were calibrated based upon more precise schedule group profiles gathered onsite. A weighting scheme was devised (based upon total new fixture connected load) within each schedule group to attain premise level schedules within the on-site sample. The detected bias in customer self-report hours of operation from the telephone response was then applied to the larger sample of telephone survey self-reports by business type, thus calibrating all telephone survey lighting schedules. The details of this load shape comparison and adjustment are very similar to the methods used in adjusting schedule group self-reports. For that reason, greater detail is not provided regarding the specifics steps implemented to adjust the telephone survey self-reports.
- Lastly, business type segment level adjusted fixture operating schedules were generated for use in MDSS impacts outside the survey and on-site audit samples. These segment mean business type schedules incorporate two distinct calibration steps, bias in on-site self-reported schedules, and bias in telephone survey self-reported schedules, calibration steps that are grounded on the best available information gathered in this research effort: lighting logger data. All schedules derived, whether customer-specific or business type segment-specific, were hourly/daytype/seasonal probabilities that a customer operates their lighting system, stored in this fashion to enable impact calculations at the hourly level.

B.5.2 Business Type and Technology Group Operating Factors

Operating factors, the percentage of lights operating during a specified time interval, were generated by business type and technology group, for facility operating and non-operating periods by daytype. The operating factors that are applied to the probability that a given facility is operating comprise the open operating factor (OOF), and those that are applied to one minus the probability that a given facility is operating comprise the closed operating factor (COF). The data sources contributing to these estimates were taken primarily from two sources: new technology lamp counts performed at the time of each audit, and lighting logger data used in conjunction with the calibrated schedule group profiles. The steps that were implemented to derive operating factors are presented below.

- OOFs were primarily supported by lamp counts that were taken during each on-site audit. Lamp counts were conducted for each retrofit technology installed, and segmented into lamps that were on and lamps that were off, representing a technology-specific instantaneous OOFs. Since on-site audits were conducted on

weekdays during normal facility business hours, lamp counts were used to estimate OOFs for weekdays. These customer results were then weighted across customers, yielding a single business type and technology group operating factor that was used consistently for all retrofit estimates falling into that particular segment. For business type and technology group segments with relatively low numbers of lamps counted, weighted mean values were generated across a number of business type segments to strengthen those mean values.

- COFs were estimated by daytype and business type using logger data, calibrated schedule group profiles, and weights by technology that are based upon retrofit fixture connected load. A simplified description of the procedure implemented is that all hourly logger observations categorized as non-operating, for a particular business and daytype segment, were used to generate a single mean value. This is roughly true, though a weighting scheme was implemented based upon the total schedule group retrofit technology connected load.
- It was also necessary to produce both Saturday and Sunday operating factors for the facility operating condition, with no supporting lamp count data. The loggers were used to generate OOFs by daytype, during the facility operating period. The ratio of resulting Saturday or Sunday operating factors to weekday provided a business type operating factor adjustment. These adjustments were then applied to the operating factors generated using lamp count data, yielding Saturday and Sunday OOFs. This analysis step also allowed for a comparison by business type of OOFs that were generated using lamp counts with those generated using logger data. These comparisons strongly support the operating factors generated for weekdays using lamp counts, which, in turn, support the operating factors generated using logger profiles.

B.5.3 HVAC Interactive Effects

B.5.3.1 Introduction to HVAC Interactive effects

In addition to the direct effects of lighting retrofits on premise energy and demand, the contribution of impact caused by cooling and heating system use is described in this section. Internal gains affect both the air-conditioning and heating loads in buildings, and thus HVAC equipment run-time and consumption. Lighting retrofits modify the heat gain in buildings, and thus heating system and air-conditioner usage. When high-efficiency lighting systems replace standard-efficiency systems, cooling loads are decreased while heating loads increase. This section presents the method used to quantify those impacts.

The engineering data sources used to evaluate the 1994 commercial lighting program are identified in Exhibit B-4. Shaded regions identify the primary data sources contributing to HVAC interactive estimates.

Exhibit B-4

Data Sources Contributing to Heating and Cooling Interactive Estimates

| Research Objectives | Data Sources | | | Telephone Survey | | On-Site Audit | | P/NP Metering | |
|-----------------------------------|---------------|----------------|---------------|----------------------|-------------------------|----------------------|-------------------------|---------------|--------------|
| | Usage Metered | Demand Metered | MDSS Database | Lighting Participant | Program Non-Participant | Lighting Participant | Program Non-Participant | Spot Watt | TOU Metering |
| IMPACT ANALYSIS | | | | | | | | | |
| Unit Operating Load/Impact | | | | | | | | | |
| Old Wattage | | | 4 | | | 4 | 4 | 4 | |
| New Wattage | | | 4 | | | 4 | | 4 | |
| Impact (UOI) | | | 4 | | | 4 | | 4 | |
| Hours of Operation | | | | | | | | | |
| Operating Factor (OF) | | | | 4 | 4 | 4 | 4 | | 4 |
| Operating Hours (OH) | | | | 4 | 4 | 4 | 4 | | 4 |
| Measure Installation | | | | | | | | | |
| Unit Installed (U) | | | 4 | | | 4 | | | |
| Retention | | | | | | 4 | | | |
| Burned-Out Lamps | | | | | | 4 | 4 | | |
| Impact Adjustment | | | | | | | | | |
| SAE Demand Realization Rate | | | | | | | | | |
| SAE Energy Realization Rate | | | | | | | | | |
| H-Factor by Cost Periods | | | | | | | | | |
| Net-to-Gross Ratio | | | | | | | | | |
| Interactions | | | | | | | | | |
| Cooling Savings | | | | 4 | 4 | 4 | | | |
| Heating Penalty | | | | 4 | 4 | 4 | | | |

Survey responses and calibration data gathered on-site were the most important data sources contributing to the HVAC interactive analyses of energy and demand.

The interactive effects of HVAC appliances were estimated using methods developed by ASHRAE, and published in the *ASHRAE Journal*.³ This article explores the use of HVAC energy as a function of energy-efficient lighting design, and potential savings and penalties resulting from efficient technology retrofits.

This section includes a thorough overview of the steps required to implement interactive adjustments to lighting technology-level impacts. Flowcharts are used to depict key decisions that must be made for each contributing customer, and equations are supplied that were used to estimate the interactive benefits (savings) and costs (penalties) for each lighting participant.

³ Rundquist, R., et al. 1993. "Calculating Lighting and HVAC Interactions", *ASHRAE Journal*, November 1993, pages 28-37.

B.5.3.2 Cooling Energy Equations

The algorithm that was used to estimate cooling energy interactive savings is presented in Exhibit B-5. To estimate the annual cooling energy contribution from the HVAC system, two new terms are introduced in addition to those already required to estimate the lighting technology-only contribution.

Exhibit B-5

Gross Annual Cooling Energy Impact Algorithm

$$COOLSAV_j = \left[HGANNUAL_j \times \frac{1}{MCOP_j} \right] \times \left[\sum_{t=1}^{T_j} \Delta kWh_{tjz} \right]$$

where:

$COOLSAV_j$ = Annual HVAC savings resulting from lighting reduction for premise j

$HGANNUAL_j$ = Annual fraction of internal heat gain removed mechanically for premise j

$MCOP_j$ = Marginal coefficient of performance of cooling equipment for premise j

ΔkWh_{tjz} = Technology t annual energy savings for premise j, a member of industry group z

T_j = The number of lighting technologies installed in premise j

The first term, $HGANNUAL_j$, describes the fraction of heat gain removed mechanically from the building, as defined in the ASHRAE method Table 1 (from the ASHRAE article, appended to this report). The fraction of heat gain removed mechanically is a function of building size, and whether or not the building is served by an economizer (a device that uses outside air rather than mechanically chilled air to cool buildings when the outside temperature is sufficiently low). The reduced heat gain caused by an energy-efficient lighting retrofit can only benefit cooling system energy use when lighting waste heat is mechanically cooled. Additionally, the fraction of heat gain that is mechanically cooled is always less than one, because of outdoor air ventilation

(including the use of economizers), exhaust fans (that mechanically remove heat), and building envelope infiltration.

Table 1 inputs are weather normalized for various locations throughout the United States, including three cities within PG&E's service territory. Either Santa Barbara, San Francisco, or Sacramento was used as a proxy for each participant site.

The second term, MCOP_j, defines the marginal cooling system efficiency, a variable describing the efficiency (including all auxiliaries, and supply and return fans) applicable to the incremental cooling load. A default system efficiency is supplied by the ASHRAE method for estimates that involve the retrofit of lighting systems. The MCOP term serves as a conversion constant in the HVAC energy equation, producing an estimate of electricity consumption needed to mechanically cool lighting waste heat.


Next the methods used to determine the cooling interactive terms used in the ASHRAE method are described in greater detail.

B.5.3.3 Application of the ASHRAE Cooling Energy Method

Exhibit B-6 introduces the decision-making processes leading to the calculation of annual cooling energy impacts. This exhibit illustrates several key points.

- First, cooling impacts were estimated only for premises with cooling systems.
- Second, engineering impacts were estimated only for sites served by electric-powered cooling systems, since engineering impacts served as inputs to SAE analyses, which were supported by electric billing data. Engineering impacts were estimated in two ways.
 - For premises served by HVAC systems that included an economizer mode, ASHRAE article Table 1 HGANNUAL_j values were selected.
 - For premises without economizers, values for HGANNUAL_j were calculated based upon the building size per floor.

Exhibit B-6
Determining the Cooling Interactive Contribution to Energy Impacts



Buildings are classified into three size categories: large, medium, and small, with relatively large to small values of HGANNUAL_j, respectively. Premises served by economizers have the smallest relative values of HGANNUAL_j, thus implying that less lighting system heat is mechanically cooled on an annual basis when economizers are present.

ASHRAE HVAC impacts are achieved by multiplying the heat gain fraction removed mechanically (HGANNUAL_j) and the marginal coefficient of performance (MCOP_j) with annual fixture-level energy impacts for indoor lighting systems, on a per-premise basis. The resulting cooling energy savings are used as inputs to the SAE analyses, along with both technology-level impacts and heating penalty estimates (as described below).

B.5.3.4 Heating Energy Equations

To estimate the annual heating energy penalty from HVAC system electric heating, three new terms are introduced in addition to those already required to estimate the lighting technology-only impacts. The algorithm presented in Exhibit B-7 was used to estimate heating energy interactive penalties, and includes the following distinctive terms:

- HVAC interactive heating estimates include a term that describes the fraction of internal heat gain contributing to the building heating loads (HLANNUAL_j), as defined in the ASHRAE publication, Table 1. The following points must be considered :
 - Because of the typical reduction in internal gains associated with lighting efficiency upgrades, more heat is needed from the HVAC system to meet building losses.
 - This input is weather normalized for various locations throughout the United States, including three cities located within PG&E's service territory. A particular city is used as a proxy for each participant site.
- The contribution to the heating system is also influenced by the dimensions of each building. The fraction of each retrofit on the exterior 15-foot perimeter, PERIMETER_j, is used to define the fraction of fixture heat contributing to the annual heating load. The internal "core" zones are always assumed to require cooling, never heating.
- HVAC interactive estimates also include a term that describes the heating system efficiency (HPCOP_j), which depends upon system type for estimates of electric energy penalties, specifically, whether heat pump or resistance heat. Resistance heaters are assumed to have an HPCOP of 1.0, whereas an HPCOP of 1.5 is recommended for heat pump systems.

Exhibit B-7 Gross Annual Heating Energy Impact Algorithm

$$HEATPEN_j = \left[HLANNUAL_j \times PERIMETER_j \times \frac{1}{HPCOP_j} \right] \times \left[\sum_{t=1}^{T_j} \Delta kWh_{tjz} \right]$$

where:

| | | |
|------------------------|---|---|
| HEATPEN _j | = | Annual HVAC penalty resulting from lighting retrofit for premise j |
| HLANNUAL _j | = | Annual fraction of internal heat gain contributing to building heating load for premise j |
| PERIMETER _j | = | Fraction of lighting retrofit on the perimeter area for premise j |
| HPCOP _j | = | Heat pump coefficient of performance of heating equipment for premise j |
| ΔkWh_{tjz} | = | Technology t annual energy savings for premise j, a member of industry group z |
| T _j | = | The number of lighting technologies installed in premise j |


Next the logic used to determine heating interactive estimates (according to the ASHRAE method) are described in greater detail.

B.5.3.5 Application of the ASHRAE Heating Energy Method

As described earlier, the efficient lighting technologies installed under the lighting program caused a reduction in internal heat gains in buildings, and a related increase in the energy required to heat internal spaces. The flow chart shown in Exhibit B-8 establishes the general decisions used to estimate heating impacts using the ASHRAE method. To apply the ASHRAE method requires determining the heating system fuel and, if electric, whether or not the system is a heat pump.

Exhibit B-8

Determining the Heating Interactive Contribution to Energy Impacts



Presented next are the methods used to determine the distribution of annual cooling impacts and heating penalties among each hour of the year.

B.5.3.6 Hourly HVAC Impacts

PG&E requires that impacts be generated according to costing periods related to TOU customer rates. Since the ASHRAE impacts predict a reduction in cooling energy use and increased heating energy use on an annual basis, a methodology had to be developed to distribute the annual impacts determined using the ASHRAE method to each customer on an hourly basis. This section describes the method that was developed.

The distribution of impacts to each hour of the day was accomplished while maintaining several key constraints.

- HVAC impacts were applied during selected days in proportion to hourly lighting system impacts.
- Cooling impacts were applied to selected days as a function of summed daily temperature.
- Heating impacts were applied to selected days as a function of summed daily temperature.
- HVAC impacts for any given hour were applied based upon mechanical system efficiency parameters supported by the ASHRAE method.

Details regarding the methodology are described below, with special consideration of the constraints described above.

In applying both cooling and heating impacts, certain parameters introduced in exhibits B-5 and B-7 specify the fraction of annual fixture heat gain that must be either mechanically cooled or mechanically heated. For cooling impacts, the term $HG_{ANNUALj}$ describes the customer-specific fraction of fixture heat gain that requires cooling, and for heating impacts, $HL_{ANNUALj} \times PERIMETERj$ describes the customer-specific fraction of the fixture heat gain that contributes to annual heating loads. The method of distributing HVAC impacts over each hour of the year relies upon these terms to identify the fraction of days in each year to which HVAC impacts were applied. To select specific days (to which HVAC impacts are applied), all days in a year were ranked according to summed daily temperatures, for each of three applicable weather tapes, WYEC Santa Barbara, San Francisco, and Sacramento. Dry bulb temperatures were used for this procedure.

For cooling impacts, the selected days to which impacts were applied on an hourly basis are those days with the highest summed daily temperatures. The number of days

applied per customer is always $HGANNUAL_j \times 365$. Hourly impacts for applicable indoor measures were generated using the following formula:

$$HVAC_{ijzdhs} = \frac{UEI_{jzdhs}}{MCOP_j}$$

Likewise, for heating impacts, the selected days to which impacts were applied on an hourly basis are those days with the lowest summed daily temperatures. The number of days applied per customer is always $HLANNUAL_j \times PERIMETER_j \times 365$. Hourly impacts for applicable indoor measures were generated using the following formula:

$$HVAC_{ijzdhs} = \frac{UEI_{jzdhs}}{HPCOP_j}$$

B.5.3.7 HVAC Demand

The distribution of hourly estimates of HVAC impact during the summer on-peak period and system peak hour, vary day-to-day with changes in fixture operating schedule and outdoor temperature. To arrive at a single program figure for any particular business type and lighting technology segment, mean values were calculated for the peak hour across the entire summer on-peak period, thus providing a diversified estimate of HVAC impact.

This concludes the derivation of HVAC interactive engineering parameters.

B.6 Evaluation Results

B.6.1 Overview

This section provides the reader with detailed engineering results for parameters that contributed to unadjusted gross evaluation impact estimates. PG&E should consider adopting many of the results presented to improve the accuracy of program design estimates.

B.6.2 Measured Fixture Connected Loads

Noncoincident change in fixture connected load for each measure installed was determined based upon manufacturers' product literature for both the retrofit technologies, and for assumed existing technologies. To test the accuracy of manufacturers' literature, instantaneous fixture connected loads were measured during on-site activities. Equipped with a spot-watt metering device called a watt probe, both new and existing fixture connected loads were measured. Measurements were taken by locating a switch with just a single type of fixture served on that particular circuit. An attempt was always made to take measurements on circuits with as many new fixtures as possible, thus ensuring high precision for circuits drawing more than 200 watts.

Individual measurements were grouped based upon several selected technology groups. Technologies were grouped to attain a single result that represents a diverse group of fixture configurations (i.e., the T8 technology group contained measurements for 2', 4', and 8' fixtures, in 1-, 2-, 3-, and 4-lamp configurations). Furthermore, the measurements were all normalized for these groupings per total lamp wattage in each fixture. This allowed the calculation of confidence bounds surrounding measurements from a diverse group of fixture configurations that all fall into a particular technology group.

Measured fixture connected load results, normalized to total lamp watts served, are provided in Exhibit B-9. At the top of the exhibit, mean normalized measurements are presented by technology group, along with the lower and upper confidence bounds, calculated at the 95 percent confidence interval.

**Exhibit B-9
Technology Group Spot-Watt Results**

| Technology Group | Normalized Spot Watt Measurement Results | | | | | |
|------------------------|---|--|--------------------|-------------------------|-------------|-------------|
| | Number of Spot Watt Measurements per Technology Group | Mean Ratio of Measured Watts to Lamp Watts | Standard Deviation | 95% Confidence Interval | Lower Bound | Upper Bound |
| T-12 Fixtures | 27 | 1.04 | 0.08 | 0.03 | 1.01 | 1.07 |
| T-8 Fixtures | 85 | 0.94 | 0.15 | 0.03 | 0.91 | 0.97 |
| CF Fixtures | 13 | 1.11 | 0.20 | 0.12 | 0.99 | 1.23 |
| Metal Halide Fixtures | 7 | 1.19 | 0.18 | 0.17 | 1.02 | 1.36 |
| HPS Fixtures | 5 | 0.92 | 0.31 | 0.39 | 0.53 | 1.31 |
| Mercury Vapor Fixtures | 2 | 1.19 | 0.03 | 0.29 | 0.90 | 1.49 |

| Technology Group | Program Design Fixture Description | Tested Program Design Fixture Connected Loads | | | |
|------------------------|------------------------------------|---|------------------|-----------------------|--|
| | | Watts per fixture | Total Lamp Watts | Ratio MDSS/Lamp Watts | Within the 95% C.I. for the Specific Technology Group? |
| T-12 Fixtures | 2L 4' T-12 w/ ES MB | 80 | 80 | 1.00 | Yes |
| T-12 Fixtures | 3L 4' T-12 w/ 2 ES MB | 121 | 120 | 1.01 | Yes |
| T-12 Fixtures | 2L 8' T-12 w/ 2 ES MB | 151 | 150 | 1.01 | Yes |
| T-8 Fixtures | 2L 4' T-8 w/ EB | 58 | 64 | 0.91 | Yes |
| T-8 Fixtures | 3L 4' T-8 w/ EB | 84 | 96 | 0.88 | No |
| T-8 Fixtures | 2L 8' T-8 w/ EB | 106 | 118 | 0.90 | Yes |
| CF Fixtures | 13 Watt Compact Fl. | 15 | 13 | 1.15 | Yes |
| CF Fixtures | 2 23 Watt Compact Fl. | 30 | 26 | 1.15 | Yes |
| CF Fixtures | 44 Watt Compact Fl. | 48 | 44 | 1.09 | Yes |
| Metal Halide Fixtures | 175 Watt Metal Halide | 210 | 175 | 1.20 | Yes |
| Metal Halide Fixtures | 250 Watt Metal Halide | 292 | 250 | 1.17 | Yes |
| Metal Halide Fixtures | 400 Watt Metal Halide | 455 | 400 | 1.14 | Yes |
| HPS Fixtures | 35 Watt Int HPS | 43 | 35 | 1.23 | Yes |
| HPS Fixtures | 70 Watt Int HPS | 88 | 70 | 1.26 | Yes |
| HPS Fixtures | 100 Watt Int HPS | 130 | 100 | 1.30 | Yes |
| HPS Fixtures | 100 Watt Ext HPS | 130 | 100 | 1.30 | Yes |
| HPS Fixtures | 400 Watt Ext HPS | 465 | 400 | 1.16 | Yes |
| Mercury Vapor Fixtures | 250 Watt Mercury Vapor | 285 | 250 | 1.14 | Yes |
| Mercury Vapor Fixtures | 400 Watt Mercury Vapor | 450 | 400 | 1.13 | Yes |
| Mercury Vapor Fixtures | 750 Watt Mercury Vapor | 820 | 750 | 1.09 | Yes |
| Mercury Vapor Fixtures | 1000 Watt Mercury Vapor | 1075 | 1000 | 1.08 | Yes |

To test the accuracy of fixture connected load levels that were assumed for both the calculation of evaluation results and program design estimates, selected fixture connected loads from each technology group were tested to determine whether or not the normalized connected loads for those fixtures fall within the measured 95 percent confidence interval. These tests were carried out based upon the technology group to which each measure belongs, as summarized in the bottom portion of Exhibit B-9. These results show that in all but one of the selected cases, the fixture connected loads used to derive impacts fell within the 95 percent confidence interval for a particular technology group. This result suggests that fixture connected loads based upon manufacturers' product literature are accurate and should continue to be used.

B.6.3 Burned Out Lamp Rates

When retrofit lighting programs are implemented, burned-out lamps are often replaced. For those particular lamps, the first year impacts yield an increase in energy use, though the program saves energy across all observations. In addition, new fixtures often fail a short time after installation, resulting in a decrease in energy use for those particular fixtures. In an effort to quantify these impacts, burned-out lamps were counted during the on-site audits (in addition to the total number of lamps observed). All such counts were categorized as either retrofit technologies or existing technologies, to allow separate analysis of the pre- and post-retrofit burned-out lamp rates.

Total lamp counts yielded significant burned-out lamp results in four fixture categories, as provided in Exhibit B-10 below:

Exhibit B-10

Observed Burned Out Lamp Rates

| Pre- or Post-Retrofit | Technology Group | Observed Burned Out Lamp Rate |
|-----------------------|----------------------|-------------------------------|
| Pre-Retrofit | Incandescent | 2.16% |
| Pre-Retrofit | Standard Fluorescent | 3.05% |
| Post-Retrofit | Compact Fluorescent | 0.37% |
| Post-Retrofit | Standard Fluorescent | 0.26% |

These burned-out lamp observations were applied to the pre- and post-retrofit connected load assumptions based upon the following rules:

- Burned-out lamp rates were only applied within the RE program because of the diversity of measures that were applied within the Customized program.
- Burned-out lamp rates were only applied to measures where both the pre- and post-retrofit technologies had supporting burned-out lamp data, never just pre- or just post-retrofit fixture loads.

The following equation was used to incorporate burn-out rates within the estimated change in connected load pre- to post-retrofit:

$$kW_{NCP} = [(1 - BO_E) \times kW_E] - [(1 - BO_R) \times kW_R]$$

Where:

BO_E = Estimated burn-out rate for the existing measure system

BO_R = Estimated burn-out rate for the retrofit measure system

B.6.4 Existing Fixture Saturation by Technology Group



All RE evaluation impacts utilize program design assumptions regarding the fixtures removed at the time of retrofit. These assumptions were tested using observed existing technology saturations recorded during implementation of the on-site audits.

Exhibit B-11 provides the results of existing fixture saturation comparisons, according to both participation in the RE program and on-site results. Estimates of the total number of lamps replaced were derived using participation data and assumed fixture configurations for replaced systems, yielding total lamps by technology group. Estimates from the on-site audits were derived by mapping each existing system observation to a particular technology group, and then subsequently summing the total number of lamp observations recorded during on-site activities within each technology group.

The existing system fixture saturation recorded on site agrees in general with the assumed program design saturation, though the fixture types are more diverse in the actual population. The change in connected load pre- to post-retrofit is a very important parameter used to estimate program savings, and yet little is actually known about the type or frequency with which particular systems are replaced. This is a weakness in the MDSS we recommend correcting.

Exhibit B-11

Observed Existing Fixture Saturation vs. Program Design Replacement Assumptions



B.6.5 Hours of Fixture Operation by Business Type and Technology Group

Exhibit B-12 presents a summary of the annual hours of fixture operation applied in generating RE energy impacts in the commercial sector.

Exhibit B-12

Commercial Sector Annual Fixture Hours of Operation by Business Type and Technology Group

| Business Type Program and Technology Group | Commercial Sector Hours of Fixture Operation | | | | | | | | | |
|---|--|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. |
| Indoor Lighting | | | | | | | | | | |
| Retrofit Express Program | | | | | | | | | | |
| Compact Fluorescent | 3,600 | 3,100 | 3,200 | 1,800 | 5,100 | 4,300 | 4,000 | 4,900 | 2,300 | 3,900 |
| Standard Fluorescent | 3,900 | 4,300 | 3,800 | 2,000 | 6,900 | 5,200 | 4,900 | 6,500 | 3,000 | 4,800 |
| High Intensity Discharge | 4,200 | 4,000 | 3,900 | 2,400 | 6,500 | 5,600 | 5,100 | 6,800 | 3,200 | 5,100 |
| Halogen | 4,200 | 3,900 | 3,900 | 2,300 | 6,500 | 5,500 | 5,100 | 6,900 | 3,100 | 5,000 |
| Exit Signs | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 |
| Controls (Occ. Sens. Only)† | 900 | 1,000 | 800 | 600 | 700 | 1,300 | 1,400 | 1,900 | 900 | 1,100 |
| Exterior Lighting | | | | | | | | | | |
| Retrofit Express Exterior HID | 3,600 | 3,600 | 3,600 | 3,600 | 3,600 | 3,600 | 3,600 | 3,600 | 3,600 | 3,600 |

† Hours presented for occupancy sensors reflect the net reduction in hours of operation.

Although the hours presented are at the detailed level of business type and technology group, providing details from the engineering methods applied, we cannot recommend at this time that results at this detailed level be applied to other samples of participants.

The annual fixture operating figures presented here are based upon the combined application of customer operating schedules by daytype and season, and open and closed operating factors developed by daytype, business type, and technology group. To prevent unnecessary reporting and tables, presentation of the operating factors and operating schedules has been replaced with information at levels of detail more suitable for PG&E's use, i.e., the annual fixture operating hours summaries just presented, and the summer on-peak coincident diversified operating factors that follow.

B.6.6 Coincident Diversified Operating Factors by Business Type and Technology Group

Exhibit B-13 presents a summary of the commercial sector peak-hour coincident diversified operating factors (CDOF's), the percentage of connected load use estimated for the peak hour on a mean basis across the summer on-peak period. This term incorporates diversity as a function of both customer operating schedules, and weekday open and closed operating factors that were developed by business type and technology group. These terms are presented for the purpose of providing PG&E with detailed customer retrofit performance during the critical on-peak hour.

Exhibit B-13

Commercial Sector Summer On-Peak CDOF's

| Business Type Program and Technology Group | Commercial Sector Summer On-Peak CDOF Results | | | | | | | | | |
|---|---|--------|--------------|--------|---------|------------|-------------|-------------|-----------|-------|
| | Office | Retail | College/Univ | School | Grocery | Restaurant | Health Care | Hotel/Motel | Warehouse | Misc. |
| Indoor Lighting | | | | | | | | | | |
| Retrofit Express Program | | | | | | | | | | |
| Compact Fluorescent | 0.70 | 0.59 | 0.48 | 0.40 | 0.61 | 0.59 | 0.60 | 0.58 | 0.57 | 0.54 |
| Standard Fluorescent | 0.78 | 0.94 | 0.62 | 0.46 | 0.92 | 0.79 | 0.80 | 0.78 | 0.76 | 0.71 |
| High Intensity Discharge | 0.84 | 0.85 | 0.66 | 0.58 | 0.85 | 0.85 | 0.85 | 0.81 | 0.81 | 0.76 |
| Halogen | 0.85 | 0.84 | 0.66 | 0.57 | 0.86 | 0.84 | 0.85 | 0.83 | 0.80 | 0.75 |
| Exit Signs | 0.94 | 0.94 | 0.94 | 0.94 | 0.94 | 0.94 | 0.94 | 0.94 | 0.94 | 0.94 |
| Exterior Lighting | | | | | | | | | | |
| Retrofit Express Exterior HID | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 |

We cannot recommend at this time that CDOF results, which were derived at the technology group and business type level, be transferred to other retrofit customers based upon this study alone.

B.6.7 HVAC Impact Results

Exhibit B-14 presents commercial sector mean HVAC energy and summer on-peak demand adjustment factors by business type that describe the ratio of total fixture and HVAC impact to fixture-only impact. These adjustments could be applied by business type to future estimates of technology-only lighting impacts, yielding estimates of total impacts that include the HVAC component.

Exhibit B-14

Commercial Sector HVAC Adjustments

| Industry Group | Indoor Lighting HVAC Adjustments | |
|----------------------|----------------------------------|-------------------|
| | Energy Adjustment | Demand Adjustment |
| Office | 1.14 | 1.24 |
| Retail | 1.08 | 1.16 |
| College/University | 1.19 | 1.32 |
| School | 1.12 | 1.22 |
| Grocery | 1.12 | 1.23 |
| Restaurant | 1.13 | 1.26 |
| Health Care/Hospital | 1.12 | 1.22 |
| Hotel/Motel | 1.16 | 1.27 |
| Warehouse | 1.05 | 1.10 |
| Miscellaneous | 1.10 | 1.16 |

B.6.7 Customized Incentives Methodology

Hard copy application forms for Customized program participants were obtained from PG&E, providing a critical source of information used to derive program impacts. Key engineering data from the forms were entered into a database to classify each impact by technology group, and to generate critical information regarding the retrofit system installed and the existing system removed. Classifying impacts was an important part of this analysis, since impacts tracked in the MDSS for Customized program measures are often not categorized. The method used to generate impacts (for most of the technology groups) required an estimate of the change in connected load for each measure retrofit. With these two parameters and any customer-specific schedule information, impacts were estimated using methods that are consistent with those used for the measures in the RE program. In the absence of hard copy form data, it was found that the MDSS demand impact could be used to approximate change in fixture connected load. In all cases investigated (with the exception of exterior HID lights, refrigerator case door anti-sweat devices, and EMS systems), change in connected load was tracked in the MDSS variable PKW1.

However, some of the items retrofit did not fit into a category associated with the RE measures, as described in the following cases:


- Traffic signal retrofits using red LED arrays were assumed to have a 50 percent probability of operation during every hour of the year, which is a conservative estimate. The MDSS estimates for summer on-peak were undiversified change in connected load, as was typical for most Customized measures.
- EMS system energy estimates, taken either from the application forms or the MDSS, were used, and simply applied evenly to every hour of the year.
- Supermarket refrigerator case doors were equipped with sensors (controlled by a new EMS system) to limit the run-time of anti-sweat heat strip devices. These impacts were tracked in the MDSS under the lighting program, even though these impacts are really the result of refrigeration measures. Consideration should be given in the future to tracking these impacts under another end-use category.

B.7 Indoor Impact Profiles by Business Type and Costing Period


To conclude this engineering appendix, hourly/daytype unadjusted gross energy profiles are presented for selected business types, by costing period, for all indoor lighting technologies installed under the RE program. The following profiles demonstrate the detailed information supplied to PG&E through the application of engineering estimates on an hourly basis.

Exhibit B - 15

Indoor Lighting Impact Profiles for the Office Segment During the Summer Season




Impact (MWh)



Hour of Day

Exhibit B-16

Indoor Lighting Impact Profiles for the Retail Segment During the Summer Season



Impact (MWh)






Exhibit B-17

Indoor Lighting Impact Profiles for the
Col/Univ Segment During the Summer Season




Impact (MWh)




Hour of Day

Exhibit B-18

Indoor Lighting Impact Profiles for the School Segment During the Summer Season



Impact (MWh)



Hour of Day

Exhibit B-19

Indoor Lighting Impact Profiles for the Grocery Segment During the Summer Season

Impact (MWh)






Exhibit B-20

Indoor Lighting Impact Profiles for the Health Care Segment During the Summer Season



Impact (MWh)



Hour of Day

Exhibit B-21

Indoor Lighting Impact Profiles for the Warehouse Segment During the Summer Season

Impact (MWh)






Exhibit B-22

Indoor Lighting Impact Profiles for the
Misc. Comm Segment During the Summer Season



Impact (MWh)






Exhibit B-23

Indoor Lighting Impact Profiles for the Office Segment During the Winter Season




Impact (MWh)



Hour of Day

Exhibit B-24

Indoor Lighting Impact Profiles for the Retail Segment During the Winter Season



Impact (MWh)





Exhibit B-25

Indoor Lighting Impact Profiles for the
Col/Univ Segment During the Winter Season



Impact (MWh)




Exhibit B-26

Indoor Lighting Impact Profiles for the School Segment During the Winter Season

Impact (MWh)






Exhibit B-27

Indoor Lighting Impact Profiles for the Grocery Segment During the Winter Season



Impact (MWh)






Exhibit B-28

Indoor Lighting Impact Profiles for the Health Care Segment During the Winter Season



Impact (MWh)



Hour of Day

Exhibit B - 29

Indoor Lighting Impact Profiles for the Warehouse Segment During the Winter Season

Impact (MWh)







Exhibit B-30

Indoor Lighting Impact Profiles for the Misc. Comm Segment During the Winter Season

Impact (MWh)



Appendix C

DETAILED STATISTICAL IMPACT ANALYSIS APPROACH AND RESULTS

Appendix C

BILLING REGRESSION ANALYSIS

This appendix documents the detailed analytical steps undertaken in the billing regression analysis of Pacific Gas and Electric Company's (PG&E's) 1994 Commercial Lighting Technologies Evaluation. It begins with a discussion of analysis periods and data sources used in the billing regression analysis and then presents the regression model specification and SAE realization rate. The presentation of relative precision calculation procedures and results concludes the appendix.

C.1 Overview

The billing regression analysis of the Commercial Lighting Technologies Evaluations is an integrated part of the overall net and gross impact evaluation. The key objective of the analysis is to determine the first-year program energy impacts. A statistical analysis is employed to model the differences of customers' energy usage between pre- and post-installation periods. The model is specified using actual customer billing data and independent variables that explain changes in customers' energy usage including engineering estimates of program participation. This statistically adjusted engineering (SAE) analysis is consistent with the requirements of the Load Impact Regression Model (LIRM) defined in the California Public Utilities Commission's (CPUC's) Measurement and Evaluation Protocols (the Protocols).

The results of the billing regression analysis are estimated as ratios, termed "realization rates," of realized impacts to engineering impact estimates. Realized impacts represent the fractions of the engineering estimates actually "observed" or "detected" in the statistical analysis of actual billing data. The realization rates estimated as coefficients in the SAE regression models are relative to the results of the evaluation-based engineering estimates, not the PG&E Program ex ante estimates. The SAE realization rates, the estimation of which is the topic of this appendix, are then used to estimate program impacts and realization rates relative to the ex ante estimates.

C.2 Data Sources for Billing Regression Analysis

The billing regression analysis for the 1994 Commercial Lighting Programs Evaluation uses data from four primary data sources: the PG&E Management Decision Support System (MDSS) tracking database, the billing database, the telephone survey data, and the engineering estimates of changes of usage between the pre- and post-installation

periods. It also utilizes weather data tapes from PG&E's load research weather sites. A summary of the data elements used in the regression analysis are presented below.

C.2.1 Program Participant Tracking System.

The participant tracking system for the Retrofit Express (RE) and Customized Incentives (Customized) programs was maintained as part of the MDSS. It contains program applications, rebate and technical information about installed measures, including measure description, quantity, rebate amount, and ex ante demand, and energy and therm saving estimates. The MDSS database is linked to the billing database and other program databases through PG&E's customers control numbers.

C.2.2 PG&E Billing Data.

For this evaluation, the PG&E billing data were obtained from two different data sources within PG&E. The original nonresidential billing dataset contains monthly energy usage for all nonresidential accounts in PG&E's service territory, and was used in the sample design as described in *Appendix A*. The second billing dataset, which consists only of customer accounts in the surveyed dataset, was later obtained from PG&E Load Data Services.¹ Since the second billing dataset has many useful fields that were not included in the first dataset, a decision was made to use the second billing dataset to conduct the statistical billing analysis. The billing series used in the analysis is the PG&E pro-rated monthly usage data, a series calculated by PG&E for each calendar month, from January 1991 to September 1995.

C.2.3 Weather Data

The hourly dry bulb temperature collected for 25 PG&E load research weather sites was used in the billing regression analysis to calculate total monthly cooling and heating degree days for each month in the analysis period. For each customer in the analysis dataset, the appropriate weather site was linked to that customer by using the PG&E-defined weather site to PG&E local office mapping.

C.2.4 Telephone Survey Data

Two telephone survey samples of 479 participant and 458 nonparticipant commercial customers were collected for the evaluation. The data collected in the telephone survey supplies information on energy-related changes at each site for the billing period covered by the billing regression analysis. For a detailed discussion of the telephone survey sample design and the final sample distribution, see *Appendix C*.

¹ A preliminary analysis has concluded that the monthly usage and bill read date information in these two datasets was consistent.

C.2.5 Final Analysis Sample

As discussed earlier, this evaluation utilizes a nested sample design approach. The on-site audit sample and lighting logger sample were collected as part of the telephone survey, with the exception of a few customers who completed an on-site audit and later declined to be telephone surveyed. The final analysis sample size of 480 commercial participant customers represents 325 customers who were surveyed only by telephone, 154 customers who were surveyed by telephone and on-site audited, and one customer who was on-site audited, but later refused to complete a telephone survey. This sample includes a total of 432 RE program indoor lighting participants, 20 Customized program indoor lighting participants, and 28 participants who installed only outdoor lighting measures under either the RE or Customized program. It is important to mention that various program or technology participant populations are not mutually exclusive. For example, a customer can participate both RE and Customized programs and receive rebates for both indoor and outdoor lighting measures in the same year. The following decision rules were used to define each participant population: 1) customers who received rebates for both indoor and outdoor lighting measures are classified as indoor lighting participants; and 2) customers who participated both RE and Customized programs are classified as Customized participants if there is at least one Customized lighting measure installed. The final analysis sample distribution, by business type, program, and indoor/outdoor measures, is presented in Exhibit C-1.

Exhibit C-1
Analysis Sample Distribution
By Program, End Use and Business Type

| Business Type | Participants | | | Comparison Group | Total |
|------------------|--------------|------------|---------------|------------------|------------|
| | Indoor | | Outdoor | | |
| | RE | Customized | RE/Customized | | |
| Office | 106 | 2 | 6 | 138 | 252 |
| Retail | 105 | 3 | 14 | 104 | 226 |
| Coll/Univ | 1 | 0 | 0 | 3 | 4 |
| School | 61 | 1 | 3 | 33 | 98 |
| Grocery | 27 | 11 | 0 | 30 | 68 |
| Restaurant | 20 | 0 | 2 | 29 | 51 |
| Health Care | 33 | 0 | 1 | 20 | 54 |
| Hotel/Motel | 14 | 1 | 0 | 36 | 51 |
| Warehouse | 32 | 1 | 1 | 32 | 66 |
| Commercial Misc. | 33 | 1 | 1 | 33 | 68 |
| TOTAL | 432 | 20 | 28 | 458 | 938 |

In order to estimate independent realization rates at the business type and technology level, the lighting technologies were further grouped into seven categories, as shown in

Exhibit C-2. Among those technology categories, the Standard-Efficiency Fluorescent group accounts for the largest share of impact, with approximately 65 percent of the total engineering impact estimate for energy. The second largest technology group is the Interior HID and Halogen, which accounts for about 11 percent of the impacts, followed by the Customized measures (7 percent) and the Compact Fluorescent Lamps (7 percent). The outdoor lighting measures account for approximately 5.6 percent of the total impacts.

Exhibit C-2
Analysis Sample Distribution by Technology

| Lighting Technology | Description of Technology | Sample Size * |
|---|--|----------------------|
| RE Program: Interior HID and Halogen | All Halogen Wattages, All Indoor HID Measures | 65 |
| RE Program: Compact Fluorescent Lamps | All Compact Fluorescent Measures | 175 |
| RE Program: Exit Signs | All Exit Sign Retrofit Measures | 59 |
| RE Program: Standard-Efficiency Fluorescent | Incandescent to Fluorescent Fixtures, Efficient Ballast Changeouts, T-8 Lamps and Electronic Ballasts, Delamp Fluorescent Fixtures, Reduced Wattage Lighting | 351 |
| RE Program: All Other Indoor Lighting Measures | All Controls, All Other Misc. Indoor Lighting Measures | 57 |
| Customized Program: All Indoor Measures | All Customized Incentives Lighting Measures | 20 |
| Outdoor Lighting: All Outdoor RE and Customized Measures | Exterior HPS from Mercury Vapor, Outdoor Incandescent to Fluorescent, Exterior HPS/LPS | 94 |
| | | |
| * Sum may exceed the total sample size due to multiple measure installations. | | |

C.3 Data Integration and Analysis Dataset Profiles

All data elements mentioned above were linked to the final analysis database through PG&E's unique customer control number. For this evaluation, the analysis database served as a centralized tracking system for customers' billing history, program participation, and sampling status and helped reduce data problems, such as account mismatch and double counting. All participants in the survey sample were successfully merged with the MDSS database by control.

In this section, the sample distribution and key variables in the analysis dataset were examined, and the appropriate statistics were computed to ensure that the data was sufficient, both in terms of quality and quantity, to support the billing regression analysis. The findings are grouped into the following categories, based upon the nature of the variables and their respective data sources. All the statistics presented below are based upon the integrated analysis dataset of 938 observations.

C.3.1 Unadjusted Engineering Estimates

As mentioned above, there are a total of 480 participants in the final analysis database. Unadjusted engineering estimates of energy changes were calculated for all 480 customers. The difference between change and gross impact is that the change estimate accounts for the change in consumption relative to the participants' pre-existing system, and takes into account burned-out bulbs. When burned-out bulbs have been replaced by the participant, either as part of, or simultaneously with, program participation, the billing analysis detects an increase in energy usage, offsetting the gross impact of the program. For this reason, the engineering estimates account for participant and nonparticipant burn-out rates, and account for burned-out bulb replacement in the change estimates. For the impact estimates, however, we will assume that the burned-out equipment would have been replaced, and credit the program with first-year savings associated with all equipment installed under the program.

Exhibits C-3 and C-4 below present the engineering change estimates used in the billing analysis by technology category and business type.

Exhibit C-3

Engineering Change Estimates by Technology Categories

| Technology Group | Customers Installing Measures | Mean Impact (kWh) | Total Impact (kWh) |
|---|--------------------------------------|--------------------------|---------------------------|
| Halogen and Interior HID | 65 | 44,136 | 2,868,843 |
| Compact Fluorescent | 175 | 8,412 | 1,472,142 |
| Exit Sign Retrofits | 59 | 3,131 | 184,739 |
| Standard-Efficiency Fluorescent | 351 | 32,536 | 11,420,253 |
| All Other RE Interior Technologies | 57 | 14,464 | 824,466 |
| All Interior Customized Technologies | 20 | 87,677 | 1,665,871 |
| All Outdoor Technologies | 94 | 9,449 | 888,223 |
| TOTALS* | 480 | 40,259 | 19,324,537 |
| *Total for customers is total number of customers, rather than total number of installations. | | | |


Exhibit C-4
Engineering Change Estimates by Business Type

| Building Type | Number of Customers | Mean Impact (kWh) | Total Impact (kWh) |
|----------------------|----------------------------|--------------------------|---------------------------|
| Office | 114 | 40,892 | 4,661,690 |
| Retail | 122 | 33,257 | 4,057,354 |
| College/University | 1 | 229,912 | 229,912 |
| School | 65 | 42,193 | 2,742,529 |
| Grocery | 38 | 68,724 | 2,611,521 |
| Restaurant | 22 | 14,479 | 318,539 |
| Health Care/Hospital | 34 | 54,983 | 1,869,423 |
| Hotel/Motel | 15 | 38,717 | 580,757 |
| Warehouse | 34 | 24,904 | 821,837 |
| Miscellaneous | 35 | 40,885 | 1,430,974 |
| TOTALS | 480 | 40,259 | 19,324,537 |

C.3.2 Year-to-Year Energy Usage Change

The comparison between average consumption changes for participants and comparison group customers between pre- and post-installation periods can often provide some “indication” for the program realized impacts. Exhibit C-5 presents the average usage for participants and comparison group customers between 1992 and 1995, normalized to their 1992 average usage. It clearly shows that participants, as a group, have a lower energy growth rate when compared to the comparison group customers. In fact, the growth rate difference between participants and comparison group is approximately 13 percent, the same saving ratio predicted by the unadjusted engineering estimates. The significance of this graph should not be overstated, however. This type of simple comparison, by itself, is inadequate to provide an accurate estimation of impacts, because other factors with the potential to affect the energy usage are not controlled in this comparison.

Exhibit C-5
Participant and Comparison Group Population Mean Usage 1992-1995



C.3.3 Model Specification and Results

The billing regression analysis for the 1994 Commercial Lighting Evaluation used two different multivariate regression models under an integrated framework of providing unbiased and robust model estimates in the commercial sector. The key feature of our approach is that it employs a simultaneous equation approach to account for both the year-to-year and cross-sectional variation in a manner that consistently and efficiently isolates program impacts.

A baseline model is initially estimated using only the comparison group sample. This model estimates a relationship that is then used to forecast the post-installation-year energy consumption for both participants and the comparison group as a function of pre-installation year usage. In this way, baseline energy usage is forecasted for participants by assuming that their usage will change, on average, in the same way that usage did for the comparison group.

The SAE impact model used in this evaluation is specified as a two-stage Least Square (2SLS) model² that allows for the utilization of all billing and sample data from two pre-installation periods (as described above). The estimated SAE realization rates are used to adjust the engineering estimates of expected annual energy impacts for the entire

² Dhrymes, P.J., *Introductory Econometrics*, Springer-Verlag, New York, 1978. pp 289 - 293.

participant population. These impacts are presented in *Section 4* and are used to compute program realization rates.

C.4 Analysis Periods

When the billing regression analysis is used to model the change of consumption attributable to the program measures, the first step is to isolate the pre- and post-installation periods for each customer in the analysis database so that the impact of these measures can be verified.

In accordance with the Protocols, participants are defined by the “paid date” instead of “installation date.” Therefore, almost all customers actually installed measures in 1993 or 1994, with 1994 installations accounting for approximately 75 percent of total installations.³

Two comparison periods are specified so that pre-installation data from both 1992 and 1993 can be used. Two sets of analysis periods supports the joint estimation of changes relative to two years of pre-installation data, using a simultaneous equation approach described below in the model specification section. The system is estimated using the 2SLS method as follows:

- The primary analysis periods are defined in a way that maximizes the inclusion of a majority of the sample. Because the installation dates cannot be accurately determined for all customers in the analysis database, the pre-installation period (October 1991 - September 1992) and a post-installation period (October 1994 - September 1995) are defined for the entire participant sample. This definition creates a window so that billing data excluded from the analysis is wide enough to assure that all participants have the effects of program measures isolated from the pre- and post-installation periods. In this way, realization rates are not biased by errors in estimating dates of installation.
- A second analysis period is used to estimate the first stage of the 2SLS model. The first-stage model is used only to estimate customer-specific inter-year correlations, and is less sensitive to errors that may be introduced by the estimation of the installation dates. The second pair of pre- and post-installation periods compares 1993 (October 1992 - September 1993) to 1995 (October 1994 - September 1995). For these customers, pro-rated estimates of program impacts are computed to account


³ As mentioned before, an accurate determination of the installation date is very difficult due to inadequate data; however, a best-effort estimate was implemented based upon the analysis of the inspection dates and check issue dates from the tracking system in combination with customers' self-reported installation dates.

for when the installation likely occurred, if it is estimated that installation took place during a portion of the pre-installation period.

The specification of two analysis periods allows for the analysis of pre-installation periods in a manner that, through the use of the earlier pre-installation period, minimizes measurement error in the identification of installation, and retains the information of value contributed by the more recent pre-installation period. As discussed below, these analyses periods support seasonal billing data regression models. Seasonal models resulted in more stable results without artificially deflating the parameter standard errors that would be induced by autocorrelated monthly observations.

As mentioned above, it is difficult to determine the actual installation dates because they were often missing in the MDSS database. A decision rule was developed as part of the evaluation to determine the actual installation date for each participant, based upon the survey self-reported date, MDSS completion date (if not missing), pre- and post-inspection dates, and check issue date. The following exhibit presents the participant sample distribution by estimated installation date.

Exhibit C-5
 Commercial Lighting Evaluation Sample Distribution
 By Estimated Installation Date



C.5 Baseline Model

The baseline model explains post-installation energy usage as a function of the pre-installation energy usage, weather changes, and customer self-reports of factors that could affect energy usage. In order to isolate the program impact from the energy usage changes, only the comparison group is used to fit this model. The baseline model has the following functional form:

$$kWh_{post,i} = \sum_j \alpha_j + \beta kWh_{pre,i} + \gamma (\Delta CDD_i) * kWh_{pre,i} + \sum_k \eta_k Chg_{i,k} + \varepsilon$$

Where

$kWh_{post,i}$ and $kWh_{pre,i}$ are customer i 's annualized energy usage for the post- and pre- installation periods, respectively;

ΔCDD_i is the annual change of cooling degree days (base 65°F) between post-installation year and pre-installation year;

$Chg_{i,k}$ are the customer self-reported change variables from the survey data, including adding, replacing, or removing equipment associated with major end uses, changes in number of employees and square footage;

α_j is the indicator variable (0/1) for the j th business type. It equals 1 if the customer is in that business type and 0 otherwise;

β and γ are the estimated slopes on their respective independent variables; and,

ε is the random error term of the model.

For each customer in the analysis dataset, two predicted usage values are calculated using the parameters of the baseline models estimated independently for the 1993 to 1995, and the 1992 to 1995 analysis periods. They both take the same functional form with different segment-level intercept series (α_j) and slopes (β and γ):

$$\hat{kWh}_{post,i} = F_{pre}(kWh_{pre,i}, \Delta CDD_{pre,i}) = \sum_j \alpha_j + \beta kWh_{pre,i} + \gamma (\Delta CDD_{pre,i}) * kWh_{pre,i}$$

The output of the baseline models are presented in Exhibit C-7 for the 1993 to 1995 analysis periods, and in Exhibit C-8 for the 1992 to 1995 analysis periods. Outlier analysis has identified one customer with high influence on the coefficient estimate. This customer, a college/university comparison group member, has the highest usage among all comparison group customers, and t was eliminated from both models. The final functional relation estimated as follows:

Baseline Model (1993 to 1995):

$$\begin{aligned} \widehat{kWh}_{95,i} = & 586 * OFF + 2309 * RET - 23623 * UNIV + 2374 * SCH + 545 * GRO \\ & - 6993 * RES + 1327 * HEA - 3590 * HOTEL - 18177 * WH + 1039 * MISC \\ & + 1.10 * kWh_{93,i} + 0.00071 * CDD_{95-93,i} * kWh_{93,i} \end{aligned}$$

Baseline Model (1992 to 1995):

$$\begin{aligned} \widehat{kWh}_{95,i} = & 86 * OFF - 5393 * RET - 36239 * UNIV - 547 * SCH - 5693 * GRO \\ & - 10617 * RES - 4654 * HEA - 2520 * HOTEL - 7716 * WH + 8990 * MISC \\ & + 1.08 * kWh_{92,i} + 0.000187 * CDD_{95-92,i} * kWh_{92,i} \end{aligned}$$

C.6 SAE Model

Using the predicted post-installation usage values estimated in the baseline models, a simultaneous equation model is specified to estimate the SAE realization rates. This approach employs a 2SLS model that incorporates the billing data and engineering estimates in 1993⁴ and 1995 to fit the first (or stage 1) model. The 1992 and 1995 data are used in the final (or stage 2) model. The first stage results in an estimate of customer-specific inter-year correlation that is used as an independent variable in the final model. The SAE simultaneous system can be described as follows:

$$\text{Stage 1: } kWh_{95,i} - F_{93}(kWh_{93}, \Delta CDD_{93}) = \sum_m \beta_m Eng_m + \sum_k \eta_k Chg_{i,k} + \mu_{93}$$

$$\text{Stage 2: } kWh_{95,i} - F_{92}(kWh_{92}, \Delta CDD_{92}) = \sum_m \beta'_m Eng_m + \sum_k \eta'_k Chg_{i,k} + \mu_{92}$$

$$\text{with } \mu_{92} = \lambda \mu_{93} + \sigma$$

The last equation represents the assumption that there is correlation in usage between the two years. By including the estimated residual from the stage 1 model as an independent variable in the stage 2 model, the error term in the stage 2 model simplifies to a random error term σ and results in the estimation of a more accurate and stable final SAE model.

In the stage 1 model, the difference between predicted and actual usage in 1995 was used as the dependent variable in a SAE model. Based upon the estimated participation month, the pro-rated engineering estimates and change variables were used to explain

⁴ All years mentioned in the SAE analysis, refer to a period that covers the last quarter of the previous year, and the first nine months of the current year.

the deviation of the actual usage from the predicted usage. As discussed above, the predicted usage is estimated using only the comparison group to forecast the 1995 usage as a function of 1993 usage and change of cooling degree days from 1993 to 1995. This usage prediction presents what would have happened in the absence of the program.

The stage 1 model has the same basic specification as described later for the stage 2 model. The stage 1 model was estimated on a sample of 937 observations with the same one nonparticipant sample point removed as described in the baseline model above and the only output used from this model is the model residual, which represents a customer-specific inter-year correlation. Exhibit C-7 presents the model output statistics from the stage 1 model.

Exhibit C-7
Stage 1 Model Output

| Parameter Description | Parameter Estimate | t-statistic |
|--|---------------------------|--------------------|
| Estimated Engineering Impacts for 1993 | -0.71 | 17.0 |
| Prorated Change Variables | | |
| Cooling Equip. Additions or Replacements in 1993 | -3416.55 | 0.3 |
| Cooling Equip. Removal in 1993 | 0.00 | N/A |
| Heating Equip. Additions or Replacements in 1993 | 46432.00 | 1.8 |
| Heating Equip. Removal in 1993 | -958.02 | 0.0 |
| Other Equip. Additions or Replacements in 1993 | 14825.00 | 1.6 |
| Other Equip. Removal in 1993 | 0.00 | N/A |
| Employee Additions in 1993 | 27298.00 | 2.9 |
| Employee Reductions in 1993 | -11189.00 | 0.9 |
| Square Footage Additions in 1993 | 4675.41 | 0.3 |
| Square Footage Reductions in 1993 | 15529.00 | 0.4 |
| Lighting Equipment Additions in 1993 | 14587.00 | 1.9 |
| Lighting Equipment Replacements in 1993 | -9353.96 | 0.9 |
| Lighting Equipment Removals in 1993 | -18777.00 | 0.7 |

C.7 Billing Regression Analysis Results

The coefficients of the engineering impacts in the stage 2 model are the SAE realization rates. Independent realization rates are estimated to provide PG&E with business type and technology group level results. Exhibit C-8 summarizes the final SAE model results

that was estimated using 936 customers out of a total sample of 938 customers.⁵ In addition to one nonparticipant removed in the baseline model, one more observation was removed due to its large usage.⁶ The observation removed is a participant in the health care/hospital business type, and it has the highest usage among all participants. Exhibit C-8 summarizes the independent variables used in the final stage 2 model, together with the t-statistics and the sample sizes available for each parameter estimate.

Exhibit C-8
Billing Regression Analysis Final Model Outputs

| Parameter Description | Parameter Estimate | 90% Confident Bounds | | t-statistic | Sample Sizes |
|--|-----------------------|----------------------|-------|-------------|-----------------|
| | | Lower | Upper | | |
| Customer Specific Intercept from Stage 1 | 0.95 | 0.89 | 1.01 | 25.7 | 936 |
| Estimates Realization Rates | | | | | |
| RE Program Standard Fluorescence | | | | | |
| Offices | -0.94 | -1.10 | -0.78 | 10.1 | 90 |
| Retails | -0.82 | -1.14 | -0.50 | 5.2 | 84 |
| Others | -0.70 | -0.94 | -0.46 | 6.9 | 177 |
| RE Program HID's | | | | | |
| Offices | -0.94 | -1.21 | -0.67 | 6.1 | 10 |
| Retails | -0.75 | -1.17 | -0.33 | 3.9 | 28 |
| Others | -1.60 | -1.87 | -1.33 | 6.1 | 27 |
| RE Program Compact Fluorescence | -0.62 | -1.33 | 0.09 | 2.3 | 175 |
| RE Program Other Indoor Measures | -0.40 | -2.63 | 1.83 | 0.7 | 105 |
| Customized Program Indoor Measures | -1.57 | -1.71 | -1.43 | 12.0 | 20 |
| RE/Customized Outdoor Measures | -0.54 | -1.61 | 0.53 | 1.5 | 94 |
| Change Variables (Multiplied by Pre-Usage) | | | | | |
| Add Lighting | 0.131 | -0.122 | 0.384 | 6.5 | 80 |
| Replace Lighting (Outside Program) | -0.027 | -1.124 | 1.070 | 1.5 | 38 |
| Remove Lighting | -0.171 | -1.119 | 0.777 | 1.7 | 6 |
| Replace HVAC | -0.031 | -0.689 | 0.627 | 2.5 | 60 |
| Replace Other Equipment | -0.057 | -1.142 | 1.028 | 1.5 | 52 |
| Add Employee | 0.038 | -0.819 | 0.895 | 1.9 | 103 |
| Reduce Employee | -0.053 | -0.484 | 0.378 | 3.8 | 90 |
| Installed Non-Lighting Program Measures | -0.055 | -0.534 | 0.424 | 3.4 | 18 |

⁵ A variety of data censoring criteria were employed to identify potential outliers. Models were run without outliers, resulting in final results that were equivalent to running the model with nearly the entire sample. For this reason, the final model is based upon the largest sample possible that achieved a consistent result. In this way, data censoring criteria do not introduce a qualitative element to the final model results.

⁶ Both observations have large impacts on the parameter estimates. If left in the model, the overall realization rates would be much higher and therefore the removal of these two observations represents a conservative approach to estimating program gross energy impacts.

- The dependent variable is the difference between the actual and predicted 1995 usage using the 1992 baseline model. Using the comparison between 1992 and 1995 will maximize the inclusion of the majority of the sample, as discussed in the analysis period section above.
- Customer-specific inter-year correlation is the residual term from the stage 1 model. The large t-statistics on this term suggest a strong correlation between customers' usage from one year to another. Inclusion of this term contributes to a more stable model in the sense that there is very low correlation between all the parameter estimates in the final model, especially the SAE realization rate parameters.
- Ten different realization rates are estimated corresponding to business type and technology group segments. Only those measures that have broad participation and relative high expected impacts can support a separate realization rate estimate. While all the realization rates have the right signs, some business types and technologies have much higher estimated impacts than others. All realization rate estimates are significant at the 95 percent confidence level (t-statistics greater than 2) except RE program "other indoor lighting" measures, since this segment likely has large variation and relatively low impacts. Only those realization rates that are statistically significant at the 95 percent level in the final model were used in the final gross impact calculation.
- All change variables have the expected signs. Only those change variables with a significant level greater than 0.15 were kept in the final model through a step-wise regression procedure. Variables excluded from the model include facility square footage changes, HVAC equipment removal, and participation in the 1993 programs.

While QC investigated the use of TOU and load research demand data as a means of supporting a similar SAE demand model, the load information was not available in sufficient quantity to support such an analysis. The demand analysis conducted during this evaluation is based upon engineering models calibrated to on-site audits, spot-watt measurements, lamp counts, and lighting logger data. The spot-watt data were used to calibrate new equipment manufacturers' cut sheet data based upon actual measurements. The lamp counts were used to determine operating factors and burned-out lamp rates pre- and post-installation. The lighting loggers were used to determine whether sites were actually operating in the "open" mode at the time of system peak. This was necessary, since many of the audits were conducted in the morning, and the lighting loggers confirmed the self-reports that the facility was open or closed at the time of system peak.

C.7.1 Relative Precision Calculation

Relative precision at 90 percent and 80 percent confidence levels for the adjusted gross energy impact estimates are calculated at each of the SAE analysis segments. As mentioned above, there are a total of ten analysis segments that were explicitly modeled and the relative precision estimates based upon the model output are presented in Exhibit C-9 below. In order to calculate the total program level adjusted gross impact and relative precision, the segment level results were weighted by their unadjusted engineering energy impact estimates in the following equations, and the results are presented in Exhibit C-9.

$$\text{Total Adjusted Energy Impact} = \sum_i \beta_i \text{Eng}_i$$

Where β_i and Eng_i are the SAE realization rates and unadjusted engineering impact estimates for segment i , respectively. The program level standard error can be estimated as:⁷

$$\text{StdErr} = \sqrt{\sum_i (\text{CV}_i * \beta_i * \text{Eng}_i)^2}$$

Where $\text{CV}_i = (\text{std}(\beta_i) / \beta_i)$ is the coefficient of variation in segment i , estimated in the billing regression model. Finally, the relative precision at 90 percent and 80 percent confidence levels were calculated as

$$\text{RP} = \frac{t * \text{StdErr}}{\text{Total Adj. Energy Impact}}$$

where t equals 1.645 and 1.282 for the 90% and 80% confidence levels, respectively.

⁷ This procedure assumes that the samples in different segments are independent and can be treated as strata in a stratified sampling.

Exhibit C-9
Relative Precision Calculation

| SAE Analysis Level | Engineering Gross Impact Estimate (MWh) | Realization Rate | Relative Precision at 90% | Relative Precision at 80% |
|--|--|-------------------------|----------------------------------|----------------------------------|
| RE Program Standard Fluorescents | | | | |
| Offices | 93,822 | 94% | 16% | 13% |
| Retails | 30,756 | 82% | 32% | 25% |
| Others | 83,607 | 70% | 24% | 18% |
| RE Program HIDs | | | | |
| Offices | 8,611 | 94% | 27% | 21% |
| Retails | 10,810 | 75% | 42% | 32% |
| Others | 15,302 | 160% | 27% | 21% |
| RE Program Compact Fluorescents | 23,719 | 62% | 71% | 55% |
| RE Program Other Indoor Measures | 15,635 | 40% | 224% | 175% |
| Customized Program Indoor Measures | 22,117 | 157% | 14% | 11% |
| RE/Customized Program Outdoor Measures | 18,058 | 54% | 107% | 84% |
| TOTALS | 322,437 | 86% | 16% | 12% |

The realization rates presented in Exhibit C-9 above are the gross SAE realization rates, that is the gross realized impacts as compared to the gross *evaluation engineering estimates*. In order to compute the final gross realization rates, the gross evaluation estimates compared to the gross ex ante estimates, three steps must occur. First, the gross evaluation engineering estimates presented in Exhibit C-9 are multiplied by the SAE realization rates in Exhibit C-9. Second, for the segments for which the 90 percent confidence level was not achieved (outdoor lighting and other indoor measures), the evaluation calibrated model engineering estimates of impact are to be assumed as the evaluation estimates (this is the same as assuming a realization rate of 1.0 in the previous step). When these two steps have been carried out, a total gross evaluation energy impact of 295,746 MWh is achieved (see Exhibit C-9). Third, the evaluation estimate is divided by the gross ex ante estimate of impact (300,752 MWh total), resulting in the overall gross evaluation realization rate (gross evaluation estimates compared to the gross ex ante estimates) of 0.98. These steps are carried out by segment in *Section 4, Evaluation Results Summaries*, of this report.

Appendix D

FINAL PARTICIPANTS TELEPHONE SURVEY

&S1_____ &S2_____ QC: &QC__ Screen: &S_
 Name: &NAME_____ DCOMP: &D_ LCOMP: &L_ TCOMP: &T_
 Latest Interviewer: &LI Interviewer 1: &I1 Date: &IDATE1_ Time 1: &TIM1
 PG&E C/I L DIVCODE &DVC Interviewer 2: &I2 Date: &IDATE2_ Time 2: &TIM2
 P696180 P CATI: &CN Interviewer 3: &I3 Date: &IDATE3_ Time 3: &TIM3
 ACCNT #: &ACCOUNT Interviewer 4: &I4 Date: &IDATE4_ Time 4: &TIM4
 MEASTYP: &MEASTYP Interviewer 5: &I5 Date: &IDATE5_ Time 5: &TIM5
 Control: &CONTROL Interviewer 6: &I6 Date: &IDATE6_ Time 6: &TIM6
 Business Name &BUSINESS_____ BUS TYP: &BUSTYPE_____
 Name: &NAME2_____ Business Phone: (&HA) &HP - &HL_
 Address: &ADDRESS_____ Corr. Phone: (&CA) &CP - &CL_
 City: &CITY_____ Zip: &ZIP_____ Contact: &CONTACT_____
 Callback Date: &CBD_____ Callback Time: &CBT_____
 Comment: &COMMENT1_____
 &COMMENT2_____
 Res1: &R1 Res2: &R2 Res3: &R3 Res4: &R4 Res5: &R5 Res6: &R6
 1=Complete-CB OS 6=Refusal 11=Wrong # 16=T&T wrng adr 31=Comp ALL
 2=Partial/Refusd 7=Answr Mach 12=Moved 17=Other 32=Multi-Site
 3=Call Back 8=Busy Signal 13=Fax, Modem 18=Part Comp/CB 33=IND OS/CB S
 4=No Answr 9=Not Elig 14=No Dir List ONSITE RESULTS:
 5=On Vacation 10=Disconn # 15=T&T sc020 OS1: &O1 OS2: &O2 OS3: &O3

CONTACT INFO:

&CONIFO1_____
 &CONIFO2_____
 &CONIFO3_____
 &CONIFO4_____
 &CONIFO5_____
 &CONIFO6_____
 &CONIFO7_____
 &CONIFO8_____

CONTACT INFO SCREEN:

ENTER PERSON ATTEMPTING TO CONTACT: &RESP

- 1 = Initial attempt to find contact
- 2 = Decision maker
- 3 = Technical
- 4 = Lighting
- 5 = Property Manager

PARTICIPATION CONTACT &DNAME_____
 (&DAC___) &DPRE___ - &DLAST___ Ext. &DEXT___
 CALLBACK DATE &DCBD___ CALLBACK TIME &DCBT___ Def: &DDEF___
 FIRM: &DBUSNAM_____ (1=def callback 0=general)
 &NOTED1_____
 &NOTED2_____
 &NOTED3_____
 &NOTED4_____
 &NOTED5_____

TECHNICAL CONTACT &TNAME_____
 (&TAC___) &TPRE___ - &TLAST___ Ext. &TEXT___
 CALLBACK DATE &TCBD___ CALLBACK TIME &TCBT___ Def &TDEF___
 FIRM &TBUSNAM_____ (1=Def callback 0=general)
 &NOTET1_____
 &NOTET2_____
 &NOTET3_____
 &NOTET4_____
 &NOTET5_____
 ALWAYS ENTER 1 TO SKIP FORWARD ==> &SKIP

PROPERTY MANAGEMENT CONTACT &PMNAME_____
 (&PMAC___) &PMPRE___ - &PMLAST___ Ext. &PMEXT___
 CALLBACK DATE &PMCBD___ CALLBACK TIME &PMCBT___ Def &PMDEF___
 FIRM: &PMBUSNAM_____ (1=Def callback 0=general)
 &NOTEPM1_____
 &NOTEPM2_____
 &NOTEPM3_____
 &NOTEPM4_____
 &NOTEPM5_____

LIGHTING CONTACT &LNAME_____
 (&LAC___) &LPRE___ - &LLAST___ Ext. &LEXT___
 CALLBACK DATE &LCBD___ CALLBACK TIME &LCBT___ Def &LDEF___
 FIRM: &LBUSNAM_____ (1=Def callback 0=general)
 &NOTEL1_____
 &NOTEL2_____
 &NOTEL3_____
 &NOTEL4_____
 &NOTEL5_____
 ALWAYS ENTER 1 TO SKIP FORWARD ==> &SKIP

Hello. This is &LI__ . I'm with Quantum Consulting, a management consulting firm in Berkeley, California. We're assisting PG&E in evaluating its (Customized Incentives / Retrofit Express) Program. We'd like to ask some general questions about your firm's participation in the program.

MN001. Before we start, I would like to inform you that for quality control purposes, this call may be monitored by my supervisor. Would this be OK with you?
 &MN001 1 = Yes
 0 = No
 8 = (Refused)
 9 = (Don't Know)

DECISION MAKER: IF RESPOND = . OR D THEN ASK: RESPOND = &RESPOND
 This survey will cover equipment installed at &ADDRESS_____ ?

ASK ONCE:

SC016. Is there a property management firm for this building?
&SC016
1 = Yes
0 = No --> SKIP FI003/SC005/SC006
8 = (Refused) --> SKIP FI003/SC005/SC006
9 = (Don't Know) --> SKIP FI003/SC005/SC006

SC017.- Could you please give me the name and telephone
SC024. number of someone at the property management firm who
would be able to answer questions about the building and
electrical equipment at the premise?

PROPERTY CONTACT NAME: &PMNAME_____
PROPERTY CONTACT COMPANY: &PMBUSNAM_____
PROPERTY CONTACT PHONE: (&PMAC) &PMPRE - &PMLAST_ Extension: &PMEXT
PROPERTY CONTACT TITLE: &PMTITLN
1 = President/Owner
2 = Senior Manager
3 = Financial Manager
4 = Energy Manager
5 = Operations Manager
6 = Building Manager
7 = Other SPECIFY: &PMTILOTR_____

Comment1 &PMCOM1_____
Comment2 &PMCOM2_____

ENTER 1 TO SKIP FORWARD ==>> &SKIP

FI003. Are you the sole occupant of the building?
&FI003 1 = Yes 8 = (Refused)
0 = No 9 = (Don't Know)

FI004. Is any part of &ADDRESS_____ leased space?
&FI004 1 = Yes 8 = (Refused)
0 = No 9 = (Don't Know)

SC003. This survey will cover the equipment installed at
&ADDRESS2_____. Are you the best person to talk to
about &BUSINESS_____ 's decision to participate
in the program and answer questions about
economic decision making?

&SC003
1 = Yes-->SKIP TO SC005 8 = (Refused)
0 = No 9 = (Don't Know)

SC004. Who would be the best person to talk to about
&BUSINESS_____ decision to participate in
the program?

PARTICIPATION CONTACT NAME &DNAME_____
PARTICIPATION CONTACT PHONE (&DAC_) &DPRE_____ - &DLAST_____ Ext. &DEXT_
PARTICIPATION ORGANIZATION NAME &DBUSNAM_____
PARTICIPATION CONTACT TITLE &DTITLN
1 = President/Owner
2 = Senior Manager
3 = Financial Manager
4 = Energy Manager
5 = Operations Manger

6 = Building Manger

7 = Other SPECIFY: &DTITLOTR_____

Comment1 &DCOMM1_____

Comment2 &DCOMM2_____

ENTER 1 TO SKIP ==> &SKIP

ASK SC005 IF SC016~=1:

SC005. Are you the best person to answer questions about
the size of the facility, and the type size and age
of your major electrical equipment?

&SC005

1 = Yes --> SKIP SC006

0 = No

8 = (Refused) --> SKIP SC006

9 = (Don't Know) --> SKIP SC006

SC007. Who would be the best person to talk to about
 &BUSINESS_____ 's major electricity end uses?
 LIGHT CONTACT NAME &LNAME_____
 LIGHT CONTACT PHONE (&LAC_) &LPRE__ - &LLAST__ Ext. &LEXT_
 LIGHT ORGANIZATION NAME &LBUSNAM_____
 LIGHT CONTACT TITLE <ITLF_____
 IF NOT LIGHT CONT ENTER 1 AND GET NEW TECH CONTACT, ELSE IF LIGHT ENTER 2
 ==> &WHOTECH
 TECHNICAL CONTACT NAME &TNAME_____
 TECHNICAL CONTACT PHONE (&TAC_) &TPRE__ - &TLAST__ Ext. &TEXT_
 TECHNICAL ORGANIZATION NAME &TBUSNAM_____
 TECHNICAL CONTACT TITLE &TTITLN
 1 = President/Owner 5 = Opertions Manager
 2 = Senior Manager 6 = Building Manager
 3 = Financial Manager 7 = Other SPECIFY:
 4 = Energy Manager &TTITLOTR_____

Comment1: &TCOMM1_____
 Comment2: &TCOMM2_____
 ENTER 1 TO SKIP FORWARD ==> &SKIP

ASK IF SC001~=1:
 SC006. Are you the best person who can answer questions about the
 hours of lighting equipment operation at
 &ADDRESS_____ ?
 &SC006
 1 = Yes --> SKIP SC010
 0 = No --> SKIP SC008
 8 = (Refused) --> SKIP SC010
 9 = (Don't Know) --> SKIP SC010

SC008. Who would be the best person on site to talk to about
&BUSINESS_____ 's hours of lighting operation?

DECIS CONTACT NAME &DNAME_____
DECIS CONTACT PHONE (&DAC_) &DPRE_ - &DLAST___ Ext. &DEXT___
DECIS ORGANIZATION NAME &DBUSNAM_____
DECIS CONTACT TITLE &DTITLF_____

TECH CONTACT NAME &TNAME_____
TECH CONTACT PHONE (&TAC_) &TPRE_ - &TLAST___ Ext. &TEXT___
TECH ORGANIZATION NAME &TBUSNAM_____
TECH CONTACT TITLE &TTITLF_____

IF DECIS CONTACT ENTER 1, IF TECH CONTACT ENTER 2 ELSE ENTER 3 AND GET
NEW INFO ==> &WHOLIT

ENTER NEW LIGHTING CONTACT INFORMATION:

HOURS CONTACT NAME &LNAME_____
HOURS CONTACT PHONE (&LAC_) &LPRE_ - &LLAST___ Ext. &LEXT___
HOURS ORGANIZATION NAME &LBUSNAM_____
HOURS CONTACT TITLE <ITLN_____
1 = President/Ownwer
2 = Senior Manager
3 = FInancial Manager
4 = Energy Manager
5 = Operations Manager
6 = Building Manager
7 = Other SPECIFY: <ITLOTR_____

Comment1: &LCOMM1_____
Comment2: &LCOMM2_____
ENTER 1 TO SKIP ==> &SKIP

I'd like to start by confirming some information in PG&E's program database.

SC010. Our records show that &BUSINESS_____ had high efficiency lighting installed at
&ADDRESS_____ through PG&E's
&PROG_____ Program. Is this correct?
&SC010

1 = Yes-->SKIP TO SC033/SC035 0 = No 2 = SPECIAL CASE 8 = (Ref) 9 = (DK)
(CONFIRM QUANTITIES AND MEASURES. IF RADICALLY DIFFERENT: CONFIRM ADDRESS)

QTY Measure
&SCQ1 &SCM1_____
&SCQ2 &SCM2_____
&SCQ3 &SCM3_____
&SCQ4 &SCM4_____
&SCQ5 &SCM5_____
&SCQ6 &SCM6_____
&SCQ7 &SCM7_____
&SCQ8 &SCM8_____
&SCQ9 &SCM9_____

&MULTAD ENTER 1 IF MULTIPLE ADDRESS; ELSE 0
&MULTIM ENTER 1 IF INSTALLED IN MULTIPLE TIME FRAMES; ELSE 0

SC020. Pacific Gas and Electric's (Customized Incentives/Retrofit Express) Program provides rebates to encourage customers to install energy-efficient lighting. Do you recall

&BUSINESS_____ having lighting
installed as part of PG&E's program?
&SC020
1 = Yes
0 = No--> THANK AND TERMINATE
8 = (Refused)-->THANK AND TERMINATE
9 = (Don't Know)-->THANK AND TERMINATE

SC031. What is the correct address for the facility where
&BUSINES2_____ 's lighting retrofit
occured?
&CORRADDR_____ Correct Address
&CORRCITY_____ Correct City
&CORRZIP_____ Correct Zip
T&T IF ADDRESS IS COMPLETELY DIFFERENT, OTHERWISE CONTINUE
&SC031 1 = SIMILAR ADDRESS -->SKIP TO SC035/SC037
0 = DIFFERENT ADDRESS ----> T&T

DECISION MAKER:

SC035. When was the installation of your retrofitted lighting
equipment completed?
(ENTER MONYYYY)
&SC035__ (MONYYYY) IF NOT BETWEEN JUL1993 AND SEP1994 -> T&T
&SC036 (8 = Refused 9 = Don't Know) --> T&T

ALWAYS ENTER 1 TO SKIP FORWARD =====> &SKIP

TECHNICAL:

SC037. When was the installation of your retrofitted lighting
equipment completed?
(ENTER MONYYYY)
&SC037__ (MONYYYY) IF NOT BETWEEN JUL1993 AND SEP1994 -> T&T
&SC038 (8 = Refused 9 = Don't Know) --> T&T

ALWAYS ENTER 1 TO SKIP FORWARD =====> &SKIP2

LIGHTING:

&SC039A__ (MONYYYY)
&SC039B (8 = Refused 9 = DK)
ALWAYS ENTER 1 TO SKIP FORWARD =====> &SKIP3

ALL:

FI005. Does the PG&E account &ACCOUNT__ located at the service
address &ADDRESS_____ cover
multiple buildings or does it cover only one building?
&FI005
1 = One Building --> SKIP TO FI025
2 = Multiple Buildings
3 = Portion of a building
8 = (Refused)--> SKIP TO FI025
9 = (Don't Know)--> SKIP TO FI025

FI007. Are there multiple PG&E accounts for this address?
&FI007 1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

FI010. How many buildings are covered under this service address?
&FI010 # buildings 888 = (Refused)
IF FI010 = 1 or REF/DK SKIP FI025 999 = (Don't Know)

FI015. Are there separate PG&E bills for the individual buildings?
&FI015

8 = (Refused) --> SKIP TO FI050
9 = (Don't Know) --> SKIP TO FI050

FI045. What is the name of your parent company?
&FI045_____

FI050. What is the legal tax status of your firm, that is what is your tax status for federal tax reporting purposes?
&FI050

1 = Proprietary or investor-owned, (i.e., a for-profit organization)
2 = Public: federal, state or municipal agency
3 = 501(c3): Private, nonprofit
8 = (Refused)
9 = (Don't Know)

ASK IF FI040=1; ELSE SKIP FI060:

FI055. What is the tax status of your parent company?
&FI055

1 = Proprietary or investor-owned, (i.e., a for-profit organization)
2 = Public: federal, state or municipal agency
3 = 501(c3): Private, nonprofit
8 = (Refused)
9 = (Don't Know)

DECISION MAKER:

FI060. Where are decisions regarding energy-related investments for &BUSINESS_____ made?

&FI060
1 = Made locally, on site
2 = Made at regional head office
3 = Made at national head office
4 = Made at international head office
5 = Made by PM firm/building owner
6 = Other FI062.
Specify: &FI062_____

8 = (Refused)
9 = (Don't Know)

FI070. What were the &REVTYPE_____ fiscal 1992 revenues for your firm?

&FI070
&S1_ 1 = Less than \$50,000
&S2_ 2 = \$50,000 to \$99,999
&S3_ 3 = \$100,000 to \$249,999
&S4_ 4 = \$250,000 to \$499,999
&S5_ 5 = \$500,000 to \$999,999
&S6_ 6 = \$1 million to \$2.49 million
&S7_ 7 = \$2.5 million to \$4.99 million
&S8_ 8 = \$5 million to \$9.99 million
&S9_ 9 = \$10 million to \$49.99 million
&S10_ 10 = \$50 million or more
88 = (Refused)
99 = (Don't Know)

RECORD LEVEL OF REVENUE:

FI075. &FI075 1 = Local 3 = National
 2 = Regional 4 = Worldwide

IF LEASE=1 THEN ASK; ELSE SKIP TO EI010: LEASE = &L

FI080. Do the tenants at &ADDRESS_____ pay all, none, or a portion of their electric utilities through their lease?
&FI080

- 1 = ALL utilities INCLUDED in lease --> SKIP TO FI110
- 2 = Pay some utilities through lease and others directly to PG&E
- 3 = Pays ALL utilities directly to PG&E--> SKIP FI110
- 8 = (Refused) --> SKIP FI110
- 9 = (Don't Know) --> SKIP FI110

IF (LEASE=1 AND FI080 = 2): LEASE = &L FI080 = &FI080

FI090. Which of the following utilities are paid for through the -FI100. lease? (ENTER '1' FOR ALL THAT APPLY)

(8 = Refused 9 = Don't Know)

| | |
|------------------------------------|-------------------------|
| &FI090 Indoor Lighting | &FI095 Outdoor Lighting |
| &FI091 Heating | &FI096 Cooling |
| &FI092 Ventilation | &FI097 Water Heating |
| &FI093 Electricity to Wall Outlets | &FI098 Refrigeration |
| &FI094 Cooking | &FI099 Other SPECIFY: |
| | &FI100_____ |

FI110. What is the length of the current lease at

&ADDRESS_____ ?

&FI110 Number of years 888 = (Refused)
 999 = (Don't Know)

FI115. How many years are left on the lease?

&FI115 Number of years 888 = (Refused)
 999 = (Don't Know)

PP020. In what year did you participate in the other program(s)?
(ENTER YEAR)
PP020. &PP020__ YYYY
(8 = Refused 9 = Don't Know)

Now I'd like to get your opinion of key aspects of the Retrofit Lighting Program.

DS020. Was the retrofit project delayed for any reasons, once you had decided to participate?
(DO NOT READ; ENTER 1 FOR ALL THAT APPLY; 0 FOR THOSE THAT DO NOT)
(8 = Refused 9 = Don't Know)

- &DS019 No Delays ---> SKIP SR080
- &DS020 Equipment supply problems
- &DS021 Contractor delays
- &DS022 Financial Limitations/Cash flow
- &DS023 Delays within the organization
- &DS024 Decided to spend money on something else
- &DS025 Other SPECIFY: &DS026_____

SR080. If you had to make your equipment selection again, would you install the same equipment?

- &SR080
- 1 = Yes --> SKIP EA010
- 0 = No
- 8 = (Refused)--> SKIP EA010
- 9 = (Don't Know)--> SKIP EA010

SR090. What would be your main reason for selecting other equipment?

- &SR090
- 1 = Increase the quantity of light
- 2 = Improve the color rendition
- 3 = Reduce glare
- 4 = Eliminate ballast failure
- 5 = Other : SPECIFY : &SR091_____
- 8 = (Refused)
- 9 = (Don't Know)

EA010. Have you altered how energy is used at the facility since you installed the new lighting?

- &EA010
- 1 = Yes
- 0 = No --> SKIP PD010
- 8 = (Refused) --> SKIP PD010
- 9 = (Don't Know) --> SKIP PD010

EA020. What are you doing differently?
(ENTER 1 FOR ALL THAT APPLY ELSE ENTER 0)

- &EA020 Turning on fewer lights
- &EA021 Running HVAC less
- &EA022 Decreased lighting hours
- &EA023 Other SPECIFY: &EA024_____
- &EA025 Other SPECIFY: &EA026_____
- &EA027 Other SPECIFY: &EA028_____
- &EA029 Other SPECIFY: &EA030_____
- (8 = Refused 9 = Don't Know)

PD010. When you were making your decision to purchase new lighting equipment through the program, what was the most important factor in your decision to install the new lighting?

(READ CATEGORIES IF NECESSARY)

&PD010

- 1 = Acquiring the latest technology
- 2 = Saving money on electric bills
- 3 = Obtaining a rebate
- 4 = Replacing old or broken equipment
- 5 = Knowing that the program was sponsored by PG&E
- 6 = Improving the quality of light for employees and customers
- 7 = Helping to protect the environment
- 8 = Previous experience with other PG&E programs
- 9 = Obtaining advice from another branch of your firm
- 10 = Obtaining advice from PG&E account rep
- 11 = Obtaining advice from contractors
- 12 = Other SPECIFY: PD011: &PD011_____
- 88 = (Refused)
- 99 = (Don't Know)

FR100. Why had you not previously installed high efficiency lighting equipment prior to participating in the program?

(DO NOT READ LIST; ENTER 1 FOR ALL THAT APPLY, ELSE ENTER 0)

- FR100. &FR100 Lack of money to invest in it.
- FR101. &FR101 Payback/return on investment not attractive enough.
- FR102. &FR102 Concerned that it might not save as much as claimed
- FR103. &FR103 Didn't know enough about EE lighting before
- FR104. &FR104 Didn't know where/how to obtain EE lighting.
- FR105. &FR105 Hadn't had time.
- FR106. &FR106 Concerned about light quality/brightness
- FR107. &FR107 Tenants didn't want a change
- FR108. &FR108 Decision made elsewhere
- FR109. &FR109 Was planning to install when heard about program
- FR110. &FR110 No Need/Not a Priority
- FR111. &FR111 Just remodeled
- FR112. &FR112 Just moved in/moving out soon
- FR113. &FR113 Did it less than 5 years ago.
- FR114. &FR114 Other1 SPECIFY: FR115 &FR115_____
- FR116. &FR116 (Refused)
- FR117. &FR117 (Don't Know)

SR020. If you had not replaced this equipment under the program, how long would you have waited to replace it?

&SR020 Years

777 = (Would not have replaced)

888 = (Refused)

999 = (Don't Know)

FR010. How long had you been shopping for new lighting equipment before you found out about the program?

0 = (Not Shopping; approached by vendor/contractor)

&FR010 weeks (888 = Refused 999 = Don't Know)

- FR011. How many estimates or quotes did you obtain before purchasing your new equipment?
 &FR011 Estimates
 888 = (Refused)
 999 = (Don't Know)
- FR012. Had you also considered purchasing and installing standard efficiency lighting equipment?
 &FR012
 1 = Yes
 0 = No
 8 = (Refused)
 9 = (Don't Know)
- FR013. How long did it take to decide what to purchase once you found out about the program?
 &FR013 weeks (0 = less than 1 week)
 (888 = Refused 999 = Don't Know)
- NG019. Did you delay a lighting purchase in order to participate in the Retrofit Program?
 &NG019
 1 = Yes
 0 = No
 8 = (Refused)
 9 = (Don't Know)
- FR020. Before you knew about the Lighting Program, which of the following statements best describes your company's plans to install lighting fixtures? (READ RESPONSES.)
 &FR020
 1 = You hadn't even considered purchasing new lighting equipment.
 2 = You were interested in installing lighting equipment, but hadn't yet decided on energy efficient lighting. (I.e. you were considering all your options.)
 3 = You had already decided to install HIGH efficiency lighting, but probably not within the year.
 4 = You had already decided to install HIGH efficiency lighting within the year, and you had already selected equipment.
 8 = (Refused)
 9 = (Don't Know)
- FR014. How many people were involved in the decision to participate?
 &FR014 People
 888 = (Refused) 999 = (Don't Know)
- FR015. Were you the person who made the final decision?
 &FR015
 1 = Yes --> SKIP FR017
 0 = No
 8 = (Refused)--> SKIP FR017
 9 = (Don't Know)--> SKIP FR017

FR016. What is the job title of the person who made the final decision?
&FR016N
1 = President/Owner 2 = Senior Manager
3 = Financial Manager 4 = Energy Manager
5 = Operations Manager 6 = Building Manager
7 = Other SPECIFY: &FR016OTR_____

FR017. How long did it take to reach a decision to participate in the program?
&FR017 weeks
88 = Refused
99 = Don't Know

ASK IF LEASE=1 Lease= &L

FI065. How active a role do tenants take in making equipment purchase decisions for the property at
&ADDRESS_____ ?
&FI065
1 = Very active: they are involved in every aspect of the purchase and you possess veto power
2 = Somewhat active: they approve all decisions
3 = Slight role: they have a voice but it's a single vote among many
4 = None
8 = (Refused)
9 = (Don't Know)

DC010. Which of the following financial criteria do you consider when evaluating lighting investments?
(READ LIST; ENTER 1 FOR ALL THAT APPLY; ELSE ENTER 0)
(8 = (Refused) 9 = (Don't Know))

DC010. &DC010 Payback
DC011. &DC011 Internal Rate of Return
DC012. &DC012 Net Present Value
DC013. &DC013 Other SPECIFY: DC014. &DC014_____

IF DC010=1 THEN ASK DC020

DC020. What is the payback period you require?
&DC020
1 = 1 year or less
2 = 2 years or less
3 = 3 years or less
4 = 4 years or less
5 = 5 years or less
6 = 6 years or less
7 = 7 years or less
8 = 8 years or less
9 = 9 years or less
10 = 10 years or less
11 = Other SPECIFY: DC021. &DC021_____

IF DC011=1 THEN ASK DC030

DC030. What is your organization's required internal rate of return?
&DC030 Percent
888 = (Refused)
999 = (Don't Know)

IF DC012=1 THEN ASK DC040

DC040. What is the discount rate you use when determining the net present value of an investment?
&DC040 Percent
888 = (Refused)
999 = (Don't Know)

ASK ALL:

DC050. Do you use a different &CRITERIA_____ for evaluating energy efficient equipment purchases than you use for general investments?
&DC050
1 = Yes
0 = No --> SKIP TR030
8 = (Refused) --> SKIP TR030
9 = (Don't Know) --> SKIP TR030

ASK DC051 IF DC010=1 OR DC011=1 OR DC012=1, ELSE SKIP TR030

DC051. Is the &CRITERI2_____ you use for energy efficient purchases &TYPE1_____ or &TYPE2_____ than that which you use for other general investments?
&DC051
1 = Higher/Shorter
2 = Lower/Longer
8 = (Refused)
9 = (Don't Know)

PG&E is considering redesigning some aspects of the program. I'd like to get your opinion of some possible program options.

TR030. Would you have installed the same high efficiency &EQUIP_____ equipment if rebates were eliminated, but PG&E offered financing at 1 percentage point below the prime rate?
&TR030
1 = Yes--->SKIP TO TR070
0 = No
8 = (Refused)
9 = (Don't Know)

ASK IF TR030~=1

TR040. What if the interest rate were 1.5 percentage points below the prime rate?
&TR040
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

TR050. What if rebates were reduced by 50% and PG&E offered financing at 1 percentage point below the prime rate?
&TR050
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

TR070. What if rebates were reduced by 50%, but PG&E conducted an on-site audit of the facility, and provided you with

detailed engineering analyses and recommendations?

&TR070

1 = Yes

0 = No

8 = (Refused)

9 = (Don't Know)

FUTURE SERVICES:

PR020. Would you be interested in having PG&E operate or maintain the lighting equipment at the facility?

(i.e. routine replacement of burned out bulbs)

&PR020

1 = Yes

0 = No

2 = Depends on price

8 = (Refused)

9 = (Don't Know)

PR040. Would you be interested in having all of the building's systems checked out to ensure proper operation and efficient use of energy? (i.e. building recommissioning)

&PR040

1 = Yes

0 = No

8 = (Refused)

9 = (Don't Know)

PR060. Would you be interested in having PG&E help you with any future equipment selection?

&PR060

1 = Yes

0 = No

8 = (Refused)

9 = (Don't Know)

PR001. How frequently do you have contact with your PG&E account rep?
-PR002 (CODE NUMBER OF TIMES AND PERIOD IT IS IN)

&PR001 Times

&PR002 Time Period --> IF NOT 0 SKIP PR090

0 = Never

1 = Day

2 = Week

3 = Month

4 = Year

8 = (Refused)

9 = (Don't Know)

PR005. Does someone else in the firm have contact with your PG&E rep?

&PR005

1 = Yes

0 = No --> SKIP PR090

8 = (Refused)--> SKIP PR090

9 = (Don't Know)--> SKIP PR090

PR010-11. How often does this person have contact with your PG&E account rep?

&PR010 Times --> IF 0, 8, 9 SKIP PR090

&PR011 Time Period

0 = Never

1 = Day

- 2 = Week
- 3 = Month
- 4 = Year
- 8 = (Refused)
- 9 = (Don't Know)

PR015. What is the name, title, and phone number of this person?

NAME: &REPNAME _____
 (&REPAC) &REPPRE - &REPLAST Ext &REPEXT Phone
 TITLE: &REPTITN
 1 = President/Owner
 2 = Senior Manager
 3 = Financial Manager
 4 = Energy Manager
 5 = Operations Manger
 6 = Building Manger
 7 = Other SPECIFY: &REPTIOTR _____

ENTER 1 TO SKIP ==> &SKIP

PR090. Are there any additional services you would like to see PG&E provide?

(ENTER 1 FOR ALL THAT APPLY)
 (8 = Refused 9 = Don't Know)
 &PR090 other SPECIFY: &PR091 _____
 &PR092 other SPECIFY: &PR093 _____
 &PR094 other SPECIFY: &PR095 _____

ENTER 1 TO SKIP FORWARD ==> &SKIP

FUTURE PLANS:

FR070. Are you currently planning on making any further lighting retrofits within the next two years?
 &FR070
 1 = Yes
 0 = No --> SKIP DS070
 8 = (Refused)--> SKIP DS070
 9 = (Don't Know)--> SKIP DS070

FR075. Will the new lighting be high or standard efficiency?
 &FR075
 1 = High efficiency
 0 = Standard efficiency
 8 = (Refused)
 9 = (Don't Know)

FR077. Are you planning to make this change through one of PG&E's Retrofit programs?
 &FR077
 1 = Yes
 0 = No
 8 = (Refused)
 9 = (Don't Know)

FR080. What type and how many fixtures are you planning to install?
 (READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES TO BE CHANGED; IF NONE THEN ENTER 0)
 888 = (Refused) 999 = (Don't Know)
 (READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES TO BE ADDED)
 FR080. &FR080 4 Foot T8 fluorescent
 FR081. &FR081 8 Foot T8 fluorescent
 FR082. &FR082 4 Foot Energy saver fluorescent

FR083. &FR083 8 Foot Energy saver fluorescent
 FR084. &FR084 4 Foot T12 fluorescent
 FR085. &FR085 8 Foot T12 fluorescent
 FR086. &FR086 Incandescent
 FR087. &FR087 Compact Fluorescent
 FR088. &FR088 High pressure sodium
 FR089. &FR089 Electronic Ballasts
 FR090. &FR090 Magnetic Ballasts
 FR091. &FR091 Metal Halide

CONTINUED ===> ENTER 1 TO SKIP ===> &SKIP

ENTER TYPE AND NUMBER OF FIXTURES PLANNING TO ADD:
 IF NONE ENTER 0
 888 = (Refused) 999 = (Don't Know)

FR092. &FR092 Mercury Vapor
 FR093. &FR093 Quartz
 FR094. &FR094 Reflectors (w/Delamping)
 FR095. &FR095 LED Exit Lighting
 FR096. &FR096 Watt Saver/Power Choke Devices
 FR097. &FR097 Other SPECIFY: FR098. &FR098 _____
 FR099r. &FR099R (Refused)
 FR099d. &FR099D (Don't Know)

ENTER 1 TO SKIP FORWARD ===> &SKIP

DS070. On a 1 to 7 scale, where 1 means Extremely DISsatisfied
 and 7 means Extremely Satisfied, how satisfied are you,
 overall, with PG&E's Lighting Program?
 &DS070 (ENTER NUMBER BETWEEN 1 AND 7)
 88 = (Refused)
 99 = (Don't Know)

DS080. Are you DISsatisfied with the program for any reason?
 &DS080
 1 = Yes --> ATTEMPT TO CATEGORIZE; ELSE FILL IN OPEN ENDED
 0 = No--->SKIP TO DS090
 8 = (Refused)--->SKIP TO DS090
 9 = (Don't Know)--->SKIP TO DS090

 (DO NOT READ, ENTER 1 FOR ALL THAT APPLY; ELSE ENTER 0)
 8 = (Refused) 9 = (Don't Know)
 DS081 &DS081 problems with contractor
 DS082 &DS082 rebate too small
 DS083 &DS083 problems with equipment
 DS084 &DS084 not seeing any bill savings
 DS085 &DS085 unresolved problems
 DS086 &DS086 problems with getting rebate in a timely manner
 DS087 &DS087 problems with the contracting representative

DS088 &DS088 _____
 DS089 &DS089 _____

IF NO COMMENT OR TO SKIP; ENTER 1 ==> &SKIP

DS090. Do you have any suggestions for improving PG&E's
Retrofit Lighting Program?

&DS090

1 = Yes

0 = No--->SKIP TO BC011/BH010/SCREEN 137

8 = (Refused)--->SKIP TO BC011/BH010/SCREEN 137

9 = (Don't Know)--->SKIP TO BC011/BH010/SCREEN 137

(ENTER 1 FOR ALL THAT APPLY, 0 FOR THOSE THAT DO NOT; ELSE OPEN ENDED)

DS091 &DS091 Better/More Information

DS092 &DS092 Post-Installation Inspection

DS093 &DS093 Improve Quality of light

DS094 &DS094 Larger Rebates

DS095 &DS095 Smaller Rebates

DS096 &DS096 Change Qualifying Measures

DS097 &DS097 Closer Supervision of Contractors

DS100 &DS100 _____

DS101 &DS101 _____

DS102 &DS102 _____

IF NO COMMENT, OR TO SKIP FORWARD, ENTER 1 =====> &SKIP

The following questions refer to your "FACILITY," which means ALL the buildings and tenants SERVICED BY PG&E UNDER THE FOLLOWING

Billing Name: &BUSINESS_____ ADDRESS: &ADDRESS_____

ACCOUNT # : &ACCOUNT_____

BC011. What is the main business ACTIVITY at the facility?

&BC011

- 1 = Office
- 2 = Retail (non-food)
- 3 = Manufacturing/Assembly
- 4 = Warehouse
- 5 = Restaurant
- 6 = Grocery Store
- 7 = School
- 8 = Hotel or Motel
- 9 = Hospital
- 10 = College/University
- 11 = Health Care
- 12 = Municipality
- 13 = Industrial Process
- 14 = Other SPECIFY: BC012 &BC012_____
- 88 = (Refused)
- 99 = (Don't Know)

FC060. In what year was the facility built?

&FC060

- 1 = 1992-Pres
- 2 = 1988-1991
- 3 = 1986-1987
- 4 = 1983-1985
- 5 = 1979-1982
- 6 = 1975-1978
- 7 = 1970-1974
- 8 = 1960-1969
- 9 = 1950-1959
- 10 = 1940-1949
- 11 = 1930-1939
- 12 = 1929 or earlier
- 88 = (Refused)
- 99 = (Don't Know)

FC070. How many stories does the building have?

&FC070 Stories

- 88 = (Refused)
- 99 = (Don't Know)

FC080. What is the square footage per floor of the building

at &ADDRESS_____ .

(exclude enclosed garage spaces, basements, stairwells, elevator shafts, etc)

&FC080 SQ FT

- 8 = (Refused)
- 9 = (Don't Know)

FC081. On each floor, what percentage of the space is conditioned?

&FC081 percent

- 888 = (Refused)
- 999 = (Don't Know)

FC095. Is the retrofitted area located in a conditioned space?

&FC095

- 1 = Yes
- 0 = No
- 2 = Split conditioned/non-conditioned
- 8 = (Refused)
- 9 = (Don't Know)

ASK FC100 IF FC095=2: ELSE SKIP FC110:

FC100. What percentage of the retrofitted area is in a conditioned space?

&FC100 percent 888 = (refused) 999 = (Don't Know)

FC110. Since January 1992, has the square footage covered by account # &ACCOUNT_____ increased, decreased, or stayed the same?

&FC110

1 = Increased floor space

2 = Decreased floor space

3 = Stayed the same-->SKIP TO FR034

8 = (Refused)-->SKIP TO FR034

9 = (Don't Know)-->SKIP TO FR034

FC120. What is the approximate area, in square feet, of this change?

&FC120 Square Feet

8 = (Refused)

9 = (Don't Know)

FC130. In what month and year did this change in floor space occur?

(ENTER MONTH/YEAR)

FC130. &FC130__ MONYYYY

FC131. &FC131 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

ASK IF FC110=1; ELSE SKIP TO FR033

FC140. In what month and year was this additional floor space occupied?

(ENTER MONTH/YEAR)

FC140. &FC140__ MONYYYY

FC141. &FC141 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

ASK WHERE FC110 IS NOT 1:

FR033. When was your last major space remodel?

(ENTER MONTH/YEAR IF DON'T KNOW MONTH, ASK FOR BEST GUESS AND/OR YEAR)

FR033. &FR033__ MONYYYY

FR034. &FR034 YYYY

(7 = Never Remodeled 8 = Refused 9 = Don't Know)

(IF 7, 8, or 9 THEN --> SKIP LF030/IL001)

FR035. Did this remodel include space covered by the retrofit?

&FR035

1 = Yes --> SKIP LF030/IL001

0 = No --> SKIP LF030/IL001

8 = (Refused) --> SKIP LF030/IL001

9 = (Don't Know) --> SKIP LF030/IL001

LF030. How many weekdays per year are you closed for holidays?

&LF030 Days 888 = (Refused)

999 = (Don't Know)

LF040. How many Saturdays per year are you closed for holidays?

&LF040 Days 777 = Never open on Saturdays
 888 = (Refused)
 999 = (Don't Know)

LF050. How many Sundays per year are you closed for holidays?

&LF050 Days 777 = Never open on Sundays
 888 = (Refused)
 999 = (Don't Know)

Now, I'd like to ask about operating hours at &ADDRESS_____

BH010. Are the hours that you operate your lighting equipment different from the hours that you operate your facility?

&BH010
 1 = Yes
 0 = No--->SKIP TO LF001
 8 = (Refused)--->SKIP TO LF001
 9 = (Don't Know)--->SKIP TO LF001

BH015. Do you know the hours that you operate your lighting equipment at your facility?

&BH015
 1 = Yes
 0 = No
 8 = (Refused)
 9 = (Don't Know)

LF001- Could you please tell me the facility's &HOUR_____

LF013. hours during the following times, and what percentage of the facility's lights are on at these times?

66 = On 24 Hours 888 = (Refused)
 77 = Never On 999 = (Don't Know)

| | Month | Day | Code | Same As | From | AM/PM | To | AM/PM | % ON |
|--------|----------|------|-------|---------|--------|--------|--------|--------|-------|
| LF001. | DECEMBER | WEEK | &LF1_ | &E1_ | &LF1F_ | &LF1M_ | &LF1T_ | &LF1N_ | &LW1_ |
| LF002. | DECEMBER | SAT | &LF2_ | &E2_ | &LF2F_ | &LF2M_ | &LF2T_ | &LF2N_ | &LW2_ |
| LF003. | DECEMBER | SUN | &LF3_ | &E3_ | &LF3F_ | &LF3M_ | &LF3T_ | &LF3N_ | &LW3_ |
| LF004. | APRIL | WEEK | &LF4_ | &E4_ | &LF4F_ | &LF4M_ | &LF4T_ | &LF4N_ | &LW4_ |
| LF005. | APRIL | SAT | &LF5_ | &E5_ | &LF5F_ | &LF5M_ | &LF5T_ | &LF5N_ | &LW5_ |
| LF006. | APRIL | SUN | &LF6_ | &E6_ | &LF6F_ | &LF6M_ | &LF6T_ | &LF6N_ | &LW6_ |
| LF007. | AUGUST | WEEK | &LF7_ | &E7_ | &LF7F_ | &LF7M_ | &LF7T_ | &LF7N_ | &LW7_ |
| LF008. | AUGUST | SAT | &LF8_ | &E8_ | &LF8F_ | &LF8M_ | &LF8T_ | &LF8N_ | &LW8_ |
| LF009. | AUGUST | SUN | &LF9_ | &E9_ | &LF9F_ | &LF9M_ | &LF9T_ | &LF9N_ | &LW9_ |
| LF010. | OCTOBER | WEEK | &LF10 | &E10 | &LF10F | &LF10M | &LF10T | &LF10N | &LW10 |
| LF011. | OCTOBER | SAT | &LF11 | &E11 | &LF11F | &LF11M | &LF11T | &LF11N | &LW11 |
| LF012. | OCTOBER | SUN | &LF12 | &E12 | &LF12F | &LF12M | &LF12T | &LF12N | &LW12 |
| LF013. | HOLIDAY | ALL | &LF13 | &E13 | &LF13F | &LF13M | &LF13T | &LF13N | &LW13 |

The next questions refer to the facility's conditioned floor space. That is, the areas of the facility that are heated or cooled.

LF014. Excluding exit signs, what percent of the retrofitted lights are night lights or safety lights that remain on twenty-four hours per day?
&LF014 Percent 888 = (Refused)
999 = (Don't Know)

LF025. Again excluding exit lights, but considering night lights, safety lights, lighting used by custodial staff, and general lighting, what percentage of the facility's indoor lights are on during NON-operating hours?
&LF025 Percent 888 = (Refused)
999 = (Don't Know)

LF017. What percent of the retrofitted lights are on during the following SUMMER WEEKDAY hours?
888 = (Refused) 999 = (Don't Know)

| | | | | | |
|-------|---------|---------|-------|---------|---------|
| 12 AM | &LF017X | Percent | | | |
| 1 AM | &LF017A | Percent | 12 PM | &LF017L | Percent |
| 2 AM | &LF017B | Percent | 1 PM | &LF017M | Percent |
| 3 AM | &LF017C | Percent | 2 PM | &LF017N | Percent |
| 4 AM | &LF017D | Percent | 3 PM | &LF017O | Percent |
| 5 AM | &LF017E | Percent | 4 PM | &LF017P | Percent |
| 6 AM | &LF017F | Percent | 5 PM | &LF017Q | Percent |
| 7 AM | &LF017G | Percent | 6 PM | &LF017R | Percent |
| 8 AM | &LF017H | Percent | 7 PM | &LF017S | Percent |
| 9 AM | &LF017I | Percent | 8 PM | &LF017T | Percent |
| 10 AM | &LF017J | Percent | 9 PM | &LF017U | Percent |
| 11 AM | &LF017K | Percent | 10 PM | &LF017V | Percent |
| | | | 11 PM | &LF017W | Percent |

ENTER 1 TO MOVE FORWARD ==> &SKIP

LF018. Do you follow the same schedule in the WINTER?
&LF18
1 = Yes --> SKIP IL001/SCREEN 137
0 = No
8 = (Refused)--> SKIP IL001/SCREEN 137
9 = (Don't Know)--> SKIP IL001/SCREEN 137

LF020. What percent of the retrofitted lights are on during the following WINTER WEEKDAY hours?

888 = (Refused) 999 = (Don't Know)

| | | | | | |
|-------|---------|---------|-------|---------|---------|
| 12 AM | &LF020X | Percent | | | |
| 1 AM | &LF020A | Percent | 12 PM | &LF020L | Percent |
| 2 AM | &LF020B | Percent | 1 PM | &LF020M | Percent |
| 3 AM | &LF020C | Percent | 2 PM | &LF020N | Percent |
| 4 AM | &LF020D | Percent | 3 PM | &LF020O | Percent |
| 5 AM | &LF020E | Percent | 4 PM | &LF020P | Percent |
| 6 AM | &LF020F | Percent | 5 PM | &LF020Q | Percent |
| 7 AM | &LF020G | Percent | 6 PM | &LF020R | Percent |
| 8 AM | &LF020H | Percent | 7 PM | &LF020S | Percent |
| 9 AM | &LF020I | Percent | 8 PM | &LF020T | Percent |
| 10 AM | &LF020J | Percent | 9 PM | &LF020U | Percent |
| 11 AM | &LF020K | Percent | 10 PM | &LF020V | Percent |
| | | | 11 PM | &LF020W | Percent |

ENTER 1 TO MOVE FORWARD TO IL001/SCREEN 137 ==> &SKIP

Now, I'd like to ask about the type of lighting equipment at your facility before and after participating in the program.

IL001. What percentage of your facility lighting equipment was replaced through the program?

&IL001 888 = (Refused)
999 = (Don't Know)

IL005. Of the bulbs that were replaced through the program, what percent were burned out or not working before the retrofit?

&IL005 Percent
888 = (Refused)
999 = (Don't Know)

SR010. What was the average age of the lighting fixtures you replaced?

&SR010 Years
888 = (Refused)
999 = (Don't Know)

IL010. Since January 1992, have you made any changes in indoor lighting at your facility other than changes through the program or routine replacement of burned out bulbs?

&IL010
1 = Yes
0 = No--->SKIP TO LP010/DS030
8 = (Refused)--->SKIP TO LP010/DS030
9 = (Don't Know)--->SKIP TO LP010/DS030

IL020. In what months and years did you make these changes?
 (ENTER MONTH/YEAR)
 IL020. &IL020__ MONYYYY
 IL021. &IL021 YYYY (8 = Refused 9 = Don't Know)
 (SECOND MONTH AND YEAR IF APPLICABLE)
 (ENTER MONTH/YEAR)
 IL025. &IL025__ MONYYYY
 IL026. &IL026 YYYY (8 = Refused 9 = Don't Know)
 IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR
 ENTER 1 TO SKIP FORWARD ==> &SKIP

IL040. What type and how many fixtures were affected?
 (READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES ADDED OR REMOVED,
 IF NONE THEN 0)
 888 = (Refused) 999 = (Don't Know)
 (0 = NO CHNG)
 (1 = ADDED) NUMBER
 (2 = REMOVED)
 IL040. &IL040 &IL040N 4 Foot T8 fluorescent
 IL041. &IL041 &IL041N 8 Foot T8 fluorescent
 IL042. &IL042 &IL042N 4 Foot Energy saver fluorescent
 IL043. &IL043 &IL043N 8 Foot Energy saver fluorescent
 IL044. &IL044 &IL044N 4 Foot T12 fluorescent
 IL045. &IL045 &IL045N 8 Foot T12 fluorescent
 IL046. &IL046 &IL046N Incandescent
 IL047. &IL047 &IL047N Compact Fluorescent
 IL048. &IL048 &IL048N High pressure sodium
 IL049. &IL049 &IL049N Metal Halide

CONTINUED, ENTER 1 TO MOVE FORWARD ==> &SKIP

ENTER TYPE AND NUMBER OF FIXTURES AFFECTED, IF NONE THEN 0
 888 = (Refused) 999 = (Don't Know)
 0 = No Chng
 1 = Added NUMBER
 2 = Removed
 IL050. &IL050 &IL050N Mercury Vapor
 IL051. &IL051 &IL051N Quartz
 IL052. &IL052 &IL052N Reflectors (w/Delamping)
 IL053. &IL053 &IL053N Electronic Ballasts
 IL054. &IL054 &IL054N Magnetic Ballasts
 IL055. &IL055 &IL055N LED Exit Lighting
 IL056. &IL056 &IL056N Watt Saver/Power Choke Devices
 IL057. &IL057 &IL057N Other SPECIFY: IL058 &IL058_____

ENTER 1 TO SKIP FORWARD ==> &SKIP
 GOTO DS030/LP010

ASK WHERE BALLASTS=1: &BALLAST ELSE ASK LP010

DS030. After completing the lighting retrofit, did you experience any problems with the new ballasts?

&DS030

1 = Yes

0 = No --> SKIP LP010

8 = (Refused) --> SKIP LP010

9 = (Don't Know) --> SKIP LP010

DS045. How were your equipment problems finally resolved?

&DS045

1 = Equipment was replaced by the contractor

2 = Equipment was replaced by the customer

3 = Problem still exists.

4 = Other SPECIFY: DS046: &DS046_____

8 = (Refused)

9 = (Don't Know)

LP010. Has any of the lighting equipment that was installed as part of the lighting program been removed?

&LP010

1 = Yes

0 = No--->SKIP TO SR050

8 = (Refused)--->SKIP TO SR050

9 = (Don't Know)--->SKIP TO SR050

LP020. In what months and years did you make these changes?

(ENTER MONTH/YEAR)

LP020. &LP020__ MONYYYY

LP021. &LP021 YYYY (8 = Refused 9 = Don't Know)

(SECOND MONTH AND YEAR)

(ENTER MONTH/YEAR)

LP025. &LP025__ MONYYYY

LP026. &LP026 YYYY (8 = Refused 9 = Don't Know)

ENTER 1 TO SKIP FORWARD ==> &SKIP

LP030. What type and how many fixtures were removed?

(READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES REMOVED, IF NONE THEN 0)

888 = (Refused) 999 = (Don't Know)

NUMBER

LP030. &LP030 4 Foot T8 fluorescent

LP031. &LP031 8 Foot T8 fluorescent

LP032. &LP032 4 Foot Energy saver fluorescent

LP033. &LP033 8 Foot Energy saver fluorescent

LP034. &LP034 4 Foot T12 fluorescent

LP035. &LP035 8 Foot T12 fluorescent

LP036. &LP036 Incandescent

LP037. &LP037 Compact Fluorescent

LP038. &LP038 High pressure sodium

LP039. &LP039 Metal Halide

CONTINUED, ENTER 1 TO SKIP FORWARD ==> &SKIP

ENTER NUMBER OF FIXTURES REMOVED, IF NONE THEN 0
888 = (Refused) 999 = (Don't Know)

NUMBER

| | | |
|--------|--------|----------------------------------|
| LP040. | &LP040 | Mercury Vapor |
| LP041. | &LP041 | Quartz |
| LP042. | &LP042 | Reflectors (w/Delamping) |
| LP043. | &LP043 | Electronic Ballasts |
| LP044. | &LP044 | Magnetic Ballasts |
| LP045. | &LP045 | LED Exit Lighting |
| LP046. | &LP046 | Watt Saver/Power Choke Devices |
| LP047. | &LP047 | Other SPECIFY: LP048 &LP048_____ |

ENTER 1 TO SKIP FORWARD ==> &SKIP

LP050. Why did you remove the equipment?
(DO NOT READ LIST; ENTER 1 FOR ALL THAT APPLY, ELSE ENTER 0)

| | | |
|--------|--------|----------------------------------|
| LP050. | &LP050 | Did not like light quality. |
| LP051. | &LP051 | Not enough light. |
| LP052. | &LP052 | Equipment not reliable. |
| LP053. | &LP053 | Harmonics problems. |
| LP054. | &LP054 | Ballasts Failed |
| LP055. | &LP055 | Other SPECIFY: LP056 &LP056_____ |
| LP057. | &LP057 | (Refused) |
| LP058. | &LP058 | (Don't Know) |

LP060. Did you replace the lighting equipment that you removed?
&LP060
1 = Yes
0 = No--->SKIP TO SR050
8 = (Refused)--->SKIP TO SR050
9 = (Don't Know)--->SKIP TO SR050

LP070. What type and how many fixtures replaced the equipment that
was removed? 888 = (Refused) 999 = (Don't Know)
(READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES ADDED)

| | | |
|--------|--------|---------------------------------|
| LP070. | &LP070 | 4 Foot T8 fluorescent |
| LP071. | &LP071 | 8 Foot T8 fluorescent |
| LP072. | &LP072 | 4 Foot Energy saver fluorescent |
| LP073. | &LP073 | 8 Foot Energy saver fluorescent |
| LP074. | &LP074 | 4 Foot T12 fluorescent |
| LP075. | &LP075 | 8 Foot T12 fluorescent |
| LP076. | &LP076 | Incandescent |
| LP077. | &LP077 | Compact Fluorescent |
| LP078. | &LP078 | High pressure sodium |
| LP079. | &LP079 | Electronic Ballasts |
| LP080. | &LP080 | Magnetic Ballasts |
| LP081. | &LP081 | Metal Halide |

CONTINUED, ENTER 1 TO SKIP FORWARD ==> &SKIP

ENTER TYPE AND NUMBER OF FIXTURE WHICH REPLACED THOSE REMOVED
0 = NONE OF THAT TYPE
888 = (Refused) 999 = (Don't Know)

LP082. &LP082 Mercury Vapor
LP083. &LP083 Quartz
LP084. &LP084 Reflectors (W/ Delamping)
LP085 &LP085 LED Exit Lighting
LP086 &LP086 Watt Saver/Power Choke Devices
LP087. &LP087 Other SPECIFY: LP088. &LP088_____

ENTER 1 TO SKIP FORWARD ==> &SKIP

SR050. Compared to the old lighting equipment, would you say the amount of light has increased, decreased, or remained the same?

&SR050

1 = Increased --->SKIP TO SR070

2 = Decreased

3 = Same --->SKIP TO SR070

8 = (Refused)--->SKIP TO SR070

9 = (Don't Know)--->SKIP TO SR070

IF SR050 = 2 ASK:

SR060. Are you turning on more lights to compensate?

&SR060

1 = Yes

0 = No

8 = (Refused)

9 = (Don't Know)

SR070. Compared to the old lighting equipment, would you say the color rendition is better, worse, or the same?

&SR070

1 = Better

2 = Worse

3 = Same

8 = (Refused)

9 = (Don't Know)

SR075. Compared to the old lighting equipment, would you say the new lighting gives off less, more or the same amount of glare?

&SR075

1 = Less

2 = More

3 = Same

8 = (Refused)

9 = (Don't Know)

OL010. Is OUTDOOR lighting included on the facility's utility bill?

&OL010

1 = Yes

0 = No--->SKIP TO CE010

8 = (Refused)--->SKIP TO CE010

9 = (Don't Know)--->SKIP TO CE010

OL020. Since January 1992, have you made any changes in OUTDOOR lighting at your facility?

&OL020

1 = Yes

0 = No--->SKIP TO CE010

8 = (Refused)--->SKIP TO CE010

9 = (Don't Know)--->SKIP TO CE010

OL030. In what month and year did you make these changes?
(ENTER MONTH/YEAR)

OL030 &OL030__ MONYYYY
&OL031 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OL040. Did you ADD TO, REPLACE, or REMOVE outdoor lighting?
&OL040

1 = Added lighting
2 = Replaced lighting
3 = Added AND Replaced lighting
4 = Removed
8 = (Refused)
9 = (Don't Know)

COOLING EQUIPMENT:

The next series of questions pertain to the cooling equipment at the facility.

CE010. What type of system is used to air condition this facility?
[If there is more than one system, enter the one used to cool the largest portion of this facility.]

&CE010
0 = No A/C--->SKIP TO CE080
1 = Central plant
2 = Small Packaged Systems (i.e. Rooftop or Ground)
3 = Wall or window units
4 = Heat pump
5 = Other SPECIFY: CE011 &CE011_____

8 = (Refused)

9 = (Don't Know)

CE015. What is the primary fuel used to cool your facility?

&CE015
1 = Electricity
2 = Natural Gas
3 = Other SPECIFY: CE016. &CE016_____

8 = (Refused)

9 = (Don't Know)

CE030. Does this system include an economizer?

&CE030
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

CE050. What percent of the facility is air conditioned at 4PM on Summer weekdays?

(ASK OPEN ENDED, THEN PROBE WITH CATEGORIES)

&CE050 Percent
100=100% 222=60-79% 444=20-39% 0=0% 888 = (Refused)
111=80-99% 333=40-59% 555=1-19% 999 = (Don't Know)

CE060. During what months is the cooling system operated?
(READ LIST IF NECESSARY; ENTER NUMBER 1 FOR ALL THAT APPLY)

CE059. &CE059 All Year --> SKIP CE080
 CE060. &CE060 January
 CE061. &CE061 February
 CE062. &CE062 March
 CE063. &CE063 April
 CE064. &CE064 May
 CE065. &CE065 June
 CE066. &CE066 July
 CE067. &CE067 August
 CE068. &CE068 September
 CE069. &CE069 October
 CE070. &CE070 November
 CE071. &CE071 December
 CE072. &CE072 (Refused)
 CE073. &CE073 (Don't Know)

TO SKIP FORWARD ENTER 1: ==> &SKIP

CE080. Since January 1992, have you ADDED TO, REMOVED, or REPLACED an older cooling system?

&CE080

0 = No Change-->SKIP TO HE015

1 = Added

2 = Replaced

3 = Added and Replaced

4 = Removed

8 = (Refused)-->SKIP TO HE015

9 = (Don't Know)-->SKIP TO HE015

CE090. In what month and year did you make these changes?
(ENTER MONTH/YEAR)

CE090. &CE090__ MONYYYY

CE091. &CE091 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

IF CE080=1 THEN SKIP TO CE120; ELSE ASK:

CE110. What fuel was used to power the old system?

&CE110

1 = Electricity

2 = Natural Gas

3 = Other SPECIFY: CE111. &CE111_____

8 = (Refused)

9 = (Don't Know)

IF CE080=2 or 4 THEN SKIP TO HE015

CE120. What fuel does the cooling system addition use?

&CE120

1 = Electricity

2 = Natural Gas

3 = Other SPECIFY: CE121. &CE121_____

8 = (Refused)

9 = (Don't Know)

HEATING EQUIPMENT

HE015. What is the main type of heating system used to heat your facility?

&HE015 1 = Central electric furnace 19 = None
 2 = Central heat pump 88 = (Refused)

- 3 = Central gas furnace
- 4 = Gas boiler
- 5 = Electric boiler
- 6 = Fuel oil furnace or boiler
- 7 = Electric strip heat
- 8 = Baseboard electric heating
- 9 = Room or wall AC with electric strip heat
- 10 = Permanent, non-electric room heaters
- 11 = Whole-house wall or floor electric furnace
- 12 = Whole-house wall or floor gas furnace
- 13 = Portable electric heater
- 14 = Portable kerosene heater
- 15 = Wood or coal burning stove or fireplace
- 16 = Solar collector
- 17 = Propane heating system
- 18 = Other HE016. &HE016_____

99 = (Don't Know)

HE020. What is the primary fuel used to heat your facility?
&HE020

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: HE021 &HE021_____
- 8 = (Refused)
- 9 = (Don't Know)

HE050. What percent of your facility is heated at 8AM
on WINTER weekdays?

(ASK OPEN ENDED, THEN PROBE WITH CATEGORIES)

| &HE050 | | Percent | | | |
|------------|------------|------------|------|--------------------|--|
| 100=100% | 222=60-79% | 444=20-39% | 0=0% | 888 = (Refused) | |
| 111=80-99% | 333=40-59% | 555=1-19% | | 999 = (Don't Know) | |

HE060. During what months is the heating system operated?
 (READ LIST IF NECESSARY; ENTER NUMBER 1 FOR ALL THAT APPLY)
 HE059. &HE059 All Year ---> SKIP HE080
 HE060. &HE060 January
 HE061. &HE061 February
 HE062. &HE062 March
 HE063. &HE063 April
 HE064. &HE064 May
 HE065. &HE065 June
 HE066. &HE066 July
 HE067. &HE067 August
 HE068. &HE068 September
 HE069. &HE069 October
 HE070. &HE070 November
 HE071. &HE071 December
 HE072. &HE072 (Refused)
 HE073. &HE073 (Don't Know)
 TO SKIP FORWARD ENTER 1: ==> &SKIP

HE080. Since January 1992, have you ADDED TO, REPLACED, OR REMOVED
 an older heating system?
 &HE080
 0 = No Change-->SKIP TO OE010
 1 = Added
 2 = Replaced
 3 = Added and Replaced
 4 = Removed
 8 = (Refused)-->SKIP TO OE010
 9 = (Don't Know)-->SKIP TO OE010

HE090. In what month and year did you make these changes?
 (ENTER MONTH/YEAR)
 HE090. &HE090__ MONYYYY
 HE091. &HE091 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

IF HE080=1 THEN SKIP TO HE120, ELSE ASK:

HE110. What fuel was used to power the old system?
 &HE110
 1 = Natural Gas
 2 = Propane or Bottled Gas
 3 = Oil
 4 = Steam
 5 = Electricity
 6 = Other SPECIFY: HE111. &HE111_____

IF HE080=2 OR 4 THEN SKIP TO OE010

HE120. What fuel does the heating system addition use?
&HE120
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: HE121. &HE121_____

OTHER EQUIPMENT:

OE010. Since January 1992, have you changed other equipment that makes up 10% or more of the facility's annual electric bill?
&OE010
1 = Yes
0 = No-->SKIP TO OC010
8 = (Refused)-->SKIP TO OC010
9 = (Don't Know)-->SKIP TO OC010

OE011. Which of the following types of equipment were changed?
(READ FIRST THREE THEN ASK FOR OTHER)

(READ LIST; ENTER 1 FOR ALL THAT APPLY)

OE012. &OE012 Water heating

OE013. &OE013 Cooking

OE014. &OE014 Refrigeration

Were there any other end uses changed? (RECORD BELOW)

OE015. &OE015 Other1 SPECIFY: OE016. &OE016_____

OE017. &OE017 Other2 SPECIFY: OE018. &OE018_____

OE019. &OE019 (Refused) ---> SKIP to OC010

OE011. &OE011 (Don't Know) ---> SKIP TO OC010

ASK OE020-OE050 IF OE012=1

OE020. In what month and year did you change your water heating equipment?
(ENTER MONTH/YEAR)

OE020. &OE020__ MONYYYY

OE021. &OE021 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE030. Did you ADD TO, REMOVE, or REPLACE water heating equipment?

&OE030

1 = Added--->SKIP TO OE050

2 = Replaced

3 = Added and Replaced

4 = Removed

8 = (Refused)--->SKIP TO OE060/OE100/OE140/OE180/OC010

9 = (Don't Know)--->SKIP TO OE060/OE100/OE140/OE180/OC010

OE040. What fuel was used to power the old water heating equipment?
&OE040
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE041. &OE041_____

IF OE030= 4 THEN SKIP TO OE060/OE100/OE140/OE180/OC010

OE050. What fuel does the water heating equipment addition use?
&OE050
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE051. &OE051_____

ASK OE060-OE090 IF OE013=1

OE060. In what month and year did you change your cooking equipment?
(ENTER MONYYYY)

OE060. &OE060__ MONYYYY

OE061. &OE061 YYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE070. Did you ADD TO, REMOVE, or REPLACE cooking equipment?
&OE070
1 = Added--->SKIP TO OE090
2 = Replaced
3 = Added and Replaced
4 = Removed
8 = (Refused)--->SKIP TO OE100/OE140/OE180/OC010
9 = (Don't Know)--->SKIP TO OE100/OE140/OE180/OC010

OE080. What fuel was used to power the old cooking equipment?
&OE080
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE081. &OE081_____

IF OE070= 4 THEN SKIP TO OE100/OE140/OE180/OC010

OE090. What fuel does the cooking equipment addition use?

&OE090
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE091. &OE091_____

ASK OE100-OE130 IF OE014=1
OE100. In what month and year did you change your
refrigeration equipment?
(ENTER MONTH/YEAR)

OE100. &OE100__ MONYYYY
OE101. &OE101 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE110. Did you ADD TO, REMOVE, or REPLACE refrigeration equipment?
&OE110
1 = Added--->SKIP TO OE130
2 = Replaced
3 = Added and Replaced
4 = Removed
8 = (Refused)--->SKIP TO OE140/OE180/OC010
9 = (Don't Know)--->SKIP TO OE140/OE180/OC010

OE120. What fuel was used to power the old refrigeration equipment?
&OE120
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE121. &OE121_____

IF OE110=2 OR 4 THEN SKIP TO OE140/OE180/OC010

OE130. What fuel does the refrigeration equipment addition use?
&OE130
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE131. &OE131_____

ASK OE140-OE170 IF OE015=1
OE140. In what month and year did you change your &EQUIP_____

OE140. &OE140__ MONYYYY
OE141. &OE141 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE150. Did you ADD TO, REMOVE, or REPLACE &EQUIP2_____ equipment?

&OE150

- 1 = Added--->SKIP TO OE170
- 2 = Replaced
- 3 = Added and Replaced
- 4 = Removed
- 8 = (Refused)--->SKIP TO OE180/OC010
- 9 = (Don't Know)--->SKIP TO OE180/OC010

OE160. What fuel was used to power the old &EQUIP_____ equipment?

&OE160

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE161. &OE161_____
- 8 = (Refused)
- 9 = (Don't Know)

IF OE150=2 OR 4 THEN SKIP TO OE180/OC010

OE170. What fuel does the &EQUIP_____ equipment addition use?

&OE170

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE171. &OE171_____
- 8 = (Refused)
- 9 = (Don't Know)

ASK OE180-OE210 IF OE017=1

OE180. In what month and year did you change your &EQUIP_____ equipment?

(ENTER MONTH/YEAR)

OE180. &OE180__ MONYYYY

OE181. &OE181 YYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE190. Did you ADD TO, REMOVE, or REPLACE &EQUIP2_____ equipment?
&OE190
1 = Added--->SKIP TO OE202
2 = Replaced
3 = Added and Replaced
4 = Removed
8 = (Refused)--->SKIP TO OC010
9 = (Don't Know)--->SKIP TO OC010

OE200. What fuel was used to power the old &EQUIP_____ equipment?
&OE200
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE201. &OE201_____

8 = (Refused)
9 = (Don't Know)

IF OE190=2 OR 4 THEN SKIP TO OC010

OE202. What fuel does the &EQUIP_____ equipment addition use?
&OE202
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE203. &OE203_____

8 = (Refused)
9 = (Don't Know)

OC010. Since January 1992, have you made any other changes that would affect energy usage at this facility?
&OC010
1 = Yes
0 = No--->SKIP TO EM010
8 = (Refused)--->SKIP TO EM010
9 = (Don't Know)---> SKIP TO EM010

OC020. What type of changes were made?
&OC020_____
&OC021_____

OC030. In what month and year were these changes made?
(ENTER MONTH/YEAR)

OC030. &OC030__ MONYYYY

OC031. &OC031 YYYYY (8 = Refused 9 = Don't Know)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

&NOTE1 _____
&NOTE2 _____
&NOTE3 _____
&NOTE4 _____
&NOTE5 _____
&NOTE6 _____

IF THE RESPONDENT ASK FOR PG&E REP'S PHONE # ENTER 1, AND THEN REASON &REP
&NOTREP1 _____
&NOTREP2 _____

Those are all the questions I have for today. On behalf of Pacific Gas and Electric, thank you very much for your time and cooperation.

F4 TO FIRST SCREEN AND CODE RESULT

At present we are surveying PG&E customers who HAVE participated in the Efficient Indoor Lighting Program. Since you have not participated in this PG&E program, we have no further questions for you at this time. On behalf of PG&E, I'd like to thank you very much for your cooperation today.

At present we are surveying PG&E customers who had their equipment installed between Jan 1994 and Sep 1994, and who's equipment was installed in an area cover by only one account. On behalf of PG&E, I'd like to thank you for your time.

(F4 TO FIRST SCREEN AND CODE RESULT)

BEGIN ON SITE RECRUITMENT. ASK OF PARTICIPATION CONTACT:

A subsample of customers who complete telephone surveys are being asked to participate in an additional on-site follow up visit. Your site has been selected for one of these follow up visits. These on-site visits provide additional data that is used to evaluate and verify the savings achieved by the new lighting equipment. Would you be interested in having one of our qualified technicians come and conduct an on-site inspection?

OS001. &OS001

1 = Respondent will continue
0 = Respondent will not continue

OS005. Are you the best person who can allow us access to physically inspect the retrofitted electrical equipment?

&OS005 1 = Yes --> SKIP TO 2nd CONTACT
0 = No
8 = (Refused)
9 = (Don't Know)

Who would be the best person who could allow us access to physically inspect the retrofitted electrical equipment?

READ CONTACTS, OR GET ADDITIONAL CONTACT INFO:

DECIS NAME: &DNAME _____
DECIS TITLE: &DTITLF _____
DECIS BUSINESS: &DBUSNAM _____
DECIS PHONE: (&DAC_) &DPRE - &DLAST Ext: &DEXT

TECH NAME: &TNAME _____

TECH TITLE: &TTITLF_____

TECH BUSINESS: &TBUSNAM_____

TECH PHONE: (&TAC_) &TPRE - &TLAST Ext: &TEXT

LIGHT NAME: &LNAME_____

LIGHT TITLE: <ITLF_____

LIGHT BUSINESS: &LBUSNAM_____

LIGHT PHONE: (&LAC_) &LPRE - &LLAST Ext: &LEXT

IF DECIS ENTER 1, ELSE IF TECH ENTER 2, ELSE IF LIGHT ENTER 3,
 ELSE IF NEW ON-SITE CONTACT ENTER 4: ==> &WHOOS

ENTER INFO FOR ON-SITE CONTACT:

OS NAME: &OSNAME_____

OS BUSINESS: &OSBUSNAM_____

OS PHONE: (&OSAC) &OSPRE - &OSLAST Ext: &OSEXT

OS TITLE: &OSTITLN

1 = President/Owner

2 = Senior Manager

3 = Financial Manager

4 = Energy Manager

5 = Operations Manager

6 = Building Manager

7 = Other SPECIFY: &OSTILOTR_____

ENTER 1 TO SKIP FORWARD: ==> &SKIP

Who would be an additional person who can allow us access and be
 knowlegable about the electrical equipment at the facility?
 READ CONTACT NAMES, IF NOT ONE OF THESE, GET ADDITIONAL CONTACT INFO:

DECIS NAME: &DNAME_____

DECIS TITLE: &DTITLF_____

DECIS BUSINESS: &DBUSNAM_____

DECIS PHONE: (&DAC) &DPRE - &DLAST Ext: &DEXT

TECH NAME: &TNAME_____

TECH TITLE: &TTITLF_____

TECH BUSINESS: &TBUSNAM_____

TECH PHONE: (&TAC) &TPRE - &TLAST Ext: &TEXT

LIGHT NAME: &LNAME_____

LIGHT TITLE: <ITLF_____

LIGHT BUSINESS: &LBUSNAM_____

LIGHT PHONE: (&LAC) &LPRE - &LLAST Ext: &LEXT

IF DECIS ENTER 1, ELSE IF TECH ENTER 2 , ELSE IF LIGHT ENTER 3
 IF OTHER THAN THESE THEN ENTER 4 ==> &WHOOS2

GET SECONDARY ON-SITE CONTACT INFORMATION;

SECOND CONTACT NAME &OSNAM2_____

SECOND CONTACT BUSINESS: &OSBUSNM2_____

SECOND CONTACT PHONE: (&OSAC2) &OSPRE2 - &OSLAST2 EXT: &OSEXT2

SECOND CONTACT TITLE: &OSTITN2

1 = President/Owner

2 = Senior Manager

3 = Financial Manager
4 = Energy Manager
5 = Operations Manager
6 = Building Manager
7 = Other SPECIFY: &OSTIL2OT_____

COMMENTS: &OSCOM21_____
COMMENTS: &OSCOM22_____
ENTER 1 TO SKIP FORWARD ==> &SKIP

IF YOU WISH TO SCHEDULE AN APPOINTMENT WITH THE PERSON ON THE PHONE
ENTER 1, ELSE READ BELOW THEN ENTER 2 AND CODE OS RESULT;

==> &SKIP

Those are all of the questions I have for you at this time.
I will contact &OSNAME_____ to schedule
the on-site audit. On behalf of PG&E, thank you for your time
and cooperation.

At this time, we would like to schedule an appointment for one of
our representatives to meet with you at your facility to
conduct the survey and inspect the building's new lighting
equipment.

OS020. Can we schedule a time now for one of our representatives
to meet with you at your facility?
&OS020 1 = Yes --> SKIP OS030
0 = No
8 = (Refused)
9 = (Don't Know)

OS030. How high off the floor is the highest lighting which was
retrofitted under the program?
&OS030 feet (ENTER ESTMATED LIGHTING HEIGHT)
888 = (Refused)
999 = (Don't Know)

OS040. Do you have ladders at the facility high enough to reach
this height, which could be available to the auditor?
&OS040 1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

OS045. What is the closest cross street to the facility at
&ADDRESS_____ ?

Cross Street: &XSTREET_____

ENTER 1 TO SKIP FORWARD: &SKIP

ENTER DAY: &VISDAY____ DISTRICT: &DIV_COD2
ENTER DATE: &VISDAT2____ BUSTYPE: &BUSTYPE_____
ENTER START TIME: &VISTIM1 WHO: 1 = Kevin Shovah CODE: &MAILV_____
END TIME: &VISTIM2 2 = Joe O'Mally
ENTER WHO: &VISWHO 3 = Paul William
IS THE INFORMATION CORRECT &CORR 4 = Denis Ley
USE 24HR CLOCK!!!! 1 = Yes 5 = Chuck Bennett
0 = No

I'll give you the following 800 number, should you need to reschedule or
cancel the appointment. The number is 1-800-540-7201.
If at the time of the audit, you could have a recent PG&E bill available
for the auditor, it would be very helpful.

DO NOT READ

Did the customer ask us to provide a Certificate of Insurance, or
Proof of Insurance?

&INSURE 1 = Yes 0 = No

Did the customer have any concerns about sensitive issues or processes
at their facility?

&TIPTOE 1 = Yes 0 = No

Appendix E

FINAL NONPARTICIPANTS TELEPHONE SURVEY

&S1_____ &S2_____ QC: &QC___ Screen: &S_
 Name: &NAME_____ DCOMP: &D___ LCOMP: &L___ TCOMP: &T___
 Latest Interviewer: &LI Interviewer 1: &I1 Date: &IDATE1_ Time 1: &TIM1
 PG&E C/I L DIVCODE &DVC_ Interviewer 2: &I2 Date: &IDATE2_ Time 2: &TIM2
 Non-Part CATI: &CN___ Interviewer 3: &I3 Date: &IDATE3_ Time 3: &TIM3
 ACCNT #: &ACCOUNT_____ Interviewer 4: &I4 Date: &IDATE4_ Time 4: &TIM4
 MEASTYP: &MEASTYP Interviewer 5: &I5 Date: &IDATE5_ Time 5: &TIM5
 Control: &CONTROL_____ Interviewer 6: &I6 Date: &IDATE6_ Time 6: &TIM6
 Business Name &BUSINESS_____ BUS TYP: &BUSTYPE_____

Name: &NAME2_____ Business Phone: (&HA) &HP - &HL_
 Address: &ADDRESS_____ Corr. Phone: (&CA) &CP - &CL_
 City: &CITY_____ Zip: &ZIP___ Contact: &CONTACT_____

Callback Date: &CBD_____ Callback Time: &CBT_____

Comment: &COMMENT1_____

&COMMENT2_____

Res1: &R1 Res2: &R2 Res3: &R3 Res4: &R4 Res5: &R5 Res6: &R6
 1=Complete-CB OS 6=Refusal 11=Wrong # 16=T&T wrng adr 31=Comp ALL
 2=Partial/Refusd 7=Answr Mach 12=Moved 17=Other 32=Multi-Site
 3=Call Back 8=Busy Signal 13=Fax, Modem 18=Part Comp/CB
 4=No Answr 9=Not Elig 14=No Dir List ONSITE RESULTS:
 5=On Vacation 10=Disconn # 15=T&T sc020 OS1: &O1 OS2: &O2 OS3: &O3

CONTACT INFO:

&CONIFO1_____
 &CONIFO2_____
 &CONIFO3_____
 &CONIFO4_____
 &CONIFO5_____
 &CONIFO6_____
 &CONIFO7_____
 &CONIFO8_____

CONTACT INFO SCREEN:

ENTER PERSON ATTEMPTING TO CONTACT: &RESP

- 1 = Initial attempt to find contact
- 2 = Decision maker
- 3 = Technical
- 4 = Lighting
- 5 = Property Manager

PARTICIPATION CONTACT &DNAME_____

(&DAC) &DPRE - &DLAST Ext. &DEXT_____
 CALLBACK DATE &DCBD_____ CALLBACK TIME &DCBT_____ Def: &DDEF_
 FIRM: &DBUSNAM_____ (1=def callback 0=general)

&NOTED1_____
 &NOTED2_____
 &NOTED3_____
 &NOTED4_____
 &NOTED5_____

TECHNICAL CONTACT &TNAME_____

(&TAC) &TPRE - &TLAST Ext. &TEXT_____
 CALLBACK DATE &TCBD_____ CALLBACK TIME &TCBT_____ Def &TDEF_
 FIRM &TBUSNAM_____ (1=Def callback 0=general)

&NOTET1_____
 &NOTET2_____
 &NOTET3_____
 &NOTET4_____
 &NOTET5_____

ALWAYS ENTER 1 TO SKIP FORWARD ==>>>> &SKIP

PROPERTY MANAGEMENT CONTACT &PMNAME_____

(&PAC) &PPRE - &PLAST Ext. &PMEXT_____
 CALLBACK DATE &PMCBD_____ CALLBACK TIME &PMCBT_____ Def &PMDEF_

FIRM: &PMBUSNAM_____ (1=Def callback 0=general)
&NOTEPM1_____
&NOTEPM2_____
&NOTEPM3_____
&NOTEPM4_____
&NOTEPM5_____

LIGHTING CONTACT &LNAME_____
(&LAC) &LPRE - &LLAST Ext. &LEXT_____
CALLBACK DATE &LCBD_____ CALLBACK TIME &LCBT_____ Def &LDEF_
FIRM: &LBUSNAM_____ (1=Def callback 0=general)
&NOTE1_____
&NOTE2_____
&NOTE3_____
&NOTE4_____
&NOTE5_____

ALWAYS ENTER 1 TO SKIP FORWARD ==> &SKIP

Hello. This is &LI__ . I'm with Quantum Consulting, a management consulting firm in Berkeley, California. We're assisting PG&E in evaluating its (Customized Incentives / Retrofit Express) Program. Although you are not participating in this program, we'd like to ask you some general questions about your firm's energy related decisions, and we'd like to collect some specific technical information on your major electricity end uses.

MN001. Before we start, I would like to inform you that for quality control purposes, this call may be monitored by my supervisor. Would this be OK with you?

&MN001 1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

DECISION MAKER: IF RESPOND = . OR D THEN ASK: RESPOND = &RESPOND
This survey will cover the facility at &ADDRESS_____ ?

SC001d. Does your firm own the building at &ADDRESS2_____ ?
&SC001D
1 = Yes 8 = (Refused)
0 = No --> SKIP FI002 9 = (Don't Know)

FI001d. Does your firm occupy the space at
&ADDRESS3_____ ?
&FI001D 1 = Yes --> SKIP FI003
0 = No --> SKIP SC016
8 = (Refused) --> SKIP FI003
9 = (Don't Know)--> SKIP FI003

FI002d. Does your firm manage the property at &ADDRESS4_____ ?
&FI002D 1 = Yes --> SKIP FI004
0 = No --> SKIP FI003
8 = (Refused) --> SKIP FI004
9 = (Don't Know) --> SKIP FI004

TECHNICAL: ASK WHERE RESPOND = T: RESPOND = &RESPOND
This survey will cover the facility &ADDRESS_____ .

SC001T. Do you own the building at &ADDRESS2_____ ?
&SC001T
1 = Yes 8 = (Refused)

0 = No --> SKIP FI002t 9 = (Don't Know)

FI001T. Does your firm occupy the space at
&ADDRESS3_____ ?

&FI001T 1 = Yes --> SKIP SC005
0 = No --> SKIP SC016
8 = (Refused) --> SKIP SC005
9 = (Don't Know)--> SKIP SC005

FI002T. Does your firm manage the property at &ADDRESS4_____ ?

&FI002T 1 = Yes --> SKIP FI003
0 = No --> SKIP SC005
8 = (Refused) --> SKIP SC005
9 = (Don't Know) --> SKIP SC005

LIGHTING: ASK WHERE RESPOND = L: RESPOND = &RESPOND

This survey will cover equipment installed at &ADDRESS_____ .

SC001L. Do you own the building at &ADDRESS2_____ ?

&SC001L
1 = Yes 8 = (Refused)
0 = No --> SKIP FI002L 9 = (Don't Know)

FI001L. Does your firm occupy the space at
&ADDRESS3_____ ?

&FI001L 1 = Yes --> SKIP SC006
0 = No --> SKIP SC016
8 = (Refused) --> SKIP SC006
9 = (Don't Know)--> SKIP SC006

FI002L. Does your firm manage the property at &ADDRESS4_____ ?

&FI002L 1 = Yes -->SC006
0 = No
8 = (Refused)
9 = (Don't Know)

ASK ONCE:

SC016. Is there a property management firm for this building?
&SC016

1 = Yes
0 = No --> SKIP SC003/SC005/SC006
8 = (Refused) --> SKIP SC003/SC005/SC006
9 = (Don't Know) --> SKIP SC003/SC005/SC006

SC017.- Could you please give me the name and telephone
SC024. number of someone at the property management firm who
would be able to answer questions about the building and
electrical equipment at the premise?

PROPERTY CONTACT NAME: &PMNAME_____
PROPERTY CONTACT COMPANY: &PMBUSNAM_____
PROPERTY CONTACT PHONE: (&PMAC) &PMPRE - &PMLAST_ Extension: &PMEXT
PROPERTY CONTACT TITLE: &PMTITLN_____
1 = President/Owner
2 = Senior Manager
3 = Financial Manager
4 = Energy Manager
5 = Operations Manager
6 = Building Manager
7 = Other SPECIFY: &PMTILOTR_____

Comment1 &PMCOM1_____
Comment2 &PMCOM2_____
ENTER 1 TO SKIP FORWARD ==> &SKIP

FI003. Are you the sole occupant of the building?
&FI003 1 = Yes 8 = (Refused)
0 = No 9 = (Don't Know)

FI004. Is any part of &ADDRESS_____ leased space?
&FI004 1 = Yes 8 = (Refused)
0 = No 9 = (Don't Know)

SC003. This survey will cover the equipment installed at
&ADDRESS2_____. Are you the best person to talk to
about &BUSINESS_____ 's energy related decisions.
These questions cover such topics as awareness of PG&E programs
and energy-efficiency improvements.
&SC003 1 = Yes-->SKIP TO SC005 8 = (Refused)
0 = No 9 = (Don't Know)

SC004. Who would be the best person to talk to about
&BUSINESS_____ energy related decisions?

ENERGY DECISIONS NAME: &DNAME_____
ENERGY DECISIONS PHONE (&DAC) &DPRE - &DLAST Ext. &DEXT_
ENERGY DECISIONS ORGANIZATION NAME &DBUSNAM_____
ENERGY DECISIONS CONTACT TITLE &DTITLN_____
1 = President/Owner
2 = Senior Manager
3 = Financial Manager
4 = Energy Manager
5 = Operations Manger
6 = Building Manger
7 = Other SPECIFY: &DTITLOTR_____

Comment1 &DCOMM1_____
Comment2 &DCOMM2_____
ENTER 1 TO SKIP ==> &SKIP

ASK SC005 IF SC016~=1:

SC005. Are you the best person to answer questions about the size of the facility, and the type size and age of your major electrical equipment?

- &SC005 1 = Yes --> SKIP SC006
- 0 = No
- 8 = (Refused) --> SKIP SC006
- 9 = (Don't Know) --> SKIP SC006

SC007. Who would be the best person to talk to about &BUSINESS_____ 's major electricity end uses?

LIGHT CONTACT NAME &LNAME_____
LIGHT CONTACT PHONE (&LAC_) &LPRE_ - &LLAST_ Ext. &LEXT_
LIGHT ORGANIZATION NAME &LBUSNAM_____
LIGHT CONTACT TITLE <ITLF_____
IF NOT LIGHT CONT ENTER 1 AND GET NEW TECH CONTACT, ELSE IF LIGHT ENTER 2

==> &WHOTECH
TECHNICAL CONTACT NAME &TNAME_____
TECHNICAL CONTACT PHONE (&TAC_) &TPRE_ - &TLAST_ Ext. &TEXT_
TECHNICAL ORGANIZATION NAME &TBUSNAM_____
TECHNICAL CONTACT TITLE &TTITLN_____
1 = President/Owner 5 = Operations Manager
2 = Senior Manager 6 = Building Manager
3 = Financial Manager 7 = Other SPECIFY:
4 = Energy Manager &TTITLOTR_____

Comment1: &TCOMM1_____
Comment2: &TCOMM2_____
ENTER 1 TO SKIP FORWARD ==> &SKIP

ASK IF SC001~=1:

SC006. Are you the best person who can answer questions about the hours of lighting equipment operation at &ADDRESS_____ ?

- &SC006 1 = Yes --> SKIP SC010
- 0 = No --> SKIP SC008
- 8 = (Refused) --> SKIP SC010
- 9 = (Don't Know) --> SKIP SC010

SC008. Who would be the best person on site to talk to about &BUSINESS_____ 's hours of lighting operation?

DECIS CONTACT NAME &DNAME_____
DECIS CONTACT PHONE (&DAC_) &DPRE_ - &DLAST_ Ext. &DEXT_
DECIS ORGANIZATION NAME &DBUSNAM_____
DECIS CONTACT TITLE &DTITLF_____

TECH CONTACT NAME &TNAME_____
TECH CONTACT PHONE (&TAC_) &TPRE_ - &TLAST_ Ext. &TEXT_
TECH ORGANIZATION NAME &TBUSNAM_____
TECH CONTACT TITLE &TTITLF_____

IF DECIS CONTACT ENTER 1, IF TECH CONTACT ENTER 2 ELSE ENTER 3 AND GET NEW INFO ==> &WHOLIT

ENTER NEW LIGHTING CONTACT INFORMATION:

HOURS CONTACT NAME: &LNAME_____

HOURS CONTACT PHONE: (&LAC_) &LPRE_ - &LLAST____ Ext. &LEXT____
HOURS ORGANIZATION NAME: &LBUSNAM_____
HOURS CONTACT TITLE <ITLN
1 = President/Ownwer
2 = Senior Manager
3 = FInancial Manager
4 = Energy Manager
5 = Operations Manager
6 = Building Manager
7 = Other SPECIFY: <ITLOTR_____

Comment1: &LCOMM1_____
Comment2: &LCOMM2_____

ENTER 1 TO SKIP ==> &SKIP

SC020. Pacific Gas and Electric's Customized Incentives and Retrofit Express Programs provide rebates to encourage customers to convert their standard lighting systems to more efficient. Do you recall &BUSINESS_____ having lighting installed as part of PG&E's program?
&SC020__ 1 = Yes -->THANK AND TERMINATE
0 = No
8 = (Refused) --> THANK AND TERMINATE
9 = (Don't Know) --> THANK AND TERMINATE

SC021. Was your lighing installed through the program before or after January of 1992?
&SC021__ 1 = Before January 1992
0 = After January 1992 -->THANK AND TERMINATE
8 = (Refused) -->THANK AND TERMINATE
9 = (Don't Know) -->THANK AND TERMINATE

IL010. Since January 1992, have you made any changes in indoor lighting at your facility other than routine replacement of burned out bulbs?
&IL010 1 = Yes 8 = (Refused)-->SKIP TO FI005
0 = No--->SKIP TO FI005 9 = (Don't Know)-->SKIP TO FI005

IL020. In what months and years did you make these changes?
(ENTER MONTH/YEAR)
&IL020__ MONYYYY (e.g. JUN1960)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR ENTER 1 TO SKIP
IL021. &IL021 YYYY (8 = Refused 9 = Don't Know)

SECOND MONTH AND YEAR, IF APPLICABLE:
(ENTER MONTH/YEAR)
&IL025__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR ENTER 1 TO SKIP
IL026. &IL026 YYYY (8 = Refused 9 = Don't Know)

ENTER '1' TO SKIP FORWARD ==> &SKIP

IL040. What type and how many fixtures were affected?
(READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES ADDED OR REMOVED, IF NONE THEN 0)
888 = (Refused) 999 = (Don't Know)
(0 = NO CHNG)
(1 = ADDED) NUMBER

(2 = REMOVED)

| | | | |
|--------|--------|---------|---------------------------------|
| IL040. | &IL040 | &IL040N | 4 Foot T8 fluorescent |
| IL041. | &IL041 | &IL041N | 8 Foot T8 fluorescent |
| IL042. | &IL042 | &IL042N | 4 Foot Energy saver fluorescent |
| IL043. | &IL043 | &IL043N | 8 Foot Energy saver fluorescent |
| IL044. | &IL044 | &IL044N | 4 Foot T12 fluorescent |
| IL045. | &IL045 | &IL045N | 8 Foot T12 fluorescent |
| IL046. | &IL046 | &IL046N | Incandescent |
| IL047. | &IL047 | &IL047N | Compact Fluorescent |
| IL048. | &IL048 | &IL048N | High pressure sodium |
| IL049. | &IL049 | &IL049N | Metal Halide |

CONTINUED, ENTER 1 TO MOVE FORWARD ==> &SKIP

ENTER TYPE AND NUMBER OF FIXTURES AFFECTED, IF NONE THEN ENTER 0:

0 = No Change
1 = Added NUMBER
2 = Removed
888 = (Refused)
999 = (Don't Know)

| | | | |
|--------|--------|---------|--------------------------------|
| IL050. | &IL050 | &IL050N | Mercury Vapor |
| IL051. | &IL051 | &IL051N | Quartz |
| IL052. | &IL052 | &IL052N | Reflectors (w/ Delamping) |
| IL053. | &IL053 | &IL053N | Electronic Ballasts |
| IL054. | &IL054 | &IL054N | Magnetic Ballasts |
| IL055. | &IL055 | &IL055N | LED Exit Lighting |
| IL056. | &IL056 | &IL056N | Watt Saver/Power Choke Devices |
| IL057. | &IL057 | &IL057N | Other SPECIFY: |
| | | | IL058. &IL058_____ |

Name: &NAME_____ Screen: &S_ Last: &P_ QC: &QC__

ALL:

FI005. Does the PG&E account &ACCOUNT__ located at the service
&ADDRESS_____ cover
multiple buildings or does it cover only one building?
&FI005 1 = One Building --> SKIP TO FI020
2 = Multiple Buildings
3 = Portion of a building
8 = (Refused)--> SKIP TO FI020
9 = (Don't Know)--> SKIP TO FI020

FI007. Are there multiple PG&E accounts for this address?
&FI007 1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

FI010. How many buildings are covered under this service address?
&FI010 # buildings 888 = (Refused)
 999 = (Don't Know)

IF FI010 = 1 or REF/DK SKIP FI025:

FI015. Are there separate PG&E bills for the individual buildings?
&FI015 1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

FI020. Do any other firms occupy space in the building?
&FI020 1 = Yes

0 = No --> SKIP TO FI040
8 = (Refused) --> SKIP TO FI040
9 = (Don't Know) --> SKIP TO FI040

FI025. How many other firms occupy space in the building?
&FI025 Number of firms 888 = (Refused)
999 = (Don't Know)

FI040. Which of the following descriptions best characterizes your
firm's organizational structure?
&FI040
1 = Chain or multifacility (owned or managed by a
parent corporation operating other locations)
2 = Franchise (owns a branch or subsidiary) -->
SKIP TO FI050
3 = Independent-->SKIP TO FI050
8 = (Refused) --> SKIP TO FI050
9 = (Don't Know) --> SKIP TO FI050

FI045. What is the name of your parent company?
&FI045_____

FI050. What is the legal tax status of your firm, that is what is
your tax status for federal tax reporting purposes?
&FI050
1 = Proprietary or investor-owned, (i.e. a for-profit organization)
2 = Public: federal, state or municipal agency
3 = 501(c3): Private, nonprofit
8 = (Refused)
9 = (Don't Know)

DECISION MAKER:

FI060. Where are decisions regarding energy-related investments for
&BUSINESS_____ made?
&FI060
1 = Made locally, on site
2 = Made at regional head office
3 = Made at national head office
4 = Made at international head office
5 = Made by PM firm/building owner
6 = Other FI062.
Specify: &FI062_____

8 = (Refused)
9 = (Don't Know)

EI010. Approximately how many people are currently employed at
the facility, including both full- and part-time employees?
&EI010 Number of Employees 888 = (Refused)
999 = (Don't Know)

EI020. Since January 1992, has the number of people employed at this facility changed?
&EI020 1 = Yes
0 = No--->SKIP TO FI080
8 = (Refused)--->SKIP TO FI080
9 = (Don't Know)--->SKIP TO FI080

EI030. In what month and year did this change in the number of employees occur? (ENTER MONTH/YEAR)
&EI030___ MONYYYY

IF DON'T KNOW ASK FOR BEST GUESS OR YEAR:
EI031. &EI031___ YYYY 8 = (Refused) 9 = (Don't Know)

EI040. Approximately how many people were employed at this facility before the change occurred, including both full and part-time employees?
&EI040 Number of Employees

777 = Seasonal Workforce --> ENTER COMMENTS BELOW
888 = (Refused)
999 = (Don't Know)

&EI041 _____
&EI042 _____
&EI043 _____
ENTER 1 TO SKIP FORWARD --> &SKIP

IF LEASE=1 THEN ASK; ELSE SKIP TO EI010: LEASE = &L

FI080. Do the tenants at &ADDRESS_____ pay all, none, or a portion of their electric utilities through their lease?
&FI080
1 = ALL utilities INCLUDED in lease --> SKIP TO FI110
2 = Pay some utilities through lease and others directly to PG&E
3 = Pays ALL utilities directly to PG&E--> SKIP FI110
8 = (Refused) --> SKIP FI110
9 = (Don't Know) --> SKIP FI110

IF (LEASE=1 AND FI080 = 2): LEASE = &L FI080 = &FI080

FI090- Which of the following utilities are paid for through the
FI100. lease? (ENTER '1' FOR ALL THAT APPLY)

8 = (Refused)
9 = (Don't Know)

| | |
|------------------------------------|-------------------------|
| &FI090 Indoor Lighting | &FI095 Outdoor Lighting |
| &FI091 Heating | &FI096 Cooling |
| &FI092 Ventilation | &FI097 Water Heating |
| &FI093 Electricity to Wall Outlets | &FI098 Refrigeration |
| &FI094 Cooking | &FI099 Other SPECIFY: |
| | &FI100 _____ |

FI120. Is this the current tenant's first lease at this address?
&FI120 1 = Yes 8 = (Refused)
0 = No 9 = (Don't Know)

IS001. Do you have a lighting contractor that you regularly use/rely on?
&IS001 1 = Yes

0 = No SKIP --> SKIP AW005
8 = (Refused) --> SKIP AW005
9 = (Don't Know) --> SKIP AW005

IS002. Did the contractor that you use/rely on tell you about the Retrofit Lighting Program?

&IS002 1 = Yes 8 = (Refused)
0 = No 9 = (Don't Know)

AW005. Have you heard of PG&E's Customized Lighting or Retrofit Express Express Programs?

&AW005 1 = Yes
0 = No -->SKIP TO PP010
8 = (Refused) -->SKIP TO PP010
9 = (Don't Know) -->SKIP TO PP010

AW010. When did you first become aware of PG&E's Customized Incentives or Retrofit Express Programs?

&AW010 MONYYYY (i.e. JUN1960)

IF DON'T KNOW MONTH AND YEAR, ASK FOR BEST GUESS YEAR AND CODE BELOW:

&AW011 YYYY 8 = (Refused)
9 = (Don't Know)

ASK IF RETRO=1 AND AW011=REFUSED OR DON'T KNOW; ELSE SKIP TO IS010:

AW015. Did you find out about the Retrofit Express Program BEFORE or AFTER you made the decision to purchase your new lighting?

&AW015 1 = Before Purchase Decision
0 = After Purchase Decision
8 = (Refused)
9 = (Don't Know)

ASK IF IS002~=1; ELSE SKIP TO PP010:

IS010. How did you FIRST learn about the Retrofit Lighting Program

&IS010 (DO NOT READ)

CUSTOMER APPROACHED SOMEONE:

1 = Respondent approached vendor/contractor
2 = Respondent approached PG&E concerning another matter and found out about program

SOMEONE APPROACHED THE CUSTOMER:

3 = Contacted by PG&E account rep
4 = Contacted by lighting contractor
5 = Contacted by electrical contractor
6 = PG&E Brochure in mail
7 = Bill Insert
8 = Word of mouth from friends or co-workers within the organization
9 = Word of mouth from friends or other business people outside of company

10 = Television, Radio, Newspaper ad

11 = Other SPECIFY: IS020. &IS020_____

88 = (Refused) 99 = (Don't Know)

PP010. Has your firm participated in any PG&E sponsored energy conservation programs?

&PP010

1 = Yes
0 = No--->SKIP TO PD010/TR030
2 = Not aware of other programs--->SKIP TO PD010/TR030

8 = (Refused)--->SKIP TO PD010/TR030
9 = (Don't Know)--->SKIP TO PD010/TR030

PP020. In what year did you participate in the program(s)?
(ENTER YEAR)

&PP020__ YYYY 8 = (Refused)
 9 = (Don't Know)

ASK IF RETRO=1; ELSE SKIP TO TR030:

PD010. When you were making your decision to purchase new lighting equipment, what was the most important factor in your decision to the new lighting? (READ CATEGORIES IF NECESSARY)

&PD010 1 = Acquiring the latest technology
 2 = Saving money on electric bills
 4 = Replacing old or broken equipment
 6 = Improving the quality of light for employees and customers
 7 = Helping to protect the environment
 9 = Obtaining advice from another branch of your firm
 10 = Obtaining advice from PG&E account rep
 11 = Obtaining advice from contractors
 12 = Other SPECIFY: PD011: &PD011_____

88 = (Refused)
99 = (Don't Know)

ASK IF RETRO=1, AND AWARE OF PROGRAM PRIOR TO RETROFIT:

FR100. Why did you choose to purchase your equipment outside of the program? (DO NOT READ LIST: ENTER 1 IF APPLIES, 0 IF NOT)

FR100. &FR100 Lack of money to invest in it.
FR101. &FR101 Payback/return on investment not attractive enough.
FR102. &FR102 Concerned that it might not save as much as claimed
FR103. &FR103 Didn't know enough about EE lighting before
FR104. &FR104 Didn't know where/how to obtain EE lighting.
FR105. &FR105 Hadn't had time.
FR106. &FR106 Concerned about light quality/brightness
FR107. &FR107 Tenants didn't want a change
FR108. &FR108 Decision made elsewhere
FR109. &FR109 Was planning to install when heard about program
FR110. &FR110 Program participation seemed like to much of a hassle
FR114. &FR114 Other1 SPECIFY: FR115 &FR115_____

FR116. &FR116 (Refused)
FR117. &FR117 (Don't Know)

FR011. How many estimates or quotes did you obtain before purchasing your new equipment?

&FR011 Estimates 888 = (Refused)
 999 = (Don't Know)

FR012. Did you obtain estimates for both high efficiency and standard efficiency lighting equipment?
 &FR012 1 = Both standard and high efficiency
 2 = Standard efficiency only
 3 = High efficiency only
 8 = (Refused)
 9 = (Don't Know)

FR014. How many people were involved in the decision to install your new lighting?
 &FR014 People 888 = (Refused)
 999 = (Don't Know)

FR015. Were you the person who made the final decision?
 &FR015
 1 = Yes --> SKIP FR017
 0 = No
 8 = (Refused)--> SKIP FR017
 9 = (Don't Know)--> SKIP FR017

FR016. What is the job title of the person who made the final decision?
 &FR016_____ Title

ASK IF LEASE=1 Lease= &L:

FI065. How active a role do tenants take in making equipment purchase decisions for the property at
 &ADDRESS_____ ?
 &FI065
 1 = Very active: they are involved in every aspect of the purchase and you possess veto power
 2 = Somewhat active: they approve all decisions
 3 = Slight role: they have a voice but it's a single vote among many
 4 = None
 8 = (Refused)
 9 = (Don't Know)

TR030. Would you consider a retrofit of your &TYPE__ lighting with T-8 high efficiency equipment if PG&E offered financing at 1 percentage point below the prime rate?
 &TR030
 1 = Yes--->SKIP TO TR070
 0 = No
 8 = (Refused)
 9 = (Don't Know)

ASK IF TR030~=1:

TR040. What if the interest rate were 1.5 percentage points below the prime rate?
 &TR040
 1 = Yes
 0 = No
 8 = (Refused)
 9 = (Don't Know)

TR050. What if PG&E offered a rebate of \$15 per fixture, and financing at 1 percentage point below the prime rate?
&TR050
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

IF TR040=1 or TR050=1 THEN SKIP TO TR070

TR070. What you consider a retrofit of your current lighting with T-8 high-efficiency fluorescent fixtures if PG&E offered rebates of \$15 per fixture, but conducted an on-site audit of the facility, and provided you with detailed engineering analyses and recommendations?
&TR070
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

FUTURE SERVICES:

PG&E is currently planning on offering some new services to its commercial and industrial customers...

PR020. Would you be interested in having PG&E operate or maintain the lighting equipment at the facility?
(i.e. routine replacement of burned out bulbs)
&PR020
1 = Yes
0 = No
2 = Depends on price
8 = (Refused)
9 = (Don't Know)

PR040. Would you be interested in having all of the building's systems checked out to ensure proper operation and efficient use of energy? (i.e. building recommissioning)
&PR040
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

PR060. Would you be interested in having PG&E help you with any future equipment selection?
&PR060
1 = Yes
0 = No
8 = (Refused)
9 = (Don't Know)

PR001- How frequently do you have contact with your PG&E account rep?

PR002. (CODE NUMBER OF TIMES AND PERIOD IT IS IN)
&PR001 Times
&PR002 Time Period --> IF NOT 0 SKIP PR090
0 = Never
1 = Day
2 = Week
3 = Month
4 = Year
8 = (Refused)
9 = (Don't Know)

PR005. Does someone else in the firm have contact with your PG&E rep?
&PR005
1 = Yes
0 = No --> SKIP PR090

8 = (Refused)--> SKIP PR090
9 = (Don't Know)--> SKIP PR090

PR010- How often does this person have contact with your PG&E
PR011. account rep?

&PR010 Times --> IF 0, 8, 9 SKIP PR090
&PR011 Time Period
0 = Never
1 = Day
2 = Week
3 = Month
4 = Year
8 = (Refused)
9 = (Don't Know)

PR015. What is the name, title, and phone number of this person?

&REPNAME _____ Name
&REPTITLE _____ Title
(&RAC) &RPRE - &RLAST Ext &REPEXT Phone

ENTER 1 TO SKIP FORWARD ==> &SKIP

PR090. Are there any additional services you would like to see PG&E
provide?

(ENTER 1 FOR ALL THAT APPLY)
8 = (Refused)
9 = (Don't Know)
&PR090 other SPECIFY: &PR091 _____
&PR092 other SPECIFY: &PR093 _____
&PR094 other SPECIFY: &PR095 _____

ENTER 1 TO SKIP FORWARD ==> &SKIP

DC010. Which of the following financial criteria do you consider when
evaluating lighting investments?

(READ LIST; ENTER 1 FOR ALL THAT APPLY; ELSE ENTER 0)
8 = (Refused)
9 = (Don't Know)

DC010. &DC010 Payback
DC011. &DC011 Internal Rate of Return
DC012. &DC012 Net Present Value
DC013. &DC013 Other SPECIFY: DC014. &DC014 _____

IF DC010=1 THEN ASK DC020

DC020. What is the payback period you require?

&DC020

1 = 1 year or less

2 = 2 years or less

3 = 3 years or less

4 = 4 years or less

5 = 5 years or less

6 = 6 years or less

7 = 7 years or less

8 = 8 years or less

9 = 9 years or less

10 = 10 years or less

11 = Other SPECIFY: DC021. &DC021_____

88 = (Refused)

99 = (Don't Know)

IF DC011=1 THEN ASK DC030:

DC030. What is your organization's required internal rate of return?

&DC030 Percent

888 = (Refused)

999 = (Don't Know)

IF DC012=1 THEN ASK DC040:

DC040. What is the discount rate you use when determining the net present value of an investment?

&DC040 Percent

888 = (Refused)

999 = (Don't Know)

ASK ALL:

DC050. Do you use a different &CRITERIA_____ for evaluating energy efficient equipment purchases than you use for general investments?

&DC050 1 = Yes

0 = No --> SKIP BC021

8 = (Refused) --> SKIP BC021

9 = (Don't Know) --> SKIP BC021

ASK DC051 IF DC010=1 OR DC011=1 OR DC012=1; ELSE SKIP BC021:

DC051. Is the &CRITERI2_____ you use for energy efficient purchases &TYPE1_____ or &TYPE2_____ than that which you use for other general investments?

&DC051

1 = Higher/Shorter

2 = Lower/Longer

8 = (Refused)

9 = (Don't Know)

BC021. Are any other locations of your business participating in the Customized Incentives or Retrofit Express Programs?

&BC021 1 = Yes

8 = (Refused)

0 = No

9 = (Don't Know)

BC022. How many of your other locations are participating in the Customized Incentives or Retrofit Express Programs?

&BC022 Locations

888 = (Refused)

999 = (Don't Know)

FUTURE PLANS:

FR070. Are you currently planning on making any lighting retrofits within the next two years?

- &FR070 1 = Yes
- 0 = No --> SKIP PR020
- 8 = (Refused) --> SKIP PR020
- 9 = (Don't Know) --> SKIP PR020

FR075. Will the new lighting be high or standard efficiency?

- &FR075 1 = High efficiency
- 0 = Standard efficiency
- 8 = (Refused)
- 9 = Don't Know)

FR077. Are you planning to make this change through one of PG&E's Retrofit programs?

- &FR077 1 = Yes
- 0 = No
- 8 = (Refused)
- 9 = (Don't Know)

FR080. What type and how many fixtures are you planning to install?

- (READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES TO BE CHANGED; IF NONE THEN ENTER 0)
- 888 = (Refused) 999 = (Don't Know)
- (READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES TO BE ADDED)

- FR080. &FR080 4 Foot T8 fluorescent
- FR081. &FR081 8 Foot T8 fluorescent
- FR082. &FR082 4 Foot Energy saver fluorescent
- FR083. &FR083 8 Foot Energy saver fluorescent
- FR084. &FR084 4 Foot T12 fluorescent
- FR085. &FR085 8 Foot T12 fluorescent
- FR086. &FR086 Incandescent
- FR087. &FR087 Compact Fluorescent
- FR088. &FR088 High pressure sodium
- FR089. &FR089 Electronic Ballasts
- FR090. &FR090 Magnetic Ballasts
- FR091. &FR091 Metal Halide

CONTINUED ==> ENTER 1 TO SKIP ==> &SKIP

ENTER TYPE AND NUMBER OF FIXTURES PLANNING TO ADD:
IF NONE ENTER 0

- 888 = (Refused)
- 999 = (Don't Know)

- FR092. &FR092 Mercury Vapor
- FR093. &FR093 Quartz
- FR094. &FR094 Reflectors (w/Delamping)
- FR095. &FR095 LED Exit Lighting
- FR096. &FR096 Watt Saver/Power Choke Devices
- FR097. &FR097 Other SPECIFY: FR098. &FR098 _____
- FR099r. &FR099R (Refused)
- FR099d. &FR099D (Don't Know)

ENTER 1 TO SKIP FORWARD ==> &SKIP

The following questions refer to your "FACILITY," which means ALL the buildings and tenants SERVICED BY PG&E UNDER THE FOLLOWING Nonparticipant Telephone Survey E-16 1994 PG&E Lighting Evaluation

BILLING NAME: &BUSINESS_____ ADDRESS: &ADDRESS_____

ACCOUNT #: &ACCOUNT_____

BC011. What is the main business ACTIVITY at the facility?

&BC011

- 1 = Office 88 = (Refused)
- 2 = Retail (non-food) 99 = (Don't Know)
- 3 = Manufacturing/Assembly
- 4 = Warehouse
- 5 = Restaurant
- 6 = Grocery Store
- 7 = School
- 8 = Hotel or Motel
- 9 = Hospital
- 10 = College/University
- 11 = Health Care
- 12 = Municipality
- 13 = Industrial Process
- 14 = Other SPECIFY: BC012 &BC012_____

FC110. Since January 1992, has the square footage covered by account # &ACCOUNT_____ increased, decreased, or stayed the same?

- &FC110
- 1 = Increased floor space
 - 2 = Decreased floor space
 - 3 = Stayed the same-->SKIP TO FR033
 - 8 = (Refused)-->SKIP TO FR033
 - 9 = (Don't Know)-->SKIP TO FR033

FC120. What is the approximate area, in square feet, of this change?

- &FC120 Square Feet
- 8 = (Refused)
 - 9 = (Don't Know)

FC130. In what month and year did this change in floor space occur?
(ENTER MONTH/YEAR)

&FC130__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR:

FC131. &FC131 YYYY (8 = Refused 9 = Don't Know)

IF FC110=1; ELSE SKIP TO BH010

FC140. In what month and year was this additional floor space occupied?
(ENTER MONTH/YEAR)

&FC140__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS, AND/OR YEAR:

FC141. &FC141 YYYY (8 = Refused 9 = Don't Know)

ASK WHERE FC110 IS NOT 1:

FR033. When was your last major space remodel?

(ENTER MONTH/YEAR)

&FR033__ MONYYYY (e.g. JUN1960)

IF DON'T KNOW ASK FOR BEST GUESS AND/OR YEAR:
 FR034. &FR034 YYY 7 = Never Remodeled
 8 = (Refused)
 9 = (Don't Know)

IF 7, 8, or 9 THEN --> SKIP BH010/IL001:

FR035. Did this remodel include space covered by the retrofit?
 &FR035 1 = Yes --> SKIP LF001/IL001
 0 = No --> SKIP LF001/IL001
 8 = (Refused) --> SKIP LF001/IL001
 9 = (Don't Know) --> SKIP LF001/IL001

LF001- Could you please tell me the facility's &HOUR _____
 LF013. hours during the following times, and what percentage of the
 facility's lights are on at these times?

66 = On 24 Hours 888 = (Refused)
 77 = Never On 999 = (Don't Know)

| | Month | Day | Code | Same As | From | AM/PM | To | AM/PM | % ON |
|--------|----------|------|-------|---------|--------|--------|--------|--------|-------|
| LF001. | DECEMBER | WEEK | &LF1_ | &E1_ | &LF1F_ | &LF1M_ | &LF1T_ | &LF1N_ | &LW1_ |
| LF002. | DECEMBER | SAT | &LF2_ | &E2_ | &LF2F_ | &LF2M_ | &LF2T_ | &LF2N_ | &LW2_ |
| LF003. | DECEMBER | SUN | &LF3_ | &E3_ | &LF3F_ | &LF3M_ | &LF3T_ | &LF3N_ | &LW3_ |
| LF004. | APRIL | WEEK | &LF4_ | &E4_ | &LF4F_ | &LF4M_ | &LF4T_ | &LF4N_ | &LW4_ |
| LF005. | APRIL | SAT | &LF5_ | &E5_ | &LF5F_ | &LF5M_ | &LF5T_ | &LF5N_ | &LW5_ |
| LF006. | APRIL | SUN | &LF6_ | &E6_ | &LF6F_ | &LF6M_ | &LF6T_ | &LF6N_ | &LW6_ |
| LF007. | AUGUST | WEEK | &LF7_ | &E7_ | &LF7F_ | &LF7M_ | &LF7T_ | &LF7N_ | &LW7_ |
| LF008. | AUGUST | SAT | &LF8_ | &E8_ | &LF8F_ | &LF8M_ | &LF8T_ | &LF8N_ | &LW8_ |
| LF009. | AUGUST | SUN | &LF9_ | &E9_ | &LF9F_ | &LF9M_ | &LF9T_ | &LF9N_ | &LW9_ |
| LF010. | OCTOBER | WEEK | &LF10 | &E10 | &LF10F | &LF10M | &LF10T | &LF10N | &LW10 |
| LF011. | OCTOBER | SAT | &LF11 | &E11 | &LF11F | &LF11M | &LF11T | &LF11N | &LW11 |
| LF012. | OCTOBER | SUN | &LF12 | &E12 | &LF12F | &LF12M | &LF12T | &LF12N | &LW12 |
| LF013. | HOLIDAY | ALL | &LF13 | &E13 | &LF13F | &LF13M | &LF13T | &LF13N | &LW13 |

The next questions refer to the facility's conditioned floor space.
 That is, the areas of the facility that are heated or cooled.

LF015. What percentage of the facility's conditioned floor space is
 lighted during business hours?
 &LF015 Percent 888 = (Refused)
 999 = (Don't Know)

Now, I'd like to ask about the type of lighting equipment at your
 facility before you changed your lighting.

SR010. What was the average age of the lighting fixtures
 you replaced?
 &SR010 Years 888 = (Refused)
 999 = (Don't Know)

SR100. What is the average age of the existing lighting equipment
 at your facility?
 &SR100 Years 888 = (Refused)
 999 = (Don't Know)

ASK WHERE RETRO = 1; ELSE SKIP TO OL010:

LP010. Has any of the lighting equipment that was installed been removed?
 &LP010 1 = Yes
 0 = No--->SKIP TO OL010
 8 = (Refused)--->SKIP TO OL010
 9 = (Don't Know)--->SKIP TO OL010

LP020. In what months and years did you make these
 changes?

(ENTER MONTH/YEAR)
&LP020__ MONYYYY
LP021. &LP021 YYYY 8 = Refused 9 = Don't Know

SECOND MONTH AND YEAR: (ENTER MONTH/YEAR)
&LP025__ MONYYYY
LP026. &LP026 YYYY 8 = Refused 9 = Don't Know

ENTER 1 TO SKIP FORWARD ==> &SKIP

LP030. What type and how many fixtures were removed?
(READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES REMOVED,
IF NONE THEN 0)

888 = (Refused)
999 = (Don't Know)

| | NUMBER | |
|--------|--------|---------------------------------|
| LP030. | &LP030 | 4 Foot T8 fluorescent |
| LP031. | &LP031 | 8 Foot T8 fluorescent |
| LP032. | &LP032 | 4 Foot Energy saver fluorescent |
| LP033. | &LP033 | 8 Foot Energy saver fluorescent |
| LP034. | &LP034 | 4 Foot T12 fluorescent |
| LP035. | &LP035 | 8 Foot T12 fluorescent |
| LP036. | &LP036 | Incandescent |
| LP037. | &LP037 | Compact Fluorescent |
| LP038. | &LP038 | High pressure sodium |
| LP039. | &LP039 | Metal Halide |

CONTINUED, ENTER 1 TO SKIP FORWARD ==> &SKIP

ENTER NUMBER OF FIXTURES REMOVED, IF NONE THEN 0

888 = (Refused)
999 = (Don't Know)

| | NUMBER | |
|--------|--------|----------------------------------|
| LP040. | &LP040 | Mercury Vapor |
| LP041. | &LP041 | Quartz |
| LP042. | &LP042 | Reflectors (w/Delamping) |
| LP043. | &LP043 | Electronic Ballasts |
| LP044. | &LP044 | Magnetic Ballasts |
| LP045. | &LP045 | LED Exit Lighting |
| LP046. | &LP046 | Watt Saver/Power Choke Devices |
| LP047. | &LP047 | Other SPECIFY: LP048 &LP048_____ |

ENTER 1 TO SKIP FORWARD ==> &SKIP

LP070. What type and how many fixtures replaced the equipment that was removed? 888 = (Refused)
999 = (Don't Know)

(READ LIST IF NECESSARY; ENTER NUMBER OF FIXTURES ADDED)

LP070. &LP070 4 Foot T8 fluorescent
LP071. &LP071 8 Foot T8 fluorescent
LP072. &LP072 4 Foot Energy saver fluorescent
LP073. &LP073 8 Foot Energy saver fluorescent
LP074. &LP074 4 Foot T12 fluorescent
LP075. &LP075 8 Foot T12 fluorescent
LP076. &LP076 Incandescent
LP077. &LP077 Compact Fluorescent
LP078. &LP078 High pressure sodium
LP079. &LP079 Electronic Ballasts
LP080. &LP080 Magnetic Ballasts
LP081. &LP081 Metal Halide

CONTINUED, ENTER 1 TO SKIP FORWARD ==> &SKIP

ENTER TYPE AND NUMBER OD FIXTURE WHICH REPLACED THOSE REMOVED

0 = NONE OF THAT TYPE
888 = (Refused)
999 = (Don't Know)

NUMBER
LP082. &LP082 Mercury Vapor
LP083. &LP083 Quartz
LP084. &LP084 Reflectors (W/ Delamping)
LP085 &LP085 LED Exit Lighting
LP086 &LP086 Watt Saver/Power Choke Devices
LP087. &LP087 Other SPECIFY: LP088. &LP088_____

ENTER 1 TO SKIP FORWARD ==> &SKIP

OL010. Is OUTDOOR lighting included on the facility's utility bill?
&OL010

1 = Yes
0 = No--->SKIP TO CE010
8 = (Refused)--->SKIP TO CE010
9 = (Don't Know)--->SKIP TO CE010

OL020. Since January 1992, have you made any changes in OUTDOOR lighting at your facility?
&OL020

1 = Yes
0 = No--->SKIP TO CE010
8 = (Refused)--->SKIP TO CE010
9 = (Don't Know)--->SKIP TO CE010

OL030. In what month and year did you make these changes?
(ENTER MONTH/YEAR)
&OL030__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR:

OL031. &OL031 YYYY 8 = (Refused)
9 = (Don't Know)

OL040. Did you ADD TO, REPLACE, or REMOVE outdoor lighting?
&OL040

1 = Added lighting

- 2 = Replaced lighting
- 3 = Added AND Replaced lighting
- 4 = Removed
- 8 = (Refused)
- 9 = (Don't Know)

COOLING EQUIPMENT:

The next series of questions pertain to the cooling equipment at the facility.

CE010. What type of system is used to air condition this facility?
 [If there is more than one system, enter the one used to cool the largest portion of this facility.]

&CE010

- 0 = No A/C--->SKIP TO CE080
- 1 = Central plant
- 2 = Small Packaged Systems (i.e. Rooftop or Ground)
- 3 = Wall or window units
- 4 = Heat pump
- 5 = Other SPECIFY: CE011 &CE011_____
- 8 = (Refused)
- 9 = (Don't Know)

CE015. What is the primary fuel used to cool your facility?

&CE015

- 1 = Electricity
- 2 = Natural Gas
- 3 = Other SPECIFY: CE016. &CE016_____
- 8 = (Refused)
- 9 = (Don't Know)

CE060. During what months is the cooling system operated?

(READ LIST IF NECESSARY; ENTER NUMBER 1 FOR ALL THAT APPLY)

- CE059. &CE059 All Year --> SKIP CE080
- CE060. &CE060 January
- CE061. &CE061 February
- CE062. &CE062 March
- CE063. &CE063 April
- CE064. &CE064 May
- CE065. &CE065 June
- CE066. &CE066 July
- CE067. &CE067 August
- CE068. &CE068 September
- CE069. &CE069 October
- CE070. &CE070 November
- CE071. &CE071 December
- CE072. &CE072 (Refused)
- CE073. &CE073 (Don't Know)

TO SKIP FORWARD ENTER 1: ==> &SKIP

CE080. Since January 1992, have you ADDED TO, REMOVED, or REPLACED an older cooling system?

&CE080 0 = No Change-->SKIP TO HE015
1 = Added
2 = Replaced
3 = Added and Replaced
4 = Removed
8 = (Refused)-->SKIP TO HE015
9 = (Don't Know)-->SKIP TO HE015

CE090. In what month and year did you make these changes?
(ENTER MONTH/YEAR)

&CE090__ MONYYYY (i.e. JUN1960)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

CE091. &CE091 YYYY (8 = Refused 9 = Don't Know)

IF CE080=1 THEN SKIP TO CE120; ELSE ASK:

CE110. What fuel was used to power the old system?

&CE110
1 = Electricity
2 = Natural Gas
3 = Other SPECIFY: CE111. &CE111_____
8 = (Refused)
9 = (Don't Know)

IF CE080 = 4 THEN SKIP TO HE015

CE120. What fuel does the cooling system addition use?

&CE120
1 = Electricity
2 = Natural Gas
3 = Other SPECIFY: CE121. &CE121_____
8 = (Refused)
9 = (Don't Know)

HEATING EQUIPMENT:

HE015. What is the main type of heating system used to heat your facility?

&HE015 1 = Central electric furnace 19 = None
2 = Central heat pump 88 = (Refused)
3 = Central gas furnace 99 = (Don't Know)
4 = Gas boiler
5 = Electric boiler
6 = Fuel oil furnace or boiler
7 = Electric strip heat
8 = Baseboard electric heating
9 = Room or wall AC with electric strip heat
10 = Permanent, non-electric room heaters
11 = Whole-house wall or floor electric furnace
12 = Whole-house wall or floor gas furnace
13 = Portable electric heater
14 = Portable kerosene heater
15 = Wood or coal burning stove or fireplace
16 = Solar collector
17 = Propane heating system
18 = Other HE016. &HE016_____

HE020. What is the primary fuel used to heat your facility?

&HE020

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: HE021 &HE021_____
- 8 = (Refused)
- 9 = (Don't Know)

HE060. During what months is the heating system operated?
 (READ LIST IF NECESSARY; ENTER NUMBER 1 FOR ALL THAT APPLY)

HE059. &HE059 All Year ---> SKIP HE080
 HE060. &HE060 January
 HE061. &HE061 February
 HE062. &HE062 March
 HE063. &HE063 April
 HE064. &HE064 May
 HE065. &HE065 June
 HE066. &HE066 July
 HE067. &HE067 August
 HE068. &HE068 September
 HE069. &HE069 October
 HE070. &HE070 November
 HE071. &HE071 December
 HE072. &HE072 (Refused)
 HE073. &HE073 (Don't Know)

TO SKIP FORWARD ENTER 1: ==> &SKIP

HE080. Since January 1992, have you ADDED TO, REPLACED, or REMOVED an older heating system?
 &HE080 0 = No Change-->SKIP TO OE010
 1 = Added
 2 = Replaced
 3 = Added and Replaced
 4 = Removed
 8 = (Refused)-->SKIP TO OE010
 9 = (Don't Know)-->SKIP TO OE010

HE090. In what month and year did you make these changes?
 (ENTER MONTH/YEAR)
 &HE090__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR
 HE091. &HE091 YYYY (8 = Refused 9 = Don t Know)

IF HE080=1 THEN SKIP TO HE120, ELSE ASK:

HE110. What fuel was used to power the old system?
 &HE110

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Steam
- 5 = Electricity
- 6 = Other SPECIFY: HE111. &HE111_____
- 8 = (Refused)
- 9 = (Don't Know)

IF HE080 = 4 THEN SKIP TO OE010:

HE120. What fuel does the heating system addition use?
 &HE120

- 1 = Natural Gas
- 2 = Propane or Bottled Gas

- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: HE121. &HE121_____
- 8 = (Refused)
- 9 = (Don't Know)

OTHER EQUIPMENT:

OE010. Since January 1992, have you changed other equipment that makes up 10% or more of the facility's annual electric bill?
&OE010

- 1 = Yes
- 0 = No-->SKIP TO OC010
- 8 = (Refused)-->SKIP TO OC010
- 9 = (Don't Know)-->SKIP TO OC010

OE011. Which of the following types of equipment were changed?
(READ FIRST THREE THEN ASK FOR OTHER)
(READ LIST; ENTER 1 FOR ALL THAT APPLY)

- OE012. &OE012 Water heating
- OE013. &OE013 Cooking
- OE014. &OE014 Refrigeration

Were there any other end uses changed? (RECORD BELOW)

- OE015. &OE015 Other1 SPECIFY: OE016. &OE016_____
- OE017. &OE017 Other2 SPECIFY: OE018. &OE018_____
- OE019. &OE019 (Refused) ---> SKIP to OC010
- OE011. &OE011 (Don't Know) ---> SKIP TO OC010

ASK OE020-OE050 IF OE012=1

OE020. In what month and year did you change your water heating equipment?
(ENTER MONTH/YEAR)
&OE020__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE021. &OE021 YYYY (8 = Refused 9 = Don't Know)

OE030. Did you ADD TO, REMOVE, or REPLACE water heating equipment?

- &OE030 1 = Added -->SKIP TO OE050
- 2 = Replaced
- 3 = Added and Replaced
- 4 = Removed
- 8 = (Refused)--->SKIP TO OE060
- 9 = (Don't Know)--->SKIP TO OE060

OE040. What fuel was used to power the old water heating equipment?

- &OE040
- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE041. &OE041_____

8 = (Refused)
9 = (Don't Know)

IF OE030 = 4 THEN SKIP TO OE060:

OE050. What fuel does the water heating equipment addition use?
&OE050

1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE051. &OE051_____

8 = (Refused)
9 = (Don't Know)

ASK OE060-OE090 IF OE013=1

OE060. In what month and year did you change your cooking equipment?
(ENTER MONYYYY)
&OE060__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE061. &OE061 YYY (8 = Refused 9 = Don't Know)

OE070. Did you ADD TO, REMOVE, or REPLACE cooking equipment?
&OE070

1 = Added--->SKIP TO OE090
2 = Replaced
3 = Added and Replaced
4 = Removed
8 = (Refused)--->SKIP TO OE100
9 = (Don't Know)--->SKIP TO OE100

OE080. What fuel was used to power the old cooking equipment?
&OE080

1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE081. &OE081_____

8 = (Refused)
9 = (Don't Know)

IF OE070 = 4 THEN SKIP TO OE100:

OE090. What fuel does the cooking equipment addition use?
&OE090

1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE091. &OE091_____

8 = (Refused)
9 = (Don't Know)

ASK OE100-OE130 IF OE014=1

OE100. In what month and year did you change your refrigeration equipment?
(ENTER MONTH/YEAR)
&OE100__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE101. &OE101 YYY (8 = Refused 9 = Don't Know)

OE110. Did you ADD TO, REMOVE, or REPLACE refrigeration equipment?
&OE110

1 = Added--->SKIP TO OE130

- 2 = Replaced
- 3 = Added and Replaced
- 4 = Removed
- 8 = (Refused)--->SKIP TO OE140
- 9 = (Don't Know)--->SKIP TO OE140

OE120. What fuel was used to power the old refrigeration equipment?
&OE120

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE121. &OE121_____
- 8 = (Refused)
- 9 = (Don't Know)

IF OE110 = 4 THEN SKIP TO OE140

OE130. What fuel does the refrigeration equipment addition use?
&OE130

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE131. &OE131_____
- 8 = (Refused)
- 9 = (Don't Know)

ASK OE140-OE170 IF OE015=1

OE140. In what month and year did you change your &EQUIP_____ (ENTER MONTH/YEAR)
&OE140__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE141. &OE141 YYYY (8 = Refused 9 = Don't Know)

OE150. Did you ADD TO, REMOVE, or REPLACE &EQUIP2_____ equipment?
&OE150

- 1 = Added--->SKIP TO OE170
- 2 = Replaced
- 3 = Added and Replaced
- 4 = Removed
- 8 = (Refused)--->SKIP TO OE180
- 9 = (Don't Know)--->SKIP TO OE180

OE160. What fuel was used to power the old &EQUIP_____ equipment?
&OE160

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE161. &OE161_____
- 8 = (Refused)
- 9 = (Don't Know)

IF OE150 = 4 THEN SKIP TO OE180

OE170. What fuel does the &EQUIP_____ equipment addition use?
&OE170

- 1 = Natural Gas
- 2 = Propane or Bottled Gas
- 3 = Oil
- 4 = Electricity
- 5 = Other SPECIFY: OE171. &OE171_____
- 8 = (Refused)
- 9 = (Don't Know)

ASK OE180-OE210 IF OE017=1:

OE180. In what month and year did you change your
&EQUIP_____ equipment?
(ENTER MONTH/YEAR)
&OE180__ MONYYYY (JUN1960)

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OE181. &OE181 YYYYY (8 = Refused 9 = Don't Know)

OE190. Did you ADD TO, REMOVE, or REPLACE &EQUIP2_____ equipment?
&OE190 1 = Added--->SKIP TO OE202
2 = Replaced
3 = Added and Replaced
4 = Removed
8 = (Refused)--->SKIP TO OC010
9 = (Don't Know)--->SKIP TO OC010

OE200. What fuel was used to power the old &EQUIP_____ equipment?
&OE200
1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE201. &OE201_____

IF OE190 = 4 THEN SKIP TO OC010

OE202. What fuel does the &EQUIP_____ equipment addition use?
&OE202 1 = Natural Gas
2 = Propane or Bottled Gas
3 = Oil
4 = Electricity
5 = Other SPECIFY: OE203. &OE203_____

OC010. Since January 1992, have you made any other changes that would affect energy usage at this facility?
&OC010 1 = Yes
0 = No--->SKIP TO EM010
8 = (Refused)--->SKIP TO EM010
9 = (Don't Know)---> SKIP TO EM010

OC020. What type of changes were made?
&OC020_____
&OC021_____

OC030. In what month and year were these changes made?
(ENTER MONTH/YEAR)
&OC030__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

OC031. &OC031 YYYYY (8 = Refused 9 = Don't Know)

EM010. Do you have an in-house Energy Management System at this facility?
&EM010
1 = Yes
0 = No-->SKIP TO CP010
8 = (Refused)-->SKIP TO CP010
9 = (Don't Know)-->SKIP TO CP010

EM020. In what month and year was the Energy Management System installed?
(ENTER MONTH/YEAR)
&EM020__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

EM021. &EM021 YYYY 8 = (Refused)
9 = (Don't Know)

CP010. Do you have a cogeneration plant at this facility?
&CP010

1 = Yes
0 = No --> SKIP
8 = (Refused) --> SKIP
9 = (Don't Know) --> SKIP

CP020. In what month and year did the cogeneration plant begin operating?
(ENTER MONTH/YEAR)

&CP020__ MONYYYY

IF DOESN'T KNOW, ASK FOR BEST GUESS AND/OR YEAR

CP021. &CP021 YYYY (8 = Refused 9 = Don t Know)

Those are all of the questions I have for you at this time. Before
you go I'd like to get your job title.

USE JOB KEY TO CODE ALL:

1 = President/Owner 2 = Senior Manager
3 = Financial Manager 4 = Energy Manager
5 = Operations Manager 6 = Building Manager
7 = Other SPECIFY

DECISION TITLE CF009. Job Title: &DTITLN
SPECIFY: &DTITLOTR_____

TECHNICAL TITLE CF010. Job Title: &TTITLN
SPECIFY: &TTITLOTR_____

LIGHTING TITLE CF011. Job Title: <ITLN
SPECIFY: <ITLOTR_____

==> &DIV_COD2 <== ==> &SERVCITY <== ==> &OSFLAG <== 1 = OK OS
0 = NO OS

TO SKIP TO ON-SITE RECRUITMENT ENTER 1: MEASTYP: &MEASTYP

TO SKIP TO COMMENT FIELDS ENTER 2: BUSTYP: &BUSTYP

TO SKIP FORWARD ENTER 1 OR 2 HERE ==> &SKIP

DE1. Do you have any additional comments at this time?
&DE1 1 = Yes 0 = No 8 = (Refused) 9 = (Don't Know)

&DECOMM1_____

&DECOMM2_____

&DECOMM3_____

IF THERE ARE ANY COMMENTS ABOUT THE ANSWERS WITHIN THIS SURVEY

ENTER 1 HERE, THEN ENTER YOUR COMMENTS==> &COMM

&NOTE1_____

&NOTE2_____

&NOTE3_____

&NOTE4_____

&NOTE5_____

&NOTE6_____

IF THE RESPONDENT ASK FOR PG&E REP'S PHONE # ENTER 1, AND THEN REASON &REP

&NOTREP1

&NOTREP2

Those are all the questions I have for today. On behalf of Pacific Gas and Electric, thank you very much for your time and cooperation.

F4 TO FIRST SCREEN AND CODE RESULT

A subsample of customers who complete telephone surveys are being asked to participate in an additional on-site follow up visit. Your site has been selected for one of these follow up visits. These on-site visits provide additional data that is used to evaluate and verify the savings achieved by the new lighting equipment. Would you be interested in having one of our qualified technicians come and conduct an on-site inspection?

OS001. &OS001

1 = Respondent will continue

0 = Respondent will not continue

OS005. Are you the best person who can allow us access to physically inspect the retrofitted electrical equipment?

&OS005 1 = Yes --> SKIP TO 2nd CONTACT

0 = No

8 = (Refused)

9 = (Don't Know)

Who would be the best person who could allow us access to physically inspect the retrofitted electrical equipment?

READ CONTACTS, OR GET ADDITIONAL CONTACT INFO:

DECIS NAME: &DNAME _____
DECIS TITLE: &DTITLF _____
DECIS BUSINESS: &DBUSNAM _____
DECIS PHONE: (&DAC_) &DPRE - &DLAST Ext: &DEXT

TECH NAME: &TNAME _____
TECH TITLE: &TTITLF _____
TECH BUSINESS: &TBUSNAM _____
TECH PHONE: (&TAC_) &TPRE - &TLAST Ext: &TEXT

LIGHT NAME: &LNAME _____
LIGHT TITLE: <ITLF _____
LIGHT BUSINESS: &LBUSNAM _____
LIGHT PHONE: (&LAC_) &LPRE - &LLAST Ext: &LEXT

IF DECIS ENTER 1, ELSE IF TECH ENTER 2, ELSE IF LIGHT ENTER 3,
ELSE IF NEW ON-SITE CONTACT ENTER 4: ==> &WHOOS

ENTER INFO FOR ON-SITE CONTACT:

OS NAME: &OSNAME _____
OS BUSINESS: &OSBUSNAM _____
OS PHONE: (&OSA) &OSP - &OSL Ext: &OSEXT
OS TITLE: &OSTITLN
1 = President/Owner
2 = Senior Manager
3 = Financial Manager
4 = Energy Manager
5 = Operations Manager
6 = Building Manager
7 = Other SPECIFY: &OSTILOTR _____

ENTER 1 TO SKIP FORWARD: ==> &SKIP

Who would be an additional person who can allow us access and be knowledgeable about the electrical equipment at the facility?

READ CONTACT NAMES, IF NOT ONE OF THESE, GET ADDITIONAL CONTACT INFO:

DECIS NAME: &DNAME _____
DECIS TITLE: &DTITLF _____
DECIS BUSINESS: &DBUSNAM _____
DECIS PHONE: (&DAC) &DPRE - &DLAST Ext: &DEXT

TECH NAME: &TNAME _____
TECH TITLE: &TTITLF _____
TECH BUSINESS: &TBUSNAM _____
TECH PHONE: (&TAC) &TPRE - &TLAST Ext: &TEXT

LIGHT NAME: &LNAME _____
LIGHT TITLE: <ITLF _____
LIGHT BUSINESS: &LBUSNAM _____
LIGHT PHONE: (&LAC) &LPRE - &LLAST Ext: &LEXT

IF DECIS ENTER 1, ELSE IF TECH ENTER 2 , ELSE IF LIGHT ENTER 3
IF OTHER THAN THESE THEN ENTER 4 ==> &WHOOS2

GET SECONDARY ON-SITE CONTACT INFORMATION;

SECOND CONTACT NAME &OSNAM2_____

SECOND CONTACT BUSINESS: &OSBUSNM2_____

SECOND CONTACT PHONE: (&OA2) &OP2 - &OL2 EXT: &OSEXT2

SECOND CONTACT TITLE: &OSTITN2

1 = President/Owner

2 = Senior Manager

3 = Financial Manager

4 = Energy Manager

5 = Operations Manager

6 = Building Manager

7 = Other SPECIFY: &OSTIL2OT_____

COMMENTS: &OSCOM21_____

COMMENTS: &OSCOM22_____

ENTER 1 TO SKIP FORWARD ==> &SKIP

IF YOU WISH TO SCHEDULE AN APPOINTMENT WITH THE PERSON ON THE PHONE
ENTER 1, ELSE READ BELOW THEN ENTER 2 AND CODE OS RESULT;

==> &SKIP

Those are all of the questions I have for you at this time.
I will contact &OSNAME_____ to schedule
the on-site audit. On behalf of PG&E, thank you for your time
and cooperation.

At this time, we would like to schedule an appointment for one of
our our representatives to meet with you at your facility to
conduct the survey and inspect the building's new lighting
equipment.

OS020. Can we schedule a time now for one of our representatives
to meet with you at your facility?

&OS020 1 = Yes --> SKIP OS030

0 = No

8 = (Refused)

9 = (Don't Know)

OS045. What is the closest cross street to the facility at
&ADDRESS_____ ?

Cross Street: &XSTREET_____

ENTER 1 TO SKIP FORWARD: &SKIP

ENTER DAY: &VISDAY____ DISTRICT: &DIV_COD2
ENTER DATE: &VISDAT2____ BUSTYPE: &BUSTYPE_____
ENTER START TIME: &VISTIM1 WHO: 1 = Kevin Shovah CODE: &MAILV_____
END TIME: &VISTIM2 2 = Joe O'Mally
ENTER WHO: &VISWHO 3 = Paul William
IS THE INFORMATION CORRECT &CORR 4 = Denis Ley
USE 24HR CLOCK!!!! 1 = Yes 5 = Chuck Bennett
0 = No

I'll give you the following 800 number, should you need to reschedule or
cancel the appointment. The number is 1-800-540-7201.
If at the time of the audit, you could have a recent PG&E bill available
for the auditor, it would be very helpful.

DO NOT READ

Did the customer ask us to provide a Certificate of Insurance, or
Proof of Insurance?

&INSURE 1 = Yes 0 = No

Did the customer have any concerns about sensitive issues or processes
at their facility?

&TIPTOE 1 = Yes 0 = No

Let me just confirm this information with you:

YOUR NAME IS: &NEWNAME2_____
AT: &NEWBUS2_____
YOUR TITLE IS: &NEWTITL2_____
YOUR ADDRESS IS: &NEWADD2_____
YOUR PHONE NUMBER IS: (&N1_) &N2_ - &N3__ EXTENSION: &NEXT

OS050. Is this information correct?

&OS050 1 = Yes 0 = No 8 = (Refused) 9 = (Don't Know)

CORRECTED INFO: ENTER ALL INFORMATION

NAME: &NEWNAME5_____
BUSINESS: &NEWBUS5_____
ADDRESS: &NEWADD5_____
PHONE: (&N51) &N52 - &N53_ EXT: &NEXT5
TITLE: &NEWTITN5 SPECIFY: &NEWTIOTR_____

1 = President/Owner 2 = Senior Manager 3 = Financial Manager
4 = Energy Manager 5 = Operations Manager 6 = Building Manager
7 = Other SPECIFY

Thank you very much. I will contact &NEWNAME3_____
On behalf of Pacific Gas and Electric, thank you for your time today.
GO TO SC150 AND CODE RESULT: ALWAYS ENTER '1': &SKIP

Appendix F

FINAL PARTICIPANTS ON-SITE INSTRUMENT

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

OVERALL FACILITY CHARACTERISTICS

Sheet 1 of _____

Is this a logger site? __ <Yes/No> __

Inspector: _____

Appointment date: __ <Sched. Date> __

Appointment Time: __ <Sched. Time> __

Company name: __ <Co. Name> __

On-Site Date _____

Company Address: __ <Add & Num> __

City and Zip: __ <City & Zip> __

Contact name: __ <Sched. Contact> __

Contact title: _____

Contact phone no: __ <Sched. Phone No.> __

Alternate Contact: __ <Sched. Contact2> __

Alternate title: _____

Alternate phone no: __ <Sched. Phone No.2> __

Actual Contact: _____

Actual title: _____

Actual phone no: _____

Facility function description: __ <Bustype> __

Facility function update: __ **PD#1-1** __

PG&E account no.: __ <Acc. No.> __

Verify account no.: __ **PD#1-2** __

PG&E control no.: __ <Cntrl No.> __

Verify control no.: __ **PD#1-3** __

No. PG&E accounts for retrofit area?: __ <No. Accts> __ Verify no. acnts: __ **PD#1-4** __

PG&E cntrl 1: _____ PG&E cntrl 2: _____ PG&E cntrl 3: _____

%Retro cntrl 1: _ **PD#1-5** _ %Retro cntrl 2: _ **PD#1-6** _ %Retro cntrl 3: _ **PD#1-7** _

S.I.C. Code: __ <SIC> __ Verify SIC: __ **PD#1-8** __

No. of stories: _____ Year built _____ Total sq. ft.: _____ No. of people @ 4:00 PM: _____

Sq. ft. heated: _____ Sq. ft. air cond: _____ Sq. ft. of Retrofit: _____

Is retrofitted area heated? __ **PD#1-9** __ Is retrofitted area air conditioned? __ **PD#1-10** __

Primary function of retro. area: __ **PD#1-11** __ % of all lights retrofitted: _ **PD#1-12** _

Heating fuel: __ **PD#1-13** __

Heating system type: __ **PD#1-14** __

Cooling fuel: __ **PD#1-15** __

Cooling system type: __ **PD#1-16** __

% of retrofit on outer 15' perimeter: __ **PD#1-17** __ Economizer?: __ **PD#1-18** __

Does the facility replace all fluorescent lamps routinely (relamp)? __ **PD#1-19** __

If yes, how often does complete relamping occur? __ **PD#1-20** __ (months)

How often are burned out lamps replaced? __ **PD#1-21** __

Comments? _____

UTD = Unable to determine.

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

SCHEDULE GROUP WORKSHEET FORM

Sheet 2 of ____

Date: __**PD#2-1**__

Total tenant square footage: __**PD#2-2**__ sq. ft.

Group 2 Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 2 Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 2 Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 2 Primary Use: __**PD#2-12**__

Group 3 Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 3 Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 3 Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 3 Primary Use: __**PD#2-12**__

Group 4 Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 4 Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 4 Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 4 Primary Use: __**PD#2-12**__

Group 5 thru N Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 5 thru N Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 5 thru N Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 5 Primary Use: __**PD#2-12**__

Group 1 -- "Exit Lights" on a Twenty-Four Hour per Day Schedule

Percent of Tenant Square Footage.: __**PD#2-10**__

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

RETENTION PANEL WORKSHEET FORM

Sheet 3 of ____

Date: __**PD#3-1**__

Building Plans Secured?: __**PD#3-2**__

| # | Room Schd Descr | Use Area Grp | Count | Count <Techn Grp> <Meas Desc> <L??> <No.> Install. | Count <Techn Grp> <Meas Desc> <L??> <No.> Install. | Count <Techn Grp> <Meas Desc> <L??> <No.> |
|----|--------------------|-----------------|--------|--|--|---|
| 1 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 2 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 3 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 4 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 5 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 6 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 7 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 8 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 9 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 10 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 11 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 12 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 13 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 14 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 15 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 16 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 17 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 18 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 19 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 20 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 21 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 22 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 23 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 24 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 25 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 26 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 27 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |

Install.

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

28

_____*#3-3* *#3-4*_____

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

NEW TECHNOLOGY INSPECTION SHEET

Sheet ___ of ___

Technology Group __ <generic group>_ Measure Description: __ <specific descr.>_
 Measure Code: _____ <L??>_____ No. Inst.: __ <No.>_ Verified No.?: _**PD#0**_
 Watts per Fixture: __ <watts new>_ Fixture Location: _____ <location>_____
 Location/Measure Notes: _____

Ballast Brand: _____ **PD#1**_____ Ballast Model #: _____
 Volts: _**PD#2**_ Amps*: _**PD#3**_ Power Factor: _**PD#4**_
 Wiring: _**PD#5**_ Ballast Notes: _**PD#6**_
 No. of Ballasts/ Fixture: _**PD#7**_ Dual Switching: _**PD#8**_

Lamp Brand: _____ **PD#9**_____ Lamp Model #: _____
 Lamps Per Fixture: _**PD#10**_ Watts per Lamp: _**PD#11**_
 Lamp Type: _**PD#12**_ Lamp Notes: _**PD#13**_

Total Lamps Insp.: _____ Lamps On: _____ Lamps Off: _____
 No. of Lamps in Burned out Fixt's. _____ No. of Burned out Lamps††: _____

Instantaneous Load Meas. 1: _____ No. of Fixtures 1: _____ Power Factor 1: _**PD#4**_
 Instantaneous Load Meas. 2: _____ No. of Fixtures 2: _____ Power Factor 2: _**PD#4**_
 Instantaneous Load Meas. 3: _____ No. of Fixtures 3: _____ Power Factor 3: _**PD#4**_

% of <L??> in Schd. Group 1: _**PD#1-5**_ % of <L??> in Schd. Group 2: _**PD#1-5**_
 % of <L??> in Schd. Group 3: _**PD#1-5**_ % of <L??> in Schd. Grp 4 thru N: _**PD#1-5**_

LOGID1: _**PD#20**_ Primary Use Area: _**PD#21**_ Prim. Schd Grp: _**PD#22**_
 Date Initiated: _**PD#24**_ Hour Initiated: _**PD#25**_ Occ. Sensor?: _**PD#26**_
 Logger placement Description: _____ Floor #: _**PD#27**_

LOGID2 thru N: _**PD#20**_ Prim Use Area: _**PD#21**_ Prim Schd Grp: _**PD#22**_
 Date Initiated: _**PD#24**_ Hour Initiated: _**PD#25**_ Occ. Sensor?: _**PD#26**_
 Logger placement Description: _____ Floor #: _**PD#27**_

Additional Comments: _____

*Line amps if stated, not 430 or 460 ma lamp current.

††No. of burned out lamps must be counted separately and exclusive of burned out fixtures.

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

EXISTING TECHNOLOGY INSPECTION SHEET

Sheet ___ of ___

Technology Group __**PD#E-1**_ Measure Description: __**PD#E-2**_

More Descr: _____ Replaced?: __**PD#E-3**_

Fixture Length: __**PD#E-4**_

Location/Measure Notes: _____

Ballast Brand: _____**PD#E-5**_____ Ballast Model #: _____

Volts: __**PD#E-6**_ Amps*: __**PD#E-7**_ Power Factor: __**PD#E-8**_

Wiring: __**PD#E-9**_ Ballast Notes: __**PD#10**_

No. of Ballasts/ Fixture: __**PD#E-11**_ Dual Switching: __**PD#E-12**_

Second. Ballast: _____**PD#E-5**_____ Ballast Model #: _____

Volts: __**PD#E-6**_ Amps*: __**PD#E-7**_ Power Factor: __**PD#E-8**_

Wiring: __**PD#E-9**_ Ballast Notes: __**PD#10**_

No. of Ballasts/ Fixture: __**PD#E-11**_ Dual Switching: __**PD#E-12**_

Lamp Brand: _____**PD#E-13**_____ Lamp Model #: _____

Lamps Per Fixture: __**PD#E-14**_ Watts per Lamp: __**PD#E-15**_

Lamp Type: __**PD#E-16**_ Lamp Notes: __**PD#E-17**_

Secondary Lamp: _____**PD#E-13**_____ Lamp Model #: _____

Lamps Per Fixture: __**PD#E-14**_ Watts per Lamp: __**PD#E-15**_

Lamp Type: __**PD#E-16**_ Lamp Notes: __**PD#E-17**_

Total Lamps Insp.: _____ Lamps On: _____ Lamps Off: _____

No. of Lamps in Burned out Fixt's. _____ No. of Burned out Lamps††: _____

Instantaneous Load Meas. 1: _____ No. of Fixtures 1: _____ Power Factor 1: __**PD#4**_

Instantaneous Load Meas. 2: _____ No. of Fixtures 2: _____ Power Factor 2: __**PD#4**_

Instantaneous Load Meas. 3: _____ No. of Fixtures 3: _____ Power Factor 3: __**PD#4**_

Additional Comments: _____

*Line amps if stated, not 430 or 460 ma lamp current.

††No. of burned out lamps must be counted separately and exclusive of burned out fixtures.

Appendix G

FINAL NONPARTICIPANTS ON-SITE INSTRUMENT

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

OVERALL FACILITY CHARACTERISTICS

Sheet 1 of _____

Is this a logger site? __ <Yes/No> __

Inspector: _____

Appointment date: __ <Sched. Date> __

Appointment Time: __ <Sched. Time> __

Company name: __ <Co. Name> __

On-Site Date _____

Company Address: __ <Add & Num> __

City and Zip: __ <City & Zip> __

Contact name: __ <Sched. Contact> __

Contact title: _____

Contact phone no: __ <Sched. Phone No.> __

Alternate Contact: __ <Sched. Contact2> __

Alternate title: _____

Alternate phone no: __ <Sched. Phone No.2> __

Actual Contact: _____

Actual title: _____

Actual phone no: _____

Facility function description: __ <Bustype> __

Facility function update: __ **PD#1-1** __

PG&E account no.: __ <Acc. No.> __

Verify account no.: __ **PD#1-2** __

PG&E control no.: __ <Cntrl No.> __

Verify control no.: __ **PD#1-3** __

No. PG&E accounts for retrofit area?: __ <No. Accts> __ Verify no. acnts: __ **PD#1-4** __

PG&E cntrl 1: _____ PG&E cntrl 2: _____ PG&E cntrl 3: _____

%Retro cntrl 1: _ **PD#1-5** _ %Retro cntrl 2: _ **PD#1-6** _ %Retro cntrl 3: _ **PD#1-7** _

S.I.C. Code: __ <SIC> __ Verify SIC: __ **PD#1-8** __

No. of stories: _____ Year built _____ Total sq. ft.: _____ No. of people @ 4:00 PM: _____

Sq. ft. heated: _____ Sq. ft. air cond: _____ Sq. ft. of Retrofit: _____

Is retrofitted area heated? __ **PD#1-9** __ Is retrofitted area air conditioned? __ **PD#1-10** __

Primary function of retro. area: __ **PD#1-11** __ % of all lights retrofitted: _ **PD#1-12** _

Heating fuel: __ **PD#1-13** __

Heating system type: __ **PD#1-14** __

Cooling fuel: __ **PD#1-15** __

Cooling system type: __ **PD#1-16** __

% of retrofit on outer 15' perimeter: __ **PD#1-17** __ Economizer?: __ **PD#1-18** __

Does the facility replace all fluorescent lamps routinely (relamp)? __ **PD#1-19** __

If yes, how often does complete relamping occur? __ **PD#1-20** __ (months)

How often are burned out lamps replaced? __ **PD#1-21** __

Comments? _____

UTD = Unable to determine.

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

SCHEDULE GROUP WORKSHEET FORM

Sheet 2 of ____

Date: __**PD#2-1**__

Total tenant square footage: __**PD#2-2**__ sq. ft.

Group 2 Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 2 Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 2 Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 2 Primary Use: __**PD#2-12**__

Group 3 Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 3 Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 3 Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 3 Primary Use: __**PD#2-12**__

Group 4 Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 4 Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 4 Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 4 Primary Use: __**PD#2-12**__

Group 5 thru N Weekday Lights Sched.: From __**PD#2-3**__ to __**PD#2-4**__

Group 5 thru N Saturday Lights Sched.: From __**PD#2-5**__ to __**PD#2-6**__

Group 5 thru N Sunday Lights Sched.: From __**PD#2-7**__ to __**PD#2-8**__

Percent of Tenant Square Footage.: __**PD#2-10**__

Percent Night or Safety Lights.: __**PD#2-11**__ Group 5 Primary Use: __**PD#2-12**__

Group 1 -- "Exit Lights" on a Twenty-Four Hour per Day Schedule

Percent of Tenant Square Footage.: __**PD#2-10**__

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

RETENTION PANEL WORKSHEET FORM

Sheet 3 of ____

Date: __**PD#3-1**__

Building Plans Secured?: __**PD#3-2**__

| # | Room Schd Descr | Use Area Grp | Count | Count <Techn Grp> <Meas Desc> <L??> <No.> Install. | Count <Techn Grp> <Meas Desc> <L??> <No.> Install. | Count <Techn Grp> <Meas Desc> <L??> <No.> |
|----|--------------------|-----------------|--------|--|--|---|
| 1 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 2 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 3 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 4 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 5 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 6 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 7 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 8 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 9 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 10 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 11 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 12 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 13 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 14 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 15 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 16 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 17 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 18 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 19 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 20 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 21 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 22 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 23 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 24 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 25 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 26 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |
| 27 | _____ | *#3-3* | *#3-4* | _____ | _____ | _____ |

Install.

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

28

_____*#3-3* *#3-4*_____

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

NEW TECHNOLOGY INSPECTION SHEET

Sheet ___ of ___

Technology Group __ <generic group>_ Measure Description: __ <specific descr.>_
 Measure Code: _____ <L??>_____ No. Inst.: __ <No.>_ Verified No.?: _**PD#0**_
 Watts per Fixture: __ <watts new>_ Fixture Location: _____ <location>_____
 Location/Measure Notes: _____

Ballast Brand: _____ **PD#1**_____ Ballast Model #: _____
 Volts: _**PD#2**_ Amps*: _**PD#3**_ Power Factor: _**PD#4**_
 Wiring: _**PD#5**_ Ballast Notes: _**PD#6**_
 No. of Ballasts/ Fixture: _**PD#7**_ Dual Switching: _**PD#8**_

Lamp Brand: _____ **PD#9**_____ Lamp Model #: _____
 Lamps Per Fixture: _**PD#10**_ Watts per Lamp: _**PD#11**_
 Lamp Type: _**PD#12**_ Lamp Notes: _**PD#13**_

Total Lamps Insp.: _____ Lamps On: _____ Lamps Off: _____
 No. of Lamps in Burned out Fixt's. _____ No. of Burned out Lamps††: _____

Instantaneous Load Meas. 1: _____ No. of Fixtures 1: _____ Power Factor 1: _**PD#4**_
 Instantaneous Load Meas. 2: _____ No. of Fixtures 2: _____ Power Factor 2: _**PD#4**_
 Instantaneous Load Meas. 3: _____ No. of Fixtures 3: _____ Power Factor 3: _**PD#4**_

% of <L??> in Schd. Group 1: _**PD#1-5**_ % of <L??> in Schd. Group 2: _**PD#1-5**_
 % of <L??> in Schd. Group 3: _**PD#1-5**_ % of <L??> in Schd. Grp 4 thru N: _**PD#1-5**_

LOGID1: _**PD#20**_ Primary Use Area: _**PD#21**_ Prim. Schd Grp: _**PD#22**_
 Date Initiated: _**PD#24**_ Hour Initiated: _**PD#25**_ Occ. Sensor?: _**PD#26**_
 Logger placement Description: _____ Floor #: _**PD#27**_

LOGID2 thru N: _**PD#20**_ Prim Use Area: _**PD#21**_ Prim Schd Grp: _**PD#22**_
 Date Initiated: _**PD#24**_ Hour Initiated: _**PD#25**_ Occ. Sensor?: _**PD#26**_
 Logger placement Description: _____ Floor #: _**PD#27**_

Additional Comments: _____

*Line amps if stated, not 430 or 460 ma lamp current.

††No. of burned out lamps must be counted separately and exclusive of burned out fixtures.

PG&E COMMERCIAL AND INDUSTRIAL LIGHTING TECHNOLOGIES EVALUATION

On-site ID: _____

EXISTING TECHNOLOGY INSPECTION SHEET

Sheet ___ of ___

| | | |
|---|--------------------------------|----------------------------------|
| Technology Group __**PD#E-1**_ Measure Description: __**PD#E-2**_ | | |
| More Descr: _____ | Replaced?: __**PD#E-3**_ | |
| Fixture Length: __**PD#E-4**_ | | |
| Location/Measure Notes: _____ | | |
| | | |
| Ballast Brand: _____**PD#E-5**_ | Ballast Model #: _____ | |
| Volts: __**PD#E-6**_ | Amps*: __**PD#E-7**_ | Power Factor: __**PD#E-8**_ |
| Wiring: __**PD#E-9**_ | Ballast Notes: __**PD#10**_ | |
| No. of Ballasts/ Fixture: __**PD#E-11**_ | Dual Switching: __**PD#E-12**_ | |
| | | |
| Second. Ballast: _____**PD#E-5**_ Ballast Model #: _____ | | |
| Volts: __**PD#E-6**_ | Amps*: __**PD#E-7**_ | Power Factor: __**PD#E-8**_ |
| Wiring: __**PD#E-9**_ | Ballast Notes: __**PD#10**_ | |
| No. of Ballasts/ Fixture: __**PD#E-11**_ | Dual Switching: __**PD#E-12**_ | |
| | | |
| Lamp Brand: _____**PD#E-13**_ Lamp Model #: _____ | | |
| Lamps Per Fixture: __**PD#E-14**_ | Watts per Lamp: __**PD#E-15**_ | |
| Lamp Type: __**PD#E-16**_ | Lamp Notes: __**PD#E-17**_ | |
| | | |
| Secondary Lamp: _____**PD#E-13**_ Lamp Model #: _____ | | |
| Lamps Per Fixture: __**PD#E-14**_ | Watts per Lamp: __**PD#E-15**_ | |
| Lamp Type: __**PD#E-16**_ | Lamp Notes: __**PD#E-17**_ | |
| | | |
| Total Lamps Insp.: _____ | Lamps On: _____ | Lamps Off: _____ |
| No. of Lamps in Burned out Fixt's. _____ | | No. of Burned out Lamps††: _____ |
| | | |
| Instantaneous Load Meas. 1: _____ | No. of Fixtures 1: _____ | Power Factor 1: __**PD#4**_ |
| Instantaneous Load Meas. 2: _____ | No. of Fixtures 2: _____ | Power Factor 2: __**PD#4**_ |
| Instantaneous Load Meas. 3: _____ | No. of Fixtures 3: _____ | Power Factor 3: __**PD#4**_ |

Additional Comments: _____

*Line amps if stated, not 430 or 460 ma lamp current.

††No. of burned out lamps must be counted separately and exclusive of burned out fixtures.

Appendix H

PARTICIPANTS TELEPHONE SURVEY RESPONSE FREQUENCIES

audit OK?

| MN001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 1 | 0.2 | 1 | 0.2 |
| Yes | 468 | 99.8 | 469 | 100.0 |

Frequency Missing = 10

Own building?/Decis

| SC001D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 188 | 39.9 | 188 | 39.9 |
| Yes | 283 | 60.1 | 471 | 100.0 |

Frequency Missing = 8

Firm occupies space/Decis

| FI001D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 13 | 4.3 | 13 | 4.3 |
| Yes | 291 | 95.7 | 304 | 100.0 |

Frequency Missing = 175

Firm manages prop/Decis

| FI002D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 107 | 56.0 | 107 | 56.0 |
| Yes | 84 | 44.0 | 191 | 100.0 |

Frequency Missing = 288

Own building?/Tech

| SC001T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 15 | 41.7 | 15 | 41.7 |
| Yes | 21 | 58.3 | 36 | 100.0 |

Frequency Missing = 443

Firm occupies space/Tech

| FI001T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 1 | 4.8 | 1 | 4.8 |
| Yes | 20 | 95.2 | 21 | 100.0 |

Frequency Missing = 458

Firm manages prop/Tech

| FI002T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 9 | 56.3 | 9 | 56.3 |
| Yes | 7 | 43.8 | 16 | 100.0 |

Frequency Missing = 463

Own building?/Light

| SC001L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 2 | 25.0 | 2 | 25.0 |
| Yes | 6 | 75.0 | 8 | 100.0 |

Frequency Missing = 471

Firm occupies space/Light

| FI001L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| Yes | 6 | 100.0 | 6 | 100.0 |

Frequency Missing = 473

Firm manages prop/Light

| FI002L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| Yes | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Is there a PM firm?

| SC016 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 9 | 75.0 | 9 | 75.0 |
| Yes | 3 | 25.0 | 12 | 100.0 |

Frequency Missing = 467

Are you the sole occupant?

| FI003 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 150 | 31.8 | 150 | 31.8 |
| Yes | 322 | 68.2 | 472 | 100.0 |

Frequency Missing = 7

Is any part of building leased?

| FI004 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 35 | 17.5 | 35 | 17.5 |
| Yes | 165 | 82.5 | 200 | 100.0 |

Frequency Missing = 279

Is person decision maker

| SC003 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 7 | 1.5 | 7 | 1.5 |
| Yes | 464 | 98.5 | 471 | 100.0 |

Frequency Missing = 8

Is person Tech person

| SC005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 17 | 3.6 | 17 | 3.6 |
| Yes | 453 | 96.4 | 470 | 100.0 |

Frequency Missing = 9

Is person Light person

| SC006 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 11 | 2.3 | 11 | 2.3 |
| Yes | 461 | 97.7 | 472 | 100.0 |

Frequency Missing = 7

Date of installation - Decision Maker

| SC035 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JUL1993 | 13 | 2.8 | 13 | 2.8 |
| AUG1993 | 8 | 1.7 | 21 | 4.6 |
| SEP1993 | 10 | 2.2 | 31 | 6.8 |
| OCT1993 | 11 | 2.4 | 42 | 9.2 |
| NOV1993 | 12 | 2.6 | 54 | 11.8 |
| DEC1993 | 32 | 7.0 | 86 | 18.7 |
| JAN1994 | 23 | 5.0 | 109 | 23.7 |
| FEB1994 | 31 | 6.8 | 140 | 30.5 |
| MAR1994 | 17 | 3.7 | 157 | 34.2 |
| APR1994 | 36 | 7.8 | 193 | 42.0 |
| MAY1994 | 33 | 7.2 | 226 | 49.2 |
| JUN1994 | 54 | 11.8 | 280 | 61.0 |
| JUL1994 | 43 | 9.4 | 323 | 70.4 |
| AUG1994 | 53 | 11.5 | 376 | 81.9 |
| SEP1994 | 81 | 17.6 | 457 | 99.6 |
| DEC1994 | 2 | 0.4 | 459 | 100.0 |

Frequency Missing = 20

Date of installation - Technical

| SC037 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JUL1993 | 3 | 7.1 | 3 | 7.1 |
| OCT1993 | 1 | 2.4 | 4 | 9.5 |
| DEC1993 | 2 | 4.8 | 6 | 14.3 |
| JAN1994 | 4 | 9.5 | 10 | 23.8 |
| MAR1994 | 2 | 4.8 | 12 | 28.6 |
| APR1994 | 3 | 7.1 | 15 | 35.7 |
| MAY1994 | 4 | 9.5 | 19 | 45.2 |
| JUN1994 | 6 | 14.3 | 25 | 59.5 |
| JUL1994 | 4 | 9.5 | 29 | 69.0 |
| AUG1994 | 8 | 19.0 | 37 | 88.1 |
| SEP1994 | 5 | 11.9 | 42 | 100.0 |

Frequency Missing = 437

Date of installation - Lighting

| SC039A | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| SEP1993 | 2 | 12.5 | 2 | 12.5 |
| OCT1993 | 1 | 6.3 | 3 | 18.8 |
| DEC1993 | 1 | 6.3 | 4 | 25.0 |
| JAN1994 | 1 | 6.3 | 5 | 31.3 |
| FEB1994 | 1 | 6.3 | 6 | 37.5 |
| MAR1994 | 1 | 6.3 | 7 | 43.8 |
| APR1994 | 1 | 6.3 | 8 | 50.0 |
| MAY1994 | 1 | 6.3 | 9 | 56.3 |
| JUN1994 | 2 | 12.5 | 11 | 68.8 |
| JUL1994 | 1 | 6.3 | 12 | 75.0 |
| AUG1994 | 1 | 6.3 | 13 | 81.3 |
| SEP1994 | 3 | 18.8 | 16 | 100.0 |

Frequency Missing = 463

Single/Multiple/Portion of Building

| FI005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------------------|-----------|---------|-------------------------|-----------------------|
| One building | 325 | 73.7 | 325 | 73.7 |
| Multiple bldng | 101 | 22.9 | 426 | 96.6 |
| Portion of a bldng | 15 | 3.4 | 441 | 100.0 |

Frequency Missing = 38

Multiple accnts for addr?

| FI007 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 63 | 53.4 | 63 | 53.4 |
| Yes | 55 | 46.6 | 118 | 100.0 |

Frequency Missing = 361

Num buildings covered by address

| FI010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 1.8 | 2 | 1.8 |
| 1 | 15 | 13.2 | 17 | 14.9 |
| 2 | 23 | 20.2 | 40 | 35.1 |
| 3 | 11 | 9.6 | 51 | 44.7 |
| 4 | 4 | 3.5 | 55 | 48.2 |
| 5 | 5 | 4.4 | 60 | 52.6 |
| 6 | 3 | 2.6 | 63 | 55.3 |
| 7 | 5 | 4.4 | 68 | 59.6 |
| 8 | 5 | 4.4 | 73 | 64.0 |
| 9 | 4 | 3.5 | 77 | 67.5 |
| 10 | 3 | 2.6 | 80 | 70.2 |
| 11 | 3 | 2.6 | 83 | 72.8 |
| 12 | 3 | 2.6 | 86 | 75.4 |
| 13 | 4 | 3.5 | 90 | 78.9 |
| 14 | 4 | 3.5 | 94 | 82.5 |
| 15 | 3 | 2.6 | 97 | 85.1 |
| 16 | 2 | 1.8 | 99 | 86.8 |
| 17 | 3 | 2.6 | 102 | 89.5 |
| 18 | 3 | 2.6 | 105 | 92.1 |
| 19 | 1 | 0.9 | 106 | 93.0 |
| 20 | 1 | 0.9 | 107 | 93.9 |
| 21 | 2 | 1.8 | 109 | 95.6 |
| 22 | 3 | 2.6 | 112 | 98.2 |
| 23 | 1 | 0.9 | 113 | 99.1 |
| 37 | 1 | 0.9 | 114 | 100.0 |

Frequency Missing = 365

Separate bills for buildings?

| FI015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 85 | 85.9 | 85 | 85.9 |
| Yes | 14 | 14.1 | 99 | 100.0 |

Frequency Missing = 380

Number other firms in building

| FI025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 298 | 67.3 | 298 | 67.3 |
| 0.1 | 1 | 0.2 | 299 | 67.5 |
| 1 | 48 | 10.8 | 347 | 78.3 |
| 2 | 26 | 5.9 | 373 | 84.2 |
| 3 | 10 | 2.3 | 383 | 86.5 |
| 4 | 10 | 2.3 | 393 | 88.7 |
| 5 | 10 | 2.3 | 403 | 91.0 |
| 6 | 6 | 1.4 | 409 | 92.3 |
| 7 | 4 | 0.9 | 413 | 93.2 |
| 8 | 8 | 1.8 | 421 | 95.0 |
| 9 | 3 | 0.7 | 424 | 95.7 |
| 10 | 6 | 1.4 | 430 | 97.1 |
| 12 | 2 | 0.5 | 432 | 97.5 |
| 13 | 1 | 0.2 | 433 | 97.7 |
| 15 | 1 | 0.2 | 434 | 98.0 |
| 16 | 1 | 0.2 | 435 | 98.2 |
| 18 | 1 | 0.2 | 436 | 98.4 |
| 20 | 2 | 0.5 | 438 | 98.9 |
| 21 | 1 | 0.2 | 439 | 99.1 |
| 24 | 1 | 0.2 | 440 | 99.3 |
| 30 | 1 | 0.2 | 441 | 99.5 |
| 40 | 1 | 0.2 | 442 | 99.8 |
| 50 | 1 | 0.2 | 443 | 100.0 |

Frequency Missing = 36

Any locats of bisns part n RE/CI

| BC021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 226 | 52.8 | 226 | 52.8 |
| 1 | 58 | 13.6 | 284 | 66.4 |
| 2 | 29 | 6.8 | 313 | 73.1 |
| 3 | 15 | 3.5 | 328 | 76.6 |
| 4 | 7 | 1.6 | 335 | 78.3 |
| 5 | 9 | 2.1 | 344 | 80.4 |
| 7 | 4 | 0.9 | 348 | 81.3 |
| 8 | 1 | 0.2 | 349 | 81.5 |
| 9 | 2 | 0.5 | 351 | 82.0 |
| 10 | 1 | 0.2 | 352 | 82.2 |
| 11 | 7 | 1.6 | 359 | 83.9 |
| 12 | 2 | 0.5 | 361 | 84.3 |
| 13 | 2 | 0.5 | 363 | 84.8 |
| 14 | 1 | 0.2 | 364 | 85.0 |
| 16 | 2 | 0.5 | 366 | 85.5 |
| 17 | 13 | 3.0 | 379 | 88.6 |
| 18 | 18 | 4.2 | 397 | 92.8 |
| 20 | 10 | 2.3 | 407 | 95.1 |
| 25 | 7 | 1.6 | 414 | 96.7 |
| 29 | 1 | 0.2 | 415 | 97.0 |
| 43 | 9 | 2.1 | 424 | 99.1 |
| 1000 | 4 | 0.9 | 428 | 100.0 |

Frequency Missing = 51

Number people currently employed

| EI010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 7 | 1.6 | 7 | 1.6 |
| 1 | 14 | 3.2 | 21 | 4.9 |
| 2 | 14 | 3.2 | 35 | 8.1 |
| 3 | 17 | 3.9 | 52 | 12.1 |
| 4 | 14 | 3.2 | 66 | 15.3 |
| 5 | 25 | 5.8 | 91 | 21.1 |
| 6 | 17 | 3.9 | 108 | 25.1 |
| 7 | 13 | 3.0 | 121 | 28.1 |
| 8 | 12 | 2.8 | 133 | 30.9 |
| 9 | 12 | 2.8 | 145 | 33.6 |
| 10 | 10 | 2.3 | 155 | 36.0 |
| 11 | 5 | 1.2 | 160 | 37.1 |
| 12 | 4 | 0.9 | 164 | 38.1 |
| 13 | 3 | 0.7 | 167 | 38.7 |
| 14 | 11 | 2.6 | 178 | 41.3 |
| 15 | 26 | 6.0 | 204 | 47.3 |
| 16 | 4 | 0.9 | 208 | 48.3 |
| 17 | 4 | 0.9 | 212 | 49.2 |
| 18 | 7 | 1.6 | 219 | 50.8 |
| 19 | 1 | 0.2 | 220 | 51.0 |
| 20 | 8 | 1.9 | 228 | 52.9 |
| 21 | 1 | 0.2 | 229 | 53.1 |
| 22 | 5 | 1.2 | 234 | 54.3 |
| 23 | 4 | 0.9 | 238 | 55.2 |
| 24 | 4 | 0.9 | 242 | 56.1 |
| 25 | 11 | 2.6 | 253 | 58.7 |
| 26 | 1 | 0.2 | 254 | 58.9 |
| 28 | 1 | 0.2 | 255 | 59.2 |
| 29 | 1 | 0.2 | 256 | 59.4 |
| 30 | 14 | 3.2 | 270 | 62.6 |
| 31 | 2 | 0.5 | 272 | 63.1 |
| 32 | 2 | 0.5 | 274 | 63.6 |
| 33 | 2 | 0.5 | 276 | 64.0 |
| 34 | 1 | 0.2 | 277 | 64.3 |
| 35 | 7 | 1.6 | 284 | 65.9 |
| 36 | 2 | 0.5 | 286 | 66.4 |
| 37 | 5 | 1.2 | 291 | 67.5 |
| 38 | 2 | 0.5 | 293 | 68.0 |
| 39 | 1 | 0.2 | 294 | 68.2 |
| 40 | 9 | 2.1 | 303 | 70.3 |
| 42 | 5 | 1.2 | 308 | 71.5 |
| 43 | 1 | 0.2 | 309 | 71.7 |
| 45 | 5 | 1.2 | 314 | 72.9 |
| 46 | 1 | 0.2 | 315 | 73.1 |
| 47 | 2 | 0.5 | 317 | 73.5 |
| 49 | 1 | 0.2 | 318 | 73.8 |
| 50 | 15 | 3.5 | 333 | 77.3 |
| 53 | 1 | 0.2 | 334 | 77.5 |
| 54 | 1 | 0.2 | 335 | 77.7 |
| 55 | 3 | 0.7 | 338 | 78.4 |

Number people currently employed

| EI010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 60 | 10 | 2.3 | 348 | 80.7 |
| 65 | 3 | 0.7 | 351 | 81.4 |
| 70 | 5 | 1.2 | 356 | 82.6 |
| 71 | 1 | 0.2 | 357 | 82.8 |
| 75 | 4 | 0.9 | 361 | 83.8 |
| 80 | 6 | 1.4 | 367 | 85.2 |
| 95 | 1 | 0.2 | 368 | 85.4 |
| 100 | 12 | 2.8 | 380 | 88.2 |
| 115 | 1 | 0.2 | 381 | 88.4 |
| 120 | 2 | 0.5 | 383 | 88.9 |
| 125 | 1 | 0.2 | 384 | 89.1 |
| 130 | 1 | 0.2 | 385 | 89.3 |
| 140 | 1 | 0.2 | 386 | 89.6 |
| 150 | 21 | 4.9 | 407 | 94.4 |
| 163 | 1 | 0.2 | 408 | 94.7 |
| 165 | 1 | 0.2 | 409 | 94.9 |
| 180 | 1 | 0.2 | 410 | 95.1 |
| 185 | 1 | 0.2 | 411 | 95.4 |
| 200 | 7 | 1.6 | 418 | 97.0 |
| 205 | 1 | 0.2 | 419 | 97.2 |
| 220 | 1 | 0.2 | 420 | 97.4 |
| 250 | 2 | 0.5 | 422 | 97.9 |
| 300 | 2 | 0.5 | 424 | 98.4 |
| 330 | 1 | 0.2 | 425 | 98.6 |
| 350 | 1 | 0.2 | 426 | 98.8 |
| 600 | 1 | 0.2 | 427 | 99.1 |
| 1000 | 2 | 0.5 | 429 | 99.5 |
| 1400 | 1 | 0.2 | 430 | 99.8 |
| 1500 | 1 | 0.2 | 431 | 100.0 |

Frequency Missing = 48

Any change in number of employees?

| EI020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 333 | 76.0 | 333 | 76.0 |
| Yes | 105 | 24.0 | 438 | 100.0 |

Frequency Missing = 41

Mon/Year of change in employees

| EI030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1992 | 1 | 2.4 | 1 | 2.4 |
| MAR1992 | 1 | 2.4 | 2 | 4.9 |
| APR1992 | 1 | 2.4 | 3 | 7.3 |
| SEP1992 | 1 | 2.4 | 4 | 9.8 |
| JAN1993 | 1 | 2.4 | 5 | 12.2 |
| JUN1993 | 3 | 7.3 | 8 | 19.5 |
| JUL1993 | 1 | 2.4 | 9 | 22.0 |
| DEC1993 | 1 | 2.4 | 10 | 24.4 |
| JAN1994 | 2 | 4.9 | 12 | 29.3 |
| FEB1994 | 1 | 2.4 | 13 | 31.7 |
| MAR1994 | 2 | 4.9 | 15 | 36.6 |
| JUL1994 | 3 | 7.3 | 18 | 43.9 |
| AUG1994 | 3 | 7.3 | 21 | 51.2 |
| SEP1994 | 5 | 12.2 | 26 | 63.4 |
| OCT1994 | 3 | 7.3 | 29 | 70.7 |
| NOV1994 | 2 | 4.9 | 31 | 75.6 |
| JAN1995 | 3 | 7.3 | 34 | 82.9 |
| FEB1995 | 1 | 2.4 | 35 | 85.4 |
| MAR1995 | 2 | 4.9 | 37 | 90.2 |
| APR1995 | 2 | 4.9 | 39 | 95.1 |
| MAY1995 | 2 | 4.9 | 41 | 100.0 |

Frequency Missing = 438

Year of change in employees

| EI031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 4 | 13.3 | 4 | 13.3 |
| 1993 | 8 | 26.7 | 12 | 40.0 |
| 1994 | 16 | 53.3 | 28 | 93.3 |
| 1995 | 2 | 6.7 | 30 | 100.0 |

Frequency Missing = 449

Number people employed B4 chng

| ----- | ----- | ----- | ----- | ----- | ----- |
|------------------|-----------|---------|-------------------------|-----------------------|-------|
| EI040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent | |
| 1 | 2 | 2.2 | 2 | 2.2 | |
| 2 | 5 | 5.4 | 7 | 7.6 | |
| 3 | 5 | 5.4 | 12 | 13.0 | |
| 4 | 5 | 5.4 | 17 | 18.5 | |
| 5 | 6 | 6.5 | 23 | 25.0 | |
| 6 | 4 | 4.3 | 27 | 29.3 | |
| 7 | 3 | 3.3 | 30 | 32.6 | |
| 8 | 3 | 3.3 | 33 | 35.9 | |
| 9 | 2 | 2.2 | 35 | 38.0 | |
| 10 | 2 | 2.2 | 37 | 40.2 | |
| 11 | 3 | 3.3 | 40 | 43.5 | |
| 12 | 2 | 2.2 | 42 | 45.7 | |
| 13 | 2 | 2.2 | 44 | 47.8 | |
| 14 | 2 | 2.2 | 46 | 50.0 | |
| 15 | 4 | 4.3 | 50 | 54.3 | |
| 16 | 1 | 1.1 | 51 | 55.4 | |
| 18 | 2 | 2.2 | 53 | 57.6 | |
| 19 | 1 | 1.1 | 54 | 58.7 | |
| 20 | 1 | 1.1 | 55 | 59.8 | |
| 22 | 6 | 6.5 | 61 | 66.3 | |
| 24 | 1 | 1.1 | 62 | 67.4 | |
| 25 | 3 | 3.3 | 65 | 70.7 | |
| 28 | 2 | 2.2 | 67 | 72.8 | |
| 30 | 3 | 3.3 | 70 | 76.1 | |
| 31 | 1 | 1.1 | 71 | 77.2 | |
| 33 | 1 | 1.1 | 72 | 78.3 | |
| 40 | 2 | 2.2 | 74 | 80.4 | |
| 45 | 1 | 1.1 | 75 | 81.5 | |
| 50 | 1 | 1.1 | 76 | 82.6 | |
| 51 | 1 | 1.1 | 77 | 83.7 | |
| 60 | 1 | 1.1 | 78 | 84.8 | |
| 65 | 1 | 1.1 | 79 | 85.9 | |
| 70 | 1 | 1.1 | 80 | 87.0 | |
| 80 | 2 | 2.2 | 82 | 89.1 | |
| 100 | 2 | 2.2 | 84 | 91.3 | |
| 112 | 1 | 1.1 | 85 | 92.4 | |
| 145 | 1 | 1.1 | 86 | 93.5 | |
| 250 | 2 | 2.2 | 88 | 95.7 | |
| 325 | 1 | 1.1 | 89 | 96.7 | |
| Season Workforce | 3 | 3.3 | 92 | 100.0 | |

Frequency Missing = 387

OBS EI041

- 1 APPROX. 50 EXTRA EMPLOYEES FOR HOLIDAYS
- 2 WINTERTIME MORE

Organizational Structure

| FI040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Chain/Multifacil | 100 | 22.4 | 100 | 22.4 |
| Franchise | 31 | 6.9 | 131 | 29.3 |
| Independant | 316 | 70.7 | 447 | 100.0 |

Frequency Missing = 32

OBS FI045

1 MAIL BOXES ETC.
2 GREAT WESTERN
3 PRIMARY PLUS
4 GREAT WESTERN
5 MASONS
6 DEPARTMENT OF INTERIOR
7 US BANK
8 US BANK
9 GREAT WESTERN
10 US BANK
11 WELLS FARGO BANK
12 US BANK
13 US BANK
14 US BANK
15 SERVICE CORP. INTERNTL
16 MOTHER LODGE HOLDING CO
17 GREAT WESTERN
18 SARATOGA BAN CORP
19 COUNTY OF SANTA BARBARA
20 CITY OF MANTECA
21 CITY OF SAN MATEO
22 CHEVRON
23 AIR TOUCH
24 UNION PACIFIC CORPORATION
25 SCOTTY RENTS INC
26 PARADISE RECR AN PARK DISTRICT.
27 MUFARRAH ENTERPRISE
28 VALU8ES INC.
29 ROLLINS LEASING CORP.
30 CARE PHARMACIES INCORPORATED
31 KUMAR JEWELERS, INC.
32 AUTO PARTS WHOLESALE
33 KAISER FOUNDATION
34 TOYS R US, INC.
35 COIT SERVICES INC.
36 BROADWAY STORES INC.
37 FUJI FILM.
38 AMERICAN LINEN
39 BROADWAY STORES INC.
40 CALIFORNIA FAIRS
41 PETCO ANIMAL SUPPLIES
42 SAFEGUARD SCIENTIFIC
43 PETROLEUM SALES INC.
44 PETCO ANIMAL SUPPLIES
45 N. CAL CON. OF 7TH DAY ADVENT.
46 FAIRFEILD SUSUIN UNIFIED SCHOOL DISTRICT
47 PRINCETON JOINT UNIFIED SCHOOLS
48 LEMORE ELEMENTARY SCHOOL DISTRICT
49 LOS LOMITAS SCHOOL DISTRICT
50 MARIPOSA COUNTY SCHOOL DIST.
51 MARIPOSA COUNTY SCHOOL DIST.
52 OAKLAND DIOCESES
53 SCHOOL DIST.

OBS FI045

54 AMERICAN STORES .
55 AMERICAN STORES .
56 AMERICAN STORES .
57 AMERICAN STORES .
58 AMERICAN STORES .
59 AMERICAN STORES .
60 AMERICAN STORES .
61 AMERICAN STORES .
62 AMERICAN STORES .
63 AMERICAN STORES .
64 AMERICAN STORES .
65 AMERICAN STORES .
66 AMERICAN STORES .
67 AMERICAN STORES .
68 AMERICAN STORES .
69 AMERICAN STORES .
70 AMERICAN STORES .
71 AMERICAN STORES .
72 WENDYS INT.
73 NATIONS FOOD SERVICE
74 NATIONS FOOD SERVICE
75 SPECTURM FOODS
76 TRANSAMERICA
77 LYONS REST.
78 WENDYS INT.
79 LYONS REST.
80 LYONS REST.
81 KASIER PERMANENTE
82 ADVENTISIT HEALTH SYSTEMS WEST.
83 ADVENTISIT HEALTH SYSTEMS WEST.
84 HILLSDALE GROUP
85 MAIN STREET ATHLETICS
86 INDEPENDENT QUALITY CARE
87 NORTHERN CAL 7 DAY ADVEN.
88 HEALTH CARE MANAGEMENT
89 CLUB CORP OF AMERICA
90 KAISER FOUNDATION
91 CHAMA INC
92 KASIER FOUNDATION HOSPITAL .
93 CATHOLIC HEALTH CARE WEST
94 GUIDE DOGS FOR THE BLIND
95 KEMPTON GROUP
96 NORCAL ELECTRIC
97 PUBLIC STORAGE MANAGEMENT INC.
98 UNITED STATES COMPANY
99 GRAYBAR ELECTRIC INC.
100 NETCO FOODS INC
101 CITY OF MANTECA

Legal Tax Status

| FI050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------|-----------|---------|-------------------------|-----------------------|
| For-Profit | 301 | 66.3 | 301 | 66.3 |
| Public | 82 | 18.1 | 383 | 84.4 |
| 501(c3)Non-profit | 71 | 15.6 | 454 | 100.0 |

Frequency Missing = 25

Tax status of parent company

| FI055 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------|-----------|---------|-------------------------|-----------------------|
| For-Profit | 70 | 72.2 | 70 | 72.2 |
| Public | 14 | 14.4 | 84 | 86.6 |
| 501(c3)Non-profit | 13 | 13.4 | 97 | 100.0 |

Frequency Missing = 382

Where are energy decisions made

| FI060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------------|-----------|---------|-------------------------|-----------------------|
| Locally on site | 331 | 72.4 | 331 | 72.4 |
| Regional head | 89 | 19.5 | 420 | 91.9 |
| National head | 22 | 4.8 | 442 | 96.7 |
| PM firm/build owner | 4 | 0.9 | 446 | 97.6 |
| Other | 4 | 0.9 | 450 | 98.5 |
| Local owner | 3 | 0.7 | 453 | 99.1 |
| Board Of Supervisors | 4 | 0.9 | 457 | 100.0 |

Frequency Missing = 22

OBS FI062

- 1 DON'T MAKE INVESTMENTS
- 2 DIST. BOARD OF DIRECTORS
- 3 H.P. SEARS& MERCHANT ASSOC TOGETHER
- 4 DISTRICT OFFICE
- 5 DIST OFFICE (UNDER REGIONAL)
- 6 MADE AT OWNER'S OFFICE
- 7 CO. BOARD OF SUPES
- 8 DEPARTMENT SITE
- 9 BOARD OF SUPERVISOR
- 10 LOCAL SCHOOL BOARD.
- 11 DEPENDS ON DIFFERNET SITUATIONS.
- 12 LOCAL NOT ON SITE.
- 13 OWNER

Fiscal 1992 revenues

| FI070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| < 50000 | 9 | 4.0 | 9 | 4.0 |
| 50000<99999 | 8 | 3.5 | 17 | 7.5 |
| 100000<249999 | 22 | 9.7 | 39 | 17.3 |
| 250000<499999 | 26 | 11.5 | 65 | 28.8 |
| 500000<999999 | 30 | 13.3 | 95 | 42.0 |
| 1 mil<2.49 mil | 27 | 11.9 | 122 | 54.0 |
| 2.5 mil<4.99 mil | 21 | 9.3 | 143 | 63.3 |
| 5 mil<9.99 mil | 13 | 5.8 | 156 | 69.0 |
| 10 mil<49.99 mil | 26 | 11.5 | 182 | 80.5 |
| >10 mil | 44 | 19.5 | 226 | 100.0 |

Frequency Missing = 253

Level of revenue

| FI075 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| Local | 159 | 70.4 | 159 | 70.4 |
| Regional | 59 | 26.1 | 218 | 96.5 |
| National | 7 | 3.1 | 225 | 99.6 |
| Worldwide | 1 | 0.4 | 226 | 100.0 |

Frequency Missing = 253

Are utilities payed thru lease?

| FI080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|-------------------------|-----------------------|
| All included | 53 | 26.8 | 53 | 26.8 |
| Some included | 14 | 7.1 | 67 | 33.8 |
| All paid direct | 131 | 66.2 | 198 | 100.0 |

Frequency Missing = 281

Indoor Light paid thru lease

| FI090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 5 | 41.7 | 5 | 41.7 |
| Yes | 7 | 58.3 | 12 | 100.0 |

Frequency Missing = 467

Heat paid thru lease

| FI091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 6 | 50.0 | 6 | 50.0 |
| Yes | 6 | 50.0 | 12 | 100.0 |

Frequency Missing = 467

Ventilation paid thru lease

| FI092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 6 | 54.5 | 6 | 54.5 |
| Yes | 5 | 45.5 | 11 | 100.0 |

Frequency Missing = 468

Elec to outlets paid thru lease

| FI093 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 6 | 50.0 | 6 | 50.0 |
| Yes | 6 | 50.0 | 12 | 100.0 |

Frequency Missing = 467

Cooking paid thru lease

| FI094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 10 | 83.3 | 10 | 83.3 |
| Yes | 2 | 16.7 | 12 | 100.0 |

Frequency Missing = 467

Outdoor Light paid thru lease

| FI095 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 4 | 30.8 | 4 | 30.8 |
| Yes | 9 | 69.2 | 13 | 100.0 |

Frequency Missing = 466

Cooling paid thru lease

| FI096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 7 | 58.3 | 7 | 58.3 |
| Yes | 5 | 41.7 | 12 | 100.0 |

Frequency Missing = 467

H2O heat paid thru lease

| FI097 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 6 | 50.0 | 6 | 50.0 |
| Yes | 6 | 50.0 | 12 | 100.0 |

Frequency Missing = 467

Refridgeration paid thru lease

| FI098 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 8 | 66.7 | 8 | 66.7 |
| Yes | 4 | 33.3 | 12 | 100.0 |

Frequency Missing = 467

Other paid thru lease

| FI099 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 12 | 92.3 | 12 | 92.3 |
| Yes | 1 | 7.7 | 13 | 100.0 |

Frequency Missing = 466

OBS

FI100

- 1 VARIES BY TENANT.
- 2 COMMON AREA LIGHTING

Length of current lease

| FI110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 31 | 18.9 | 31 | 18.9 |
| 1 | 8 | 4.9 | 39 | 23.8 |
| 1.5 | 1 | 0.6 | 40 | 24.4 |
| 2 | 8 | 4.9 | 48 | 29.3 |
| 3 | 10 | 6.1 | 58 | 35.4 |
| 5 | 54 | 32.9 | 112 | 68.3 |
| 7 | 4 | 2.4 | 116 | 70.7 |
| 8 | 1 | 0.6 | 117 | 71.3 |
| 8.5 | 1 | 0.6 | 118 | 72.0 |
| 9 | 1 | 0.6 | 119 | 72.6 |
| 10 | 28 | 17.1 | 147 | 89.6 |
| 12 | 1 | 0.6 | 148 | 90.2 |
| 15 | 3 | 1.8 | 151 | 92.1 |
| 20 | 6 | 3.7 | 157 | 95.7 |
| 22 | 2 | 1.2 | 159 | 97.0 |
| 25 | 1 | 0.6 | 160 | 97.6 |
| 30 | 1 | 0.6 | 161 | 98.2 |
| 40 | 1 | 0.6 | 162 | 98.8 |
| 60 | 1 | 0.6 | 163 | 99.4 |
| 74 | 1 | 0.6 | 164 | 100.0 |

Frequency Missing = 315

Years left on lease

| FI115 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 45 | 29.4 | 45 | 29.4 |
| 0.5 | 2 | 1.3 | 47 | 30.7 |
| 1 | 10 | 6.5 | 57 | 37.3 |
| 1.5 | 1 | 0.7 | 58 | 37.9 |
| 2 | 24 | 15.7 | 82 | 53.6 |
| 3 | 13 | 8.5 | 95 | 62.1 |
| 4 | 13 | 8.5 | 108 | 70.6 |
| 5 | 14 | 9.2 | 122 | 79.7 |
| 7 | 6 | 3.9 | 128 | 83.7 |
| 7.5 | 2 | 1.3 | 130 | 85.0 |
| 8 | 5 | 3.3 | 135 | 88.2 |
| 9 | 3 | 2.0 | 138 | 90.2 |
| 10 | 3 | 2.0 | 141 | 92.2 |
| 12 | 1 | 0.7 | 142 | 92.8 |
| 14 | 2 | 1.3 | 144 | 94.1 |
| 15 | 3 | 2.0 | 147 | 96.1 |
| 18 | 2 | 1.3 | 149 | 97.4 |
| 19 | 2 | 1.3 | 151 | 98.7 |
| 24 | 1 | 0.7 | 152 | 99.3 |
| 60 | 1 | 0.7 | 153 | 100.0 |

Frequency Missing = 326

Is it first lease?

| FI120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 95 | 54.6 | 95 | 54.6 |
| Yes | 79 | 45.4 | 174 | 100.0 |

Frequency Missing = 305

Have a regular light contr?

| IS001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 303 | 65.9 | 303 | 65.9 |
| Yes | 157 | 34.1 | 460 | 100.0 |

Frequency Missing = 19

Reg Light Contr inform bout prog?

| IS002 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 65 | 42.8 | 65 | 42.8 |
| Yes | 87 | 57.2 | 152 | 100.0 |

Frequency Missing = 327

How first learned of Prog

| IS010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------------|-----------|---------|-------------------------|-----------------------|
| Resp aproch vendor | 17 | 3.9 | 17 | 3.9 |
| Resp aproch PG&E | 11 | 2.5 | 28 | 6.4 |
| Contd by acct rep | 147 | 33.5 | 175 | 39.9 |
| Contd by lit cont | 82 | 18.7 | 257 | 58.5 |
| Contd by elec cont | 31 | 7.1 | 288 | 65.6 |
| Brochure n mail | 49 | 11.2 | 337 | 76.8 |
| Bill insert | 3 | 0.7 | 340 | 77.4 |
| Word of mouth in org | 27 | 6.2 | 367 | 83.6 |
| Word of mouth out org | 58 | 13.2 | 425 | 96.8 |
| TV/Radio/News | 3 | 0.7 | 428 | 97.5 |
| Other | 11 | 2.5 | 439 | 100.0 |

Frequency Missing = 40

OBS IS020

1 BY MEANS OF HIS JOB-ESI ENERGY SY
2 CONTRACTOR
3 TRIBAL GRANT
4 NATIONAL OFFICE
5 NATIONAL OFFICE
6 VARIES, PO WATCHES FOR PROGRAMS
7 NATIONAL OFFICE
8 NATIONAL OFFICE
9 NATIONAL OFFICE
10 NATIONAL OFFICE
11 WORKSHOP IN CONCORD
12 THROUGH A CUSTOMER
13 CLIENT IN THE FIRM NOTIFIED
14 COMPANY SUGESSTED IT
15 TRADE MAGAZINES
16 ELECTRICAL SUPPLIER
17 TRADE MAGAZINES
18 PCIFIC UTILITIESM CONSULTANTS
19 ENERGY MASTERS CO.
20 ENERGY MASTERS CO.
21 ENERGY MASTERS CO.
22 KNEW ABOUT IT
23 ENERGY MASTERS CO.
24 GRAINGER /BILL HEALD
25 GENERAL CONTRACTOR
26 ENERGY MASTERS CO.
27 ENERGY MASTERS CO.
28 GENERAL CONTRACTOR
29 GENERAL CONTRACTOR
30 STATE BULLETEN
31 GENERAL CONTRACTOR
32 STATE BULLETEN
33 GENERAL CONTRACTOR
34 GENERAL CONTRACTOR
35 GENERAL CONTRACTOR
36 ENERGY MASTERS CO.
37 ENERGY MASTERS CO.
38 ENERGY MASTER/ENERGY CONSULTANTS
39 ENERGY MASTERS CO.
40 PG&E INTERNS(?)
41 ELECTRICIANS RECOMMENDED IT
42 REC'D A FLYER IN MAIL...
43 PACIFIC ENERGY CENTER
44 PACIFIC ENERGY CENTER
45 DONE AS GENERAL IMPROVEMENT
46 LIGHTBULB SALESPERSON
47 SELL THE LIGHTING EQUIPMENT
48 HE IS PROMOTER OF PROGRAM

Firm Part in any PG&E prog?

| PP010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| No | 276 | 61.6 | 276 | 61.6 |
| Yes | 170 | 37.9 | 446 | 99.6 |
| Not aware others | 2 | 0.4 | 448 | 100.0 |

Frequency Missing = 31

Year firm part in PG_E prog

| PP020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1982 | 2 | 1.4 | 2 | 1.4 |
| 1984 | 5 | 3.5 | 7 | 4.9 |
| 1985 | 2 | 1.4 | 9 | 6.3 |
| 1987 | 1 | 0.7 | 10 | 7.0 |
| 1988 | 1 | 0.7 | 11 | 7.7 |
| 1989 | 11 | 7.7 | 22 | 15.4 |
| 1990 | 9 | 6.3 | 31 | 21.7 |
| 1991 | 23 | 16.1 | 54 | 37.8 |
| 1992 | 14 | 9.8 | 68 | 47.6 |
| 1993 | 22 | 15.4 | 90 | 62.9 |
| 1994 | 28 | 19.6 | 118 | 82.5 |
| 1995 | 25 | 17.5 | 143 | 100.0 |

Frequency Missing = 336

No delays with retro project

| DS019 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 55 | 12.2 | 55 | 12.2 |
| 1 | 397 | 87.8 | 452 | 100.0 |

Frequency Missing = 27

Equipment supply probs

| DS020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 40 | 57.1 | 40 | 57.1 |
| 1 | 30 | 42.9 | 70 | 100.0 |

Frequency Missing = 409

Contractor delays

| DS021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 57 | 83.8 | 57 | 83.8 |
| 1 | 11 | 16.2 | 68 | 100.0 |

Frequency Missing = 411

Financial limitations

| DS022 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 63 | 94.0 | 63 | 94.0 |
| 1 | 4 | 6.0 | 67 | 100.0 |

Frequency Missing = 412

Delays within the organization

| DS023 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 60 | 85.7 | 60 | 85.7 |
| 1 | 10 | 14.3 | 70 | 100.0 |

Frequency Missing = 409

Decided to spend money on something else

| DS024 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 69 | 100.0 | 69 | 100.0 |

Frequency Missing = 410

Other delay

| DS025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 63 | 88.7 | 63 | 88.7 |
| 1 | 8 | 11.3 | 71 | 100.0 |

Frequency Missing = 408

OBS DS026

- 1 WEATHER
- 2 COMMUNICATION PROBLEMS
- 3 WEATHER
- 4 COMMUNICATION DELAY
- 5 WEATHER
- 6 WEATHER
- 7 COMPLICATIONS
- 8 DELIVERY OF EQUIP.
- 9 REBATES WERE DELAYED 2-3 MONTHS

Weather complications

| DS027 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 475

Choose same equipment if buying again?

| SR080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 45 | 10.1 | 45 | 10.1 |
| Yes | 400 | 89.9 | 445 | 100.0 |

Frequency Missing = 34

Reason for choosing other equipment

| SR090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------------|-----------|---------|-------------------------|-----------------------|
| incrs quality lighting | 8 | 17.4 | 8 | 17.4 |
| elmnat ballst fallout | 10 | 21.7 | 18 | 39.1 |
| other | 12 | 26.1 | 30 | 65.2 |
| incrs general equip | 6 | 13.0 | 36 | 78.3 |
| cheaper equipment | 10 | 21.7 | 46 | 100.0 |

Frequency Missing = 433

OBS SR091

- 1 QUALITY OF EQUIPMENT
- 2 COST
- 3 HIGH MAINTENANC4E
- 4 NO COVERS ON LIGHTS
- 5 NOT GETTING CREDIT
- 6 LEAVE THE WAY IT WAS
- 7 EARLY BURN OUT OF LAMPS
- 8 WOULD NOT SELECT OTHER EQ
- 9 WOULD HAVE RETROFIT MORE
- 10 DIDN'T SAVE ANY MONEY
- 11 DIFF. FOR PAINT SHOP
- 12 FLIMSY EQUIPMENT, FAILURE
- 13 ECO.OF SCREW IN REPLACEME
- 14 ECO.OF SCREW IN REPLACEME
- 15 ECO.OF SCREW IN REPLACEME
- 16 ECO.OF SCREW IN REPLACEME
- 17 ECO.OF SCREW IN REPLACEME
- 18 ECO.OF SCREW IN REPLACEME
- 19 ECO.OF SCREW IN REPLACEME
- 20 ECO.OF SCREW IN REPLACEME
- 21 NEW EQUIP BETTER
- 22 ECO.OF SCREW IN REPLACEME
- 23 EASILY STOLEN
- 24 NOT AS DEPENDABLE
- 25 THERE IS BETTER EQUIPMENT
- 26 THERE IS BETTER EQUIPMENT
- 27 TOO EXPENSIVE
- 28 MORE CONSER.CHOICE

Altered energy use since retrofit?

| EA010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 374 | 83.7 | 374 | 83.7 |
| Yes | 73 | 16.3 | 447 | 100.0 |

Frequency Missing = 32

Turning on fewer lights

| EA020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 41 | 68.3 | 41 | 68.3 |
| 1 | 19 | 31.7 | 60 | 100.0 |

Frequency Missing = 419

Running HVAC less

| EA021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 55 | 94.8 | 55 | 94.8 |
| 1 | 3 | 5.2 | 58 | 100.0 |

Frequency Missing = 421

Decreased lighting hours

| EA022 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 50 | 80.6 | 50 | 80.6 |
| 1 | 12 | 19.4 | 62 | 100.0 |

Frequency Missing = 417

Energy change other1

| EA023 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 27 | 38.0 | 27 | 38.0 |
| 1 | 44 | 62.0 | 71 | 100.0 |

Frequency Missing = 408

OBS EA024

1 TRYING TO CAREFUL ON USEAGE
2 NEW METER
3 REMOVED REFRIGERATION
4 USING LESS ENERGY
5 BILL AND USAGE INCREASED
6 HAD TO ISTALL MORE LIGHTS
7 MOTION DETECTION
8 COMP ENERGY MGT SYSTEM
9 LIGHTS INSTALLED ARE MORE EFFICIEN
10 INCREASED LIGHTING HOURS
11 INCREASED LIGHTING HOURS
12 PUTTING IN NEW LIGHTS
13 INSTALLED MOYTON SENSORS
14 INSTALLED SKYLIGHTS
15 NEW MOTORS ARE NOW EFFICIENT
16 INSTALLED CONVEYER SYSTEM
17 MOTION DET. ALOW LESS LIGHT AND TI
18 MORE LIGHTING HOURS
19 TIME CLOCKS USED
20 REDUCED HOURS
21 TIME CLOCKS USED
22 TIMERS FOR LIGHT TURN ON
23 TIME CLOCKS USED
24 TIME CLOCKS USED
25 TIME CLOCKS USED
26 TIME CLOCKS USED
27 TIME CLOCKS USED
28 TIME CLOCKS USED
29 TIME CLOCKS USED
30 TIME CLOCKS USED
31 TIME CLOCKS USED
32 TIME CLOCKS USED
33 ADDED MORE LIGHTING
34 MOTION DET. ALOW LESS LIGHT AND TI
35 TIME CLOCKS USED
36 INSTALLED AC FOR THE FIRST TIME WH
37 ENERGY MAN. SYS. INSTALLED
38 INSTALLED MOYTON SENSORS
39 MORE ENERGY CONSERVATION
40 DECREASED UTILITY BILLS
41 USING MORE LIGHTING HOURS BECAUSE
42 MORE LIGHTING
43 CUT DOWN LIGHTING HRS W\BROODER
44 INSTALLATION OF OCCUPANCY SENSORS
45 INSTALLED LESS EFFICIENT REFRIGERA

Energy change other2

| EA025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 57 | 86.4 | 57 | 86.4 |
| 1 | 9 | 13.6 | 66 | 100.0 |

Frequency Missing = 413

OBS EA026

- 1 " " " NUMBER OF LIGHTS IN USE.
- 2 INSTALLED TIMERS FOR LIGHTS
- 3 HEAT/AIR COND. PUT ON AUTOMATIC.
- 4 LINKED LIGHTS TO MOTION SENSORS
- 5 ME OF OPER. NEW ELECTRONIC THERM.
- 6 ME OF OPER. NEW ELECTRONIC THERM.
- 7 WHEN RETRO WAS DONE
- 8 OF TIMING OVERLAP W/INCREASING DAY
- 9 ADDED 16 HVAC UNITS
- 10 TION

Energy change other3

| EA027 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 63 | 98.4 | 63 | 98.4 |
| 1 | 1 | 1.6 | 64 | 100.0 |

Frequency Missing = 415

OBS EA028

- 1 LIGHT

Energy change other4

| EA029 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 69 | 98.6 | 69 | 98.6 |
| 1 | 1 | 1.4 | 70 | 100.0 |

Frequency Missing = 409

OBS EA030

1 ADDED OTHER EQUIP.

Added equipment

| EA031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 5 | 100.0 | 5 | 100.0 |

Frequency Missing = 474

More hours

| EA032 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 7 | 100.0 | 7 | 100.0 |

Frequency Missing = 472

Control devices

| EA033 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 19 | 100.0 | 19 | 100.0 |

Frequency Missing = 460

General conservation

| EA045 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 475

Most important changeout factor

| PD010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------------------|-----------|---------|-------------------------|-----------------------|
| Get latest tech | 19 | 4.2 | 19 | 4.2 |
| Save \$ on bills | 276 | 60.7 | 295 | 64.8 |
| Get rebate | 37 | 8.1 | 332 | 73.0 |
| Replc old/brokn | 20 | 4.4 | 352 | 77.4 |
| Imprv qual lite | 50 | 11.0 | 402 | 88.4 |
| Help protct environ | 7 | 1.5 | 409 | 89.9 |
| Prev prog expern | 1 | 0.2 | 410 | 90.1 |
| Obtn Advce act r | 1 | 0.2 | 411 | 90.3 |
| Other | 11 | 2.4 | 422 | 92.7 |
| Energy Effiecienc | 7 | 1.5 | 429 | 94.3 |
| New Lighting Qua | 13 | 2.9 | 442 | 97.1 |
| Short Payback Pe | 3 | 0.7 | 445 | 97.8 |
| Attractive Finan | 1 | 0.2 | 446 | 98.0 |
| Combination | 9 | 2.0 | 455 | 100.0 |

Frequency Missing = 24

OBS PD011

1 DURIBILITY OF FIXUTRES
2 LOOKING FOR TAMPER RESISTENCE EQU
3 PAYBACK PERIOD/ MONEY
4 GOOD TIMING NEEDED THE WORK
5 EASE OF MAINTENANCE
6 COULD PAY W/SAVINGS
7 2,3,5
8 2,3,5
9 HAD ALREADY PURCHASED EQUIP PRIOR
10 2,3,5
11 2,3,5
12 COMBINATION OF 2,3, 6
13 HIGHEST RATE OF PAYBACK
14 ALL OF THE ABOVE
15 COMBINATION 2,4
16 UPGRADING TO NEW TECHNOLOGY
17 SECURITY
18 ENERGY CONSERVATION
19 REDUCE HEAT IN THE STORE
20 TO LIGHT UP THE LOT
21 IT WAS A GOOD SAFETY DECISION
22 COST OF INSTALLATION
23 BETTER STORE APPEREANCE
24 MAKING THE LIGHTING EFFICIENT
25 CHEAP INSTALLATION & REBATE
26 THE REBATES
27 WANTED TO IMPROVE LIGHTING
28 SAVE MONEY & HAVE GOOD LIGHTS
29 ADVICE FROM PG&E
30 MOST RELIABLE EQUIP.
31 LOW INTEREST LOAN
32 SAVING ENERGY
33 LOGEVITY AND QUALITY
34 MOST RELIABLE EQUIP.
35 LOGEVITY AND QUALITY
36 LOGEVITY AND QUALITY
37 LOGEVITY AND QUALITY
38 LOGEVITY AND QUALITY
39 LOGEVITY AND QUALITY
40 LOGEVITY AND QUALITY
41 ENERGY EFF.
42 ENERGY EFF.
43 MORE ENERGY EFFICIENT
44 FINANCING & REBATE
45 CONFIDENCE IN CONTRACTOR
46 RELIABILITY OF THE PRODUCT.
47 ENERGY EFFICIENT
48 OBTAINING INSTANT START FLOUR.
49 OBTAINING INSTANT START FLOUR.
50 SAVE MONEY AND IMPROVE LIGHT
51 RELIBILITY OF LIGHTING
52 QUALITY OF PRODUCT
53 HIGHEST RATE OF PAYBACK

Didn't do prior/Lack \$

| FR100 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 327 | 74.0 | 327 | 74.0 |
| Yes | 115 | 26.0 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/payback not enuf

| FR101 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 418 | 94.6 | 418 | 94.6 |
| Yes | 24 | 5.4 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/not save as much

| FR102 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 435 | 98.4 | 435 | 98.4 |
| Yes | 7 | 1.6 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/unaware about EE light

| FR103 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 303 | 68.6 | 303 | 68.6 |
| Yes | 139 | 31.4 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/didn't know where/how

| FR104 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 417 | 94.3 | 417 | 94.3 |
| Yes | 25 | 5.7 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/hadn't had time

| FR105 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 422 | 95.5 | 422 | 95.5 |
| Yes | 20 | 4.5 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/concern w/ bright

| FR106 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 434 | 98.2 | 434 | 98.2 |
| Yes | 8 | 1.8 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/tenants didn't want

| FR107 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 437 | 98.9 | 437 | 98.9 |
| Yes | 5 | 1.1 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/decision made elsewhere

| FR108 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 440 | 99.3 | 440 | 99.3 |
| Yes | 3 | 0.7 | 443 | 100.0 |

Frequency Missing = 36

Didn't do prior/was planning to do

| FR109 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 438 | 99.1 | 438 | 99.1 |
| Yes | 4 | 0.9 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/2 part 2 big a hassle

| FR110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 395 | 89.4 | 395 | 89.4 |
| Yes | 47 | 10.6 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/just remodeled

| FR111 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 435 | 98.4 | 435 | 98.4 |
| Yes | 7 | 1.6 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/moving soon

| FR112 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 431 | 97.5 | 431 | 97.5 |
| Yes | 11 | 2.5 | 442 | 100.0 |

Frequency Missing = 37

Didn't do prior/did it <5 years ago

| FR113 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 441 | 100.0 | 441 | 100.0 |

Frequency Missing = 38

Didn't do prior/Other specified

| FR114 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 365 | 82.6 | 365 | 82.6 |
| Yes | 77 | 17.4 | 442 | 100.0 |

Frequency Missing = 37

OBS FR115

1 WAS NOT AT THIS OFFICE YET
2 INVEST IN ORDER TO SAVE
3 HADN'T HEARD ABOUT IT
4 NEEDED TO UPGRADE
5 NEEDED TO UPGRADE
6 NEVER HEARD OF IT
7 LOWERD CEILING SO NEEDED NEW
8 REPLACING BALLASTS
9 TOO EXPENSIVE
10 OTHER SYSTEM WAS OK
11 NEEDED TO UPGRADE
12 GOT TIRED OF OLD EQUIPMENT
13 NEEDED TO UPGRADE
14 CO. BUERACRACY
15 IT IS A NEW BUILDING
16 WOULD NOT BE COST EFFECTIVE
17 CONCERNED WITH QUALITY OF BA
18 0
19 DIDN'T KNOW SHE COULD
20 1
21 UNHELPFUL PEOPLE AT OTHER CO
22 DDID NOT KNOW OF THE PROGRAM
23 OLD BLDNG ,NOT KNOW CAN DO
24 NEVER HEARD OF PROGRAM
25 WAS EXPENSIVE AT THE TIME
26 NEVER THOUGHT ABOUT IT
27 DIDN'T THINK ABOUT IT
28 DID NOT KNOW ABOUT PROGRAM
29 BLDNG TOO OLD
30 DID NOT OF REBATE
31 NEVER OFFERED
32 NOT ENOUGH INCENTIVE/TIME
33 0
34 IMPROVEMENT ON IMPROVEMENT
35 LIGHTING IS DIFFERENT
36 DID NOT KNOW ABOUT PROGRAM
37 CONSTANTLY UPDATING FOR EE
38 DID NOT KNOW ABOUT REBATES
39 DID NOT KNOW ABOUT PROGRAM
40 OLD BUILDING AND WASN'T OPT.
41 HE HAD NEVER HEARD OF IT
42 CASH FLOW PROBLEM
43 0
44 ALWAYS GROUP RELAMP
45 ALWAYS GROUP RELAMP
46 ALWAYS GROUP RELAMP
47 ALWAYS GROUP RELAMP
48 ALWAYS GROUP RELAMP
49 ALWAYS GROUP RELAMP
50 ALWAYS GROUP RELAMP
51 ALWAYS GROUP RELAMP
52 ALWAYS GROUP RELAMP
53 ALWAYS GROUP RELAMP

OBS FR115

54 ALWAYS GROUP RELAMP
55 ALWAYS GROUP RELAMP
56 ALWAYS GROUP RELAMP
57 ALWAYS GROUP RELAMP
58 ALWAYS GROUP RELAMP
59 ALWAYS GROUP RELAMP
60 ALWAYS GROUP RELAMP
61 ALWAYS GROUP RELAMP
62 NOTHING AVAILABLE
63 MORE E.E.
64 MORE E.E.
65 WAS NOT AWARE OF ANY PRO.
66 NO SPECIAL REASON
67 MATURE INDUSTRY
68 WASN'T AWARE OF PROGRAM
69 GOV WOULD REQ.
70 WASN'T REQUIRED
71 PRODUCT REFINED AND RELIABL
72 EQUIPMENT COSTS A LOT OF \$
73 DID IT BEFORE PROGRAM TOO
74 0
75 POSSIBLY WAS MOVING
76 0
77 WEREN'T AWARE OF REBATE
78 NEVER HEARD OF THE PROGRAM
79 WORRIED ABOUTQUALITY
80 0

Didn't do prior/Refused

| FR116 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 378 | 100.0 | 378 | 100.0 |

Frequency Missing = 101

Didn't do prior/Don't Know

| FR117 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 425 | 93.2 | 425 | 93.2 |
| Yes | 31 | 6.8 | 456 | 100.0 |

Frequency Missing = 23

How long would have waited to replace?

| SR020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 7.6 | 24 | 7.6 |
| 0.5 | 1 | 0.3 | 25 | 7.9 |
| 1 | 49 | 15.5 | 74 | 23.4 |
| 2 | 36 | 11.4 | 110 | 34.8 |
| 3 | 7 | 2.2 | 117 | 37.0 |
| 4 | 4 | 1.3 | 121 | 38.3 |
| 5 | 16 | 5.1 | 137 | 43.4 |
| 7 | 3 | 0.9 | 140 | 44.3 |
| 10 | 7 | 2.2 | 147 | 46.5 |
| 15 | 4 | 1.3 | 151 | 47.8 |
| 20 | 1 | 0.3 | 152 | 48.1 |
| 777 | 164 | 51.9 | 316 | 100.0 |

Frequency Missing = 163

How long shopping for equipment?

| FR010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 336 | 78.3 | 336 | 78.3 |
| 1 | 8 | 1.9 | 344 | 80.2 |
| 2 | 3 | 0.7 | 347 | 80.9 |
| 3 | 2 | 0.5 | 349 | 81.4 |
| 4 | 14 | 3.3 | 363 | 84.6 |
| 8 | 9 | 2.1 | 372 | 86.7 |
| 12 | 8 | 1.9 | 380 | 88.6 |
| 13 | 1 | 0.2 | 381 | 88.8 |
| 15 | 1 | 0.2 | 382 | 89.0 |
| 16 | 1 | 0.2 | 383 | 89.3 |
| 20 | 1 | 0.2 | 384 | 89.5 |
| 24 | 8 | 1.9 | 392 | 91.4 |
| 25 | 1 | 0.2 | 393 | 91.6 |
| 32 | 3 | 0.7 | 396 | 92.3 |
| 48 | 1 | 0.2 | 397 | 92.5 |
| 50 | 1 | 0.2 | 398 | 92.8 |
| 52 | 14 | 3.3 | 412 | 96.0 |
| 96 | 1 | 0.2 | 413 | 96.3 |
| 98 | 1 | 0.2 | 414 | 96.5 |
| 100 | 5 | 1.2 | 419 | 97.7 |
| 150 | 9 | 2.1 | 428 | 99.8 |
| 200 | 1 | 0.2 | 429 | 100.0 |

Frequency Missing = 50

How many estimates or quotes B4 purchase

| FR011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 95 | 21.7 | 95 | 21.7 |
| 1 | 105 | 24.0 | 200 | 45.8 |
| 2 | 85 | 19.5 | 285 | 65.2 |
| 3 | 116 | 26.5 | 401 | 91.8 |
| 4 | 22 | 5.0 | 423 | 96.8 |
| 5 | 3 | 0.7 | 426 | 97.5 |
| 6 | 3 | 0.7 | 429 | 98.2 |
| 8 | 1 | 0.2 | 430 | 98.4 |
| 10 | 3 | 0.7 | 433 | 99.1 |
| 13 | 1 | 0.2 | 434 | 99.3 |
| 23 | 2 | 0.5 | 436 | 99.8 |
| 50 | 1 | 0.2 | 437 | 100.0 |

Frequency Missing = 42

Get est 4 bth high and stand eff lights?

| FR012 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 335 | 75.6 | 335 | 75.6 |
| Yes | 108 | 24.4 | 443 | 100.0 |

Frequency Missing = 36

How to purchase once aware?

| FR013 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 135 | 31.5 | 135 | 31.5 |
| 1 | 47 | 11.0 | 182 | 42.4 |
| 2 | 54 | 12.6 | 236 | 55.0 |
| 3 | 17 | 4.0 | 253 | 59.0 |
| 4 | 58 | 13.5 | 311 | 72.5 |
| 5 | 1 | 0.2 | 312 | 72.7 |
| 6 | 5 | 1.2 | 317 | 73.9 |
| 8 | 41 | 9.6 | 358 | 83.4 |
| 9 | 1 | 0.2 | 359 | 83.7 |
| 10 | 2 | 0.5 | 361 | 84.1 |
| 12 | 19 | 4.4 | 380 | 88.6 |
| 16 | 8 | 1.9 | 388 | 90.4 |
| 20 | 1 | 0.2 | 389 | 90.7 |
| 24 | 7 | 1.6 | 396 | 92.3 |
| 26 | 4 | 0.9 | 400 | 93.2 |
| 32 | 1 | 0.2 | 401 | 93.5 |
| 52 | 26 | 6.1 | 427 | 99.5 |
| 70 | 1 | 0.2 | 428 | 99.8 |
| 100 | 1 | 0.2 | 429 | 100.0 |

Frequency Missing = 50

Delay purchase to participate?

| NG019 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 421 | 93.1 | 421 | 93.1 |
| Yes | 31 | 6.9 | 452 | 100.0 |

Frequency Missing = 27

Plans prior to awareness

| FR020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Hdnt consdrd | 207 | 45.7 | 207 | 45.7 |
| Hdnt yet decd EE | 119 | 26.3 | 326 | 72.0 |
| Decd EE nt w/in | 64 | 14.1 | 390 | 86.1 |
| Decd nd selctd E | 63 | 13.9 | 453 | 100.0 |

Frequency Missing = 26

number people involved in decision

| FR014 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0.3 | 1 | 0.2 | 1 | 0.2 |
| 1 | 120 | 26.6 | 121 | 26.8 |
| 2 | 147 | 32.6 | 268 | 59.4 |
| 3 | 67 | 14.9 | 335 | 74.3 |
| 4 | 23 | 5.1 | 358 | 79.4 |
| 5 | 9 | 2.0 | 367 | 81.4 |
| 6 | 25 | 5.5 | 392 | 86.9 |
| 7 | 7 | 1.6 | 399 | 88.5 |
| 8 | 12 | 2.7 | 411 | 91.1 |
| 9 | 3 | 0.7 | 414 | 91.8 |
| 10 | 9 | 2.0 | 423 | 93.8 |
| 11 | 1 | 0.2 | 424 | 94.0 |
| 12 | 7 | 1.6 | 431 | 95.6 |
| 15 | 3 | 0.7 | 434 | 96.2 |
| 20 | 13 | 2.9 | 447 | 99.1 |
| 23 | 1 | 0.2 | 448 | 99.3 |
| 25 | 3 | 0.7 | 451 | 100.0 |

Frequency Missing = 28

Is this person final decision maker

| FR015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 192 | 41.9 | 192 | 41.9 |
| Yes | 266 | 58.1 | 458 | 100.0 |

Frequency Missing = 21

Job title of final decision maker

| FR016N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 1 | 6 | 31.6 | 6 | 31.6 |
| 7 | 13 | 68.4 | 19 | 100.0 |

Frequency Missing = 460

| OBS | FR016OTR |
|-----|--------------------------|
| 1 | BOARD |
| 2 | JOINT DECISION BY COMMIT |
| 3 | BOARD |
| 4 | BOARD |
| 5 | VP |
| 6 | BOARD |
| 7 | CEO |
| 8 | BOARD |
| 9 | CEO |
| 10 | DON'T KNOW |
| 11 | ? |
| 12 | NONE |
| 13 | CONTROLLER |

job title of final decision maker

| FR017 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------------|-----------|---------|----------------------|--------------------|
| 0 | 160 | 36.5 | 160 | 36.5 |
| 0.6999998093 | 1 | 0.2 | 161 | 36.8 |
| 1 | 100 | 22.8 | 261 | 59.6 |
| 2 | 49 | 11.2 | 310 | 70.8 |
| 3 | 15 | 3.4 | 325 | 74.2 |
| 4 | 46 | 10.5 | 371 | 84.7 |
| 6 | 4 | 0.9 | 375 | 85.6 |
| 8 | 25 | 5.7 | 400 | 91.3 |
| 12 | 18 | 4.1 | 418 | 95.4 |
| 16 | 4 | 0.9 | 422 | 96.3 |
| 20 | 1 | 0.2 | 423 | 96.6 |
| 24 | 4 | 0.9 | 427 | 97.5 |
| 26 | 3 | 0.7 | 430 | 98.2 |
| 36 | 2 | 0.5 | 432 | 98.6 |
| 52 | 4 | 0.9 | 436 | 99.5 |
| 100 | 2 | 0.5 | 438 | 100.0 |

Frequency Missing = 41

Group Relamps

| FR118 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 1 | 18 | 100.0 | 18 | 100.0 |

Frequency Missing = 461

Not Aware of Program

| FR119 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 1 | 13 | 100.0 | 13 | 100.0 |

Frequency Missing = 466

Didn't know if qualified

| FR120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

How active a role do tenants have in dec

| FI065 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Very active | 102 | 51.3 | 102 | 51.3 |
| Somewhat active | 21 | 10.6 | 123 | 61.8 |
| Slight role | 18 | 9.0 | 141 | 70.9 |
| None | 58 | 29.1 | 199 | 100.0 |

Frequency Missing = 280

Financial Criteria/Payback

| DC010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 109 | 24.5 | 109 | 24.5 |
| Yes | 335 | 75.5 | 444 | 100.0 |

Frequency Missing = 35

Financial Criteria/Internal ROR

| DC011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 337 | 76.4 | 337 | 76.4 |
| Yes | 104 | 23.6 | 441 | 100.0 |

Frequency Missing = 38

Financial Criteria/Net Pres Value

| DC012 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 381 | 86.6 | 381 | 86.6 |
| Yes | 59 | 13.4 | 440 | 100.0 |

Frequency Missing = 39

Financial Criteria/Other

| DC013 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 416 | 93.1 | 416 | 93.1 |
| Yes | 31 | 6.9 | 447 | 100.0 |

Frequency Missing = 32

OBS DC014

- 1 DONTCAREWEMAKETENANTSHAPPY
- 2 COST OF OPERATION
- 3 REBATE AND LOWER RATES
- 4 UPKEEP& SAVINGS
- 5 NONE
- 6 DONTCAREWEMAKETENANTSHAPPY
- 7 ENERGY SAVINGS
- 8 POTENTIAL SAVINGS IN FUTURE
- 9 MAINTENANCE AND COST
- 10 OPERATING COST EFFICIENCY
- 11 NEED FOR LIGHTING
- 12 HOW WELL WE ASSUME IT WILL WK
- 13 AFFORDABILITY
- 14 ENVIRONMENTAL.QUALITY, COST
- 15 LONGEVITY & EFFICIENCY
- 16 EASY TO USE, QUIET
- 17 SAVINGS ON FUTURE COSTS
- 18 EFFICIENT POWER USE
- 19 SAVINGS
- 20 SAVINGS
- 21 LOOK AT OUT OF POCKET COST
- 22 CONSERVATION
- 23 OVER ALL SAVINGS IN POWER
- 24 QUALITY COMPARISON SAMPLES
- 25 INITIAL COST OF EQUIPMENT
- 26 OVER ALL SAVINGS IN POWER
- 27 LOWER BILLS; REBATE
- 28 COST PER USE
- 29 NONE - ONLY CUSTOMER IMPACT
- 30 LABOR COST FOR REPLACEMENT
- 31 DEPENDS ON IF YOU GET MONEY

Savings

| DC015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 467

Initial cost

| DC016 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Operating cost

| DC017 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

What is payback period

| DC020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 1 yr or < | 108 | 36.1 | 108 | 36.1 |
| 2 yr or < | 80 | 26.8 | 188 | 62.9 |
| 3 yr or < | 42 | 14.0 | 230 | 76.9 |
| 4 yr or < | 13 | 4.3 | 243 | 81.3 |
| 5 yr or < | 26 | 8.7 | 269 | 90.0 |
| 7 yr or < | 6 | 2.0 | 275 | 92.0 |
| 9 yr or < | 2 | 0.7 | 277 | 92.6 |
| 10 yr or < | 13 | 4.3 | 290 | 97.0 |
| Other | 9 | 3.0 | 299 | 100.0 |

Frequency Missing = 180

OBS DC021

1 BASED ON ROI
 2 EVAL'D BY EACH PROJECT, BUT 2 YR
 3 15 YEARS OR LESS
 4 MAIN CONCERN WAS ENVIRONMENTAL
 5 NO SET STANDARD
 6 NONE
 7 NO STANDARD.
 8 NONE REQUIRED; HE DIDN'T FIGURE.
 9 DEPENDS ON SITUATION

What is IROR

| DC030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 5 | 15.2 | 5 | 15.2 |
| 1 | 1 | 3.0 | 6 | 18.2 |
| 2 | 1 | 3.0 | 7 | 21.2 |
| 3 | 2 | 6.1 | 9 | 27.3 |
| 7 | 1 | 3.0 | 10 | 30.3 |
| 10 | 1 | 3.0 | 11 | 33.3 |
| 11 | 2 | 6.1 | 13 | 39.4 |
| 12 | 2 | 6.1 | 15 | 45.5 |
| 15 | 7 | 21.2 | 22 | 66.7 |
| 17 | 1 | 3.0 | 23 | 69.7 |
| 20 | 1 | 3.0 | 24 | 72.7 |
| 25 | 2 | 6.1 | 26 | 78.8 |
| 30 | 2 | 6.1 | 28 | 84.8 |
| 40 | 1 | 3.0 | 29 | 87.9 |
| 50 | 3 | 9.1 | 32 | 97.0 |
| 100 | 1 | 3.0 | 33 | 100.0 |

Frequency Missing = 446

What is discount rate

| DC040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 11.8 | 2 | 11.8 |
| 5 | 1 | 5.9 | 3 | 17.6 |
| 6 | 1 | 5.9 | 4 | 23.5 |
| 8 | 3 | 17.6 | 7 | 41.2 |
| 10 | 2 | 11.8 | 9 | 52.9 |
| 12 | 1 | 5.9 | 10 | 58.8 |
| 15 | 4 | 23.5 | 14 | 82.4 |
| 20 | 1 | 5.9 | 15 | 88.2 |
| 25 | 1 | 5.9 | 16 | 94.1 |
| 35 | 1 | 5.9 | 17 | 100.0 |

Frequency Missing = 462

Use diff financl critera for EE vs other

| DC050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 240 | 63.2 | 240 | 63.2 |
| Yes | 140 | 36.8 | 380 | 100.0 |

Frequency Missing = 99

EE critera high/short or lower/long

| DC051 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Higher/Shorter | 66 | 59.5 | 66 | 59.5 |
| Lower/Longer | 45 | 40.5 | 111 | 100.0 |

Frequency Missing = 368

Retorft if 0 rebate/1%<prime financing

| TR030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 264 | 64.9 | 264 | 64.9 |
| Yes | 143 | 35.1 | 407 | 100.0 |

Frequency Missing = 72

Retorft if 0 rebate/1.5%<prime financing

| TR040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 240 | 91.3 | 240 | 91.3 |
| Yes | 23 | 8.7 | 263 | 100.0 |

Frequency Missing = 216

Retorft if 50% rebate/1%<prime financing

| TR050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 157 | 68.6 | 157 | 68.6 |
| Yes | 72 | 31.4 | 229 | 100.0 |

Frequency Missing = 250

Retorft if 50% rebate/on-site audit

| TR070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 139 | 34.2 | 139 | 34.2 |
| Yes | 268 | 65.8 | 407 | 100.0 |

Frequency Missing = 72

Intrstd in operate/maintain lights

| | PR020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-------|-----------|---------|-------------------------|-----------------------|
| No | | 307 | 70.3 | 307 | 70.3 |
| Yes | | 56 | 12.8 | 363 | 83.1 |
| Depends on price | | 74 | 16.9 | 437 | 100.0 |

Frequency Missing = 42

Intrstd in building recommissioning

| | PR040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-------|-----------|---------|-------------------------|-----------------------|
| No | | 128 | 29.3 | 128 | 29.3 |
| Yes | | 309 | 70.7 | 437 | 100.0 |

Frequency Missing = 42

Intrstd in future equip selection hlp

| | PR060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-------|-----------|---------|-------------------------|-----------------------|
| No | | 86 | 19.1 | 86 | 19.1 |
| Yes | | 365 | 80.9 | 451 | 100.0 |

Frequency Missing = 28

Times have contact w/ account rep

| PR001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 198 | 45.9 | 198 | 45.9 |
| 0.2 | 1 | 0.2 | 199 | 46.2 |
| 0.5 | 1 | 0.2 | 200 | 46.4 |
| 1 | 155 | 36.0 | 355 | 82.4 |
| 2 | 40 | 9.3 | 395 | 91.6 |
| 3 | 10 | 2.3 | 405 | 94.0 |
| 4 | 14 | 3.2 | 419 | 97.2 |
| 5 | 5 | 1.2 | 424 | 98.4 |
| 6 | 6 | 1.4 | 430 | 99.8 |
| 7 | 1 | 0.2 | 431 | 100.0 |

Frequency Missing = 48

time period have contact w/ account rep

| PR002 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| Never | 201 | 45.9 | 201 | 45.9 |
| Day | 9 | 2.1 | 210 | 47.9 |
| Week | 30 | 6.8 | 240 | 54.8 |
| Month | 58 | 13.2 | 298 | 68.0 |
| Year | 140 | 32.0 | 438 | 100.0 |

Frequency Missing = 41

Someone else have contact w/ acct rep

| PR005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 178 | 88.6 | 178 | 88.6 |
| Yes | 23 | 11.4 | 201 | 100.0 |

Frequency Missing = 278

Times other has contact w/ account rep

| PR010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 6.3 | 1 | 6.3 |
| 1 | 2 | 12.5 | 3 | 18.8 |
| 2 | 10 | 62.5 | 13 | 81.3 |
| 3 | 2 | 12.5 | 15 | 93.8 |
| 4 | 1 | 6.3 | 16 | 100.0 |

Frequency Missing = 463

time period othr has contct w/ acct rep

| PR011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Month | 10 | 66.7 | 10 | 66.7 |
| Year | 5 | 33.3 | 15 | 100.0 |

Frequency Missing = 464

Any other services would like

| PR090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 308 | 81.3 | 308 | 81.3 |
| Yes | 71 | 18.7 | 379 | 100.0 |

Frequency Missing = 100

Any other services would like

| PR092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 339 | 94.2 | 339 | 94.2 |
| Yes | 21 | 5.8 | 360 | 100.0 |

Frequency Missing = 119

Any other services would like

| PR094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 330 | 92.2 | 330 | 92.2 |
| Yes | 28 | 7.8 | 358 | 100.0 |

Frequency Missing = 121

OBS PR091

1 ENERGY INFO/SAVING UPDATES(NEWSLETTER)
2 LOWER RATES;
3 COME OUT AND CHECK EQUIP. TO SEE IF IT
4 INFORM ABOUT HIGH-TECH EQUIPMENT
5 SEMI ANNUAL REPORT ON EFFECIANCY
6 OTHER IDEAS ON HOW TO SAVE ENERGY
7 SEMI ANNUAL REPORT ON EFFECIANCY
8 MORE ADVERTISEMENT OF PROGRAMS
9 BETTER SERVICE AND INFORMATION IN
10 CLARIFY ENERGY AUDIT SERVICES
11 INTERESTED IN PROGRAM FOR HEATING
12 INFO RE ELEC USAGE/SQ. FT. HVAC/LIGHTS
13 SEMI ANNUAL REPORT ON EFFECIANCY
14 QUICKER RESPONSE TO DOWNED WIRES
15 SEMI ANNUAL REPORT ON EFFECIANCY
16 INTERESTED IN SIMILAR PROGRAM FOR GAS
17 RECYCLING
18 METERING UPGRADES, OR SUBMETERING
19 LOWER RATES
20 GET RID OF 800#
21 CLOSER MONITORING AND FEEDBACK OF
22 MORE INTERFACING W/CUSTOMER
23 BETTER ACCESS TO KNOWLEDGE ABOUT POWER
24 GOOD TECH. SUPPORT.
25 MORE PRE-INSTALL ADVICE ON ENERGY USIN
26 WOULD LIKE TO HAVE THE METERS CHECKED
27 COMPETITIVE PRICING
28 ADVICE ON ELECTRICAL EQUIP (HVAC)
29 RE-INSTATE LAST YEARS REBATE
30 LOWER RATES
31 WOULD LIKE FOR THEM TO CHECK
32 MORE DETAILED INFORMATION FROM PG&E
33 CONSOLIDATED BILLING FOR SAME LOCATION
34 ENGINEERING HELP IN LIGHTING
35 GET ELECTRICITY ON QUICKER WHEN IT GOE
36 ANNUAL ON-SITE AUDIT
37 FREE ELECTRICITY
38 GETTING ON SAME STREET CIRCUIT AS
39 CONTINUE SAME SERVICE
40 ANALYSIS OF WHICH RATE PLAN IS BEST
41 CLASSROOM EDUCATION
42 MAINTAIN REBATES
43 CONTINUE SAME SERVICE
44 MORE FREE HELP LIKE THE OLD DADYS
45 MORE FREE HELP LIKE THE OLD DADYS
46 MORE ON SITE AUDITS
47 CONSOLIDATE BILLING FOR ENTIRE DIST.
48 BETTER SERVICE OF THEIR AUDIT, OF ALL
49 NO ADDITIONAL FEES FOR SUGGESTED WORKS
50 LOWER RATES
51 WANTS PG&E TO BE ACCOUTABLE FOR MONEY
52 KNOW EFFICIENCY OF REFRIDERATION UNITS
53 PAY ALITTLE MORE ATTENTION TO CUSTOMER

OBS PR091

54 CHECK VOLTAGE COMING INTO BUILDING
55 KITCHEN MONITOR-BRING IT BACK
56 KITCHEN MONITOR-BRING IT BACK
57 KITCHEN MONITOR-BRING IT BACK
58 KNOWLEDGE OF TIME USE METERS AVAILABLE
59 BETTER BILLING INFO AND BUILDING DATA
60 CHECKING EFFICIENCY
61 MORE PRO-ACTIVE IN CONSERVING ENERGY
62 CONSULTANTION AS TO WHERE TO GET THE E
63 EVALUATE EQUIPMENT FOR RELIABILITY
64 METER ANALYSIS EFFICIENCY RATING OF
65 VISIT BUSINESSES AND OFFER ENERGY
66 ENERGY AUDIT AND EQUIPMENT INFO
67 LESS EXPENSIVE SERVICES
68 CONTINUE REBATE PROGRAM AS IS
69 INFARED TESTING
70 CUSTOME REBATE PROGRAM EASIER TO DEAL
71 MAKE IT EASIER ON BUSINESSES LIKE MINE

OBS PR093

1 ENERGY EFFICIENT
2 POWER OUTAGE SITUATIONS
3 AND COOLING
4 IN LAKE COUNTY, IT'S TERRIBLE.
5 POWER USAGE AND RATES
6 OUTAGES
7 DEVICES
8 TO BE SURE SHE'S NOT PAYING FOR
9 CHANGE CLOSING DATE STRUCTURE
10 SYSTEM EFFICIENCY
11 S OUT
12 OTHER BUSINESSES ON THE STREET.
13 KEEP GIVING OUT LITURATURE
14 DETAILS ABOUT THE PROGRAM
15 THEY SPEND
16 AND DOLLAR VALUE TO RUN
17 POWER EFFIENCY.
18 EQUIP TO PROTECT SMALL BUSINESSES
19 AND ANALYSES ENERGY USAGE IN ELECTRONI
20 QUIPMENT, PRICES VARY W/DIFFERENT STOR
21 MAJOR ITEMS FOR REPLACEMENT & CHANGI G
22 SAVINGS ADVICE
23 PCB TESTING
24 WITH ESPECIALLY IN REFRIGERATION
25 AND STAY A MONOPOLY DO NOT SPLIT UP

OBS PR095

- 1 CHECK THE HOMES FOR INSPECTIONS.
- 2 POST INSTALLATION BUG CORRECTION
- 3 NEIGHBOR'S ELECTRICITY
- 4 BETTER COMMUNICATION ON PROGRAM REQ
- 5 CONSOLIDATE BILLS OF ALL BUSINESS.
- 6 SMALL BU. EDUCATION OF PROGRAMS
- 7 MORE INFO ABOUT RETROFIT PROGRAM
- 8 TRAINING IN ELEC. CALCULATIONS.
- 9 TRAINING IN ELEC. CALCULATIONS.
- 10 TRAINING IN ELEC. CALCULATIONS.
- 11 TRAINING IN ELEC. CALCULATIONS.
- 12 TRAINING IN ELEC. CALCULATIONS.
- 13 TRAINING IN ELEC. CALCULATIONS.
- 14 TRAINING IN ELEC. CALCULATIONS.
- 15 TRAINING IN ELEC. CALCULATIONS.
- 16 TRAINING IN ELEC. CALCULATIONS.
- 17 TRAINING IN ELEC. CALCULATIONS.
- 18 TRAINING IN ELEC. CALCULATIONS.
- 19 TRAINING IN ELEC. CALCULATIONS.
- 20 TRAINING IN ELEC. CALCULATIONS.
- 21 TRAINING IN ELEC. CALCULATIONS.
- 22 TRAINING IN ELEC. CALCULATIONS.
- 23 TRAINING IN ELEC. CALCULATIONS.
- 24 TRAINING IN ELEC. CALCULATIONS.
- 25 TRAINING IN ELEC. CALCULATIONS.
- 26 FORMAT
- 27 ES
- 28 EQUIPMENT DECISIONS
- 29 FOLLOW UP ON REBATE PROGRAM

More EE info and energy audits

| PR096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 26 | 100.0 | 26 | 100.0 |

Frequency Missing = 453

Planning any future retrofits

| FR070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 274 | 62.8 | 274 | 62.8 |
| Yes | 162 | 37.2 | 436 | 100.0 |

Frequency Missing = 43

Future lights/high or standard EE

| FR075 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Standard EE | 3 | 2.0 | 3 | 2.0 |
| High EE | 148 | 98.0 | 151 | 100.0 |

Frequency Missing = 328

Future retrofit though program?

| FR077 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 8 | 5.3 | 8 | 5.3 |
| Yes | 144 | 94.7 | 152 | 100.0 |

Frequency Missing = 327

Future Lights/4' T-8

| FR080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 31 | 40.3 | 31 | 40.3 |
| 1 | 8 | 10.4 | 39 | 50.6 |
| 2 | 1 | 1.3 | 40 | 51.9 |
| 5 | 1 | 1.3 | 41 | 53.2 |
| 8 | 1 | 1.3 | 42 | 54.5 |
| 10 | 1 | 1.3 | 43 | 55.8 |
| 12 | 1 | 1.3 | 44 | 57.1 |
| 16 | 2 | 2.6 | 46 | 59.7 |
| 25 | 1 | 1.3 | 47 | 61.0 |
| 40 | 3 | 3.9 | 50 | 64.9 |
| 43 | 1 | 1.3 | 51 | 66.2 |
| 50 | 1 | 1.3 | 52 | 67.5 |
| 98 | 1 | 1.3 | 53 | 68.8 |
| 120 | 1 | 1.3 | 54 | 70.1 |
| 140 | 1 | 1.3 | 55 | 71.4 |
| 200 | 3 | 3.9 | 58 | 75.3 |
| 250 | 1 | 1.3 | 59 | 76.6 |
| 300 | 2 | 2.6 | 61 | 79.2 |
| 398 | 1 | 1.3 | 62 | 80.5 |
| 600 | 1 | 1.3 | 63 | 81.8 |
| 700 | 2 | 2.6 | 65 | 84.4 |
| 900 | 1 | 1.3 | 66 | 85.7 |
| 1000 | 11 | 14.3 | 77 | 100.0 |

Frequency Missing = 402

Future Lights/8' T-8

| FR081 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 84 | 89.4 | 84 | 89.4 |
| 1 | 4 | 4.3 | 88 | 93.6 |
| 12 | 2 | 2.1 | 90 | 95.7 |
| 60 | 1 | 1.1 | 91 | 96.8 |
| 200 | 1 | 1.1 | 92 | 97.9 |
| 600 | 1 | 1.1 | 93 | 98.9 |
| 1000 | 1 | 1.1 | 94 | 100.0 |

Frequency Missing = 385

Future Lights/4' ES Fluor

| FR082 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 87 | 92.6 | 87 | 92.6 |
| 9 | 1 | 1.1 | 88 | 93.6 |
| 12 | 1 | 1.1 | 89 | 94.7 |
| 20 | 1 | 1.1 | 90 | 95.7 |
| 30 | 1 | 1.1 | 91 | 96.8 |
| 50 | 1 | 1.1 | 92 | 97.9 |
| 100 | 2 | 2.1 | 94 | 100.0 |

Frequency Missing = 385

Future Lights/8' ES Fluor

| FR083 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 89 | 94.7 | 89 | 94.7 |
| 1 | 3 | 3.2 | 92 | 97.9 |
| 12 | 1 | 1.1 | 93 | 98.9 |
| 344 | 1 | 1.1 | 94 | 100.0 |

Frequency Missing = 385

Future Lights/4' T-12

| FR084 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 89 | 96.7 | 89 | 96.7 |
| 2 | 1 | 1.1 | 90 | 97.8 |
| 4 | 1 | 1.1 | 91 | 98.9 |
| 8 | 1 | 1.1 | 92 | 100.0 |

Frequency Missing = 387

Future Lights/8' T-12

| FR085 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 92 | 97.9 | 92 | 97.9 |
| 1 | 1 | 1.1 | 93 | 98.9 |
| 9 | 1 | 1.1 | 94 | 100.0 |

Frequency Missing = 385

Future Lights/Incandescent

| FR086 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 90 | 93.8 | 90 | 93.8 |
| 4 | 1 | 1.0 | 91 | 94.8 |
| 8 | 1 | 1.0 | 92 | 95.8 |
| 12 | 2 | 2.1 | 94 | 97.9 |
| 75 | 1 | 1.0 | 95 | 99.0 |
| 100 | 1 | 1.0 | 96 | 100.0 |

Frequency Missing = 383

Future Lights/Compact Fluor

| FR087 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 89 | 89.0 | 89 | 89.0 |
| 1 | 3 | 3.0 | 92 | 92.0 |
| 10 | 1 | 1.0 | 93 | 93.0 |
| 15 | 1 | 1.0 | 94 | 94.0 |
| 16 | 1 | 1.0 | 95 | 95.0 |
| 72 | 1 | 1.0 | 96 | 96.0 |
| 200 | 2 | 2.0 | 98 | 98.0 |
| 350 | 1 | 1.0 | 99 | 99.0 |
| 1000 | 1 | 1.0 | 100 | 100.0 |

Frequency Missing = 379

Future Lights/High pres sodium

| FR088 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 87 | 87.0 | 87 | 87.0 |
| 1 | 3 | 3.0 | 90 | 90.0 |
| 4 | 1 | 1.0 | 91 | 91.0 |
| 10 | 1 | 1.0 | 92 | 92.0 |
| 12 | 3 | 3.0 | 95 | 95.0 |
| 20 | 1 | 1.0 | 96 | 96.0 |
| 24 | 1 | 1.0 | 97 | 97.0 |
| 30 | 1 | 1.0 | 98 | 98.0 |
| 100 | 1 | 1.0 | 99 | 99.0 |
| 200 | 1 | 1.0 | 100 | 100.0 |

Frequency Missing = 379

Future Lights/Elec Ballasts

| FR089 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 85 | 88.5 | 85 | 88.5 |
| 1 | 1 | 1.0 | 86 | 89.6 |
| 10 | 1 | 1.0 | 87 | 90.6 |
| 30 | 1 | 1.0 | 88 | 91.7 |
| 40 | 1 | 1.0 | 89 | 92.7 |
| 120 | 2 | 2.1 | 91 | 94.8 |
| 300 | 1 | 1.0 | 92 | 95.8 |
| 700 | 1 | 1.0 | 93 | 96.9 |
| 1000 | 3 | 3.1 | 96 | 100.0 |

Frequency Missing = 383

Future Lights/Magnetic Ballasts

| FR090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 96 | 99.0 | 96 | 99.0 |
| 8 | 1 | 1.0 | 97 | 100.0 |

Frequency Missing = 382

Future Lights/Metal Halide

| FR091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 89 | 91.8 | 89 | 91.8 |
| 1 | 1 | 1.0 | 90 | 92.8 |
| 4 | 1 | 1.0 | 91 | 93.8 |
| 6 | 1 | 1.0 | 92 | 94.8 |
| 8 | 1 | 1.0 | 93 | 95.9 |
| 12 | 1 | 1.0 | 94 | 96.9 |
| 20 | 1 | 1.0 | 95 | 97.9 |
| 50 | 1 | 1.0 | 96 | 99.0 |
| 63 | 1 | 1.0 | 97 | 100.0 |

Frequency Missing = 382

Future Lights/Mercury Vapor

| FR092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 96 | 94.1 | 96 | 94.1 |
| 1 | 1 | 1.0 | 97 | 95.1 |
| 20 | 2 | 2.0 | 99 | 97.1 |
| 1000 | 3 | 2.9 | 102 | 100.0 |

Frequency Missing = 377

Future Lights/Quartz

| FR093 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 95 | 94.1 | 95 | 94.1 |
| 1 | 4 | 4.0 | 99 | 98.0 |
| 7 | 1 | 1.0 | 100 | 99.0 |
| 12 | 1 | 1.0 | 101 | 100.0 |

Frequency Missing = 378

Future Lights/Reflectors

| FR094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 98 | 98.0 | 98 | 98.0 |
| 5 | 1 | 1.0 | 99 | 99.0 |
| 398 | 1 | 1.0 | 100 | 100.0 |

Frequency Missing = 379

Future Lights/LED Exit Lights

| FR095 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 99 | 97.1 | 99 | 97.1 |
| 20 | 1 | 1.0 | 100 | 98.0 |
| 24 | 1 | 1.0 | 101 | 99.0 |
| 100 | 1 | 1.0 | 102 | 100.0 |

Frequency Missing = 377

Future Lights/Watt Saver-Power Choke

| FR096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 102 | 100.0 | 102 | 100.0 |

Frequency Missing = 377

Future Lights/Other

| FR097 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 97 | 91.5 | 97 | 91.5 |
| 1 | 6 | 5.7 | 103 | 97.2 |
| 100 | 1 | 0.9 | 104 | 98.1 |
| 500 | 2 | 1.9 | 106 | 100.0 |

Frequency Missing = 373

- | | |
|-----|-----------------------------|
| OBS | FR098 |
| 1 | PHOTOCELL CONTROL |
| 2 | EXTERIOR / PARKING LOT |
| 3 | MOTION SENSORS, 300 E\REXT. |
| 4 | HIHG PRESS. SODIUM |
| 5 | HALOGEN |
| 6 | T8 FLOUR |
| 7 | AMBIENT FLURORECENTS |
| 8 | 80 |
| 9 | MR16=2600 |
| 10 | 6-400 WATT METAL HALIDE |
| 11 | MR16=2600 |
| 12 | MR16=2600 |
| 13 | MOST RECENT ENERGY-EFFICI. |
| 14 | HIHG PRESS. SODIUM |

Future Lights/Refused

| FR099R | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 101 | 100.0 | 101 | 100.0 |

Frequency Missing = 378

Future Lights/Don't Know

| FR099D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 98 | 100.0 | 98 | 100.0 |

Frequency Missing = 381

Program satisfaction: 1-7 scale

| DS070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 2 | 5 | 1.1 | 5 | 1.1 |
| 3 | 7 | 1.5 | 12 | 2.7 |
| 4 | 14 | 3.1 | 26 | 5.8 |
| 5 | 80 | 17.7 | 106 | 23.5 |
| 6 | 152 | 33.6 | 258 | 57.1 |
| 7 | 194 | 42.9 | 452 | 100.0 |

Frequency Missing = 27

Dissatisfied for any reason?

| DS080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 381 | 84.1 | 381 | 84.1 |
| Yes | 72 | 15.9 | 453 | 100.0 |

Frequency Missing = 26

Problems with contractor

| DS081 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 49 | 76.6 | 49 | 76.6 |
| 1 | 15 | 23.4 | 64 | 100.0 |

Frequency Missing = 415

Rebate too small

| DS082 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 52 | 81.3 | 52 | 81.3 |
| 1 | 12 | 18.8 | 64 | 100.0 |

Frequency Missing = 415

Problems with equipment

| DS083 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 55 | 84.6 | 55 | 84.6 |
| 1 | 10 | 15.4 | 65 | 100.0 |

Frequency Missing = 414

Not seeing any bill savings

| DS084 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 54 | 84.4 | 54 | 84.4 |
| 1 | 10 | 15.6 | 64 | 100.0 |

Frequency Missing = 415

Unresolved problems

| DS085 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 58 | 90.6 | 58 | 90.6 |
| 1 | 6 | 9.4 | 64 | 100.0 |

Frequency Missing = 415

Problems with getting rebate

| DS086 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 55 | 84.6 | 55 | 84.6 |
| 1 | 10 | 15.4 | 65 | 100.0 |

Frequency Missing = 414

Problems with the contract rep

| DS087 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 59 | 89.4 | 59 | 89.4 |
| 1 | 7 | 10.6 | 66 | 100.0 |

Frequency Missing = 413

OBS DS088

1 MORE CONTACT W/ PGE REP
2 THOUGHT IT WAS A "REAL HASSLE"
3 CONTRACTOR TOOK TO LONG UNRELIABLE.
4 RECEIVED A QUOTE FOR REBATE, BUT FINAL REBATE WAS LESS THAN
5 DIFFICULT DUE TO COMMUNICATION BARRIERS, LOT OF QUESTIONS ASK
6 APPLICATION FORMS ARE CONFUSING
7 NEW LIGHTS INTERFERE W/ INFRA-RED REMOTES AND PG&E KEEPS
8 GETTING THE REBATE REFUNDED IN A TIMELY MANNER.
9 INCONSISTENCY OF REBATES AND SUPPORT OF PROGRAM
10 PROGRAM DIED BEFORE NEXT INSTALLATION, THERE.
11 BALLASTS ARE DEFECTIVE ON A CONTINUING BASIS.
12 UNHAPPY W/PGE REP HANDLED MISUNDERSTANDING ON CLOSING DATE
13 DIDN'T GET THE FORMS FOR REBATE OUT QUICK ENOUGH, TO THE REPS
14 0
15 LIGHTING COULD BE BRIGHTER
16 AT TIMES IT'S HARD TO KNOW WHERE TO GO TO GET INFO
17 GOT DOUBLE REBATE AMOUNT, HAD TO HAVE OVERAGE SENT BACK.
18 INSUFFICIENT "COVERAGE": TOO MANY RESTRICTIONS...
19 POOR PLANNING AND ATTN. TO DETAIL
20 POOR PLANNING AND ATTN. TO DETAIL
21 POOR PLANNING AND ATTN. TO DETAIL
22 SALES PERSON WAS WRONG ABOUT REPLACEMENT COSTS COST US MONEY
23 POOR SENSOR DOES NOT OPERATE PROPERTY
24 PROBLEM WITH BALLEST
25 POOR PLANNING AND ATTN. TO DETAIL
26 POOR PLANNING AND ATTN. TO DETAIL
27 PROGRAM DEADLINES VERY INCONVENIENT TO FIT WITH INSTALLATION
28 POOR PLANNING AND ATTN. TO DETAIL
29 1 REQUIREMENTS ARE GETTING MORE TECHNICAL.
30 POOR PLANNING AND ATTN. TO DETAIL
31 POOR PLANNING AND ATTN. TO DETAIL
32 20 % OF THE REBATE NOT YET RECEIVED
33 POOR PLANNING AND ATTN. TO DETAIL
34 OFFER BETTER INFO & REBATES, RARELY RECEIVE INFO ABOUT RETRIF
35 NEED WORKING SAMPLES TO DEDIDE WHICH WORKS BEST IN A SITUATIO
36 HELP FINDING H. EFF. LIGHTING
37 HELP FINDING H. EFF. LIGHTING
38 PAPER WORK REDUCTION FOR MULTI SITES
39 PAPER WORK REDUCTION FOR MULTI SITES
40 PAPER WORK REDUCTION FOR MULTI SITES
41 TOOK TO LONG TO RECEIVE REBATE.
42 REBATE SHOULD BE STRUCTURED ON BASIS OF ACTUAL ENERGY SAVINGS
43 GET LITTLE INFO ON PROGRAMS
44 0
45 0
46 UNRESPONSIVE
47 REBATE CUTS
48 PROBLEM WITH THE ACCOUNT REP THEY WERE NOT QUITE SURE WHO WAS
49 THE REBATE IS NOT AVAIABLE FOR CERTAIN THINGS THAT HE WANTS
50 GETTING ALOT OF "LEAKY" INFORMATION.ABOUT REBATES BEING CUTT

OBS DS089

1 QUOTED
 2 ED FOR PROGRAM DID NOT APPLY TO THE CHURCH SPECIFICALLY.
 3 SAYING THEY'LL DO SOMETHING---THEN THEY DISAPPEAR
 4 TIMING
 5 AND NO LOCAL OFFICE KNOWLEDGE.
 6 0
 7 0
 8 POOR AUDITING WITHIN PG&E ???
 9 WE NEEDED ADVICE FROM PGE
 10 SCHEDULE
 11 IT, ESPECIALLY FOR COMMERCIAL ACCOUNTS
 12 N; NEEDS WATTAGE HOURS FOR LIGHT AMOUNT AND COST
 13 NO LOCAL CONTACT
 14 0
 15 0
 16 0
 17 RESPONSIBLE
 18 TO DO
 19 GIVE OUT KNOWLEDGEABLE INFORMATION TO CUSTOMERS.

Suggestion for improving program?

| DS090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 267 | 59.9 | 267 | 59.9 |
| Yes | 179 | 40.1 | 446 | 100.0 |

Frequency Missing = 33

Better/More Information

| DS091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 94 | 61.8 | 94 | 61.8 |
| 1 | 58 | 38.2 | 152 | 100.0 |

Frequency Missing = 327

Post-Installation Inspection

| DS092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 128 | 97.0 | 128 | 97.0 |
| 1 | 4 | 3.0 | 132 | 100.0 |

Frequency Missing = 347

Improve Quality of light

| DS093 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 127 | 96.9 | 127 | 96.9 |
| 1 | 4 | 3.1 | 131 | 100.0 |

Frequency Missing = 348

Larger Rebates

| DS094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 67 | 48.2 | 67 | 48.2 |
| 1 | 72 | 51.8 | 139 | 100.0 |

Frequency Missing = 340

Smaller Rebates

| DS095 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 132 | 100.0 | 132 | 100.0 |

Frequency Missing = 347

Change Qualifying Measures

| DS096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 132 | 98.5 | 132 | 98.5 |
| 1 | 2 | 1.5 | 134 | 100.0 |

Frequency Missing = 345

Closer Supervision of Contractors

| DS097 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 120 | 88.2 | 120 | 88.2 |
| 1 | 16 | 11.8 | 136 | 100.0 |

Frequency Missing = 343

OBS DS100

1 IMPROVE GENERAL EFFIECIENCY
2 MORE EQUIPMENT ADVICE
3 OUTREACH IS IMPORTANT ESPECIALLY FOR SMALLER FACILITIES
4 1 LESS PAPERWORK
5 0
6 WOULD LIKE TO SEE OLD FIXTURES REPLACED
7 EXTEND TO PROPERTY IN LODI
8 BETTER COMMUNICATION ABOUT SUCH PROGRAMS
9 MORE INCENTIVES FOR NONPROFIT ORGANIZATIONS, CURRENTLY HAVE
10 0
11 PG&E SHOULD DROP REBATES BECAUSE IT KEEPS GETTING SMALLER
12 PG&E SHOULD DROP REBATES BECAUSE IT KEEPS GETTING SMALLER
13 MORE ON SIGHT HELP AND RECOMENDATIONS
14 0
15 MAKE INFO MORE ACCESSIBLE TO ALL TYPES OF GROUPS
16 PG&E SHOULD DROP REBATES BECAUSE IT KEEPS GETTING SMALLER
17 MORE GUIDANCE IN EQUIPMENT SELECTION
18 PROGRAM MISREPRESENTED IN RELATION TO SAVINGS ATTAINABLE
19 MORE PEOPLE DELIVERING MORE INFO TO BUSINESSE
20 0
21 NEED TO HAV EMORE ADVERTISING FOR THE PROGRAM
22 BETTER ADVERTISING TO LET PEOPLE KNOW OF PROGRAM
23 0
24 0
25 KEEP IT AVAILABLE !!!!!
26 PG&E SHOULD DROP REBATES BECAUSE IT KEEPS GETTING SMALLER
27 SIMPLIFY AND LEAVE ROOM FOR FLEXIBILITY IN REBATES
28 0
29 MORE TIMELY AND PRECISE INFO
30 GIVE CUSTOMER TOUR OF ENERY SYSTEM IN SF
31 PROVIDE BETTER ENGINEERING CRITERA AND SUPPORT, ALCO HIGHE
32 FOLLOW UP COULD BE A LITTLE BIT STRONGER.
33 KEEP THE REBATE GOING..THE WAY IT IS
34 JUST CONTINUE THE PROGRAM
35 SEND SURVEY BY MAIL
36 NO ONE TOLD HIM HOW MANY LUMENS ARE NEEDED FOR EVERY SQ. FT.
37 PAY MORE QUICKLY
38 BETTER ADVERTISING OF PROGRAM
39 MORE\BETTER ADVERTISING
40 WOULD LIKE TO SEE A DEMONSTRATION AREA WHERE PG&E COULD DEMON
41 MORE INFO ABOUT THE EQUIPMENT ITSELF.
42 0
43 0
44 NO ONE TOLD HIM HOW MANY LUMENS ARE NEEDED FOR EVERY SQ. FT.
45 PROGRAM DIDN'T STIPULATE CERTAIN LAMP CONFIGURATIONS PRESENT
46 SHORTEN THE SURVEY
47 MAINTAIN SAME AMOUNT OF REBATE
48 0
49 KEEP IT GOING
50 BIAX LAMP SHOULD BE INCLUDED IN RETROFIT PACKAGE
51 GO BACK AND PROVE THAT THE SAVINGS WERE THERE; FOLLOW UP.
52 WOULD LIKE MORE ENGINEERING ADVICE ON THE RETROFITS.
53 KEEP IT GOING

OBS DS100

54 0

55 0

56 0

57 0

58 0

59 FIX SENSORS

60 0

61 0

62 KEEP IT GOING

63 TIMELY REBATE -- REBATE WAS LATE

64 0

65 0

66 0

67 0

68 0

69 PG&E SHOULD GET MORE INVOLVED IN INFO ABOUT EQUIP. SELECTION

70 HAVE PROGRAM RUN ALL YEAR WITHUT CUTOFF DATES

71 0

72 SPECIFY EQUIPMENT THAT YOU GET REBATES ON

73 FORMS CONFUSING NEED TO BE RE-WRITTEN

74 BETTER CONTACT W/ENGINEERS WHO CAN ANSWER TECHNICAL QUESTIONS

75 CONTRACTOR BROKE LIGHTS LEADING TO BUS. CLOSING, NOT POLITE

76 BETTER REBATES FOR COMMERCIAL ACCOUNTS, DIDN'T SAVE MUCH FR

77 ANALYSIS OF BEST RETURN FOR PARTICULAR BUILDING

78 FOLLOW-UP FROM PG&E AFTER INSTALLATION OF EQUIPMENT, AND

79 NOT SURE IF SUGGESTION INVOLVES PG&E AND EFFICIENCY PROGRAM.

80 KEP PROGRAMS GOING

81 KEP PROGRAMS GOING

82 KEP PROGRAMS GOING

83 KEP PROGRAMS GOING

84 KEP PROGRAMS GOING

85 KEP PROGRAMS GOING

86 KEP PROGRAMS GOING

87 KEP PROGRAMS GOING

88 KEP PROGRAMS GOING

89 KEP PROGRAMS GOING

90 KEP PROGRAMS GOING

91 KEP PROGRAMS GOING

92 KEP PROGRAMS GOING

93 KEP PROGRAMS GOING

94 KEP PROGRAMS GOING

95 KEP PROGRAMS GOING

96 REDUCE RATES

97 KEP PROGRAMS GOING

98 KEP PROGRAMS GOING

99 BRING WORKING SAMPLES

100 DON'T CHANGE IT

101 MAKE IT EASYER TO APPLY FOR PROGRAMS

102 MAKE IT EASYER TO APPLY FOR PROGRAMS

103 SURVEY TOO LONG

104 CONCENTRATE ON RENDITION AND LOOKS FOR RETAIL

105 EDUCATE AS TO WHAT IS AVAILABLE

106 CONCENTRATE ON RENDITION AND LOOKS FOR RETAIL

OBS DS100

107 CONCENTRATE ON RENDITION AND LOOKS FOR RETAIL
108 PUT THIS SURVEY IN WRITTEN FORM.
109 DON'T REDUCE THE REBATES
110 KEEP IT GOING
111 KEEP PROGRAM IN PLACE AND EXPAND; REBATES EXCELLANT WAY TO GO
112 FASTER RECEIPT OF REBATE CHECKS
113 0
114 SHOWROOM TO SEE ALL YOUR OPTIONS & FIXTURES THAT WOULD BE
115 BETTER CONTACT WITH REP
116 REBATE IS GOOD INCENTIVE
117 0
118 SOME REBATES ARE NOT APPLICABLE TO ENCOURAGE PPL TO USE HIGH
119 BETTER TRAINED EMPLOYEES
120 MORE ENGINEERING SUPPORT. BETTER STATISTICS ON PAYBACK PERIOD
121 GO BACK TO THE 1991 REBATE PROGRAM
122 LARGER PARTICIPATION IN HELPING COMPANIES SELLECT EQUIPMENT
123 MAKE THE PROGRAM MORE FLEXIBLE
124 1

OBS DS101

1 0
2 PRIVATE CONTRACTOR & HAVE HAD COMMUNICATION DIFFICULTY
3 0
4 0
5 0
6 0
7 0
8 0
9 R REBATES
10 STRATE RELATIVE LIGHTING
11 0
12 0
13 IN THE MARKET PLACE, MAKING THE RETROFIT A HASSLE
14 0
15 0
16 0
17 0
18 0
19 0
20 0
21 0
22 0
23 0
24 0
25 0
26 0
27 [G&E COULD GIVE UNBIASED OPINION, CONTRACTORS ARE PROFIT MOTI
28 0
29 OM PROGRAM, NOT MUCH IMPROVEMENT SEEN, NOT DOING MUCH FOR THE
30 PROOF OF SAVINGS.
31 0
32 COMPATIABLE W/OLD BULIDINGS
33 0
34 EFFICIENCY PRODUCTS
35 0
36 0
37 ADVERTISE TO COMPANIES BETTER

| OBS | DS102 |
|-----|--|
| 1 | 0 |
| 2 | 0 |
| 3 | 0 |
| 4 | 0 |
| 5 | 0 |
| 6 | 0 |
| 7 | 0 |
| 8 | 0 |
| 9 | 0 |
| 10 | 0 |
| 11 | 0 |
| 12 | 0 |
| 13 | 0 |
| 14 | 0 |
| 15 | 0 |
| 16 | 0 |
| 17 | 0 |
| 18 | 0 |
| 19 | 0 |
| 20 | 0 |
| 21 | 0 |
| 22 | 0 |
| 23 | VATED |
| 24 | 0 |
| 25 | M, WASN'T WORTH THE MONEY, BILL STILL TOO HIGH |
| 26 | 1 |
| 27 | 0 |
| 28 | 0 |
| 29 | 0 |
| 30 | 0 |

Main business activity

| BC011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Office | 59 | 12.6 | 59 | 12.6 |
| Retail (no-food) | 82 | 17.6 | 141 | 30.2 |
| Manuf/Assmbly | 8 | 1.7 | 149 | 31.9 |
| Warehouse | 10 | 2.1 | 159 | 34.0 |
| Restaurant | 22 | 4.7 | 181 | 38.8 |
| Grocery Store | 26 | 5.6 | 207 | 44.3 |
| School | 69 | 14.8 | 276 | 59.1 |
| Hotel/Motel | 14 | 3.0 | 290 | 62.1 |
| Hospital | 10 | 2.1 | 300 | 64.2 |
| Collg/Univ | 1 | 0.2 | 301 | 64.5 |
| Health Care | 18 | 3.9 | 319 | 68.3 |
| Municipalnty | 3 | 0.6 | 322 | 69.0 |
| Indust procss | 1 | 0.2 | 323 | 69.2 |
| Other | 144 | 30.8 | 467 | 100.0 |

Frequency Missing = 12

OBS BC012

1 REAL ESTATE AND PROP. MNG.
2 CHURCH
3 RELIGIOUS
4 FLIGHT TRAINING, SALES
5 INS. COMPANY
6 POST OFFICE
7 CREDIT UNION
8 CHURCH
9 RECREATIONAL FACILITY
10 CHURCH
11 LEGAL AIDE OFFICE
12 LAW PRACTICE
13 CHURCH
14 CHURCH
15 CHURCH
16 LOCAL UNION
17 COMMUNITY SERVICE ORGANIZATION
18 REAL ESTATE CONTRACTOR
19 MAIL AND BUSS. SERV
20 CHURCH
21 FINANCIAL PLANNING
22 CHURCH
23 TRADE AND SERVICE ORGANIZATION
24 BANKS
25 MAIL SERVICES
26 FINIANCIAL INSTITUTION
27 FINIANCIAL INSTITUTION
28 RETAIL BANKING
29 RETAIL BANKING
30 COMMERCIAL BANK
31 YOUTH SERVICES
32 MAIL SERVICES
33 MEETING HALL
34 BANKING
35 TEMPLE
36 FINANICIAL INSTITUTION
37 FINANICIAL INSTITUTION
38 BANKS
39 CHURCH
40 RETAIL BANKING
41 FIRE DEPARTMENT
42 POST OFFICE
43 FINANICIAL INSTITUTION
44 BRANCH BANKING
45 FINANICIAL INSTITUTION
46 BANKS
47 CHURCH
48 BANKING FACILITY
49 FIRE PROTECTION
50 AIRPORYT
51 BANK
52 FINIANCIAL INSTITUTION
53 FINIANCIAL INSTITUTION

OBS BC012

54 FINANICIAL INSTITUTION
55 LAW ENFORCEMENT
56 BANKING FACILITY
57 FINANICIAL INSTITUTION
58 FIRE PROTECTION DISTRICT
59 FUNERAL
60 C. P. A.
61 BANKS
62 CO. OFFICES, /STATE& FED
63 CHURCH
64 MAIL SERVICES
65 ACCOUNTING
66 RETAIL BANKING
67 CONGRESS. OFFICE
68 COMMERCIAL BANK
69 CHURCH
70 ACCOUNTING
71 LIBRARY
72 MAIL SERVICES
73 CREDIT UNION
74 WIRELESS COMMUNICATIONS
75 COMBIN. OF 1,2,3
76 YMCA
77 CABLE COMPANY
78 LAW FIRM
79 ELEC. COMPONENT TESTING HOUSE
80 AUTOMOBILES SALES
81 RENTAL EQUIPMENT
82 COIN LAUNDRY
83 AUTO PAINT SUPPLIES
84 RETAIL STATIONERS
85 AUTO REPAIR
86 LIBRARY
87 ORDTDHODONTIC LAB
88 CHURCH
89 LANDSCAPE ARCITECHTURE
90 BEAUTY SALON
91 AUTOMOTIVE
92 VIDEO RENTALS
93 AUTOMOTIVE REPAIR
94 LAUNDROMAT
95 FURNITURE SHOWROOM
96 RECREATION
97 AUTO REPAIR SERVICE
98 LAUNDROMAT & DRY CLEANERS
99 GROCERY, RETAIL, ETC.
100 MORTUARY
101 AUTO BODY REPAIR
102 LAUNDERMAT
103 COIN LAUNDRY
104 SERVICE ORIENTED
105 SERVICE ORIENTED
106 AUTO BODY REPAIR

OBS BC012

107 AMUSEMENT PARK
108 CAR WASH
109 COURT REPORTING
110 SERVICE DONE IN CUST'S HOME
111 FILM PROCESSING
112 RENTAL 4 UNIFORMS
113 BOWLING CENTER
114 VEGETABLE SEED PRODUCTION COMP.
115 PACKAGE DISTRIBUTION
116 EDUCATION
117 CHURCH ,OFFICES AND PRESCHOOL.
118 LIQUOR STORE
119 WINERY
120 LIQUOR STORE
121 RETAIL, FOOD
122 DENTAL OFFICE
123 DENTISTRY
124 ATHLETIC GYM
125 HEALTH CLUB
126 HEALTH CLUB
127 PHYSICIAN OFFICES
128 GOLF COURSE\
129 TENNIS CLUB
130 HEALTH CLUB
131 AUTO REPAIRS
132 SALES AND SERVICE
133 SELF STORAGE
134 ELECTRICAL WHOLESALE SUPPLY
135 WHOLESALE
136 INDIVIDUAL SELF STORAGE UNITS
137 MULTIPLE USES
138 TRCATOR SALES REPAIRS
139 WINE STORAGE WAREHOUSE
140 ELECTRICAL DATA WHOLESALE
141 WHOLE SALE DISTRIBUTER
142 SELL SEMI CUNDUCTER MAN. EQUIP.
143 OCF FACILITY AND WAREHOUSING
144 CD&TAPE DISTRIBUTOR

Year facility built

| FC060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 1992-Pres | 3 | 0.8 | 3 | 0.8 |
| 1988-1991 | 31 | 7.8 | 34 | 8.5 |
| 1986-1987 | 26 | 6.5 | 60 | 15.0 |
| 1983-1985 | 27 | 6.8 | 87 | 21.8 |
| 1979-1982 | 36 | 9.0 | 123 | 30.8 |
| 1975-1978 | 36 | 9.0 | 159 | 39.8 |
| 1970-1974 | 53 | 13.3 | 212 | 53.0 |
| 1960-1969 | 71 | 17.8 | 283 | 70.8 |
| 1950-1959 | 47 | 11.8 | 330 | 82.5 |
| 1940-1949 | 32 | 8.0 | 362 | 90.5 |
| 1930-1939 | 16 | 4.0 | 378 | 94.5 |
| 1929 or B4 | 22 | 5.5 | 400 | 100.0 |

Frequency Missing = 79

Stories of facility

| FC070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 330 | 73.7 | 330 | 73.7 |
| 1.5 | 2 | 0.4 | 332 | 74.1 |
| 2 | 78 | 17.4 | 410 | 91.5 |
| 3 | 22 | 4.9 | 432 | 96.4 |
| 4 | 9 | 2.0 | 441 | 98.4 |
| 5 | 3 | 0.7 | 444 | 99.1 |
| 6 | 1 | 0.2 | 445 | 99.3 |
| 7 | 2 | 0.4 | 447 | 99.8 |
| 12 | 1 | 0.2 | 448 | 100.0 |

Frequency Missing = 31

Univariate Procedure

Variable=FC080

Square footage/floor of facility

Moments

| | | | |
|----------|----------|----------|----------|
| N | 390 | Sum Wgts | 390 |
| Mean | 23646.08 | Sum | 9221970 |
| Std Dev | 48154.68 | Variance | 2.3189E9 |
| Skewness | 5.673287 | Kurtosis | 42.98696 |
| USS | 1.12E12 | CSS | 9.02E11 |
| CV | 203.6477 | Std Mean | 2438.407 |
| T:Mean=0 | 9.697345 | Pr> T | 0.0001 |
| Num ^= 0 | 390 | Num > 0 | 390 |
| M(Sign) | 195 | Pr>= M | 0.0001 |
| Sgn Rank | 38122.5 | Pr>= S | 0.0001 |

Quantiles(Def=5)

| | | | |
|----------|--------|-----|--------|
| 100% Max | 520539 | 99% | 263000 |
| 75% Q3 | 26976 | 95% | 85000 |
| 50% Med | 8000 | 90% | 46750 |
| 25% Q1 | 3000 | 10% | 1500 |
| 0% Min | 45 | 5% | 1000 |
| | | 1% | 416 |
| Range | 520494 | | |
| Q3-Q1 | 23976 | | |
| Mode | 5000 | | |

Extremes

| Lowest | Obs | Highest | Obs |
|--------|------|---------|------|
| 45(| 39) | 216000(| 450) |
| 161(| 376) | 263000(| 246) |
| 300(| 23) | 299968(| 288) |
| 416(| 373) | 393299(| 291) |
| 500(| 151) | 520539(| 272) |

| | |
|---------------|-------|
| Missing Value | D |
| Count | 61 |
| % Count/Nobs | 13.53 |

Square footage/floor of AC space

| FC081 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 27 | 6.1 | 27 | 6.1 |
| 1 | 4 | 0.9 | 31 | 7.0 |
| 2 | 1 | 0.2 | 32 | 7.2 |
| 3 | 1 | 0.2 | 33 | 7.4 |
| 5 | 2 | 0.5 | 35 | 7.9 |
| 6 | 1 | 0.2 | 36 | 8.1 |
| 9 | 2 | 0.5 | 38 | 8.6 |
| 10 | 3 | 0.7 | 41 | 9.3 |
| 15 | 3 | 0.7 | 44 | 9.9 |
| 20 | 7 | 1.6 | 51 | 11.5 |
| 25 | 7 | 1.6 | 58 | 13.1 |
| 30 | 2 | 0.5 | 60 | 13.5 |
| 35 | 1 | 0.2 | 61 | 13.8 |
| 40 | 1 | 0.2 | 62 | 14.0 |
| 45 | 1 | 0.2 | 63 | 14.2 |
| 50 | 14 | 3.2 | 77 | 17.4 |
| 57 | 1 | 0.2 | 78 | 17.6 |
| 60 | 4 | 0.9 | 82 | 18.5 |
| 65 | 5 | 1.1 | 87 | 19.6 |
| 66 | 3 | 0.7 | 90 | 20.3 |
| 70 | 7 | 1.6 | 97 | 21.9 |
| 75 | 13 | 2.9 | 110 | 24.8 |
| 80 | 8 | 1.8 | 118 | 26.6 |
| 85 | 2 | 0.5 | 120 | 27.1 |
| 90 | 18 | 4.1 | 138 | 31.2 |
| 95 | 7 | 1.6 | 145 | 32.7 |
| 97 | 1 | 0.2 | 146 | 33.0 |
| 98 | 3 | 0.7 | 149 | 33.6 |
| 99 | 2 | 0.5 | 151 | 34.1 |
| 100 | 289 | 65.2 | 440 | 99.3 |
| 800 | 1 | 0.2 | 441 | 99.5 |
| 3500 | 1 | 0.2 | 442 | 99.8 |
| 30000 | 1 | 0.2 | 443 | 100.0 |

Frequency Missing = 36

Retrofit located in a AC space?

| FC095 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 71 | 15.9 | 71 | 15.9 |
| 1 | 344 | 77.0 | 415 | 92.8 |
| 2 | 32 | 7.2 | 447 | 100.0 |

Frequency Missing = 32

% of Retrofit located in AC space

| FC100 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 6 | 16.2 | 6 | 16.2 |
| 3 | 1 | 2.7 | 7 | 18.9 |
| 5 | 1 | 2.7 | 8 | 21.6 |
| 15 | 2 | 5.4 | 10 | 27.0 |
| 20 | 1 | 2.7 | 11 | 29.7 |
| 25 | 1 | 2.7 | 12 | 32.4 |
| 33 | 1 | 2.7 | 13 | 35.1 |
| 50 | 5 | 13.5 | 18 | 48.6 |
| 60 | 2 | 5.4 | 20 | 54.1 |
| 70 | 2 | 5.4 | 22 | 59.5 |
| 75 | 2 | 5.4 | 24 | 64.9 |
| 80 | 4 | 10.8 | 28 | 75.7 |
| 90 | 2 | 5.4 | 30 | 81.1 |
| 95 | 1 | 2.7 | 31 | 83.8 |
| 99 | 3 | 8.1 | 34 | 91.9 |
| 100 | 3 | 8.1 | 37 | 100.0 |

Frequency Missing = 442

Since Jan1992, size changed

| FC110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Increasd space | 46 | 10.3 | 46 | 10.3 |
| Decreasd space | 2 | 0.4 | 48 | 10.8 |
| Stayed same | 397 | 89.2 | 445 | 100.0 |

Frequency Missing = 34

Area of size change

| FC120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 1.9 | 1 | 1.9 |
| 1 | 5 | 9.4 | 6 | 11.3 |
| 150 | 1 | 1.9 | 7 | 13.2 |
| 350 | 1 | 1.9 | 8 | 15.1 |
| 450 | 1 | 1.9 | 9 | 17.0 |
| 700 | 1 | 1.9 | 10 | 18.9 |
| 800 | 1 | 1.9 | 11 | 20.8 |
| 1000 | 2 | 3.8 | 13 | 24.5 |
| 1200 | 1 | 1.9 | 14 | 26.4 |
| 1600 | 1 | 1.9 | 15 | 28.3 |
| 1800 | 1 | 1.9 | 16 | 30.2 |
| 2000 | 14 | 26.4 | 30 | 56.6 |
| 2500 | 1 | 1.9 | 31 | 58.5 |
| 3000 | 3 | 5.7 | 34 | 64.2 |
| 3500 | 3 | 5.7 | 37 | 69.8 |
| 4000 | 8 | 15.1 | 45 | 84.9 |
| 5000 | 2 | 3.8 | 47 | 88.7 |
| 5800 | 1 | 1.9 | 48 | 90.6 |
| 6000 | 1 | 1.9 | 49 | 92.5 |
| 7000 | 3 | 5.7 | 52 | 98.1 |
| 10000 | 1 | 1.9 | 53 | 100.0 |

Frequency Missing = 426

Month/Year of area change

| FC130 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| OCT1992 | 1 | 4.8 | 1 | 4.8 |
| NOV1992 | 1 | 4.8 | 2 | 9.5 |
| AUG1993 | 2 | 9.5 | 4 | 19.0 |
| SEP1993 | 1 | 4.8 | 5 | 23.8 |
| JAN1994 | 1 | 4.8 | 6 | 28.6 |
| FEB1994 | 2 | 9.5 | 8 | 38.1 |
| APR1994 | 2 | 9.5 | 10 | 47.6 |
| MAY1994 | 2 | 9.5 | 12 | 57.1 |
| JUN1994 | 1 | 4.8 | 13 | 61.9 |
| JUL1994 | 3 | 14.3 | 16 | 76.2 |
| AUG1994 | 2 | 9.5 | 18 | 85.7 |
| DEC1994 | 1 | 4.8 | 19 | 90.5 |
| APR1995 | 1 | 4.8 | 20 | 95.2 |
| JUN1995 | 1 | 4.8 | 21 | 100.0 |

Frequency Missing = 458

Year of area change

| FC131 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 6 | 18.2 | 6 | 18.2 |
| 1993 | 23 | 69.7 | 29 | 87.9 |
| 1994 | 4 | 12.1 | 33 | 100.0 |

Frequency Missing = 446

Month/Year of area increase occupied

| FC140 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| OCT1992 | 1 | 5.0 | 1 | 5.0 |
| NOV1992 | 1 | 5.0 | 2 | 10.0 |
| AUG1993 | 1 | 5.0 | 3 | 15.0 |
| SEP1993 | 2 | 10.0 | 5 | 25.0 |
| FEB1994 | 2 | 10.0 | 7 | 35.0 |
| APR1994 | 2 | 10.0 | 9 | 45.0 |
| MAY1994 | 1 | 5.0 | 10 | 50.0 |
| JUN1994 | 2 | 10.0 | 12 | 60.0 |
| JUL1994 | 1 | 5.0 | 13 | 65.0 |
| AUG1994 | 1 | 5.0 | 14 | 70.0 |
| SEP1994 | 1 | 5.0 | 15 | 75.0 |
| NOV1994 | 1 | 5.0 | 16 | 80.0 |
| DEC1994 | 1 | 5.0 | 17 | 85.0 |
| JAN1995 | 1 | 5.0 | 18 | 90.0 |
| APR1995 | 1 | 5.0 | 19 | 95.0 |
| JUN1995 | 1 | 5.0 | 20 | 100.0 |

Frequency Missing = 459

Year of area increase occupied

| FC141 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 6 | 20.0 | 6 | 20.0 |
| 1993 | 21 | 70.0 | 27 | 90.0 |
| 1994 | 3 | 10.0 | 30 | 100.0 |

Frequency Missing = 449

Month/Year of last major space remodel

| FR033 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1970 | 1 | 1.6 | 1 | 1.6 |
| MAR1970 | 1 | 1.6 | 2 | 3.2 |
| SEP1975 | 1 | 1.6 | 3 | 4.8 |
| DEC1980 | 1 | 1.6 | 4 | 6.5 |
| JUN1984 | 1 | 1.6 | 5 | 8.1 |
| OCT1984 | 1 | 1.6 | 6 | 9.7 |
| MAR1985 | 1 | 1.6 | 7 | 11.3 |
| NOV1985 | 1 | 1.6 | 8 | 12.9 |
| DEC1985 | 1 | 1.6 | 9 | 14.5 |
| FEB1986 | 1 | 1.6 | 10 | 16.1 |
| APR1986 | 1 | 1.6 | 11 | 17.7 |
| JUN1986 | 1 | 1.6 | 12 | 19.4 |
| JUN1987 | 2 | 3.2 | 14 | 22.6 |
| NOV1987 | 1 | 1.6 | 15 | 24.2 |
| DEC1987 | 1 | 1.6 | 16 | 25.8 |
| AUG1988 | 1 | 1.6 | 17 | 27.4 |
| JUN1989 | 1 | 1.6 | 18 | 29.0 |
| SEP1989 | 1 | 1.6 | 19 | 30.6 |
| OCT1989 | 1 | 1.6 | 20 | 32.3 |
| NOV1989 | 1 | 1.6 | 21 | 33.9 |
| DEC1989 | 1 | 1.6 | 22 | 35.5 |
| MAR1990 | 1 | 1.6 | 23 | 37.1 |
| MAY1990 | 1 | 1.6 | 24 | 38.7 |
| OCT1990 | 1 | 1.6 | 25 | 40.3 |
| JAN1991 | 1 | 1.6 | 26 | 41.9 |
| JUL1991 | 1 | 1.6 | 27 | 43.5 |
| JUN1992 | 1 | 1.6 | 28 | 45.2 |
| AUG1992 | 1 | 1.6 | 29 | 46.8 |
| JUN1993 | 1 | 1.6 | 30 | 48.4 |
| AUG1993 | 1 | 1.6 | 31 | 50.0 |
| SEP1993 | 2 | 3.2 | 33 | 53.2 |
| NOV1993 | 1 | 1.6 | 34 | 54.8 |
| JAN1994 | 2 | 3.2 | 36 | 58.1 |
| FEB1994 | 2 | 3.2 | 38 | 61.3 |
| MAR1994 | 2 | 3.2 | 40 | 64.5 |
| APR1994 | 2 | 3.2 | 42 | 67.7 |
| MAY1994 | 1 | 1.6 | 43 | 69.4 |
| JUN1994 | 1 | 1.6 | 44 | 71.0 |
| JUL1994 | 2 | 3.2 | 46 | 74.2 |
| SEP1994 | 1 | 1.6 | 47 | 75.8 |
| OCT1994 | 1 | 1.6 | 48 | 77.4 |
| NOV1994 | 2 | 3.2 | 50 | 80.6 |
| DEC1994 | 2 | 3.2 | 52 | 83.9 |
| JAN1995 | 4 | 6.5 | 56 | 90.3 |
| FEB1995 | 1 | 1.6 | 57 | 91.9 |
| MAR1995 | 1 | 1.6 | 58 | 93.5 |
| MAY1995 | 4 | 6.5 | 62 | 100.0 |

Frequency Missing = 417

Year of last major space remodel

| FR034 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 0.3 | 1 | 0.3 |
| Never remodelled | 204 | 61.8 | 205 | 62.1 |
| 1955 | 1 | 0.3 | 206 | 62.4 |
| 1960 | 1 | 0.3 | 207 | 62.7 |
| 1961 | 1 | 0.3 | 208 | 63.0 |
| 1964 | 1 | 0.3 | 209 | 63.3 |
| 1965 | 3 | 0.9 | 212 | 64.2 |
| 1967 | 1 | 0.3 | 213 | 64.5 |
| 1970 | 1 | 0.3 | 214 | 64.8 |
| 1972 | 1 | 0.3 | 215 | 65.2 |
| 1974 | 2 | 0.6 | 217 | 65.8 |
| 1976 | 1 | 0.3 | 218 | 66.1 |
| 1979 | 2 | 0.6 | 220 | 66.7 |
| 1980 | 9 | 2.7 | 229 | 69.4 |
| 1981 | 3 | 0.9 | 232 | 70.3 |
| 1983 | 1 | 0.3 | 233 | 70.6 |
| 1984 | 2 | 0.6 | 235 | 71.2 |
| 1985 | 3 | 0.9 | 238 | 72.1 |
| 1986 | 3 | 0.9 | 241 | 73.0 |
| 1987 | 5 | 1.5 | 246 | 74.5 |
| 1988 | 7 | 2.1 | 253 | 76.7 |
| 1989 | 9 | 2.7 | 262 | 79.4 |
| 1990 | 15 | 4.5 | 277 | 83.9 |
| 1991 | 12 | 3.6 | 289 | 87.6 |
| 1992 | 13 | 3.9 | 302 | 91.5 |
| 1993 | 6 | 1.8 | 308 | 93.3 |
| 1994 | 17 | 5.2 | 325 | 98.5 |
| 1995 | 5 | 1.5 | 330 | 100.0 |

Frequency Missing = 149

Did remodel cover space retrofitted

| FR035 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 42 | 22.2 | 42 | 22.2 |
| Yes | 147 | 77.8 | 189 | 100.0 |

Frequency Missing = 290

Weekdays per year closed for holidays

| LF030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 66 | 16.5 | 66 | 16.5 |
| 1 | 27 | 6.8 | 93 | 23.3 |
| 2 | 22 | 5.5 | 115 | 28.8 |
| 3 | 20 | 5.0 | 135 | 33.8 |
| 4 | 17 | 4.3 | 152 | 38.1 |
| 5 | 34 | 8.5 | 186 | 46.6 |
| 6 | 29 | 7.3 | 215 | 53.9 |
| 7 | 38 | 9.5 | 253 | 63.4 |
| 8 | 20 | 5.0 | 273 | 68.4 |
| 9 | 8 | 2.0 | 281 | 70.4 |
| 10 | 48 | 12.0 | 329 | 82.5 |
| 11 | 6 | 1.5 | 335 | 84.0 |
| 12 | 22 | 5.5 | 357 | 89.5 |
| 13 | 5 | 1.3 | 362 | 90.7 |
| 14 | 1 | 0.3 | 363 | 91.0 |
| 15 | 5 | 1.3 | 368 | 92.2 |
| 16 | 1 | 0.3 | 369 | 92.5 |
| 18 | 1 | 0.3 | 370 | 92.7 |
| 20 | 3 | 0.8 | 373 | 93.5 |
| 22 | 2 | 0.5 | 375 | 94.0 |
| 23 | 7 | 1.8 | 382 | 95.7 |
| 24 | 1 | 0.3 | 383 | 96.0 |
| 25 | 10 | 2.5 | 393 | 98.5 |
| 30 | 1 | 0.3 | 394 | 98.7 |
| 35 | 1 | 0.3 | 395 | 99.0 |
| 45 | 1 | 0.3 | 396 | 99.2 |
| 52 | 1 | 0.3 | 397 | 99.5 |
| 62 | 1 | 0.3 | 398 | 99.7 |
| 105 | 1 | 0.3 | 399 | 100.0 |

Frequency Missing = 80

Saturdays per year closed for holidays

| LF040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 0 | 169 | 44.7 | 169 | 44.7 |
| 1 | 7 | 1.9 | 176 | 46.6 |
| 2 | 26 | 6.9 | 202 | 53.4 |
| 3 | 6 | 1.6 | 208 | 55.0 |
| 4 | 3 | 0.8 | 211 | 55.8 |
| 5 | 2 | 0.5 | 213 | 56.3 |
| 6 | 3 | 0.8 | 216 | 57.1 |
| 7 | 2 | 0.5 | 218 | 57.7 |
| 9 | 1 | 0.3 | 219 | 57.9 |
| 10 | 1 | 0.3 | 220 | 58.2 |
| 11 | 1 | 0.3 | 221 | 58.5 |
| 12 | 2 | 0.5 | 223 | 59.0 |
| 13 | 1 | 0.3 | 224 | 59.3 |
| 14 | 1 | 0.3 | 225 | 59.5 |
| 20 | 1 | 0.3 | 226 | 59.8 |
| 25 | 2 | 0.5 | 228 | 60.3 |
| 32 | 1 | 0.3 | 229 | 60.6 |
| 36 | 1 | 0.3 | 230 | 60.8 |
| 48 | 1 | 0.3 | 231 | 61.1 |
| 50 | 1 | 0.3 | 232 | 61.4 |
| 52 | 6 | 1.6 | 238 | 63.0 |
| Never open | 140 | 37.0 | 378 | 100.0 |

Frequency Missing = 101

Sundays per year closed for holidays

| LF050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 0 | 144 | 36.5 | 144 | 36.5 |
| 1 | 9 | 2.3 | 153 | 38.8 |
| 2 | 10 | 2.5 | 163 | 41.4 |
| 3 | 1 | 0.3 | 164 | 41.6 |
| 5 | 1 | 0.3 | 165 | 41.9 |
| 6 | 1 | 0.3 | 166 | 42.1 |
| 7 | 1 | 0.3 | 167 | 42.4 |
| 9 | 1 | 0.3 | 168 | 42.6 |
| 10 | 2 | 0.5 | 170 | 43.1 |
| 11 | 1 | 0.3 | 171 | 43.4 |
| 12 | 2 | 0.5 | 173 | 43.9 |
| 45 | 1 | 0.3 | 174 | 44.2 |
| 52 | 6 | 1.5 | 180 | 45.7 |
| Never open | 214 | 54.3 | 394 | 100.0 |

Frequency Missing = 85

Lighting hours different from operating?

| BH010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 308 | 67.2 | 308 | 67.2 |
| Yes | 150 | 32.8 | 458 | 100.0 |

Frequency Missing = 21

Aware of lighting hours

| BH015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Yes | 149 | 100.0 | 149 | 100.0 |

Frequency Missing = 330

light hours/from: Dec Week

| LF1F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 49 | 10.5 | 49 | 10.5 |
| 4:00 | 4 | 0.9 | 53 | 11.3 |
| 4:30 | 2 | 0.4 | 55 | 11.8 |
| 5:00 | 9 | 1.9 | 64 | 13.7 |
| 5:15 | 1 | 0.2 | 65 | 13.9 |
| 5:30 | 5 | 1.1 | 70 | 15.0 |
| 5:45 | 1 | 0.2 | 71 | 15.2 |
| 6:00 | 47 | 10.0 | 118 | 25.2 |
| 6:30 | 17 | 3.6 | 135 | 28.8 |
| 7:00 | 79 | 16.9 | 214 | 45.7 |
| 7:30 | 41 | 8.8 | 255 | 54.5 |
| 7:45 | 1 | 0.2 | 256 | 54.7 |
| 8:00 | 108 | 23.1 | 364 | 77.8 |
| 8:15 | 1 | 0.2 | 365 | 78.0 |
| 8:30 | 17 | 3.6 | 382 | 81.6 |
| 9:00 | 52 | 11.1 | 434 | 92.7 |
| 9:30 | 7 | 1.5 | 441 | 94.2 |
| 10:00 | 14 | 3.0 | 455 | 97.2 |
| 10:30 | 1 | 0.2 | 456 | 97.4 |
| 11:00 | 5 | 1.1 | 461 | 98.5 |
| 12:00 | 1 | 0.2 | 462 | 98.7 |
| 16:00 | 2 | 0.4 | 464 | 99.1 |
| 16:30 | 1 | 0.2 | 465 | 99.4 |
| 17:00 | 2 | 0.4 | 467 | 99.8 |
| 19:00 | 1 | 0.2 | 468 | 100.0 |

Frequency Missing = 11

light hours/from: Dec Sat

| LF2F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 227 | 48.9 | 227 | 48.9 |
| 4:00 | 1 | 0.2 | 228 | 49.1 |
| 4:30 | 1 | 0.2 | 229 | 49.4 |
| 5:00 | 8 | 1.7 | 237 | 51.1 |
| 5:15 | 1 | 0.2 | 238 | 51.3 |
| 5:30 | 1 | 0.2 | 239 | 51.5 |
| 6:00 | 30 | 6.5 | 269 | 58.0 |
| 6:30 | 2 | 0.4 | 271 | 58.4 |
| 7:00 | 19 | 4.1 | 290 | 62.5 |
| 7:30 | 15 | 3.2 | 305 | 65.7 |
| 7:45 | 1 | 0.2 | 306 | 65.9 |
| 8:00 | 55 | 11.9 | 361 | 77.8 |
| 8:30 | 5 | 1.1 | 366 | 78.9 |
| 8:45 | 1 | 0.2 | 367 | 79.1 |
| 9:00 | 52 | 11.2 | 419 | 90.3 |
| 9:30 | 4 | 0.9 | 423 | 91.2 |
| 10:00 | 25 | 5.4 | 448 | 96.6 |
| 11:00 | 5 | 1.1 | 453 | 97.6 |
| 11:30 | 1 | 0.2 | 454 | 97.8 |
| 12:00 | 1 | 0.2 | 455 | 98.1 |
| 13:00 | 1 | 0.2 | 456 | 98.3 |
| 14:00 | 1 | 0.2 | 457 | 98.5 |
| 16:00 | 2 | 0.4 | 459 | 98.9 |
| 16:30 | 1 | 0.2 | 460 | 99.1 |
| 17:00 | 2 | 0.4 | 462 | 99.6 |
| 17:30 | 1 | 0.2 | 463 | 99.8 |
| 20:00 | 1 | 0.2 | 464 | 100.0 |

Frequency Missing = 15

light hours/from: Dec Sun

| LF3F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 314 | 67.5 | 314 | 67.5 |
| 4:00 | 1 | 0.2 | 315 | 67.7 |
| 4:30 | 1 | 0.2 | 316 | 68.0 |
| 5:00 | 3 | 0.6 | 319 | 68.6 |
| 5:30 | 1 | 0.2 | 320 | 68.8 |
| 6:00 | 23 | 4.9 | 343 | 73.8 |
| 6:30 | 2 | 0.4 | 345 | 74.2 |
| 7:00 | 10 | 2.2 | 355 | 76.3 |
| 7:30 | 5 | 1.1 | 360 | 77.4 |
| 8:00 | 35 | 7.5 | 395 | 84.9 |
| 8:30 | 2 | 0.4 | 397 | 85.4 |
| 9:00 | 21 | 4.5 | 418 | 89.9 |
| 9:30 | 1 | 0.2 | 419 | 90.1 |
| 10:00 | 18 | 3.9 | 437 | 94.0 |
| 10:30 | 2 | 0.4 | 439 | 94.4 |
| 11:00 | 14 | 3.0 | 453 | 97.4 |
| 11:30 | 1 | 0.2 | 454 | 97.6 |
| 12:00 | 4 | 0.9 | 458 | 98.5 |
| 13:00 | 2 | 0.4 | 460 | 98.9 |
| 16:00 | 2 | 0.4 | 462 | 99.4 |
| 16:30 | 1 | 0.2 | 463 | 99.6 |
| 17:00 | 1 | 0.2 | 464 | 99.8 |
| 20:00 | 1 | 0.2 | 465 | 100.0 |

Frequency Missing = 14

light hours/from: Apr Week

| LF4F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 48 | 10.5 | 48 | 10.5 |
| 4:00 | 4 | 0.9 | 52 | 11.3 |
| 4:30 | 1 | 0.2 | 53 | 11.5 |
| 5:00 | 10 | 2.2 | 63 | 13.7 |
| 5:15 | 1 | 0.2 | 64 | 13.9 |
| 5:30 | 5 | 1.1 | 69 | 15.0 |
| 5:45 | 1 | 0.2 | 70 | 15.3 |
| 6:00 | 50 | 10.9 | 120 | 26.1 |
| 6:30 | 16 | 3.5 | 136 | 29.6 |
| 7:00 | 79 | 17.2 | 215 | 46.8 |
| 7:30 | 39 | 8.5 | 254 | 55.3 |
| 7:45 | 1 | 0.2 | 255 | 55.6 |
| 8:00 | 103 | 22.4 | 358 | 78.0 |
| 8:15 | 1 | 0.2 | 359 | 78.2 |
| 8:30 | 17 | 3.7 | 376 | 81.9 |
| 9:00 | 49 | 10.7 | 425 | 92.6 |
| 9:30 | 7 | 1.5 | 432 | 94.1 |
| 10:00 | 16 | 3.5 | 448 | 97.6 |
| 10:30 | 1 | 0.2 | 449 | 97.8 |
| 11:00 | 4 | 0.9 | 453 | 98.7 |
| 12:00 | 1 | 0.2 | 454 | 98.9 |
| 16:00 | 1 | 0.2 | 455 | 99.1 |
| 17:00 | 1 | 0.2 | 456 | 99.3 |
| 19:00 | 3 | 0.7 | 459 | 100.0 |

Frequency Missing = 20

light hours/from: Apr Sat

| LF5F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 219 | 48.0 | 219 | 48.0 |
| 4:00 | 1 | 0.2 | 220 | 48.2 |
| 5:00 | 9 | 2.0 | 229 | 50.2 |
| 5:15 | 1 | 0.2 | 230 | 50.4 |
| 5:30 | 1 | 0.2 | 231 | 50.7 |
| 6:00 | 32 | 7.0 | 263 | 57.7 |
| 6:30 | 1 | 0.2 | 264 | 57.9 |
| 7:00 | 22 | 4.8 | 286 | 62.7 |
| 7:30 | 15 | 3.3 | 301 | 66.0 |
| 7:45 | 1 | 0.2 | 302 | 66.2 |
| 8:00 | 54 | 11.8 | 356 | 78.1 |
| 8:30 | 5 | 1.1 | 361 | 79.2 |
| 8:45 | 1 | 0.2 | 362 | 79.4 |
| 9:00 | 50 | 11.0 | 412 | 90.4 |
| 9:30 | 4 | 0.9 | 416 | 91.2 |
| 10:00 | 26 | 5.7 | 442 | 96.9 |
| 11:00 | 4 | 0.9 | 446 | 97.8 |
| 11:30 | 1 | 0.2 | 447 | 98.0 |
| 12:00 | 1 | 0.2 | 448 | 98.2 |
| 13:00 | 1 | 0.2 | 449 | 98.5 |
| 14:00 | 1 | 0.2 | 450 | 98.7 |
| 16:00 | 1 | 0.2 | 451 | 98.9 |
| 17:00 | 1 | 0.2 | 452 | 99.1 |
| 17:30 | 1 | 0.2 | 453 | 99.3 |
| 19:00 | 2 | 0.4 | 455 | 99.8 |
| 20:00 | 1 | 0.2 | 456 | 100.0 |

Frequency Missing = 23

light hours/from: Apr Sun

| LF6F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 303 | 66.6 | 303 | 66.6 |
| 4:00 | 1 | 0.2 | 304 | 66.8 |
| 5:00 | 4 | 0.9 | 308 | 67.7 |
| 5:30 | 1 | 0.2 | 309 | 67.9 |
| 6:00 | 29 | 6.4 | 338 | 74.3 |
| 6:30 | 1 | 0.2 | 339 | 74.5 |
| 7:00 | 11 | 2.4 | 350 | 76.9 |
| 7:30 | 6 | 1.3 | 356 | 78.2 |
| 8:00 | 30 | 6.6 | 386 | 84.8 |
| 8:30 | 2 | 0.4 | 388 | 85.3 |
| 9:00 | 24 | 5.3 | 412 | 90.5 |
| 9:30 | 1 | 0.2 | 413 | 90.8 |
| 10:00 | 16 | 3.5 | 429 | 94.3 |
| 10:30 | 2 | 0.4 | 431 | 94.7 |
| 11:00 | 14 | 3.1 | 445 | 97.8 |
| 11:30 | 1 | 0.2 | 446 | 98.0 |
| 12:00 | 3 | 0.7 | 449 | 98.7 |
| 13:00 | 2 | 0.4 | 451 | 99.1 |
| 16:00 | 1 | 0.2 | 452 | 99.3 |
| 19:00 | 2 | 0.4 | 454 | 99.8 |
| 20:00 | 1 | 0.2 | 455 | 100.0 |

Frequency Missing = 24

light hours/from: Aug Week

| LF7F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 79 | 17.3 | 79 | 17.3 |
| 4:00 | 4 | 0.9 | 83 | 18.2 |
| 4:30 | 2 | 0.4 | 85 | 18.6 |
| 5:00 | 10 | 2.2 | 95 | 20.8 |
| 5:15 | 1 | 0.2 | 96 | 21.1 |
| 5:30 | 5 | 1.1 | 101 | 22.1 |
| 5:45 | 1 | 0.2 | 102 | 22.4 |
| 6:00 | 47 | 10.3 | 149 | 32.7 |
| 6:30 | 7 | 1.5 | 156 | 34.2 |
| 7:00 | 63 | 13.8 | 219 | 48.0 |
| 7:30 | 39 | 8.6 | 258 | 56.6 |
| 7:45 | 1 | 0.2 | 259 | 56.8 |
| 8:00 | 93 | 20.4 | 352 | 77.2 |
| 8:15 | 1 | 0.2 | 353 | 77.4 |
| 8:30 | 18 | 3.9 | 371 | 81.4 |
| 9:00 | 51 | 11.2 | 422 | 92.5 |
| 9:30 | 7 | 1.5 | 429 | 94.1 |
| 10:00 | 16 | 3.5 | 445 | 97.6 |
| 10:30 | 1 | 0.2 | 446 | 97.8 |
| 11:00 | 3 | 0.7 | 449 | 98.5 |
| 12:00 | 1 | 0.2 | 450 | 98.7 |
| 14:00 | 1 | 0.2 | 451 | 98.9 |
| 16:00 | 1 | 0.2 | 452 | 99.1 |
| 17:00 | 1 | 0.2 | 453 | 99.3 |
| 19:00 | 1 | 0.2 | 454 | 99.6 |
| 20:30 | 1 | 0.2 | 455 | 99.8 |
| 21:00 | 1 | 0.2 | 456 | 100.0 |

Frequency Missing = 23

light hours/from: Aug Sat

| LF8F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 222 | 48.9 | 222 | 48.9 |
| 4:00 | 1 | 0.2 | 223 | 49.1 |
| 4:30 | 1 | 0.2 | 224 | 49.3 |
| 5:00 | 8 | 1.8 | 232 | 51.1 |
| 5:15 | 1 | 0.2 | 233 | 51.3 |
| 5:30 | 1 | 0.2 | 234 | 51.5 |
| 6:00 | 30 | 6.6 | 264 | 58.1 |
| 6:30 | 1 | 0.2 | 265 | 58.4 |
| 7:00 | 20 | 4.4 | 285 | 62.8 |
| 7:30 | 15 | 3.3 | 300 | 66.1 |
| 7:45 | 1 | 0.2 | 301 | 66.3 |
| 8:00 | 53 | 11.7 | 354 | 78.0 |
| 8:30 | 6 | 1.3 | 360 | 79.3 |
| 8:45 | 1 | 0.2 | 361 | 79.5 |
| 9:00 | 50 | 11.0 | 411 | 90.5 |
| 9:30 | 4 | 0.9 | 415 | 91.4 |
| 10:00 | 25 | 5.5 | 440 | 96.9 |
| 11:00 | 3 | 0.7 | 443 | 97.6 |
| 11:30 | 1 | 0.2 | 444 | 97.8 |
| 12:00 | 1 | 0.2 | 445 | 98.0 |
| 13:00 | 1 | 0.2 | 446 | 98.2 |
| 14:00 | 2 | 0.4 | 448 | 98.7 |
| 16:00 | 1 | 0.2 | 449 | 98.9 |
| 17:00 | 1 | 0.2 | 450 | 99.1 |
| 17:30 | 1 | 0.2 | 451 | 99.3 |
| 19:00 | 1 | 0.2 | 452 | 99.6 |
| 20:00 | 1 | 0.2 | 453 | 99.8 |
| 21:00 | 1 | 0.2 | 454 | 100.0 |

Frequency Missing = 25

light hours/from: Aug Sun

| LF9F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 305 | 66.9 | 305 | 66.9 |
| 4:00 | 1 | 0.2 | 306 | 67.1 |
| 4:30 | 1 | 0.2 | 307 | 67.3 |
| 5:00 | 3 | 0.7 | 310 | 68.0 |
| 5:30 | 1 | 0.2 | 311 | 68.2 |
| 6:00 | 28 | 6.1 | 339 | 74.3 |
| 6:30 | 1 | 0.2 | 340 | 74.6 |
| 7:00 | 11 | 2.4 | 351 | 77.0 |
| 7:30 | 6 | 1.3 | 357 | 78.3 |
| 8:00 | 30 | 6.6 | 387 | 84.9 |
| 8:30 | 3 | 0.7 | 390 | 85.5 |
| 9:00 | 23 | 5.0 | 413 | 90.6 |
| 9:30 | 1 | 0.2 | 414 | 90.8 |
| 10:00 | 16 | 3.5 | 430 | 94.3 |
| 10:30 | 2 | 0.4 | 432 | 94.7 |
| 11:00 | 13 | 2.9 | 445 | 97.6 |
| 11:30 | 1 | 0.2 | 446 | 97.8 |
| 12:00 | 3 | 0.7 | 449 | 98.5 |
| 13:00 | 2 | 0.4 | 451 | 98.9 |
| 14:00 | 1 | 0.2 | 452 | 99.1 |
| 16:00 | 1 | 0.2 | 453 | 99.3 |
| 19:00 | 1 | 0.2 | 454 | 99.6 |
| 20:00 | 1 | 0.2 | 455 | 99.8 |
| 21:00 | 1 | 0.2 | 456 | 100.0 |

Frequency Missing = 23

light hours/from: Oct Week

| LF10F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 47 | 10.3 | 47 | 10.3 |
| 4:00 | 4 | 0.9 | 51 | 11.2 |
| 4:30 | 1 | 0.2 | 52 | 11.4 |
| 5:00 | 10 | 2.2 | 62 | 13.6 |
| 5:15 | 1 | 0.2 | 63 | 13.8 |
| 5:30 | 5 | 1.1 | 68 | 14.9 |
| 5:45 | 1 | 0.2 | 69 | 15.1 |
| 6:00 | 47 | 10.3 | 116 | 25.4 |
| 6:30 | 16 | 3.5 | 132 | 28.9 |
| 7:00 | 78 | 17.1 | 210 | 46.1 |
| 7:30 | 40 | 8.8 | 250 | 54.8 |
| 7:45 | 1 | 0.2 | 251 | 55.0 |
| 8:00 | 103 | 22.6 | 354 | 77.6 |
| 8:15 | 1 | 0.2 | 355 | 77.9 |
| 8:30 | 17 | 3.7 | 372 | 81.6 |
| 9:00 | 49 | 10.7 | 421 | 92.3 |
| 9:30 | 7 | 1.5 | 428 | 93.9 |
| 10:00 | 15 | 3.3 | 443 | 97.1 |
| 10:30 | 1 | 0.2 | 444 | 97.4 |
| 11:00 | 4 | 0.9 | 448 | 98.2 |
| 12:00 | 1 | 0.2 | 449 | 98.5 |
| 16:00 | 2 | 0.4 | 451 | 98.9 |
| 16:30 | 1 | 0.2 | 452 | 99.1 |
| 17:00 | 1 | 0.2 | 453 | 99.3 |
| 18:00 | 1 | 0.2 | 454 | 99.6 |
| 19:00 | 2 | 0.4 | 456 | 100.0 |

Frequency Missing = 23

light hours/from: Oct Sat

| LF11F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 222 | 48.9 | 222 | 48.9 |
| 4:00 | 1 | 0.2 | 223 | 49.1 |
| 5:00 | 9 | 2.0 | 232 | 51.1 |
| 5:15 | 1 | 0.2 | 233 | 51.3 |
| 5:30 | 1 | 0.2 | 234 | 51.5 |
| 6:00 | 30 | 6.6 | 264 | 58.1 |
| 6:30 | 1 | 0.2 | 265 | 58.4 |
| 7:00 | 19 | 4.2 | 284 | 62.6 |
| 7:30 | 15 | 3.3 | 299 | 65.9 |
| 7:45 | 1 | 0.2 | 300 | 66.1 |
| 8:00 | 54 | 11.9 | 354 | 78.0 |
| 8:30 | 5 | 1.1 | 359 | 79.1 |
| 8:45 | 1 | 0.2 | 360 | 79.3 |
| 9:00 | 49 | 10.8 | 409 | 90.1 |
| 9:30 | 4 | 0.9 | 413 | 91.0 |
| 10:00 | 25 | 5.5 | 438 | 96.5 |
| 11:00 | 4 | 0.9 | 442 | 97.4 |
| 11:30 | 1 | 0.2 | 443 | 97.6 |
| 12:00 | 1 | 0.2 | 444 | 97.8 |
| 13:00 | 1 | 0.2 | 445 | 98.0 |
| 14:00 | 1 | 0.2 | 446 | 98.2 |
| 16:00 | 2 | 0.4 | 448 | 98.7 |
| 16:30 | 1 | 0.2 | 449 | 98.9 |
| 17:00 | 1 | 0.2 | 450 | 99.1 |
| 17:30 | 1 | 0.2 | 451 | 99.3 |
| 18:00 | 1 | 0.2 | 452 | 99.6 |
| 19:00 | 1 | 0.2 | 453 | 99.8 |
| 20:00 | 1 | 0.2 | 454 | 100.0 |

Frequency Missing = 25

light hours/from: Oct Sun

| LF12F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 306 | 67.1 | 306 | 67.1 |
| 4:00 | 1 | 0.2 | 307 | 67.3 |
| 5:00 | 4 | 0.9 | 311 | 68.2 |
| 5:30 | 1 | 0.2 | 312 | 68.4 |
| 6:00 | 28 | 6.1 | 340 | 74.6 |
| 6:30 | 1 | 0.2 | 341 | 74.8 |
| 7:00 | 10 | 2.2 | 351 | 77.0 |
| 7:30 | 6 | 1.3 | 357 | 78.3 |
| 8:00 | 30 | 6.6 | 387 | 84.9 |
| 8:30 | 2 | 0.4 | 389 | 85.3 |
| 9:00 | 22 | 4.8 | 411 | 90.1 |
| 9:30 | 1 | 0.2 | 412 | 90.4 |
| 10:00 | 16 | 3.5 | 428 | 93.9 |
| 10:30 | 2 | 0.4 | 430 | 94.3 |
| 11:00 | 14 | 3.1 | 444 | 97.4 |
| 11:30 | 1 | 0.2 | 445 | 97.6 |
| 12:00 | 3 | 0.7 | 448 | 98.2 |
| 13:00 | 2 | 0.4 | 450 | 98.7 |
| 16:00 | 2 | 0.4 | 452 | 99.1 |
| 16:30 | 1 | 0.2 | 453 | 99.3 |
| 18:00 | 1 | 0.2 | 454 | 99.6 |
| 19:00 | 1 | 0.2 | 455 | 99.8 |
| 20:00 | 1 | 0.2 | 456 | 100.0 |

Frequency Missing = 23

light hours/from: Holiday

| LF13F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 358 | 79.6 | 358 | 79.6 |
| 5:00 | 2 | 0.4 | 360 | 80.0 |
| 5:15 | 1 | 0.2 | 361 | 80.2 |
| 5:30 | 2 | 0.4 | 363 | 80.7 |
| 6:00 | 23 | 5.1 | 386 | 85.8 |
| 6:30 | 1 | 0.2 | 387 | 86.0 |
| 7:00 | 7 | 1.6 | 394 | 87.6 |
| 7:30 | 5 | 1.1 | 399 | 88.7 |
| 8:00 | 20 | 4.4 | 419 | 93.1 |
| 8:30 | 3 | 0.7 | 422 | 93.8 |
| 9:00 | 8 | 1.8 | 430 | 95.6 |
| 9:30 | 1 | 0.2 | 431 | 95.8 |
| 10:00 | 9 | 2.0 | 440 | 97.8 |
| 10:30 | 1 | 0.2 | 441 | 98.0 |
| 11:00 | 4 | 0.9 | 445 | 98.9 |
| 12:00 | 1 | 0.2 | 446 | 99.1 |
| 16:00 | 1 | 0.2 | 447 | 99.3 |
| 16:30 | 1 | 0.2 | 448 | 99.6 |
| 17:00 | 1 | 0.2 | 449 | 99.8 |
| 19:00 | 1 | 0.2 | 450 | 100.0 |

Frequency Missing = 29

light hours/am or pm: Dec Week

| LF1M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 460 | 96.4 | 460 | 96.4 |
| D | 10 | 2.1 | 470 | 98.5 |
| P | 7 | 1.5 | 477 | 100.0 |

Frequency Missing = 2

light hours/am or pm: Dec Sat

| LF2M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 453 | 95.4 | 453 | 95.4 |
| D | 12 | 2.5 | 465 | 97.9 |
| P | 10 | 2.1 | 475 | 100.0 |

Frequency Missing = 4

light hours/am or pm: Dec Sun

| LF3M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 453 | 95.4 | 453 | 95.4 |
| D | 11 | 2.3 | 464 | 97.7 |
| P | 11 | 2.3 | 475 | 100.0 |

Frequency Missing = 4

light hours/am or pm: Apr Week

| LF4M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 453 | 96.6 | 453 | 96.6 |
| D | 10 | 2.1 | 463 | 98.7 |
| P | 6 | 1.3 | 469 | 100.0 |

Frequency Missing = 10

light hours/am or pm: Apr Sat

| LF5M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 446 | 95.5 | 446 | 95.5 |
| D | 12 | 2.6 | 458 | 98.1 |
| P | 9 | 1.9 | 467 | 100.0 |

Frequency Missing = 12

light hours/am or pm: Apr Sun

| LF6M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 445 | 95.7 | 445 | 95.7 |
| D | 11 | 2.4 | 456 | 98.1 |
| P | 9 | 1.9 | 465 | 100.0 |

Frequency Missing = 14

light hours/am or pm: Aug Week

| LF7M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 448 | 96.3 | 448 | 96.3 |
| D | 10 | 2.2 | 458 | 98.5 |
| P | 7 | 1.5 | 465 | 100.0 |

Frequency Missing = 14

light hours/am or pm: Aug Sat

| LF8M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 443 | 95.3 | 443 | 95.3 |
| D | 12 | 2.6 | 455 | 97.8 |
| P | 10 | 2.2 | 465 | 100.0 |

Frequency Missing = 14

light hours/am or pm: Aug Sun

| LF9M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 445 | 95.5 | 445 | 95.5 |
| D | 11 | 2.4 | 456 | 97.9 |
| P | 10 | 2.1 | 466 | 100.0 |

Frequency Missing = 13

light hours/am or pm: Oct Week

| LF10M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 447 | 96.1 | 447 | 96.1 |
| D | 10 | 2.2 | 457 | 98.3 |
| P | 8 | 1.7 | 465 | 100.0 |

Frequency Missing = 14

light hours/am or pm: Oct Sat

| LF11M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 442 | 95.1 | 442 | 95.1 |
| D | 12 | 2.6 | 454 | 97.6 |
| P | 11 | 2.4 | 465 | 100.0 |

Frequency Missing = 14

light hours/am or pm: Oct Sun

| LF12M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 444 | 95.3 | 444 | 95.3 |
| D | 11 | 2.4 | 455 | 97.6 |
| P | 11 | 2.4 | 466 | 100.0 |

Frequency Missing = 13

light hours/am or pm: Holiday

| LF13M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 444 | 95.7 | 444 | 95.7 |
| D | 15 | 3.2 | 459 | 98.9 |
| P | 5 | 1.1 | 464 | 100.0 |

Frequency Missing = 15

light hours/to: Dec Week

| LF1T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 1 | 0.2 | 1 | 0.2 |
| 1:00 | 1 | 0.2 | 2 | 0.4 |
| 1:30 | 1 | 0.2 | 3 | 0.6 |
| 2:00 | 1 | 0.2 | 4 | 0.9 |
| 3:00 | 1 | 0.2 | 5 | 1.1 |
| 5:00 | 1 | 0.2 | 6 | 1.3 |
| 6:00 | 2 | 0.4 | 8 | 1.7 |
| 7:00 | 2 | 0.4 | 10 | 2.1 |
| 7:30 | 1 | 0.2 | 11 | 2.3 |
| 9:00 | 1 | 0.2 | 12 | 2.6 |
| 11:00 | 6 | 1.3 | 18 | 3.8 |
| 12:00 | 3 | 0.6 | 21 | 4.5 |
| 13:00 | 3 | 0.6 | 24 | 5.1 |
| 14:30 | 1 | 0.2 | 25 | 5.3 |
| 15:00 | 19 | 4.1 | 44 | 9.4 |
| 15:30 | 7 | 1.5 | 51 | 10.9 |
| 16:00 | 19 | 4.1 | 70 | 14.9 |
| 16:15 | 1 | 0.2 | 71 | 15.1 |
| 16:30 | 18 | 3.8 | 89 | 19.0 |
| 17:00 | 81 | 17.3 | 170 | 36.2 |
| 17:30 | 25 | 5.3 | 195 | 41.6 |
| 18:00 | 86 | 18.3 | 281 | 59.9 |
| 18:30 | 5 | 1.1 | 286 | 61.0 |
| 19:00 | 29 | 6.2 | 315 | 67.2 |
| 19:30 | 5 | 1.1 | 320 | 68.2 |
| 20:00 | 18 | 3.8 | 338 | 72.1 |
| 20:30 | 3 | 0.6 | 341 | 72.7 |
| 20:45 | 1 | 0.2 | 342 | 72.9 |
| 21:00 | 19 | 4.1 | 361 | 77.0 |
| 21:30 | 5 | 1.1 | 366 | 78.0 |
| 22:00 | 25 | 5.3 | 391 | 83.4 |
| 22:30 | 2 | 0.4 | 393 | 83.8 |
| 23:00 | 9 | 1.9 | 402 | 85.7 |
| 23:30 | 2 | 0.4 | 404 | 86.1 |
| 23:58 | 1 | 0.2 | 405 | 86.4 |
| 24:00 | 62 | 13.2 | 467 | 99.6 |
| 24:30 | 2 | 0.4 | 469 | 100.0 |

Frequency Missing = 10

light hours/to: Dec Sat

| LF2T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 181 | 39.0 | 181 | 39.0 |
| 1:00 | 1 | 0.2 | 182 | 39.2 |
| 1:30 | 1 | 0.2 | 183 | 39.4 |
| 2:00 | 1 | 0.2 | 184 | 39.7 |
| 3:00 | 1 | 0.2 | 185 | 39.9 |
| 5:00 | 1 | 0.2 | 186 | 40.1 |
| 6:00 | 1 | 0.2 | 187 | 40.3 |
| 7:00 | 1 | 0.2 | 188 | 40.5 |
| 7:30 | 1 | 0.2 | 189 | 40.7 |
| 9:00 | 1 | 0.2 | 190 | 40.9 |
| 11:00 | 5 | 1.1 | 195 | 42.0 |
| 11:30 | 1 | 0.2 | 196 | 42.2 |
| 12:00 | 16 | 3.4 | 212 | 45.7 |
| 13:00 | 6 | 1.3 | 218 | 47.0 |
| 13:30 | 1 | 0.2 | 219 | 47.2 |
| 14:00 | 5 | 1.1 | 224 | 48.3 |
| 14:30 | 1 | 0.2 | 225 | 48.5 |
| 15:00 | 13 | 2.8 | 238 | 51.3 |
| 15:30 | 1 | 0.2 | 239 | 51.5 |
| 16:00 | 7 | 1.5 | 246 | 53.0 |
| 16:30 | 1 | 0.2 | 247 | 53.2 |
| 17:00 | 36 | 7.8 | 283 | 61.0 |
| 17:30 | 9 | 1.9 | 292 | 62.9 |
| 17:45 | 1 | 0.2 | 293 | 63.1 |
| 18:00 | 39 | 8.4 | 332 | 71.6 |
| 18:30 | 3 | 0.6 | 335 | 72.2 |
| 19:00 | 17 | 3.7 | 352 | 75.9 |
| 20:00 | 10 | 2.2 | 362 | 78.0 |
| 20:30 | 2 | 0.4 | 364 | 78.4 |
| 21:00 | 9 | 1.9 | 373 | 80.4 |
| 21:30 | 4 | 0.9 | 377 | 81.2 |
| 22:00 | 17 | 3.7 | 394 | 84.9 |
| 22:30 | 1 | 0.2 | 395 | 85.1 |
| 23:00 | 5 | 1.1 | 400 | 86.2 |
| 23:30 | 1 | 0.2 | 401 | 86.4 |
| 23:58 | 1 | 0.2 | 402 | 86.6 |
| 24:00 | 60 | 12.9 | 462 | 99.6 |
| 24:30 | 2 | 0.4 | 464 | 100.0 |

Frequency Missing = 15

light hours/to: Dec Sun

| LF3T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 265 | 57.0 | 265 | 57.0 |
| 1:00 | 1 | 0.2 | 266 | 57.2 |
| 1:30 | 1 | 0.2 | 267 | 57.4 |
| 2:00 | 1 | 0.2 | 268 | 57.6 |
| 3:00 | 1 | 0.2 | 269 | 57.8 |
| 5:00 | 1 | 0.2 | 270 | 58.1 |
| 6:00 | 1 | 0.2 | 271 | 58.3 |
| 7:00 | 1 | 0.2 | 272 | 58.5 |
| 7:30 | 1 | 0.2 | 273 | 58.7 |
| 9:00 | 1 | 0.2 | 274 | 58.9 |
| 11:00 | 11 | 2.4 | 285 | 61.3 |
| 12:00 | 8 | 1.7 | 293 | 63.0 |
| 13:00 | 4 | 0.9 | 297 | 63.9 |
| 14:00 | 4 | 0.9 | 301 | 64.7 |
| 15:00 | 1 | 0.2 | 302 | 64.9 |
| 15:30 | 1 | 0.2 | 303 | 65.2 |
| 16:00 | 4 | 0.9 | 307 | 66.0 |
| 16:30 | 1 | 0.2 | 308 | 66.2 |
| 16:45 | 1 | 0.2 | 309 | 66.5 |
| 17:00 | 22 | 4.7 | 331 | 71.2 |
| 17:30 | 2 | 0.4 | 333 | 71.6 |
| 18:00 | 22 | 4.7 | 355 | 76.3 |
| 18:30 | 1 | 0.2 | 356 | 76.6 |
| 19:00 | 11 | 2.4 | 367 | 78.9 |
| 20:00 | 8 | 1.7 | 375 | 80.6 |
| 20:30 | 4 | 0.9 | 379 | 81.5 |
| 21:00 | 7 | 1.5 | 386 | 83.0 |
| 21:30 | 1 | 0.2 | 387 | 83.2 |
| 22:00 | 13 | 2.8 | 400 | 86.0 |
| 22:30 | 1 | 0.2 | 401 | 86.2 |
| 23:00 | 4 | 0.9 | 405 | 87.1 |
| 23:58 | 1 | 0.2 | 406 | 87.3 |
| 24:00 | 57 | 12.3 | 463 | 99.6 |
| 24:30 | 2 | 0.4 | 465 | 100.0 |

Frequency Missing = 14

light hours/to: Apr Week

| LF4T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 1 | 0.2 | 1 | 0.2 |
| 1:00 | 1 | 0.2 | 2 | 0.4 |
| 1:30 | 1 | 0.2 | 3 | 0.7 |
| 2:00 | 1 | 0.2 | 4 | 0.9 |
| 3:00 | 1 | 0.2 | 5 | 1.1 |
| 5:00 | 1 | 0.2 | 6 | 1.3 |
| 5:45 | 1 | 0.2 | 7 | 1.5 |
| 6:00 | 3 | 0.7 | 10 | 2.2 |
| 6:30 | 1 | 0.2 | 11 | 2.4 |
| 7:00 | 1 | 0.2 | 12 | 2.6 |
| 9:00 | 1 | 0.2 | 13 | 2.8 |
| 10:30 | 1 | 0.2 | 14 | 3.0 |
| 11:00 | 6 | 1.3 | 20 | 4.3 |
| 12:00 | 3 | 0.7 | 23 | 5.0 |
| 13:00 | 2 | 0.4 | 25 | 5.4 |
| 14:30 | 1 | 0.2 | 26 | 5.7 |
| 15:00 | 18 | 3.9 | 44 | 9.6 |
| 15:30 | 7 | 1.5 | 51 | 11.1 |
| 16:00 | 19 | 4.1 | 70 | 15.2 |
| 16:15 | 1 | 0.2 | 71 | 15.4 |
| 16:30 | 18 | 3.9 | 89 | 19.3 |
| 17:00 | 79 | 17.2 | 168 | 36.5 |
| 17:30 | 23 | 5.0 | 191 | 41.5 |
| 18:00 | 80 | 17.4 | 271 | 58.9 |
| 18:30 | 5 | 1.1 | 276 | 60.0 |
| 19:00 | 29 | 6.3 | 305 | 66.3 |
| 19:30 | 5 | 1.1 | 310 | 67.4 |
| 20:00 | 20 | 4.3 | 330 | 71.7 |
| 20:30 | 3 | 0.7 | 333 | 72.4 |
| 21:00 | 20 | 4.3 | 353 | 76.7 |
| 21:30 | 5 | 1.1 | 358 | 77.8 |
| 22:00 | 21 | 4.6 | 379 | 82.4 |
| 22:30 | 2 | 0.4 | 381 | 82.8 |
| 23:00 | 12 | 2.6 | 393 | 85.4 |
| 23:30 | 3 | 0.7 | 396 | 86.1 |
| 23:58 | 1 | 0.2 | 397 | 86.3 |
| 24:00 | 61 | 13.3 | 458 | 99.6 |
| 24:30 | 2 | 0.4 | 460 | 100.0 |

Frequency Missing = 19

light hours/to: Apr Sat

| LF5T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 174 | 38.2 | 174 | 38.2 |
| 1:00 | 1 | 0.2 | 175 | 38.4 |
| 1:30 | 1 | 0.2 | 176 | 38.6 |
| 2:00 | 1 | 0.2 | 177 | 38.8 |
| 3:00 | 1 | 0.2 | 178 | 39.0 |
| 5:00 | 1 | 0.2 | 179 | 39.3 |
| 5:45 | 1 | 0.2 | 180 | 39.5 |
| 6:00 | 2 | 0.4 | 182 | 39.9 |
| 6:30 | 1 | 0.2 | 183 | 40.1 |
| 9:00 | 1 | 0.2 | 184 | 40.4 |
| 10:30 | 1 | 0.2 | 185 | 40.6 |
| 11:00 | 5 | 1.1 | 190 | 41.7 |
| 11:30 | 1 | 0.2 | 191 | 41.9 |
| 12:00 | 16 | 3.5 | 207 | 45.4 |
| 13:00 | 5 | 1.1 | 212 | 46.5 |
| 13:30 | 1 | 0.2 | 213 | 46.7 |
| 14:00 | 6 | 1.3 | 219 | 48.0 |
| 14:30 | 1 | 0.2 | 220 | 48.2 |
| 15:00 | 12 | 2.6 | 232 | 50.9 |
| 15:30 | 1 | 0.2 | 233 | 51.1 |
| 16:00 | 8 | 1.8 | 241 | 52.9 |
| 16:30 | 1 | 0.2 | 242 | 53.1 |
| 17:00 | 35 | 7.7 | 277 | 60.7 |
| 17:30 | 8 | 1.8 | 285 | 62.5 |
| 17:45 | 1 | 0.2 | 286 | 62.7 |
| 18:00 | 38 | 8.3 | 324 | 71.1 |
| 18:30 | 3 | 0.7 | 327 | 71.7 |
| 19:00 | 17 | 3.7 | 344 | 75.4 |
| 20:00 | 12 | 2.6 | 356 | 78.1 |
| 20:30 | 2 | 0.4 | 358 | 78.5 |
| 21:00 | 8 | 1.8 | 366 | 80.3 |
| 21:30 | 4 | 0.9 | 370 | 81.1 |
| 22:00 | 14 | 3.1 | 384 | 84.2 |
| 22:30 | 1 | 0.2 | 385 | 84.4 |
| 23:00 | 8 | 1.8 | 393 | 86.2 |
| 23:30 | 1 | 0.2 | 394 | 86.4 |
| 23:58 | 1 | 0.2 | 395 | 86.6 |
| 24:00 | 59 | 12.9 | 454 | 99.6 |
| 24:30 | 2 | 0.4 | 456 | 100.0 |

Frequency Missing = 23

light hours/to: Apr Sun

| LF6T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 257 | 56.5 | 257 | 56.5 |
| 1:00 | 1 | 0.2 | 258 | 56.7 |
| 1:30 | 1 | 0.2 | 259 | 56.9 |
| 2:00 | 1 | 0.2 | 260 | 57.1 |
| 3:00 | 1 | 0.2 | 261 | 57.4 |
| 5:00 | 1 | 0.2 | 262 | 57.6 |
| 5:45 | 1 | 0.2 | 263 | 57.8 |
| 6:00 | 2 | 0.4 | 265 | 58.2 |
| 6:30 | 1 | 0.2 | 266 | 58.5 |
| 9:00 | 1 | 0.2 | 267 | 58.7 |
| 10:30 | 1 | 0.2 | 268 | 58.9 |
| 11:00 | 6 | 1.3 | 274 | 60.2 |
| 12:00 | 8 | 1.8 | 282 | 62.0 |
| 13:00 | 4 | 0.9 | 286 | 62.9 |
| 14:00 | 4 | 0.9 | 290 | 63.7 |
| 15:00 | 2 | 0.4 | 292 | 64.2 |
| 15:30 | 1 | 0.2 | 293 | 64.4 |
| 16:00 | 3 | 0.7 | 296 | 65.1 |
| 16:30 | 1 | 0.2 | 297 | 65.3 |
| 16:45 | 1 | 0.2 | 298 | 65.5 |
| 17:00 | 20 | 4.4 | 318 | 69.9 |
| 17:30 | 2 | 0.4 | 320 | 70.3 |
| 18:00 | 21 | 4.6 | 341 | 74.9 |
| 18:30 | 1 | 0.2 | 342 | 75.2 |
| 19:00 | 12 | 2.6 | 354 | 77.8 |
| 20:00 | 8 | 1.8 | 362 | 79.6 |
| 20:30 | 4 | 0.9 | 366 | 80.4 |
| 21:00 | 7 | 1.5 | 373 | 82.0 |
| 21:30 | 1 | 0.2 | 374 | 82.2 |
| 22:00 | 11 | 2.4 | 385 | 84.6 |
| 22:30 | 1 | 0.2 | 386 | 84.8 |
| 23:00 | 7 | 1.5 | 393 | 86.4 |
| 23:58 | 1 | 0.2 | 394 | 86.6 |
| 24:00 | 59 | 13.0 | 453 | 99.6 |
| 24:30 | 2 | 0.4 | 455 | 100.0 |

Frequency Missing = 24

light hours/to: Aug Week

| LF7T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 35 | 7.7 | 35 | 7.7 |
| 1:00 | 1 | 0.2 | 36 | 7.9 |
| 1:30 | 1 | 0.2 | 37 | 8.1 |
| 2:00 | 1 | 0.2 | 38 | 8.3 |
| 2:30 | 1 | 0.2 | 39 | 8.5 |
| 3:00 | 1 | 0.2 | 40 | 8.8 |
| 5:00 | 1 | 0.2 | 41 | 9.0 |
| 5:30 | 1 | 0.2 | 42 | 9.2 |
| 6:00 | 3 | 0.7 | 45 | 9.8 |
| 6:30 | 1 | 0.2 | 46 | 10.1 |
| 7:00 | 1 | 0.2 | 47 | 10.3 |
| 9:00 | 1 | 0.2 | 48 | 10.5 |
| 11:00 | 6 | 1.3 | 54 | 11.8 |
| 12:00 | 4 | 0.9 | 58 | 12.7 |
| 13:00 | 5 | 1.1 | 63 | 13.8 |
| 14:30 | 1 | 0.2 | 64 | 14.0 |
| 15:00 | 5 | 1.1 | 69 | 15.1 |
| 15:30 | 5 | 1.1 | 74 | 16.2 |
| 16:00 | 12 | 2.6 | 86 | 18.8 |
| 16:15 | 1 | 0.2 | 87 | 19.0 |
| 16:30 | 6 | 1.3 | 93 | 20.4 |
| 17:00 | 81 | 17.7 | 174 | 38.1 |
| 17:30 | 24 | 5.3 | 198 | 43.3 |
| 18:00 | 80 | 17.5 | 278 | 60.8 |
| 18:30 | 5 | 1.1 | 283 | 61.9 |
| 19:00 | 28 | 6.1 | 311 | 68.1 |
| 19:30 | 5 | 1.1 | 316 | 69.1 |
| 20:00 | 17 | 3.7 | 333 | 72.9 |
| 20:30 | 3 | 0.7 | 336 | 73.5 |
| 21:00 | 19 | 4.2 | 355 | 77.7 |
| 21:30 | 5 | 1.1 | 360 | 78.8 |
| 22:00 | 19 | 4.2 | 379 | 82.9 |
| 22:30 | 2 | 0.4 | 381 | 83.4 |
| 23:00 | 11 | 2.4 | 392 | 85.8 |
| 23:30 | 3 | 0.7 | 395 | 86.4 |
| 23:58 | 1 | 0.2 | 396 | 86.7 |
| 24:00 | 59 | 12.9 | 455 | 99.6 |
| 24:30 | 2 | 0.4 | 457 | 100.0 |

Frequency Missing = 22

light hours/to: Aug Sat

| LF8T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 179 | 39.4 | 179 | 39.4 |
| 1:00 | 1 | 0.2 | 180 | 39.6 |
| 1:30 | 1 | 0.2 | 181 | 39.9 |
| 2:00 | 2 | 0.4 | 183 | 40.3 |
| 3:00 | 1 | 0.2 | 184 | 40.5 |
| 5:00 | 1 | 0.2 | 185 | 40.7 |
| 5:45 | 1 | 0.2 | 186 | 41.0 |
| 6:00 | 2 | 0.4 | 188 | 41.4 |
| 6:30 | 1 | 0.2 | 189 | 41.6 |
| 9:00 | 1 | 0.2 | 190 | 41.9 |
| 11:00 | 5 | 1.1 | 195 | 43.0 |
| 11:30 | 1 | 0.2 | 196 | 43.2 |
| 12:00 | 16 | 3.5 | 212 | 46.7 |
| 13:00 | 5 | 1.1 | 217 | 47.8 |
| 13:30 | 1 | 0.2 | 218 | 48.0 |
| 14:00 | 5 | 1.1 | 223 | 49.1 |
| 14:30 | 1 | 0.2 | 224 | 49.3 |
| 15:00 | 12 | 2.6 | 236 | 52.0 |
| 15:30 | 1 | 0.2 | 237 | 52.2 |
| 16:00 | 8 | 1.8 | 245 | 54.0 |
| 16:30 | 1 | 0.2 | 246 | 54.2 |
| 17:00 | 34 | 7.5 | 280 | 61.7 |
| 17:30 | 9 | 2.0 | 289 | 63.7 |
| 17:45 | 1 | 0.2 | 290 | 63.9 |
| 18:00 | 36 | 7.9 | 326 | 71.8 |
| 18:30 | 3 | 0.7 | 329 | 72.5 |
| 19:00 | 16 | 3.5 | 345 | 76.0 |
| 20:00 | 11 | 2.4 | 356 | 78.4 |
| 20:30 | 2 | 0.4 | 358 | 78.9 |
| 21:00 | 9 | 2.0 | 367 | 80.8 |
| 21:30 | 4 | 0.9 | 371 | 81.7 |
| 22:00 | 14 | 3.1 | 385 | 84.8 |
| 22:30 | 1 | 0.2 | 386 | 85.0 |
| 23:00 | 8 | 1.8 | 394 | 86.8 |
| 23:30 | 1 | 0.2 | 395 | 87.0 |
| 23:58 | 1 | 0.2 | 396 | 87.2 |
| 24:00 | 56 | 12.3 | 452 | 99.6 |
| 24:30 | 2 | 0.4 | 454 | 100.0 |

Frequency Missing = 25

light hours/to: Aug Sun

| LF9T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 259 | 56.8 | 259 | 56.8 |
| 1:00 | 1 | 0.2 | 260 | 57.0 |
| 1:30 | 1 | 0.2 | 261 | 57.2 |
| 2:00 | 1 | 0.2 | 262 | 57.5 |
| 3:00 | 1 | 0.2 | 263 | 57.7 |
| 5:00 | 1 | 0.2 | 264 | 57.9 |
| 5:45 | 1 | 0.2 | 265 | 58.1 |
| 6:00 | 2 | 0.4 | 267 | 58.6 |
| 6:30 | 1 | 0.2 | 268 | 58.8 |
| 9:00 | 1 | 0.2 | 269 | 59.0 |
| 11:00 | 6 | 1.3 | 275 | 60.3 |
| 12:00 | 9 | 2.0 | 284 | 62.3 |
| 13:00 | 3 | 0.7 | 287 | 62.9 |
| 14:00 | 4 | 0.9 | 291 | 63.8 |
| 15:00 | 2 | 0.4 | 293 | 64.3 |
| 15:30 | 1 | 0.2 | 294 | 64.5 |
| 16:00 | 3 | 0.7 | 297 | 65.1 |
| 16:30 | 1 | 0.2 | 298 | 65.4 |
| 16:45 | 1 | 0.2 | 299 | 65.6 |
| 17:00 | 20 | 4.4 | 319 | 70.0 |
| 17:30 | 3 | 0.7 | 322 | 70.6 |
| 18:00 | 20 | 4.4 | 342 | 75.0 |
| 18:30 | 1 | 0.2 | 343 | 75.2 |
| 19:00 | 11 | 2.4 | 354 | 77.6 |
| 20:00 | 8 | 1.8 | 362 | 79.4 |
| 20:30 | 4 | 0.9 | 366 | 80.3 |
| 21:00 | 7 | 1.5 | 373 | 81.8 |
| 21:30 | 1 | 0.2 | 374 | 82.0 |
| 22:00 | 11 | 2.4 | 385 | 84.4 |
| 22:30 | 1 | 0.2 | 386 | 84.6 |
| 23:00 | 7 | 1.5 | 393 | 86.2 |
| 23:58 | 1 | 0.2 | 394 | 86.4 |
| 24:00 | 60 | 13.2 | 454 | 99.6 |
| 24:30 | 2 | 0.4 | 456 | 100.0 |

Frequency Missing = 23

light hours/to: Oct Week

| LF10T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 1 | 0.2 | 1 | 0.2 |
| 1:00 | 1 | 0.2 | 2 | 0.4 |
| 1:30 | 1 | 0.2 | 3 | 0.7 |
| 2:00 | 1 | 0.2 | 4 | 0.9 |
| 3:00 | 1 | 0.2 | 5 | 1.1 |
| 5:00 | 1 | 0.2 | 6 | 1.3 |
| 5:30 | 1 | 0.2 | 7 | 1.5 |
| 6:00 | 2 | 0.4 | 9 | 2.0 |
| 7:00 | 2 | 0.4 | 11 | 2.4 |
| 7:30 | 1 | 0.2 | 12 | 2.6 |
| 9:00 | 1 | 0.2 | 13 | 2.8 |
| 11:00 | 6 | 1.3 | 19 | 4.2 |
| 12:00 | 3 | 0.7 | 22 | 4.8 |
| 13:00 | 2 | 0.4 | 24 | 5.3 |
| 14:30 | 1 | 0.2 | 25 | 5.5 |
| 15:00 | 18 | 3.9 | 43 | 9.4 |
| 15:30 | 7 | 1.5 | 50 | 10.9 |
| 16:00 | 18 | 3.9 | 68 | 14.9 |
| 16:30 | 18 | 3.9 | 86 | 18.8 |
| 17:00 | 79 | 17.3 | 165 | 36.1 |
| 17:30 | 26 | 5.7 | 191 | 41.8 |
| 18:00 | 79 | 17.3 | 270 | 59.1 |
| 18:30 | 5 | 1.1 | 275 | 60.2 |
| 19:00 | 29 | 6.3 | 304 | 66.5 |
| 19:30 | 5 | 1.1 | 309 | 67.6 |
| 20:00 | 19 | 4.2 | 328 | 71.8 |
| 20:30 | 3 | 0.7 | 331 | 72.4 |
| 20:45 | 1 | 0.2 | 332 | 72.6 |
| 21:00 | 20 | 4.4 | 352 | 77.0 |
| 21:30 | 5 | 1.1 | 357 | 78.1 |
| 22:00 | 22 | 4.8 | 379 | 82.9 |
| 22:30 | 2 | 0.4 | 381 | 83.4 |
| 23:00 | 11 | 2.4 | 392 | 85.8 |
| 23:30 | 2 | 0.4 | 394 | 86.2 |
| 23:58 | 1 | 0.2 | 395 | 86.4 |
| 24:00 | 60 | 13.1 | 455 | 99.6 |
| 24:30 | 2 | 0.4 | 457 | 100.0 |

Frequency Missing = 22

light hours/to: Oct Sat

| LF11T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 177 | 39.0 | 177 | 39.0 |
| 1:00 | 1 | 0.2 | 178 | 39.2 |
| 1:30 | 1 | 0.2 | 179 | 39.4 |
| 2:00 | 1 | 0.2 | 180 | 39.6 |
| 3:00 | 1 | 0.2 | 181 | 39.9 |
| 5:00 | 1 | 0.2 | 182 | 40.1 |
| 5:30 | 1 | 0.2 | 183 | 40.3 |
| 6:00 | 1 | 0.2 | 184 | 40.5 |
| 7:00 | 1 | 0.2 | 185 | 40.7 |
| 7:30 | 1 | 0.2 | 186 | 41.0 |
| 9:00 | 1 | 0.2 | 187 | 41.2 |
| 11:00 | 5 | 1.1 | 192 | 42.3 |
| 11:30 | 1 | 0.2 | 193 | 42.5 |
| 12:00 | 16 | 3.5 | 209 | 46.0 |
| 13:00 | 5 | 1.1 | 214 | 47.1 |
| 13:30 | 1 | 0.2 | 215 | 47.4 |
| 14:00 | 5 | 1.1 | 220 | 48.5 |
| 14:30 | 1 | 0.2 | 221 | 48.7 |
| 15:00 | 12 | 2.6 | 233 | 51.3 |
| 15:30 | 1 | 0.2 | 234 | 51.5 |
| 16:00 | 8 | 1.8 | 242 | 53.3 |
| 16:30 | 1 | 0.2 | 243 | 53.5 |
| 17:00 | 34 | 7.5 | 277 | 61.0 |
| 17:30 | 10 | 2.2 | 287 | 63.2 |
| 17:45 | 1 | 0.2 | 288 | 63.4 |
| 18:00 | 35 | 7.7 | 323 | 71.1 |
| 18:30 | 3 | 0.7 | 326 | 71.8 |
| 19:00 | 17 | 3.7 | 343 | 75.6 |
| 20:00 | 11 | 2.4 | 354 | 78.0 |
| 20:30 | 2 | 0.4 | 356 | 78.4 |
| 21:00 | 8 | 1.8 | 364 | 80.2 |
| 21:30 | 4 | 0.9 | 368 | 81.1 |
| 22:00 | 15 | 3.3 | 383 | 84.4 |
| 22:30 | 1 | 0.2 | 384 | 84.6 |
| 23:00 | 7 | 1.5 | 391 | 86.1 |
| 23:30 | 1 | 0.2 | 392 | 86.3 |
| 23:58 | 1 | 0.2 | 393 | 86.6 |
| 24:00 | 59 | 13.0 | 452 | 99.6 |
| 24:30 | 2 | 0.4 | 454 | 100.0 |

Frequency Missing = 25

light hours/to: Oct Sun

| LF12T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 258 | 56.6 | 258 | 56.6 |
| 1:00 | 1 | 0.2 | 259 | 56.8 |
| 1:30 | 1 | 0.2 | 260 | 57.0 |
| 2:00 | 1 | 0.2 | 261 | 57.2 |
| 3:00 | 1 | 0.2 | 262 | 57.5 |
| 5:00 | 1 | 0.2 | 263 | 57.7 |
| 5:30 | 1 | 0.2 | 264 | 57.9 |
| 6:00 | 1 | 0.2 | 265 | 58.1 |
| 7:00 | 1 | 0.2 | 266 | 58.3 |
| 7:30 | 1 | 0.2 | 267 | 58.6 |
| 9:00 | 1 | 0.2 | 268 | 58.8 |
| 11:00 | 6 | 1.3 | 274 | 60.1 |
| 12:00 | 8 | 1.8 | 282 | 61.8 |
| 13:00 | 3 | 0.7 | 285 | 62.5 |
| 14:00 | 4 | 0.9 | 289 | 63.4 |
| 15:00 | 2 | 0.4 | 291 | 63.8 |
| 15:30 | 1 | 0.2 | 292 | 64.0 |
| 16:00 | 3 | 0.7 | 295 | 64.7 |
| 16:30 | 1 | 0.2 | 296 | 64.9 |
| 16:45 | 1 | 0.2 | 297 | 65.1 |
| 17:00 | 20 | 4.4 | 317 | 69.5 |
| 17:30 | 3 | 0.7 | 320 | 70.2 |
| 18:00 | 20 | 4.4 | 340 | 74.6 |
| 18:30 | 1 | 0.2 | 341 | 74.8 |
| 19:00 | 12 | 2.6 | 353 | 77.4 |
| 20:00 | 8 | 1.8 | 361 | 79.2 |
| 20:30 | 4 | 0.9 | 365 | 80.0 |
| 21:00 | 7 | 1.5 | 372 | 81.6 |
| 21:30 | 1 | 0.2 | 373 | 81.8 |
| 22:00 | 12 | 2.6 | 385 | 84.4 |
| 22:30 | 1 | 0.2 | 386 | 84.6 |
| 23:00 | 6 | 1.3 | 392 | 86.0 |
| 23:58 | 1 | 0.2 | 393 | 86.2 |
| 24:00 | 61 | 13.4 | 454 | 99.6 |
| 24:30 | 2 | 0.4 | 456 | 100.0 |

Frequency Missing = 23

light hours/to: Holiday

| LF13T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 313 | 69.6 | 313 | 69.6 |
| 2:00 | 1 | 0.2 | 314 | 69.8 |
| 3:00 | 1 | 0.2 | 315 | 70.0 |
| 6:00 | 1 | 0.2 | 316 | 70.2 |
| 7:30 | 1 | 0.2 | 317 | 70.4 |
| 9:00 | 1 | 0.2 | 318 | 70.7 |
| 11:00 | 6 | 1.3 | 324 | 72.0 |
| 11:30 | 1 | 0.2 | 325 | 72.2 |
| 12:00 | 3 | 0.7 | 328 | 72.9 |
| 13:00 | 1 | 0.2 | 329 | 73.1 |
| 14:00 | 3 | 0.7 | 332 | 73.8 |
| 15:00 | 2 | 0.4 | 334 | 74.2 |
| 15:30 | 1 | 0.2 | 335 | 74.4 |
| 16:00 | 2 | 0.4 | 337 | 74.9 |
| 17:00 | 7 | 1.6 | 344 | 76.4 |
| 17:30 | 1 | 0.2 | 345 | 76.7 |
| 18:00 | 13 | 2.9 | 358 | 79.6 |
| 18:30 | 1 | 0.2 | 359 | 79.8 |
| 19:00 | 6 | 1.3 | 365 | 81.1 |
| 20:00 | 5 | 1.1 | 370 | 82.2 |
| 20:30 | 1 | 0.2 | 371 | 82.4 |
| 21:00 | 3 | 0.7 | 374 | 83.1 |
| 21:30 | 1 | 0.2 | 375 | 83.3 |
| 22:00 | 12 | 2.7 | 387 | 86.0 |
| 23:00 | 6 | 1.3 | 393 | 87.3 |
| 23:58 | 1 | 0.2 | 394 | 87.6 |
| 24:00 | 56 | 12.4 | 450 | 100.0 |

Frequency Missing = 29

light hours/am or pm: Dec Week

| LF1N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 33 | 6.9 | 33 | 6.9 |
| D | 10 | 2.1 | 43 | 9.0 |
| P | 436 | 91.0 | 479 | 100.0 |

light hours/am or pm: Dec Sat

| LF2N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 31 | 6.5 | 31 | 6.5 |
| D | 12 | 2.5 | 43 | 9.0 |
| P | 433 | 91.0 | 476 | 100.0 |

Frequency Missing = 3

light hours/am or pm: Dec Sun

| LF3N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 30 | 6.3 | 30 | 6.3 |
| D | 11 | 2.3 | 41 | 8.6 |
| P | 435 | 91.4 | 476 | 100.0 |

Frequency Missing = 3

light hours/am or pm: Apr Week

| LF4N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 35 | 7.4 | 35 | 7.4 |
| D | 10 | 2.1 | 45 | 9.6 |
| P | 425 | 90.4 | 470 | 100.0 |

Frequency Missing = 9

light hours/am or pm: Apr Sat

| LF5N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 33 | 7.1 | 33 | 7.1 |
| D | 12 | 2.6 | 45 | 9.6 |
| P | 423 | 90.4 | 468 | 100.0 |

Frequency Missing = 11

light hours/am or pm: Apr Sun

| LF6N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 32 | 6.9 | 32 | 6.9 |
| D | 11 | 2.4 | 43 | 9.2 |
| P | 423 | 90.8 | 466 | 100.0 |

Frequency Missing = 13

light hours/am or pm: Aug Week

| LF7N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 36 | 7.7 | 36 | 7.7 |
| D | 10 | 2.1 | 46 | 9.9 |
| P | 421 | 90.1 | 467 | 100.0 |

Frequency Missing = 12

light hours/am or pm: Aug Sat

| LF8N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 32 | 6.9 | 32 | 6.9 |
| D | 12 | 2.6 | 44 | 9.4 |
| P | 422 | 90.6 | 466 | 100.0 |

Frequency Missing = 13

light hours/am or pm: Aug Sun

| LF9N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 32 | 6.9 | 32 | 6.9 |
| D | 11 | 2.4 | 43 | 9.2 |
| P | 424 | 90.8 | 467 | 100.0 |

Frequency Missing = 12

light hours/am or pm: Oct Week

| LF10N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 34 | 7.3 | 34 | 7.3 |
| D | 10 | 2.1 | 44 | 9.4 |
| P | 423 | 90.6 | 467 | 100.0 |

Frequency Missing = 12

light hours/am or pm: Oct Sat

| LF11N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 32 | 6.9 | 32 | 6.9 |
| D | 12 | 2.6 | 44 | 9.4 |
| P | 422 | 90.6 | 466 | 100.0 |

Frequency Missing = 13

light hours/am or pm: Oct Sun

| LF12N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 31 | 6.6 | 31 | 6.6 |
| D | 11 | 2.4 | 42 | 9.0 |
| P | 425 | 91.0 | 467 | 100.0 |

Frequency Missing = 12

light hours/am or pm: Holiday

| LF13N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 23 | 4.9 | 23 | 4.9 |
| D | 15 | 3.2 | 38 | 8.2 |
| P | 427 | 91.8 | 465 | 100.0 |

Frequency Missing = 14

light hours/percent on: Dec Week

| LW1 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 5 | 2 | 0.4 | 2 | 0.4 |
| 6 | 1 | 0.2 | 3 | 0.6 |
| 10 | 5 | 1.1 | 8 | 1.7 |
| 20 | 3 | 0.6 | 11 | 2.4 |
| 25 | 3 | 0.6 | 14 | 3.0 |
| 30 | 4 | 0.9 | 18 | 3.9 |
| 33 | 2 | 0.4 | 20 | 4.3 |
| 35 | 2 | 0.4 | 22 | 4.8 |
| 40 | 4 | 0.9 | 26 | 5.6 |
| 45 | 2 | 0.4 | 28 | 6.1 |
| 50 | 14 | 3.0 | 42 | 9.1 |
| 60 | 4 | 0.9 | 46 | 10.0 |
| 65 | 4 | 0.9 | 50 | 10.8 |
| 66 | 2 | 0.4 | 52 | 11.3 |
| 70 | 8 | 1.7 | 60 | 13.0 |
| 75 | 12 | 2.6 | 72 | 15.6 |
| 80 | 24 | 5.2 | 96 | 20.8 |
| 85 | 5 | 1.1 | 101 | 21.9 |
| 90 | 48 | 10.4 | 149 | 32.3 |
| 95 | 17 | 3.7 | 166 | 35.9 |
| 98 | 4 | 0.9 | 170 | 36.8 |
| 99 | 3 | 0.6 | 173 | 37.4 |
| 100 | 289 | 62.6 | 462 | 100.0 |

Frequency Missing = 17

light hours/percent on: Dec Sat

| LW2 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 70 | 15.5 | 70 | 15.5 |
| 0.5 | 1 | 0.2 | 71 | 15.7 |
| 1 | 9 | 2.0 | 80 | 17.7 |
| 2 | 28 | 6.2 | 108 | 23.9 |
| 3 | 18 | 4.0 | 126 | 27.9 |
| 5 | 29 | 6.4 | 155 | 34.4 |
| 6 | 1 | 0.2 | 156 | 34.6 |
| 8 | 1 | 0.2 | 157 | 34.8 |
| 10 | 11 | 2.4 | 168 | 37.3 |
| 13 | 1 | 0.2 | 169 | 37.5 |
| 15 | 5 | 1.1 | 174 | 38.6 |
| 20 | 12 | 2.7 | 186 | 41.2 |
| 25 | 3 | 0.7 | 189 | 41.9 |
| 30 | 10 | 2.2 | 199 | 44.1 |
| 33 | 1 | 0.2 | 200 | 44.3 |
| 35 | 1 | 0.2 | 201 | 44.6 |
| 40 | 6 | 1.3 | 207 | 45.9 |
| 45 | 2 | 0.4 | 209 | 46.3 |
| 50 | 16 | 3.5 | 225 | 49.9 |
| 60 | 3 | 0.7 | 228 | 50.6 |
| 65 | 2 | 0.4 | 230 | 51.0 |
| 66 | 2 | 0.4 | 232 | 51.4 |
| 70 | 2 | 0.4 | 234 | 51.9 |
| 75 | 8 | 1.8 | 242 | 53.7 |
| 80 | 17 | 3.8 | 259 | 57.4 |
| 85 | 3 | 0.7 | 262 | 58.1 |
| 90 | 14 | 3.1 | 276 | 61.2 |
| 95 | 5 | 1.1 | 281 | 62.3 |
| 98 | 4 | 0.9 | 285 | 63.2 |
| 99 | 1 | 0.2 | 286 | 63.4 |
| 100 | 165 | 36.6 | 451 | 100.0 |

Frequency Missing = 28

light hours/percent on: Dec Sun

| LW3 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 112 | 25.1 | 112 | 25.1 |
| 0.5 | 1 | 0.2 | 113 | 25.3 |
| 1 | 19 | 4.3 | 132 | 29.6 |
| 2 | 32 | 7.2 | 164 | 36.8 |
| 3 | 20 | 4.5 | 184 | 41.3 |
| 5 | 33 | 7.4 | 217 | 48.7 |
| 7 | 1 | 0.2 | 218 | 48.9 |
| 8 | 1 | 0.2 | 219 | 49.1 |
| 10 | 17 | 3.8 | 236 | 52.9 |
| 13 | 1 | 0.2 | 237 | 53.1 |
| 15 | 6 | 1.3 | 243 | 54.5 |
| 20 | 9 | 2.0 | 252 | 56.5 |
| 25 | 3 | 0.7 | 255 | 57.2 |
| 30 | 8 | 1.8 | 263 | 59.0 |
| 33 | 1 | 0.2 | 264 | 59.2 |
| 40 | 6 | 1.3 | 270 | 60.5 |
| 45 | 1 | 0.2 | 271 | 60.8 |
| 50 | 12 | 2.7 | 283 | 63.5 |
| 60 | 4 | 0.9 | 287 | 64.3 |
| 65 | 2 | 0.4 | 289 | 64.8 |
| 66 | 1 | 0.2 | 290 | 65.0 |
| 70 | 3 | 0.7 | 293 | 65.7 |
| 75 | 5 | 1.1 | 298 | 66.8 |
| 80 | 12 | 2.7 | 310 | 69.5 |
| 85 | 3 | 0.7 | 313 | 70.2 |
| 90 | 9 | 2.0 | 322 | 72.2 |
| 95 | 3 | 0.7 | 325 | 72.9 |
| 98 | 4 | 0.9 | 329 | 73.8 |
| 99 | 1 | 0.2 | 330 | 74.0 |
| 100 | 116 | 26.0 | 446 | 100.0 |

Frequency Missing = 33

light hours/percent on: Apr Week

| LW4 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 5 | 2 | 0.4 | 2 | 0.4 |
| 6 | 1 | 0.2 | 3 | 0.7 |
| 10 | 5 | 1.1 | 8 | 1.8 |
| 20 | 3 | 0.7 | 11 | 2.4 |
| 25 | 3 | 0.7 | 14 | 3.1 |
| 30 | 4 | 0.9 | 18 | 4.0 |
| 33 | 2 | 0.4 | 20 | 4.4 |
| 35 | 2 | 0.4 | 22 | 4.9 |
| 40 | 5 | 1.1 | 27 | 6.0 |
| 45 | 2 | 0.4 | 29 | 6.4 |
| 50 | 10 | 2.2 | 39 | 8.6 |
| 60 | 5 | 1.1 | 44 | 9.7 |
| 65 | 5 | 1.1 | 49 | 10.8 |
| 66 | 2 | 0.4 | 51 | 11.3 |
| 70 | 10 | 2.2 | 61 | 13.5 |
| 75 | 13 | 2.9 | 74 | 16.3 |
| 80 | 23 | 5.1 | 97 | 21.4 |
| 85 | 5 | 1.1 | 102 | 22.5 |
| 90 | 47 | 10.4 | 149 | 32.9 |
| 95 | 16 | 3.5 | 165 | 36.4 |
| 98 | 4 | 0.9 | 169 | 37.3 |
| 99 | 2 | 0.4 | 171 | 37.7 |
| 100 | 282 | 62.3 | 453 | 100.0 |

Frequency Missing = 26

light hours/percent on: Apr Sat

| LW5 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 68 | 15.3 | 68 | 15.3 |
| 0.5 | 1 | 0.2 | 69 | 15.5 |
| 1 | 9 | 2.0 | 78 | 17.6 |
| 2 | 27 | 6.1 | 105 | 23.6 |
| 3 | 17 | 3.8 | 122 | 27.5 |
| 5 | 27 | 6.1 | 149 | 33.6 |
| 6 | 1 | 0.2 | 150 | 33.8 |
| 8 | 1 | 0.2 | 151 | 34.0 |
| 10 | 10 | 2.3 | 161 | 36.3 |
| 13 | 1 | 0.2 | 162 | 36.5 |
| 15 | 5 | 1.1 | 167 | 37.6 |
| 20 | 12 | 2.7 | 179 | 40.3 |
| 25 | 3 | 0.7 | 182 | 41.0 |
| 30 | 11 | 2.5 | 193 | 43.5 |
| 33 | 1 | 0.2 | 194 | 43.7 |
| 35 | 1 | 0.2 | 195 | 43.9 |
| 40 | 5 | 1.1 | 200 | 45.0 |
| 45 | 2 | 0.5 | 202 | 45.5 |
| 50 | 14 | 3.2 | 216 | 48.6 |
| 60 | 2 | 0.5 | 218 | 49.1 |
| 65 | 3 | 0.7 | 221 | 49.8 |
| 66 | 2 | 0.5 | 223 | 50.2 |
| 70 | 3 | 0.7 | 226 | 50.9 |
| 75 | 7 | 1.6 | 233 | 52.5 |
| 80 | 14 | 3.2 | 247 | 55.6 |
| 85 | 3 | 0.7 | 250 | 56.3 |
| 90 | 15 | 3.4 | 265 | 59.7 |
| 92 | 1 | 0.2 | 266 | 59.9 |
| 95 | 5 | 1.1 | 271 | 61.0 |
| 98 | 4 | 0.9 | 275 | 61.9 |
| 99 | 1 | 0.2 | 276 | 62.2 |
| 100 | 168 | 37.8 | 444 | 100.0 |

Frequency Missing = 35

light hours/percent on: Apr Sun

| LW6 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 112 | 25.5 | 112 | 25.5 |
| 0.5 | 1 | 0.2 | 113 | 25.7 |
| 1 | 18 | 4.1 | 131 | 29.8 |
| 2 | 29 | 6.6 | 160 | 36.4 |
| 3 | 20 | 4.5 | 180 | 40.9 |
| 5 | 33 | 7.5 | 213 | 48.4 |
| 7 | 1 | 0.2 | 214 | 48.6 |
| 8 | 1 | 0.2 | 215 | 48.9 |
| 10 | 15 | 3.4 | 230 | 52.3 |
| 13 | 1 | 0.2 | 231 | 52.5 |
| 15 | 5 | 1.1 | 236 | 53.6 |
| 20 | 8 | 1.8 | 244 | 55.5 |
| 25 | 2 | 0.5 | 246 | 55.9 |
| 30 | 10 | 2.3 | 256 | 58.2 |
| 33 | 1 | 0.2 | 257 | 58.4 |
| 35 | 1 | 0.2 | 258 | 58.6 |
| 40 | 5 | 1.1 | 263 | 59.8 |
| 45 | 1 | 0.2 | 264 | 60.0 |
| 50 | 12 | 2.7 | 276 | 62.7 |
| 60 | 5 | 1.1 | 281 | 63.9 |
| 65 | 3 | 0.7 | 284 | 64.5 |
| 66 | 1 | 0.2 | 285 | 64.8 |
| 70 | 3 | 0.7 | 288 | 65.5 |
| 75 | 4 | 0.9 | 292 | 66.4 |
| 80 | 10 | 2.3 | 302 | 68.6 |
| 85 | 3 | 0.7 | 305 | 69.3 |
| 90 | 10 | 2.3 | 315 | 71.6 |
| 92 | 1 | 0.2 | 316 | 71.8 |
| 95 | 3 | 0.7 | 319 | 72.5 |
| 98 | 4 | 0.9 | 323 | 73.4 |
| 99 | 2 | 0.5 | 325 | 73.9 |
| 100 | 115 | 26.1 | 440 | 100.0 |

Frequency Missing = 39

light hours/percent on: Aug Week

| LW7 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 0.4 | 2 | 0.4 |
| 2 | 1 | 0.2 | 3 | 0.7 |
| 3 | 13 | 2.9 | 16 | 3.6 |
| 4 | 1 | 0.2 | 17 | 3.8 |
| 5 | 13 | 2.9 | 30 | 6.7 |
| 6 | 1 | 0.2 | 31 | 6.9 |
| 10 | 8 | 1.8 | 39 | 8.7 |
| 15 | 3 | 0.7 | 42 | 9.4 |
| 20 | 3 | 0.7 | 45 | 10.0 |
| 25 | 4 | 0.9 | 49 | 10.9 |
| 30 | 6 | 1.3 | 55 | 12.2 |
| 33 | 2 | 0.4 | 57 | 12.7 |
| 35 | 1 | 0.2 | 58 | 12.9 |
| 40 | 5 | 1.1 | 63 | 14.0 |
| 45 | 2 | 0.4 | 65 | 14.5 |
| 50 | 10 | 2.2 | 75 | 16.7 |
| 60 | 4 | 0.9 | 79 | 17.6 |
| 65 | 5 | 1.1 | 84 | 18.7 |
| 66 | 2 | 0.4 | 86 | 19.2 |
| 70 | 7 | 1.6 | 93 | 20.7 |
| 75 | 16 | 3.6 | 109 | 24.3 |
| 80 | 21 | 4.7 | 130 | 29.0 |
| 85 | 4 | 0.9 | 134 | 29.8 |
| 90 | 31 | 6.9 | 165 | 36.7 |
| 94 | 1 | 0.2 | 166 | 37.0 |
| 95 | 12 | 2.7 | 178 | 39.6 |
| 98 | 4 | 0.9 | 182 | 40.5 |
| 99 | 2 | 0.4 | 184 | 41.0 |
| 100 | 265 | 59.0 | 449 | 100.0 |

Frequency Missing = 30

light hours/percent on: Aug Sat

| LW8 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 69 | 15.7 | 69 | 15.7 |
| 0.5 | 1 | 0.2 | 70 | 15.9 |
| 1 | 9 | 2.0 | 79 | 18.0 |
| 2 | 29 | 6.6 | 108 | 24.5 |
| 3 | 17 | 3.9 | 125 | 28.4 |
| 5 | 26 | 5.9 | 151 | 34.3 |
| 6 | 1 | 0.2 | 152 | 34.5 |
| 8 | 1 | 0.2 | 153 | 34.8 |
| 10 | 11 | 2.5 | 164 | 37.3 |
| 13 | 1 | 0.2 | 165 | 37.5 |
| 15 | 6 | 1.4 | 171 | 38.9 |
| 20 | 12 | 2.7 | 183 | 41.6 |
| 25 | 3 | 0.7 | 186 | 42.3 |
| 30 | 12 | 2.7 | 198 | 45.0 |
| 33 | 1 | 0.2 | 199 | 45.2 |
| 40 | 5 | 1.1 | 204 | 46.4 |
| 45 | 2 | 0.5 | 206 | 46.8 |
| 50 | 12 | 2.7 | 218 | 49.5 |
| 60 | 3 | 0.7 | 221 | 50.2 |
| 65 | 3 | 0.7 | 224 | 50.9 |
| 66 | 2 | 0.5 | 226 | 51.4 |
| 70 | 2 | 0.5 | 228 | 51.8 |
| 75 | 7 | 1.6 | 235 | 53.4 |
| 80 | 15 | 3.4 | 250 | 56.8 |
| 85 | 3 | 0.7 | 253 | 57.5 |
| 90 | 14 | 3.2 | 267 | 60.7 |
| 94 | 1 | 0.2 | 268 | 60.9 |
| 95 | 5 | 1.1 | 273 | 62.0 |
| 98 | 4 | 0.9 | 277 | 63.0 |
| 99 | 1 | 0.2 | 278 | 63.2 |
| 100 | 162 | 36.8 | 440 | 100.0 |

Frequency Missing = 39

light hours/percent on: Aug Sun

| LW9 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 114 | 25.9 | 114 | 25.9 |
| 0.5 | 1 | 0.2 | 115 | 26.1 |
| 1 | 18 | 4.1 | 133 | 30.2 |
| 2 | 32 | 7.3 | 165 | 37.4 |
| 3 | 20 | 4.5 | 185 | 42.0 |
| 5 | 33 | 7.5 | 218 | 49.4 |
| 7 | 1 | 0.2 | 219 | 49.7 |
| 8 | 1 | 0.2 | 220 | 49.9 |
| 10 | 16 | 3.6 | 236 | 53.5 |
| 13 | 1 | 0.2 | 237 | 53.7 |
| 15 | 5 | 1.1 | 242 | 54.9 |
| 20 | 7 | 1.6 | 249 | 56.5 |
| 25 | 3 | 0.7 | 252 | 57.1 |
| 30 | 9 | 2.0 | 261 | 59.2 |
| 33 | 1 | 0.2 | 262 | 59.4 |
| 40 | 4 | 0.9 | 266 | 60.3 |
| 45 | 1 | 0.2 | 267 | 60.5 |
| 50 | 11 | 2.5 | 278 | 63.0 |
| 60 | 4 | 0.9 | 282 | 63.9 |
| 65 | 3 | 0.7 | 285 | 64.6 |
| 66 | 1 | 0.2 | 286 | 64.9 |
| 70 | 3 | 0.7 | 289 | 65.5 |
| 75 | 6 | 1.4 | 295 | 66.9 |
| 80 | 12 | 2.7 | 307 | 69.6 |
| 85 | 3 | 0.7 | 310 | 70.3 |
| 90 | 9 | 2.0 | 319 | 72.3 |
| 94 | 1 | 0.2 | 320 | 72.6 |
| 95 | 3 | 0.7 | 323 | 73.2 |
| 98 | 4 | 0.9 | 327 | 74.1 |
| 99 | 1 | 0.2 | 328 | 74.4 |
| 100 | 113 | 25.6 | 441 | 100.0 |

Frequency Missing = 38

light hours/percent on: Oct Week

| LW10 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 0.2 | 1 | 0.2 |
| 5 | 3 | 0.7 | 4 | 0.9 |
| 6 | 1 | 0.2 | 5 | 1.1 |
| 10 | 5 | 1.1 | 10 | 2.2 |
| 20 | 3 | 0.7 | 13 | 2.9 |
| 25 | 3 | 0.7 | 16 | 3.6 |
| 30 | 4 | 0.9 | 20 | 4.4 |
| 33 | 2 | 0.4 | 22 | 4.9 |
| 35 | 1 | 0.2 | 23 | 5.1 |
| 40 | 4 | 0.9 | 27 | 6.0 |
| 45 | 3 | 0.7 | 30 | 6.7 |
| 50 | 8 | 1.8 | 38 | 8.4 |
| 60 | 4 | 0.9 | 42 | 9.3 |
| 65 | 5 | 1.1 | 47 | 10.4 |
| 66 | 2 | 0.4 | 49 | 10.9 |
| 70 | 10 | 2.2 | 59 | 13.1 |
| 75 | 14 | 3.1 | 73 | 16.2 |
| 80 | 22 | 4.9 | 95 | 21.1 |
| 85 | 5 | 1.1 | 100 | 22.2 |
| 90 | 48 | 10.7 | 148 | 32.9 |
| 95 | 16 | 3.6 | 164 | 36.4 |
| 98 | 4 | 0.9 | 168 | 37.3 |
| 99 | 2 | 0.4 | 170 | 37.8 |
| 100 | 280 | 62.2 | 450 | 100.0 |

Frequency Missing = 29

light hours/percent on: Oct Sat

| LW11 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 70 | 15.8 | 70 | 15.8 |
| 0.5 | 1 | 0.2 | 71 | 16.1 |
| 1 | 9 | 2.0 | 80 | 18.1 |
| 2 | 28 | 6.3 | 108 | 24.4 |
| 3 | 17 | 3.8 | 125 | 28.3 |
| 5 | 28 | 6.3 | 153 | 34.6 |
| 6 | 1 | 0.2 | 154 | 34.8 |
| 8 | 1 | 0.2 | 155 | 35.1 |
| 10 | 10 | 2.3 | 165 | 37.3 |
| 13 | 1 | 0.2 | 166 | 37.6 |
| 15 | 6 | 1.4 | 172 | 38.9 |
| 20 | 12 | 2.7 | 184 | 41.6 |
| 25 | 3 | 0.7 | 187 | 42.3 |
| 30 | 11 | 2.5 | 198 | 44.8 |
| 33 | 1 | 0.2 | 199 | 45.0 |
| 40 | 5 | 1.1 | 204 | 46.2 |
| 45 | 2 | 0.5 | 206 | 46.6 |
| 50 | 13 | 2.9 | 219 | 49.5 |
| 60 | 2 | 0.5 | 221 | 50.0 |
| 65 | 4 | 0.9 | 225 | 50.9 |
| 66 | 2 | 0.5 | 227 | 51.4 |
| 70 | 2 | 0.5 | 229 | 51.8 |
| 75 | 7 | 1.6 | 236 | 53.4 |
| 80 | 15 | 3.4 | 251 | 56.8 |
| 85 | 3 | 0.7 | 254 | 57.5 |
| 90 | 14 | 3.2 | 268 | 60.6 |
| 95 | 5 | 1.1 | 273 | 61.8 |
| 98 | 4 | 0.9 | 277 | 62.7 |
| 99 | 1 | 0.2 | 278 | 62.9 |
| 100 | 164 | 37.1 | 442 | 100.0 |

Frequency Missing = 37

light hours/percent on: Oct Sun

| LW12 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 113 | 25.6 | 113 | 25.6 |
| 0.5 | 1 | 0.2 | 114 | 25.9 |
| 1 | 16 | 3.6 | 130 | 29.5 |
| 2 | 31 | 7.0 | 161 | 36.5 |
| 3 | 20 | 4.5 | 181 | 41.0 |
| 5 | 35 | 7.9 | 216 | 49.0 |
| 7 | 1 | 0.2 | 217 | 49.2 |
| 8 | 1 | 0.2 | 218 | 49.4 |
| 10 | 15 | 3.4 | 233 | 52.8 |
| 13 | 1 | 0.2 | 234 | 53.1 |
| 15 | 5 | 1.1 | 239 | 54.2 |
| 20 | 8 | 1.8 | 247 | 56.0 |
| 25 | 3 | 0.7 | 250 | 56.7 |
| 30 | 11 | 2.5 | 261 | 59.2 |
| 33 | 1 | 0.2 | 262 | 59.4 |
| 40 | 4 | 0.9 | 266 | 60.3 |
| 45 | 1 | 0.2 | 267 | 60.5 |
| 50 | 12 | 2.7 | 279 | 63.3 |
| 60 | 4 | 0.9 | 283 | 64.2 |
| 65 | 3 | 0.7 | 286 | 64.9 |
| 66 | 1 | 0.2 | 287 | 65.1 |
| 70 | 3 | 0.7 | 290 | 65.8 |
| 75 | 5 | 1.1 | 295 | 66.9 |
| 80 | 11 | 2.5 | 306 | 69.4 |
| 85 | 3 | 0.7 | 309 | 70.1 |
| 90 | 9 | 2.0 | 318 | 72.1 |
| 95 | 3 | 0.7 | 321 | 72.8 |
| 98 | 4 | 0.9 | 325 | 73.7 |
| 99 | 1 | 0.2 | 326 | 73.9 |
| 100 | 115 | 26.1 | 441 | 100.0 |

Frequency Missing = 38

light hours/percent on: Holiday

| LW13 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 155 | 34.4 | 155 | 34.4 |
| 0.5 | 2 | 0.4 | 157 | 34.9 |
| 1 | 20 | 4.4 | 177 | 39.3 |
| 2 | 36 | 8.0 | 213 | 47.3 |
| 3 | 22 | 4.9 | 235 | 52.2 |
| 5 | 33 | 7.3 | 268 | 59.6 |
| 6 | 1 | 0.2 | 269 | 59.8 |
| 7 | 1 | 0.2 | 270 | 60.0 |
| 8 | 1 | 0.2 | 271 | 60.2 |
| 10 | 26 | 5.8 | 297 | 66.0 |
| 13 | 1 | 0.2 | 298 | 66.2 |
| 15 | 7 | 1.6 | 305 | 67.8 |
| 20 | 8 | 1.8 | 313 | 69.6 |
| 25 | 2 | 0.4 | 315 | 70.0 |
| 30 | 7 | 1.6 | 322 | 71.6 |
| 33 | 1 | 0.2 | 323 | 71.8 |
| 40 | 3 | 0.7 | 326 | 72.4 |
| 45 | 2 | 0.4 | 328 | 72.9 |
| 50 | 11 | 2.4 | 339 | 75.3 |
| 60 | 2 | 0.4 | 341 | 75.8 |
| 65 | 3 | 0.7 | 344 | 76.4 |
| 66 | 1 | 0.2 | 345 | 76.7 |
| 70 | 3 | 0.7 | 348 | 77.3 |
| 75 | 3 | 0.7 | 351 | 78.0 |
| 80 | 10 | 2.2 | 361 | 80.2 |
| 85 | 2 | 0.4 | 363 | 80.7 |
| 90 | 5 | 1.1 | 368 | 81.8 |
| 95 | 1 | 0.2 | 369 | 82.0 |
| 98 | 3 | 0.7 | 372 | 82.7 |
| 99 | 1 | 0.2 | 373 | 82.9 |
| 100 | 77 | 17.1 | 450 | 100.0 |

Frequency Missing = 29

% are night lights on 24 hours?

| LF014 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 241 | 53.8 | 241 | 53.8 |
| 0.5 | 2 | 0.4 | 243 | 54.2 |
| 0.7 | 1 | 0.2 | 244 | 54.5 |
| 1 | 38 | 8.5 | 282 | 62.9 |
| 2 | 25 | 5.6 | 307 | 68.5 |
| 3 | 16 | 3.6 | 323 | 72.1 |
| 4 | 1 | 0.2 | 324 | 72.3 |
| 5 | 49 | 10.9 | 373 | 83.3 |
| 6 | 1 | 0.2 | 374 | 83.5 |
| 7 | 1 | 0.2 | 375 | 83.7 |
| 8 | 2 | 0.4 | 377 | 84.2 |
| 10 | 30 | 6.7 | 407 | 90.8 |
| 12 | 2 | 0.4 | 409 | 91.3 |
| 13 | 1 | 0.2 | 410 | 91.5 |
| 15 | 6 | 1.3 | 416 | 92.9 |
| 18 | 1 | 0.2 | 417 | 93.1 |
| 20 | 2 | 0.4 | 419 | 93.5 |
| 25 | 4 | 0.9 | 423 | 94.4 |
| 30 | 6 | 1.3 | 429 | 95.8 |
| 40 | 1 | 0.2 | 430 | 96.0 |
| 50 | 5 | 1.1 | 435 | 97.1 |
| 65 | 1 | 0.2 | 436 | 97.3 |
| 80 | 1 | 0.2 | 437 | 97.5 |
| 90 | 1 | 0.2 | 438 | 97.8 |
| 95 | 1 | 0.2 | 439 | 98.0 |
| 100 | 9 | 2.0 | 448 | 100.0 |

Frequency Missing = 31

% of ind lights on during non-oper hours

| LF025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 117 | 26.7 | 117 | 26.7 |
| 0.5 | 3 | 0.7 | 120 | 27.4 |
| 0.7 | 1 | 0.2 | 121 | 27.6 |
| 1 | 45 | 10.3 | 166 | 37.9 |
| 2 | 42 | 9.6 | 208 | 47.5 |
| 3 | 14 | 3.2 | 222 | 50.7 |
| 4 | 2 | 0.5 | 224 | 51.1 |
| 5 | 50 | 11.4 | 274 | 62.6 |
| 7 | 3 | 0.7 | 277 | 63.2 |
| 8 | 3 | 0.7 | 280 | 63.9 |
| 10 | 54 | 12.3 | 334 | 76.3 |
| 12 | 1 | 0.2 | 335 | 76.5 |
| 13 | 1 | 0.2 | 336 | 76.7 |
| 15 | 19 | 4.3 | 355 | 81.1 |
| 20 | 21 | 4.8 | 376 | 85.8 |
| 25 | 9 | 2.1 | 385 | 87.9 |
| 30 | 7 | 1.6 | 392 | 89.5 |
| 40 | 4 | 0.9 | 396 | 90.4 |
| 50 | 4 | 0.9 | 400 | 91.3 |
| 60 | 19 | 4.3 | 419 | 95.7 |
| 65 | 1 | 0.2 | 420 | 95.9 |
| 80 | 2 | 0.5 | 422 | 96.3 |
| 85 | 1 | 0.2 | 423 | 96.6 |
| 88 | 1 | 0.2 | 424 | 96.8 |
| 90 | 1 | 0.2 | 425 | 97.0 |
| 100 | 13 | 3.0 | 438 | 100.0 |

Frequency Missing = 41

% of retro lights on - SUM WKDAY - 1AM

| LF017A | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 241 | 55.1 | 241 | 55.1 |
| 0.5 | 1 | 0.2 | 242 | 55.4 |
| 1 | 23 | 5.3 | 265 | 60.6 |
| 2 | 19 | 4.3 | 284 | 65.0 |
| 3 | 4 | 0.9 | 288 | 65.9 |
| 4 | 1 | 0.2 | 289 | 66.1 |
| 5 | 34 | 7.8 | 323 | 73.9 |
| 8 | 1 | 0.2 | 324 | 74.1 |
| 10 | 16 | 3.7 | 340 | 77.8 |
| 12 | 1 | 0.2 | 341 | 78.0 |
| 13 | 1 | 0.2 | 342 | 78.3 |
| 15 | 6 | 1.4 | 348 | 79.6 |
| 20 | 2 | 0.5 | 350 | 80.1 |
| 25 | 3 | 0.7 | 353 | 80.8 |
| 30 | 8 | 1.8 | 361 | 82.6 |
| 33 | 1 | 0.2 | 362 | 82.8 |
| 40 | 2 | 0.5 | 364 | 83.3 |
| 50 | 20 | 4.6 | 384 | 87.9 |
| 65 | 1 | 0.2 | 385 | 88.1 |
| 75 | 1 | 0.2 | 386 | 88.3 |
| 80 | 3 | 0.7 | 389 | 89.0 |
| 90 | 2 | 0.5 | 391 | 89.5 |
| 100 | 46 | 10.5 | 437 | 100.0 |

Frequency Missing = 42

% of retro lights on - SUM WKDAY - 2AM

| LF017B | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 245 | 56.2 | 245 | 56.2 |
| 0.5 | 1 | 0.2 | 246 | 56.4 |
| 1 | 21 | 4.8 | 267 | 61.2 |
| 2 | 19 | 4.4 | 286 | 65.6 |
| 3 | 6 | 1.4 | 292 | 67.0 |
| 4 | 1 | 0.2 | 293 | 67.2 |
| 5 | 32 | 7.3 | 325 | 74.5 |
| 8 | 1 | 0.2 | 326 | 74.8 |
| 10 | 16 | 3.7 | 342 | 78.4 |
| 12 | 1 | 0.2 | 343 | 78.7 |
| 13 | 1 | 0.2 | 344 | 78.9 |
| 15 | 6 | 1.4 | 350 | 80.3 |
| 20 | 2 | 0.5 | 352 | 80.7 |
| 25 | 3 | 0.7 | 355 | 81.4 |
| 30 | 8 | 1.8 | 363 | 83.3 |
| 33 | 1 | 0.2 | 364 | 83.5 |
| 40 | 2 | 0.5 | 366 | 83.9 |
| 50 | 19 | 4.4 | 385 | 88.3 |
| 65 | 1 | 0.2 | 386 | 88.5 |
| 75 | 2 | 0.5 | 388 | 89.0 |
| 80 | 3 | 0.7 | 391 | 89.7 |
| 90 | 2 | 0.5 | 393 | 90.1 |
| 100 | 43 | 9.9 | 436 | 100.0 |

Frequency Missing = 43

% of retro lights on - SUM WKDAY - 3AM

| LF017C | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 246 | 56.7 | 246 | 56.7 |
| 0.5 | 1 | 0.2 | 247 | 56.9 |
| 1 | 20 | 4.6 | 267 | 61.5 |
| 2 | 19 | 4.4 | 286 | 65.9 |
| 3 | 6 | 1.4 | 292 | 67.3 |
| 4 | 1 | 0.2 | 293 | 67.5 |
| 5 | 32 | 7.4 | 325 | 74.9 |
| 8 | 1 | 0.2 | 326 | 75.1 |
| 10 | 16 | 3.7 | 342 | 78.8 |
| 12 | 1 | 0.2 | 343 | 79.0 |
| 13 | 1 | 0.2 | 344 | 79.3 |
| 15 | 6 | 1.4 | 350 | 80.6 |
| 20 | 2 | 0.5 | 352 | 81.1 |
| 25 | 3 | 0.7 | 355 | 81.8 |
| 30 | 8 | 1.8 | 363 | 83.6 |
| 33 | 1 | 0.2 | 364 | 83.9 |
| 40 | 2 | 0.5 | 366 | 84.3 |
| 50 | 19 | 4.4 | 385 | 88.7 |
| 65 | 1 | 0.2 | 386 | 88.9 |
| 75 | 2 | 0.5 | 388 | 89.4 |
| 80 | 2 | 0.5 | 390 | 89.9 |
| 90 | 2 | 0.5 | 392 | 90.3 |
| 100 | 42 | 9.7 | 434 | 100.0 |

Frequency Missing = 45

% of retro lights on - SUM WKDAY - 4AM

| LF017D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 243 | 56.4 | 243 | 56.4 |
| 0.5 | 1 | 0.2 | 244 | 56.6 |
| 1 | 20 | 4.6 | 264 | 61.3 |
| 2 | 18 | 4.2 | 282 | 65.4 |
| 3 | 6 | 1.4 | 288 | 66.8 |
| 4 | 1 | 0.2 | 289 | 67.1 |
| 5 | 32 | 7.4 | 321 | 74.5 |
| 8 | 1 | 0.2 | 322 | 74.7 |
| 10 | 16 | 3.7 | 338 | 78.4 |
| 12 | 1 | 0.2 | 339 | 78.7 |
| 13 | 1 | 0.2 | 340 | 78.9 |
| 15 | 6 | 1.4 | 346 | 80.3 |
| 20 | 2 | 0.5 | 348 | 80.7 |
| 25 | 3 | 0.7 | 351 | 81.4 |
| 30 | 8 | 1.9 | 359 | 83.3 |
| 33 | 1 | 0.2 | 360 | 83.5 |
| 40 | 2 | 0.5 | 362 | 84.0 |
| 50 | 19 | 4.4 | 381 | 88.4 |
| 60 | 2 | 0.5 | 383 | 88.9 |
| 65 | 1 | 0.2 | 384 | 89.1 |
| 75 | 2 | 0.5 | 386 | 89.6 |
| 80 | 1 | 0.2 | 387 | 89.8 |
| 90 | 2 | 0.5 | 389 | 90.3 |
| 100 | 42 | 9.7 | 431 | 100.0 |

Frequency Missing = 48

% of retro lights on - SUM WKDAY - 5AM

| LF017E | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 231 | 53.5 | 231 | 53.5 |
| 0.5 | 1 | 0.2 | 232 | 53.7 |
| 1 | 20 | 4.6 | 252 | 58.3 |
| 2 | 18 | 4.2 | 270 | 62.5 |
| 3 | 6 | 1.4 | 276 | 63.9 |
| 4 | 1 | 0.2 | 277 | 64.1 |
| 5 | 32 | 7.4 | 309 | 71.5 |
| 8 | 1 | 0.2 | 310 | 71.8 |
| 10 | 16 | 3.7 | 326 | 75.5 |
| 12 | 1 | 0.2 | 327 | 75.7 |
| 13 | 1 | 0.2 | 328 | 75.9 |
| 15 | 6 | 1.4 | 334 | 77.3 |
| 20 | 2 | 0.5 | 336 | 77.8 |
| 25 | 5 | 1.2 | 341 | 78.9 |
| 30 | 8 | 1.9 | 349 | 80.8 |
| 33 | 1 | 0.2 | 350 | 81.0 |
| 40 | 2 | 0.5 | 352 | 81.5 |
| 50 | 20 | 4.6 | 372 | 86.1 |
| 60 | 3 | 0.7 | 375 | 86.8 |
| 65 | 1 | 0.2 | 376 | 87.0 |
| 75 | 2 | 0.5 | 378 | 87.5 |
| 80 | 2 | 0.5 | 380 | 88.0 |
| 90 | 2 | 0.5 | 382 | 88.4 |
| 100 | 50 | 11.6 | 432 | 100.0 |

Frequency Missing = 47

% of retro lights on - SUM WKDAY - 6AM

| LF017F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 212 | 49.0 | 212 | 49.0 |
| 1 | 20 | 4.6 | 232 | 53.6 |
| 2 | 21 | 4.8 | 253 | 58.4 |
| 3 | 5 | 1.2 | 258 | 59.6 |
| 4 | 1 | 0.2 | 259 | 59.8 |
| 5 | 29 | 6.7 | 288 | 66.5 |
| 8 | 1 | 0.2 | 289 | 66.7 |
| 10 | 13 | 3.0 | 302 | 69.7 |
| 12 | 1 | 0.2 | 303 | 70.0 |
| 13 | 1 | 0.2 | 304 | 70.2 |
| 15 | 4 | 0.9 | 308 | 71.1 |
| 20 | 1 | 0.2 | 309 | 71.4 |
| 25 | 3 | 0.7 | 312 | 72.1 |
| 30 | 15 | 3.5 | 327 | 75.5 |
| 33 | 1 | 0.2 | 328 | 75.8 |
| 40 | 3 | 0.7 | 331 | 76.4 |
| 50 | 6 | 1.4 | 337 | 77.8 |
| 60 | 5 | 1.2 | 342 | 79.0 |
| 65 | 2 | 0.5 | 344 | 79.4 |
| 70 | 2 | 0.5 | 346 | 79.9 |
| 75 | 1 | 0.2 | 347 | 80.1 |
| 80 | 4 | 0.9 | 351 | 81.1 |
| 90 | 4 | 0.9 | 355 | 82.0 |
| 98 | 1 | 0.2 | 356 | 82.2 |
| 100 | 77 | 17.8 | 433 | 100.0 |

Frequency Missing = 46

% of retro lights on - SUM WKDAY - 7AM

| LF017G | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 161 | 37.1 | 161 | 37.1 |
| 1 | 19 | 4.4 | 180 | 41.5 |
| 2 | 14 | 3.2 | 194 | 44.7 |
| 3 | 3 | 0.7 | 197 | 45.4 |
| 5 | 25 | 5.8 | 222 | 51.2 |
| 7 | 1 | 0.2 | 223 | 51.4 |
| 8 | 1 | 0.2 | 224 | 51.6 |
| 9 | 1 | 0.2 | 225 | 51.8 |
| 10 | 13 | 3.0 | 238 | 54.8 |
| 12 | 1 | 0.2 | 239 | 55.1 |
| 15 | 4 | 0.9 | 243 | 56.0 |
| 25 | 5 | 1.2 | 248 | 57.1 |
| 30 | 28 | 6.5 | 276 | 63.6 |
| 40 | 2 | 0.5 | 278 | 64.1 |
| 50 | 10 | 2.3 | 288 | 66.4 |
| 60 | 5 | 1.2 | 293 | 67.5 |
| 65 | 2 | 0.5 | 295 | 68.0 |
| 66 | 1 | 0.2 | 296 | 68.2 |
| 70 | 5 | 1.2 | 301 | 69.4 |
| 75 | 4 | 0.9 | 305 | 70.3 |
| 80 | 7 | 1.6 | 312 | 71.9 |
| 85 | 1 | 0.2 | 313 | 72.1 |
| 90 | 10 | 2.3 | 323 | 74.4 |
| 95 | 4 | 0.9 | 327 | 75.3 |
| 98 | 1 | 0.2 | 328 | 75.6 |
| 100 | 106 | 24.4 | 434 | 100.0 |

Frequency Missing = 45

% of retro lights on - SUM WKDAY - 8AM

| LF017H | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 95 | 21.7 | 95 | 21.7 |
| 1 | 17 | 3.9 | 112 | 25.6 |
| 2 | 3 | 0.7 | 115 | 26.3 |
| 3 | 1 | 0.2 | 116 | 26.5 |
| 5 | 21 | 4.8 | 137 | 31.4 |
| 6 | 1 | 0.2 | 138 | 31.6 |
| 7 | 3 | 0.7 | 141 | 32.3 |
| 10 | 10 | 2.3 | 151 | 34.6 |
| 15 | 3 | 0.7 | 154 | 35.2 |
| 20 | 3 | 0.7 | 157 | 35.9 |
| 25 | 4 | 0.9 | 161 | 36.8 |
| 30 | 27 | 6.2 | 188 | 43.0 |
| 40 | 4 | 0.9 | 192 | 43.9 |
| 50 | 8 | 1.8 | 200 | 45.8 |
| 54 | 1 | 0.2 | 201 | 46.0 |
| 60 | 6 | 1.4 | 207 | 47.4 |
| 65 | 2 | 0.5 | 209 | 47.8 |
| 66 | 1 | 0.2 | 210 | 48.1 |
| 70 | 4 | 0.9 | 214 | 49.0 |
| 75 | 5 | 1.1 | 219 | 50.1 |
| 80 | 15 | 3.4 | 234 | 53.5 |
| 85 | 2 | 0.5 | 236 | 54.0 |
| 90 | 12 | 2.7 | 248 | 56.8 |
| 95 | 7 | 1.6 | 255 | 58.4 |
| 98 | 1 | 0.2 | 256 | 58.6 |
| 99 | 2 | 0.5 | 258 | 59.0 |
| 100 | 179 | 41.0 | 437 | 100.0 |

Frequency Missing = 42

% of retro lights on - SUM WKDAY - 9AM

| LF017I | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 66 | 15.1 | 66 | 15.1 |
| 1 | 20 | 4.6 | 86 | 19.6 |
| 3 | 1 | 0.2 | 87 | 19.9 |
| 5 | 17 | 3.9 | 104 | 23.7 |
| 6 | 1 | 0.2 | 105 | 24.0 |
| 7 | 2 | 0.5 | 107 | 24.4 |
| 10 | 9 | 2.1 | 116 | 26.5 |
| 15 | 1 | 0.2 | 117 | 26.7 |
| 20 | 3 | 0.7 | 120 | 27.4 |
| 25 | 5 | 1.1 | 125 | 28.5 |
| 30 | 28 | 6.4 | 153 | 34.9 |
| 40 | 2 | 0.5 | 155 | 35.4 |
| 50 | 7 | 1.6 | 162 | 37.0 |
| 60 | 6 | 1.4 | 168 | 38.4 |
| 65 | 2 | 0.5 | 170 | 38.8 |
| 66 | 2 | 0.5 | 172 | 39.3 |
| 70 | 3 | 0.7 | 175 | 40.0 |
| 75 | 5 | 1.1 | 180 | 41.1 |
| 80 | 16 | 3.7 | 196 | 44.7 |
| 85 | 2 | 0.5 | 198 | 45.2 |
| 90 | 11 | 2.5 | 209 | 47.7 |
| 95 | 7 | 1.6 | 216 | 49.3 |
| 98 | 1 | 0.2 | 217 | 49.5 |
| 99 | 2 | 0.5 | 219 | 50.0 |
| 100 | 219 | 50.0 | 438 | 100.0 |

Frequency Missing = 41

% of retro lights on - SUM WKDAY - 10AM

| LF017J | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 56 | 12.8 | 56 | 12.8 |
| 1 | 22 | 5.0 | 78 | 17.8 |
| 3 | 1 | 0.2 | 79 | 18.0 |
| 5 | 16 | 3.6 | 95 | 21.6 |
| 7 | 2 | 0.5 | 97 | 22.1 |
| 10 | 7 | 1.6 | 104 | 23.7 |
| 15 | 1 | 0.2 | 105 | 23.9 |
| 20 | 2 | 0.5 | 107 | 24.4 |
| 25 | 5 | 1.1 | 112 | 25.5 |
| 30 | 27 | 6.2 | 139 | 31.7 |
| 40 | 2 | 0.5 | 141 | 32.1 |
| 45 | 1 | 0.2 | 142 | 32.3 |
| 50 | 7 | 1.6 | 149 | 33.9 |
| 60 | 6 | 1.4 | 155 | 35.3 |
| 65 | 2 | 0.5 | 157 | 35.8 |
| 66 | 2 | 0.5 | 159 | 36.2 |
| 70 | 3 | 0.7 | 162 | 36.9 |
| 75 | 5 | 1.1 | 167 | 38.0 |
| 80 | 17 | 3.9 | 184 | 41.9 |
| 85 | 2 | 0.5 | 186 | 42.4 |
| 90 | 11 | 2.5 | 197 | 44.9 |
| 95 | 8 | 1.8 | 205 | 46.7 |
| 98 | 1 | 0.2 | 206 | 46.9 |
| 99 | 2 | 0.5 | 208 | 47.4 |
| 100 | 231 | 52.6 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 11AM

| LF017K | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 55 | 12.5 | 55 | 12.5 |
| 1 | 22 | 5.0 | 77 | 17.5 |
| 3 | 1 | 0.2 | 78 | 17.8 |
| 5 | 15 | 3.4 | 93 | 21.2 |
| 7 | 2 | 0.5 | 95 | 21.6 |
| 10 | 8 | 1.8 | 103 | 23.5 |
| 15 | 1 | 0.2 | 104 | 23.7 |
| 20 | 1 | 0.2 | 105 | 23.9 |
| 25 | 5 | 1.1 | 110 | 25.1 |
| 30 | 26 | 5.9 | 136 | 31.0 |
| 40 | 2 | 0.5 | 138 | 31.4 |
| 45 | 1 | 0.2 | 139 | 31.7 |
| 50 | 7 | 1.6 | 146 | 33.3 |
| 60 | 6 | 1.4 | 152 | 34.6 |
| 65 | 2 | 0.5 | 154 | 35.1 |
| 66 | 2 | 0.5 | 156 | 35.5 |
| 70 | 3 | 0.7 | 159 | 36.2 |
| 75 | 6 | 1.4 | 165 | 37.6 |
| 80 | 17 | 3.9 | 182 | 41.5 |
| 85 | 2 | 0.5 | 184 | 41.9 |
| 90 | 11 | 2.5 | 195 | 44.4 |
| 95 | 8 | 1.8 | 203 | 46.2 |
| 98 | 1 | 0.2 | 204 | 46.5 |
| 99 | 2 | 0.5 | 206 | 46.9 |
| 100 | 233 | 53.1 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 12PM

| LF017L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 53 | 12.1 | 53 | 12.1 |
| 1 | 21 | 4.8 | 74 | 16.9 |
| 2 | 13 | 3.0 | 87 | 19.8 |
| 3 | 1 | 0.2 | 88 | 20.0 |
| 5 | 16 | 3.6 | 104 | 23.7 |
| 7 | 2 | 0.5 | 106 | 24.1 |
| 10 | 8 | 1.8 | 114 | 26.0 |
| 15 | 1 | 0.2 | 115 | 26.2 |
| 20 | 1 | 0.2 | 116 | 26.4 |
| 25 | 4 | 0.9 | 120 | 27.3 |
| 30 | 13 | 3.0 | 133 | 30.3 |
| 40 | 2 | 0.5 | 135 | 30.8 |
| 45 | 1 | 0.2 | 136 | 31.0 |
| 50 | 12 | 2.7 | 148 | 33.7 |
| 60 | 6 | 1.4 | 154 | 35.1 |
| 65 | 2 | 0.5 | 156 | 35.5 |
| 66 | 2 | 0.5 | 158 | 36.0 |
| 70 | 3 | 0.7 | 161 | 36.7 |
| 75 | 6 | 1.4 | 167 | 38.0 |
| 80 | 18 | 4.1 | 185 | 42.1 |
| 85 | 2 | 0.5 | 187 | 42.6 |
| 90 | 12 | 2.7 | 199 | 45.3 |
| 95 | 8 | 1.8 | 207 | 47.2 |
| 98 | 1 | 0.2 | 208 | 47.4 |
| 99 | 2 | 0.5 | 210 | 47.8 |
| 100 | 229 | 52.2 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 1PM

| LF017M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 52 | 11.8 | 52 | 11.8 |
| 1 | 21 | 4.8 | 73 | 16.6 |
| 2 | 13 | 3.0 | 86 | 19.6 |
| 3 | 1 | 0.2 | 87 | 19.8 |
| 5 | 17 | 3.9 | 104 | 23.7 |
| 7 | 2 | 0.5 | 106 | 24.1 |
| 10 | 9 | 2.1 | 115 | 26.2 |
| 15 | 1 | 0.2 | 116 | 26.4 |
| 20 | 1 | 0.2 | 117 | 26.7 |
| 25 | 4 | 0.9 | 121 | 27.6 |
| 30 | 13 | 3.0 | 134 | 30.5 |
| 40 | 2 | 0.5 | 136 | 31.0 |
| 45 | 1 | 0.2 | 137 | 31.2 |
| 50 | 7 | 1.6 | 144 | 32.8 |
| 60 | 6 | 1.4 | 150 | 34.2 |
| 64 | 1 | 0.2 | 151 | 34.4 |
| 65 | 1 | 0.2 | 152 | 34.6 |
| 66 | 2 | 0.5 | 154 | 35.1 |
| 70 | 3 | 0.7 | 157 | 35.8 |
| 75 | 6 | 1.4 | 163 | 37.1 |
| 80 | 18 | 4.1 | 181 | 41.2 |
| 85 | 2 | 0.5 | 183 | 41.7 |
| 90 | 12 | 2.7 | 195 | 44.4 |
| 95 | 8 | 1.8 | 203 | 46.2 |
| 98 | 1 | 0.2 | 204 | 46.5 |
| 99 | 2 | 0.5 | 206 | 46.9 |
| 100 | 233 | 53.1 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 2PM

| LF017N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 56 | 12.8 | 56 | 12.8 |
| 1 | 21 | 4.8 | 77 | 17.5 |
| 2 | 13 | 3.0 | 90 | 20.5 |
| 3 | 1 | 0.2 | 91 | 20.7 |
| 5 | 19 | 4.3 | 110 | 25.1 |
| 7 | 2 | 0.5 | 112 | 25.5 |
| 10 | 7 | 1.6 | 119 | 27.1 |
| 15 | 1 | 0.2 | 120 | 27.3 |
| 20 | 1 | 0.2 | 121 | 27.6 |
| 25 | 3 | 0.7 | 124 | 28.2 |
| 30 | 13 | 3.0 | 137 | 31.2 |
| 40 | 2 | 0.5 | 139 | 31.7 |
| 50 | 7 | 1.6 | 146 | 33.3 |
| 60 | 6 | 1.4 | 152 | 34.6 |
| 65 | 2 | 0.5 | 154 | 35.1 |
| 66 | 2 | 0.5 | 156 | 35.5 |
| 70 | 3 | 0.7 | 159 | 36.2 |
| 75 | 6 | 1.4 | 165 | 37.6 |
| 80 | 18 | 4.1 | 183 | 41.7 |
| 85 | 2 | 0.5 | 185 | 42.1 |
| 90 | 12 | 2.7 | 197 | 44.9 |
| 95 | 8 | 1.8 | 205 | 46.7 |
| 98 | 1 | 0.2 | 206 | 46.9 |
| 99 | 2 | 0.5 | 208 | 47.4 |
| 100 | 231 | 52.6 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 3PM

| LF0170 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 60 | 13.7 | 60 | 13.7 |
| 1 | 21 | 4.8 | 81 | 18.5 |
| 2 | 13 | 3.0 | 94 | 21.4 |
| 3 | 1 | 0.2 | 95 | 21.6 |
| 5 | 17 | 3.9 | 112 | 25.5 |
| 7 | 2 | 0.5 | 114 | 26.0 |
| 10 | 7 | 1.6 | 121 | 27.6 |
| 15 | 1 | 0.2 | 122 | 27.8 |
| 20 | 2 | 0.5 | 124 | 28.2 |
| 25 | 3 | 0.7 | 127 | 28.9 |
| 30 | 13 | 3.0 | 140 | 31.9 |
| 40 | 2 | 0.5 | 142 | 32.3 |
| 50 | 7 | 1.6 | 149 | 33.9 |
| 60 | 6 | 1.4 | 155 | 35.3 |
| 65 | 2 | 0.5 | 157 | 35.8 |
| 66 | 2 | 0.5 | 159 | 36.2 |
| 70 | 3 | 0.7 | 162 | 36.9 |
| 75 | 6 | 1.4 | 168 | 38.3 |
| 80 | 17 | 3.9 | 185 | 42.1 |
| 85 | 2 | 0.5 | 187 | 42.6 |
| 90 | 11 | 2.5 | 198 | 45.1 |
| 95 | 8 | 1.8 | 206 | 46.9 |
| 98 | 1 | 0.2 | 207 | 47.2 |
| 99 | 2 | 0.5 | 209 | 47.6 |
| 100 | 230 | 52.4 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 4PM

| LF017P | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 83 | 18.9 | 83 | 18.9 |
| 1 | 20 | 4.6 | 103 | 23.5 |
| 2 | 15 | 3.4 | 118 | 26.9 |
| 5 | 9 | 2.1 | 127 | 28.9 |
| 7 | 2 | 0.5 | 129 | 29.4 |
| 10 | 5 | 1.1 | 134 | 30.5 |
| 15 | 1 | 0.2 | 135 | 30.8 |
| 20 | 1 | 0.2 | 136 | 31.0 |
| 25 | 2 | 0.5 | 138 | 31.4 |
| 30 | 3 | 0.7 | 141 | 32.1 |
| 40 | 2 | 0.5 | 143 | 32.6 |
| 50 | 6 | 1.4 | 149 | 33.9 |
| 54 | 1 | 0.2 | 150 | 34.2 |
| 60 | 6 | 1.4 | 156 | 35.5 |
| 65 | 2 | 0.5 | 158 | 36.0 |
| 66 | 2 | 0.5 | 160 | 36.4 |
| 70 | 3 | 0.7 | 163 | 37.1 |
| 75 | 6 | 1.4 | 169 | 38.5 |
| 80 | 17 | 3.9 | 186 | 42.4 |
| 85 | 2 | 0.5 | 188 | 42.8 |
| 90 | 9 | 2.1 | 197 | 44.9 |
| 95 | 9 | 2.1 | 206 | 46.9 |
| 98 | 1 | 0.2 | 207 | 47.2 |
| 99 | 2 | 0.5 | 209 | 47.6 |
| 100 | 230 | 52.4 | 439 | 100.0 |

Frequency Missing = 40

% of retro lights on - SUM WKDAY - 5PM

| LF017Q | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 87 | 19.9 | 87 | 19.9 |
| 1 | 20 | 4.6 | 107 | 24.4 |
| 2 | 17 | 3.9 | 124 | 28.3 |
| 5 | 8 | 1.8 | 132 | 30.1 |
| 7 | 2 | 0.5 | 134 | 30.6 |
| 8 | 1 | 0.2 | 135 | 30.8 |
| 10 | 4 | 0.9 | 139 | 31.7 |
| 20 | 2 | 0.5 | 141 | 32.2 |
| 25 | 2 | 0.5 | 143 | 32.6 |
| 30 | 4 | 0.9 | 147 | 33.6 |
| 40 | 2 | 0.5 | 149 | 34.0 |
| 50 | 9 | 2.1 | 158 | 36.1 |
| 60 | 6 | 1.4 | 164 | 37.4 |
| 65 | 3 | 0.7 | 167 | 38.1 |
| 66 | 2 | 0.5 | 169 | 38.6 |
| 70 | 3 | 0.7 | 172 | 39.3 |
| 75 | 6 | 1.4 | 178 | 40.6 |
| 80 | 17 | 3.9 | 195 | 44.5 |
| 85 | 2 | 0.5 | 197 | 45.0 |
| 90 | 7 | 1.6 | 204 | 46.6 |
| 95 | 9 | 2.1 | 213 | 48.6 |
| 98 | 1 | 0.2 | 214 | 48.9 |
| 99 | 2 | 0.5 | 216 | 49.3 |
| 100 | 222 | 50.7 | 438 | 100.0 |

Frequency Missing = 41

% of retro lights on - SUM WKDAY - 6PM

| LF017R | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 149 | 34.1 | 149 | 34.1 |
| 1 | 21 | 4.8 | 170 | 38.9 |
| 2 | 21 | 4.8 | 191 | 43.7 |
| 3 | 1 | 0.2 | 192 | 43.9 |
| 4 | 1 | 0.2 | 193 | 44.2 |
| 5 | 8 | 1.8 | 201 | 46.0 |
| 7 | 2 | 0.5 | 203 | 46.5 |
| 8 | 1 | 0.2 | 204 | 46.7 |
| 10 | 5 | 1.1 | 209 | 47.8 |
| 15 | 1 | 0.2 | 210 | 48.1 |
| 20 | 4 | 0.9 | 214 | 49.0 |
| 25 | 1 | 0.2 | 215 | 49.2 |
| 30 | 3 | 0.7 | 218 | 49.9 |
| 40 | 2 | 0.5 | 220 | 50.3 |
| 50 | 10 | 2.3 | 230 | 52.6 |
| 60 | 6 | 1.4 | 236 | 54.0 |
| 65 | 3 | 0.7 | 239 | 54.7 |
| 66 | 2 | 0.5 | 241 | 55.1 |
| 70 | 2 | 0.5 | 243 | 55.6 |
| 75 | 5 | 1.1 | 248 | 56.8 |
| 80 | 13 | 3.0 | 261 | 59.7 |
| 85 | 2 | 0.5 | 263 | 60.2 |
| 90 | 4 | 0.9 | 267 | 61.1 |
| 95 | 7 | 1.6 | 274 | 62.7 |
| 98 | 1 | 0.2 | 275 | 62.9 |
| 99 | 1 | 0.2 | 276 | 63.2 |
| 100 | 161 | 36.8 | 437 | 100.0 |

Frequency Missing = 42

% of retro lights on - SUM WKDAY - 7PM

| LF017S | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 191 | 43.8 | 191 | 43.8 |
| 1 | 22 | 5.0 | 213 | 48.9 |
| 2 | 29 | 6.7 | 242 | 55.5 |
| 3 | 1 | 0.2 | 243 | 55.7 |
| 4 | 1 | 0.2 | 244 | 56.0 |
| 5 | 19 | 4.4 | 263 | 60.3 |
| 7 | 2 | 0.5 | 265 | 60.8 |
| 8 | 1 | 0.2 | 266 | 61.0 |
| 10 | 10 | 2.3 | 276 | 63.3 |
| 12 | 1 | 0.2 | 277 | 63.5 |
| 15 | 3 | 0.7 | 280 | 64.2 |
| 20 | 3 | 0.7 | 283 | 64.9 |
| 25 | 3 | 0.7 | 286 | 65.6 |
| 30 | 3 | 0.7 | 289 | 66.3 |
| 35 | 1 | 0.2 | 290 | 66.5 |
| 40 | 1 | 0.2 | 291 | 66.7 |
| 50 | 8 | 1.8 | 299 | 68.6 |
| 60 | 5 | 1.1 | 304 | 69.7 |
| 65 | 4 | 0.9 | 308 | 70.6 |
| 66 | 1 | 0.2 | 309 | 70.9 |
| 75 | 3 | 0.7 | 312 | 71.6 |
| 80 | 5 | 1.1 | 317 | 72.7 |
| 85 | 2 | 0.5 | 319 | 73.2 |
| 90 | 3 | 0.7 | 322 | 73.9 |
| 95 | 4 | 0.9 | 326 | 74.8 |
| 98 | 1 | 0.2 | 327 | 75.0 |
| 99 | 1 | 0.2 | 328 | 75.2 |
| 100 | 108 | 24.8 | 436 | 100.0 |

Frequency Missing = 43

% of retro lights on - SUM WKDAY - 8PM

| LF017T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 178 | 40.9 | 178 | 40.9 |
| 0.5 | 1 | 0.2 | 179 | 41.1 |
| 1 | 25 | 5.7 | 204 | 46.9 |
| 2 | 31 | 7.1 | 235 | 54.0 |
| 3 | 2 | 0.5 | 237 | 54.5 |
| 4 | 1 | 0.2 | 238 | 54.7 |
| 5 | 24 | 5.5 | 262 | 60.2 |
| 7 | 2 | 0.5 | 264 | 60.7 |
| 8 | 1 | 0.2 | 265 | 60.9 |
| 10 | 10 | 2.3 | 275 | 63.2 |
| 12 | 1 | 0.2 | 276 | 63.4 |
| 13 | 1 | 0.2 | 277 | 63.7 |
| 15 | 3 | 0.7 | 280 | 64.4 |
| 20 | 5 | 1.1 | 285 | 65.5 |
| 25 | 1 | 0.2 | 286 | 65.7 |
| 30 | 3 | 0.7 | 289 | 66.4 |
| 35 | 1 | 0.2 | 290 | 66.7 |
| 40 | 1 | 0.2 | 291 | 66.9 |
| 50 | 8 | 1.8 | 299 | 68.7 |
| 60 | 6 | 1.4 | 305 | 70.1 |
| 65 | 3 | 0.7 | 308 | 70.8 |
| 66 | 1 | 0.2 | 309 | 71.0 |
| 75 | 4 | 0.9 | 313 | 72.0 |
| 80 | 5 | 1.1 | 318 | 73.1 |
| 85 | 1 | 0.2 | 319 | 73.3 |
| 90 | 3 | 0.7 | 322 | 74.0 |
| 95 | 2 | 0.5 | 324 | 74.5 |
| 98 | 1 | 0.2 | 325 | 74.7 |
| 100 | 110 | 25.3 | 435 | 100.0 |

Frequency Missing = 44

% of retro lights on - SUM WKDAY - 9PM

| LF017U | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 182 | 41.7 | 182 | 41.7 |
| 0.5 | 1 | 0.2 | 183 | 42.0 |
| 1 | 25 | 5.7 | 208 | 47.7 |
| 2 | 34 | 7.8 | 242 | 55.5 |
| 3 | 3 | 0.7 | 245 | 56.2 |
| 4 | 1 | 0.2 | 246 | 56.4 |
| 5 | 27 | 6.2 | 273 | 62.6 |
| 8 | 1 | 0.2 | 274 | 62.8 |
| 10 | 11 | 2.5 | 285 | 65.4 |
| 12 | 1 | 0.2 | 286 | 65.6 |
| 13 | 1 | 0.2 | 287 | 65.8 |
| 15 | 5 | 1.1 | 292 | 67.0 |
| 20 | 4 | 0.9 | 296 | 67.9 |
| 25 | 1 | 0.2 | 297 | 68.1 |
| 30 | 5 | 1.1 | 302 | 69.3 |
| 35 | 1 | 0.2 | 303 | 69.5 |
| 40 | 1 | 0.2 | 304 | 69.7 |
| 50 | 8 | 1.8 | 312 | 71.6 |
| 60 | 4 | 0.9 | 316 | 72.5 |
| 65 | 2 | 0.5 | 318 | 72.9 |
| 66 | 1 | 0.2 | 319 | 73.2 |
| 70 | 1 | 0.2 | 320 | 73.4 |
| 75 | 4 | 0.9 | 324 | 74.3 |
| 80 | 6 | 1.4 | 330 | 75.7 |
| 90 | 3 | 0.7 | 333 | 76.4 |
| 95 | 2 | 0.5 | 335 | 76.8 |
| 98 | 1 | 0.2 | 336 | 77.1 |
| 100 | 100 | 22.9 | 436 | 100.0 |

Frequency Missing = 43

% of retro lights on - SUM WKDAY - 10PM

| LF017V | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 200 | 46.0 | 200 | 46.0 |
| 0.5 | 1 | 0.2 | 201 | 46.2 |
| 1 | 23 | 5.3 | 224 | 51.5 |
| 2 | 34 | 7.8 | 258 | 59.3 |
| 3 | 3 | 0.7 | 261 | 60.0 |
| 4 | 1 | 0.2 | 262 | 60.2 |
| 5 | 27 | 6.2 | 289 | 66.4 |
| 8 | 1 | 0.2 | 290 | 66.7 |
| 10 | 13 | 3.0 | 303 | 69.7 |
| 12 | 1 | 0.2 | 304 | 69.9 |
| 13 | 1 | 0.2 | 305 | 70.1 |
| 15 | 5 | 1.1 | 310 | 71.3 |
| 20 | 4 | 0.9 | 314 | 72.2 |
| 25 | 1 | 0.2 | 315 | 72.4 |
| 30 | 8 | 1.8 | 323 | 74.3 |
| 35 | 1 | 0.2 | 324 | 74.5 |
| 40 | 2 | 0.5 | 326 | 74.9 |
| 50 | 7 | 1.6 | 333 | 76.6 |
| 60 | 4 | 0.9 | 337 | 77.5 |
| 65 | 2 | 0.5 | 339 | 77.9 |
| 70 | 3 | 0.7 | 342 | 78.6 |
| 75 | 4 | 0.9 | 346 | 79.5 |
| 80 | 1 | 0.2 | 347 | 79.8 |
| 90 | 2 | 0.5 | 349 | 80.2 |
| 95 | 2 | 0.5 | 351 | 80.7 |
| 98 | 1 | 0.2 | 352 | 80.9 |
| 100 | 83 | 19.1 | 435 | 100.0 |

Frequency Missing = 44

% of retro lights on - SUM WKDAY - 11PM

| LF017W | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 211 | 48.4 | 211 | 48.4 |
| 0.5 | 1 | 0.2 | 212 | 48.6 |
| 1 | 23 | 5.3 | 235 | 53.9 |
| 2 | 34 | 7.8 | 269 | 61.7 |
| 3 | 4 | 0.9 | 273 | 62.6 |
| 4 | 1 | 0.2 | 274 | 62.8 |
| 5 | 31 | 7.1 | 305 | 70.0 |
| 8 | 1 | 0.2 | 306 | 70.2 |
| 10 | 16 | 3.7 | 322 | 73.9 |
| 12 | 1 | 0.2 | 323 | 74.1 |
| 13 | 1 | 0.2 | 324 | 74.3 |
| 15 | 6 | 1.4 | 330 | 75.7 |
| 20 | 2 | 0.5 | 332 | 76.1 |
| 25 | 2 | 0.5 | 334 | 76.6 |
| 30 | 9 | 2.1 | 343 | 78.7 |
| 33 | 1 | 0.2 | 344 | 78.9 |
| 35 | 1 | 0.2 | 345 | 79.1 |
| 40 | 2 | 0.5 | 347 | 79.6 |
| 50 | 8 | 1.8 | 355 | 81.4 |
| 60 | 1 | 0.2 | 356 | 81.7 |
| 65 | 1 | 0.2 | 357 | 81.9 |
| 75 | 3 | 0.7 | 360 | 82.6 |
| 80 | 1 | 0.2 | 361 | 82.8 |
| 90 | 1 | 0.2 | 362 | 83.0 |
| 95 | 1 | 0.2 | 363 | 83.3 |
| 98 | 1 | 0.2 | 364 | 83.5 |
| 100 | 72 | 16.5 | 436 | 100.0 |

Frequency Missing = 43

% of retro lights on - SUM WKDAY - 12AM

| LF017X | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 236 | 53.8 | 236 | 53.8 |
| 0.5 | 1 | 0.2 | 237 | 54.0 |
| 1 | 26 | 5.9 | 263 | 59.9 |
| 2 | 19 | 4.3 | 282 | 64.2 |
| 3 | 4 | 0.9 | 286 | 65.1 |
| 4 | 1 | 0.2 | 287 | 65.4 |
| 5 | 30 | 6.8 | 317 | 72.2 |
| 8 | 1 | 0.2 | 318 | 72.4 |
| 10 | 17 | 3.9 | 335 | 76.3 |
| 12 | 1 | 0.2 | 336 | 76.5 |
| 13 | 1 | 0.2 | 337 | 76.8 |
| 15 | 6 | 1.4 | 343 | 78.1 |
| 20 | 2 | 0.5 | 345 | 78.6 |
| 25 | 3 | 0.7 | 348 | 79.3 |
| 30 | 8 | 1.8 | 356 | 81.1 |
| 33 | 1 | 0.2 | 357 | 81.3 |
| 40 | 2 | 0.5 | 359 | 81.8 |
| 50 | 19 | 4.3 | 378 | 86.1 |
| 65 | 1 | 0.2 | 379 | 86.3 |
| 75 | 1 | 0.2 | 380 | 86.6 |
| 80 | 3 | 0.7 | 383 | 87.2 |
| 90 | 2 | 0.5 | 385 | 87.7 |
| 98 | 1 | 0.2 | 386 | 87.9 |
| 100 | 53 | 12.1 | 439 | 100.0 |

Frequency Missing = 40

| LF18 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 98 | 21.6 | 98 | 21.6 |
| 1 | 356 | 78.4 | 454 | 100.0 |

Frequency Missing = 25

% of retro lights on - WTR WKDAY - 1AM

| LF020A | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 64 | 66.0 | 64 | 66.0 |
| 1 | 4 | 4.1 | 68 | 70.1 |
| 2 | 2 | 2.1 | 70 | 72.2 |
| 3 | 1 | 1.0 | 71 | 73.2 |
| 5 | 3 | 3.1 | 74 | 76.3 |
| 10 | 4 | 4.1 | 78 | 80.4 |
| 15 | 2 | 2.1 | 80 | 82.5 |
| 25 | 1 | 1.0 | 81 | 83.5 |
| 50 | 1 | 1.0 | 82 | 84.5 |
| 75 | 1 | 1.0 | 83 | 85.6 |
| 100 | 14 | 14.4 | 97 | 100.0 |

Frequency Missing = 382

% of retro lights on - WTR WKDAY - 2AM

| LF020B | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 67 | 69.1 | 67 | 69.1 |
| 1 | 3 | 3.1 | 70 | 72.2 |
| 2 | 2 | 2.1 | 72 | 74.2 |
| 3 | 1 | 1.0 | 73 | 75.3 |
| 5 | 3 | 3.1 | 76 | 78.4 |
| 10 | 4 | 4.1 | 80 | 82.5 |
| 15 | 2 | 2.1 | 82 | 84.5 |
| 25 | 1 | 1.0 | 83 | 85.6 |
| 50 | 1 | 1.0 | 84 | 86.6 |
| 75 | 1 | 1.0 | 85 | 87.6 |
| 100 | 12 | 12.4 | 97 | 100.0 |

Frequency Missing = 382

% of retro lights on - WTR WKDAY - 3AM

| LF020C | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 67 | 69.1 | 67 | 69.1 |
| 1 | 3 | 3.1 | 70 | 72.2 |
| 2 | 2 | 2.1 | 72 | 74.2 |
| 3 | 1 | 1.0 | 73 | 75.3 |
| 5 | 3 | 3.1 | 76 | 78.4 |
| 10 | 4 | 4.1 | 80 | 82.5 |
| 15 | 2 | 2.1 | 82 | 84.5 |
| 25 | 1 | 1.0 | 83 | 85.6 |
| 50 | 2 | 2.1 | 85 | 87.6 |
| 75 | 1 | 1.0 | 86 | 88.7 |
| 100 | 11 | 11.3 | 97 | 100.0 |

Frequency Missing = 382

% of retro lights on - WTR WKDAY - 4AM

| LF020D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 67 | 69.1 | 67 | 69.1 |
| 1 | 3 | 3.1 | 70 | 72.2 |
| 2 | 2 | 2.1 | 72 | 74.2 |
| 3 | 1 | 1.0 | 73 | 75.3 |
| 5 | 3 | 3.1 | 76 | 78.4 |
| 10 | 4 | 4.1 | 80 | 82.5 |
| 15 | 2 | 2.1 | 82 | 84.5 |
| 25 | 1 | 1.0 | 83 | 85.6 |
| 50 | 2 | 2.1 | 85 | 87.6 |
| 75 | 1 | 1.0 | 86 | 88.7 |
| 100 | 11 | 11.3 | 97 | 100.0 |

Frequency Missing = 382

% of retro lights on - WTR WKDAY - 5AM

| LF020E | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 66 | 68.0 | 66 | 68.0 |
| 1 | 4 | 4.1 | 70 | 72.2 |
| 2 | 2 | 2.1 | 72 | 74.2 |
| 3 | 1 | 1.0 | 73 | 75.3 |
| 5 | 3 | 3.1 | 76 | 78.4 |
| 10 | 4 | 4.1 | 80 | 82.5 |
| 15 | 2 | 2.1 | 82 | 84.5 |
| 20 | 1 | 1.0 | 83 | 85.6 |
| 25 | 1 | 1.0 | 84 | 86.6 |
| 50 | 2 | 2.1 | 86 | 88.7 |
| 75 | 1 | 1.0 | 87 | 89.7 |
| 100 | 10 | 10.3 | 97 | 100.0 |

Frequency Missing = 382

% of retro lights on - WTR WKDAY - 6AM

| LF020F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 39 | 39.8 | 39 | 39.8 |
| 1 | 2 | 2.0 | 41 | 41.8 |
| 2 | 15 | 15.3 | 56 | 57.1 |
| 3 | 1 | 1.0 | 57 | 58.2 |
| 5 | 5 | 5.1 | 62 | 63.3 |
| 10 | 4 | 4.1 | 66 | 67.3 |
| 15 | 2 | 2.0 | 68 | 69.4 |
| 20 | 1 | 1.0 | 69 | 70.4 |
| 25 | 2 | 2.0 | 71 | 72.4 |
| 50 | 2 | 2.0 | 73 | 74.5 |
| 60 | 1 | 1.0 | 74 | 75.5 |
| 70 | 9 | 9.2 | 83 | 84.7 |
| 75 | 2 | 2.0 | 85 | 86.7 |
| 80 | 1 | 1.0 | 86 | 87.8 |
| 100 | 12 | 12.2 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 7AM

| LF020G | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 25 | 25.8 | 25 | 25.8 |
| 1 | 2 | 2.1 | 27 | 27.8 |
| 2 | 1 | 1.0 | 28 | 28.9 |
| 3 | 1 | 1.0 | 29 | 29.9 |
| 5 | 1 | 1.0 | 30 | 30.9 |
| 10 | 4 | 4.1 | 34 | 35.1 |
| 25 | 1 | 1.0 | 35 | 36.1 |
| 30 | 1 | 1.0 | 36 | 37.1 |
| 50 | 4 | 4.1 | 40 | 41.2 |
| 60 | 1 | 1.0 | 41 | 42.3 |
| 70 | 2 | 2.1 | 43 | 44.3 |
| 75 | 2 | 2.1 | 45 | 46.4 |
| 80 | 3 | 3.1 | 48 | 49.5 |
| 85 | 2 | 2.1 | 50 | 51.5 |
| 90 | 13 | 13.4 | 63 | 64.9 |
| 95 | 1 | 1.0 | 64 | 66.0 |
| 99 | 7 | 7.2 | 71 | 73.2 |
| 100 | 26 | 26.8 | 97 | 100.0 |

Frequency Missing = 382

% of retro lights on - WTR WKDAY - 8AM

| LF020H | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 6 | 1 | 1.0 | 26 | 26.5 |
| 10 | 3 | 3.1 | 29 | 29.6 |
| 30 | 1 | 1.0 | 30 | 30.6 |
| 40 | 1 | 1.0 | 31 | 31.6 |
| 50 | 1 | 1.0 | 32 | 32.7 |
| 60 | 2 | 2.0 | 34 | 34.7 |
| 70 | 2 | 2.0 | 36 | 36.7 |
| 75 | 2 | 2.0 | 38 | 38.8 |
| 80 | 3 | 3.1 | 41 | 41.8 |
| 85 | 2 | 2.0 | 43 | 43.9 |
| 90 | 15 | 15.3 | 58 | 59.2 |
| 95 | 1 | 1.0 | 59 | 60.2 |
| 99 | 7 | 7.1 | 66 | 67.3 |
| 100 | 32 | 32.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 9AM

| LF020I | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 6 | 1 | 1.0 | 26 | 26.5 |
| 10 | 1 | 1.0 | 27 | 27.6 |
| 30 | 2 | 2.0 | 29 | 29.6 |
| 40 | 1 | 1.0 | 30 | 30.6 |
| 50 | 1 | 1.0 | 31 | 31.6 |
| 60 | 2 | 2.0 | 33 | 33.7 |
| 70 | 2 | 2.0 | 35 | 35.7 |
| 75 | 2 | 2.0 | 37 | 37.8 |
| 80 | 4 | 4.1 | 41 | 41.8 |
| 85 | 2 | 2.0 | 43 | 43.9 |
| 90 | 15 | 15.3 | 58 | 59.2 |
| 95 | 1 | 1.0 | 59 | 60.2 |
| 99 | 7 | 7.1 | 66 | 67.3 |
| 100 | 32 | 32.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 10AM

| LF020J | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 10 | 1 | 1.0 | 26 | 26.5 |
| 30 | 2 | 2.0 | 28 | 28.6 |
| 40 | 1 | 1.0 | 29 | 29.6 |
| 50 | 1 | 1.0 | 30 | 30.6 |
| 60 | 2 | 2.0 | 32 | 32.7 |
| 70 | 2 | 2.0 | 34 | 34.7 |
| 75 | 2 | 2.0 | 36 | 36.7 |
| 80 | 4 | 4.1 | 40 | 40.8 |
| 85 | 2 | 2.0 | 42 | 42.9 |
| 90 | 14 | 14.3 | 56 | 57.1 |
| 95 | 1 | 1.0 | 57 | 58.2 |
| 99 | 7 | 7.1 | 64 | 65.3 |
| 100 | 34 | 34.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 11AM

| LF020K | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 10 | 1 | 1.0 | 26 | 26.5 |
| 30 | 1 | 1.0 | 27 | 27.6 |
| 40 | 1 | 1.0 | 28 | 28.6 |
| 50 | 1 | 1.0 | 29 | 29.6 |
| 60 | 2 | 2.0 | 31 | 31.6 |
| 70 | 2 | 2.0 | 33 | 33.7 |
| 75 | 2 | 2.0 | 35 | 35.7 |
| 80 | 4 | 4.1 | 39 | 39.8 |
| 85 | 2 | 2.0 | 41 | 41.8 |
| 90 | 14 | 14.3 | 55 | 56.1 |
| 95 | 1 | 1.0 | 56 | 57.1 |
| 99 | 7 | 7.1 | 63 | 64.3 |
| 100 | 35 | 35.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 12PM

| LF020L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 10 | 1 | 1.0 | 26 | 26.5 |
| 30 | 1 | 1.0 | 27 | 27.6 |
| 40 | 1 | 1.0 | 28 | 28.6 |
| 50 | 1 | 1.0 | 29 | 29.6 |
| 60 | 2 | 2.0 | 31 | 31.6 |
| 70 | 2 | 2.0 | 33 | 33.7 |
| 75 | 2 | 2.0 | 35 | 35.7 |
| 80 | 4 | 4.1 | 39 | 39.8 |
| 85 | 2 | 2.0 | 41 | 41.8 |
| 90 | 14 | 14.3 | 55 | 56.1 |
| 95 | 1 | 1.0 | 56 | 57.1 |
| 99 | 7 | 7.1 | 63 | 64.3 |
| 100 | 35 | 35.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 1PM

| LF020M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 10 | 1 | 1.0 | 26 | 26.5 |
| 30 | 1 | 1.0 | 27 | 27.6 |
| 40 | 1 | 1.0 | 28 | 28.6 |
| 50 | 1 | 1.0 | 29 | 29.6 |
| 60 | 2 | 2.0 | 31 | 31.6 |
| 70 | 2 | 2.0 | 33 | 33.7 |
| 75 | 2 | 2.0 | 35 | 35.7 |
| 80 | 4 | 4.1 | 39 | 39.8 |
| 85 | 2 | 2.0 | 41 | 41.8 |
| 90 | 14 | 14.3 | 55 | 56.1 |
| 95 | 1 | 1.0 | 56 | 57.1 |
| 99 | 7 | 7.1 | 63 | 64.3 |
| 100 | 35 | 35.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 2PM

| LF020N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 5 | 1 | 1.0 | 26 | 26.5 |
| 30 | 1 | 1.0 | 27 | 27.6 |
| 40 | 1 | 1.0 | 28 | 28.6 |
| 50 | 1 | 1.0 | 29 | 29.6 |
| 60 | 2 | 2.0 | 31 | 31.6 |
| 70 | 2 | 2.0 | 33 | 33.7 |
| 75 | 2 | 2.0 | 35 | 35.7 |
| 80 | 4 | 4.1 | 39 | 39.8 |
| 85 | 2 | 2.0 | 41 | 41.8 |
| 90 | 14 | 14.3 | 55 | 56.1 |
| 95 | 1 | 1.0 | 56 | 57.1 |
| 99 | 7 | 7.1 | 63 | 64.3 |
| 100 | 35 | 35.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 3PM

| LF0200 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 5 | 1 | 1.0 | 26 | 26.5 |
| 30 | 1 | 1.0 | 27 | 27.6 |
| 40 | 1 | 1.0 | 28 | 28.6 |
| 50 | 1 | 1.0 | 29 | 29.6 |
| 60 | 2 | 2.0 | 31 | 31.6 |
| 70 | 2 | 2.0 | 33 | 33.7 |
| 75 | 2 | 2.0 | 35 | 35.7 |
| 80 | 4 | 4.1 | 39 | 39.8 |
| 85 | 2 | 2.0 | 41 | 41.8 |
| 90 | 14 | 14.3 | 55 | 56.1 |
| 95 | 1 | 1.0 | 56 | 57.1 |
| 99 | 7 | 7.1 | 63 | 64.3 |
| 100 | 35 | 35.7 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 4PM

| LF020P | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 24 | 24.5 | 24 | 24.5 |
| 1 | 1 | 1.0 | 25 | 25.5 |
| 3 | 13 | 13.3 | 38 | 38.8 |
| 5 | 4 | 4.1 | 42 | 42.9 |
| 10 | 3 | 3.1 | 45 | 45.9 |
| 30 | 1 | 1.0 | 46 | 46.9 |
| 35 | 1 | 1.0 | 47 | 48.0 |
| 40 | 1 | 1.0 | 48 | 49.0 |
| 50 | 6 | 6.1 | 54 | 55.1 |
| 60 | 2 | 2.0 | 56 | 57.1 |
| 70 | 1 | 1.0 | 57 | 58.2 |
| 75 | 2 | 2.0 | 59 | 60.2 |
| 80 | 4 | 4.1 | 63 | 64.3 |
| 99 | 7 | 7.1 | 70 | 71.4 |
| 100 | 28 | 28.6 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 5PM

| LF020Q | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 10.1 | 10 | 10.1 |
| 1 | 4 | 4.0 | 14 | 14.1 |
| 3 | 13 | 13.1 | 27 | 27.3 |
| 5 | 5 | 5.1 | 32 | 32.3 |
| 10 | 5 | 5.1 | 37 | 37.4 |
| 25 | 10 | 10.1 | 47 | 47.5 |
| 30 | 2 | 2.0 | 49 | 49.5 |
| 35 | 1 | 1.0 | 50 | 50.5 |
| 40 | 1 | 1.0 | 51 | 51.5 |
| 50 | 15 | 15.2 | 66 | 66.7 |
| 60 | 2 | 2.0 | 68 | 68.7 |
| 70 | 1 | 1.0 | 69 | 69.7 |
| 75 | 3 | 3.0 | 72 | 72.7 |
| 80 | 2 | 2.0 | 74 | 74.7 |
| 100 | 25 | 25.3 | 99 | 100.0 |

Frequency Missing = 380

% of retro lights on - WTR WKDAY - 6PM

| LF020R | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 8 | 8.1 | 8 | 8.1 |
| 1 | 4 | 4.0 | 12 | 12.1 |
| 2 | 2 | 2.0 | 14 | 14.1 |
| 3 | 13 | 13.1 | 27 | 27.3 |
| 5 | 4 | 4.0 | 31 | 31.3 |
| 10 | 10 | 10.1 | 41 | 41.4 |
| 25 | 9 | 9.1 | 50 | 50.5 |
| 30 | 1 | 1.0 | 51 | 51.5 |
| 35 | 1 | 1.0 | 52 | 52.5 |
| 40 | 1 | 1.0 | 53 | 53.5 |
| 50 | 11 | 11.1 | 64 | 64.6 |
| 60 | 1 | 1.0 | 65 | 65.7 |
| 70 | 1 | 1.0 | 66 | 66.7 |
| 75 | 3 | 3.0 | 69 | 69.7 |
| 80 | 1 | 1.0 | 70 | 70.7 |
| 100 | 29 | 29.3 | 99 | 100.0 |

Frequency Missing = 380

% of retro lights on - WTR WKDAY - 7PM

| LF020S | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 15 | 15.2 | 15 | 15.2 |
| 1 | 4 | 4.0 | 19 | 19.2 |
| 2 | 4 | 4.0 | 23 | 23.2 |
| 3 | 13 | 13.1 | 36 | 36.4 |
| 5 | 11 | 11.1 | 47 | 47.5 |
| 10 | 8 | 8.1 | 55 | 55.6 |
| 25 | 2 | 2.0 | 57 | 57.6 |
| 30 | 1 | 1.0 | 58 | 58.6 |
| 35 | 1 | 1.0 | 59 | 59.6 |
| 40 | 1 | 1.0 | 60 | 60.6 |
| 50 | 10 | 10.1 | 70 | 70.7 |
| 60 | 1 | 1.0 | 71 | 71.7 |
| 70 | 1 | 1.0 | 72 | 72.7 |
| 75 | 1 | 1.0 | 73 | 73.7 |
| 100 | 26 | 26.3 | 99 | 100.0 |

Frequency Missing = 380

% of retro lights on - WTR WKDAY - 8PM

| LF020T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 16 | 16.3 | 16 | 16.3 |
| 1 | 4 | 4.1 | 20 | 20.4 |
| 2 | 4 | 4.1 | 24 | 24.5 |
| 3 | 14 | 14.3 | 38 | 38.8 |
| 5 | 11 | 11.2 | 49 | 50.0 |
| 10 | 7 | 7.1 | 56 | 57.1 |
| 25 | 11 | 11.2 | 67 | 68.4 |
| 30 | 1 | 1.0 | 68 | 69.4 |
| 35 | 1 | 1.0 | 69 | 70.4 |
| 40 | 1 | 1.0 | 70 | 71.4 |
| 50 | 1 | 1.0 | 71 | 72.4 |
| 60 | 1 | 1.0 | 72 | 73.5 |
| 70 | 1 | 1.0 | 73 | 74.5 |
| 75 | 1 | 1.0 | 74 | 75.5 |
| 80 | 1 | 1.0 | 75 | 76.5 |
| 100 | 23 | 23.5 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 9PM

| LF020U | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 16 | 16.3 | 16 | 16.3 |
| 1 | 5 | 5.1 | 21 | 21.4 |
| 2 | 4 | 4.1 | 25 | 25.5 |
| 3 | 14 | 14.3 | 39 | 39.8 |
| 5 | 12 | 12.2 | 51 | 52.0 |
| 10 | 8 | 8.2 | 59 | 60.2 |
| 25 | 11 | 11.2 | 70 | 71.4 |
| 30 | 1 | 1.0 | 71 | 72.4 |
| 35 | 1 | 1.0 | 72 | 73.5 |
| 40 | 1 | 1.0 | 73 | 74.5 |
| 50 | 1 | 1.0 | 74 | 75.5 |
| 70 | 1 | 1.0 | 75 | 76.5 |
| 75 | 1 | 1.0 | 76 | 77.6 |
| 80 | 1 | 1.0 | 77 | 78.6 |
| 100 | 21 | 21.4 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 10PM

| LF020V | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 27 | 27.6 | 27 | 27.6 |
| 1 | 5 | 5.1 | 32 | 32.7 |
| 2 | 4 | 4.1 | 36 | 36.7 |
| 3 | 14 | 14.3 | 50 | 51.0 |
| 5 | 4 | 4.1 | 54 | 55.1 |
| 10 | 8 | 8.2 | 62 | 63.3 |
| 25 | 11 | 11.2 | 73 | 74.5 |
| 30 | 1 | 1.0 | 74 | 75.5 |
| 35 | 1 | 1.0 | 75 | 76.5 |
| 40 | 1 | 1.0 | 76 | 77.6 |
| 50 | 1 | 1.0 | 77 | 78.6 |
| 70 | 1 | 1.0 | 78 | 79.6 |
| 75 | 1 | 1.0 | 79 | 80.6 |
| 100 | 19 | 19.4 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 11PM

| LF020W | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 31 | 31.6 | 31 | 31.6 |
| 1 | 4 | 4.1 | 35 | 35.7 |
| 2 | 4 | 4.1 | 39 | 39.8 |
| 3 | 14 | 14.3 | 53 | 54.1 |
| 5 | 5 | 5.1 | 58 | 59.2 |
| 10 | 9 | 9.2 | 67 | 68.4 |
| 20 | 1 | 1.0 | 68 | 69.4 |
| 25 | 10 | 10.2 | 78 | 79.6 |
| 35 | 1 | 1.0 | 79 | 80.6 |
| 50 | 1 | 1.0 | 80 | 81.6 |
| 70 | 1 | 1.0 | 81 | 82.7 |
| 75 | 1 | 1.0 | 82 | 83.7 |
| 100 | 16 | 16.3 | 98 | 100.0 |

Frequency Missing = 381

% of retro lights on - WTR WKDAY - 12AM

| LF020X | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 64 | 66.0 | 64 | 66.0 |
| 1 | 4 | 4.1 | 68 | 70.1 |
| 2 | 2 | 2.1 | 70 | 72.2 |
| 3 | 1 | 1.0 | 71 | 73.2 |
| 5 | 3 | 3.1 | 74 | 76.3 |
| 10 | 3 | 3.1 | 77 | 79.4 |
| 15 | 2 | 2.1 | 79 | 81.4 |
| 25 | 1 | 1.0 | 80 | 82.5 |
| 50 | 1 | 1.0 | 81 | 83.5 |
| 75 | 1 | 1.0 | 82 | 84.5 |
| 100 | 15 | 15.5 | 97 | 100.0 |

Frequency Missing = 382

% of light equip changed through prog

| IL001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 0.6 | 2 | 0.6 |
| 1 | 3 | 0.8 | 5 | 1.4 |
| 2 | 2 | 0.6 | 7 | 1.9 |
| 3 | 1 | 0.3 | 8 | 2.2 |
| 4 | 1 | 0.3 | 9 | 2.5 |
| 5 | 11 | 3.0 | 20 | 5.5 |
| 8 | 1 | 0.3 | 21 | 5.8 |
| 10 | 8 | 2.2 | 29 | 8.0 |
| 11 | 1 | 0.3 | 30 | 8.3 |
| 15 | 4 | 1.1 | 34 | 9.4 |
| 17 | 4 | 1.1 | 38 | 10.5 |
| 20 | 10 | 2.8 | 48 | 13.3 |
| 25 | 5 | 1.4 | 53 | 14.6 |
| 30 | 10 | 2.8 | 63 | 17.4 |
| 33 | 4 | 1.1 | 67 | 18.5 |
| 35 | 2 | 0.6 | 69 | 19.1 |
| 40 | 12 | 3.3 | 81 | 22.4 |
| 45 | 2 | 0.6 | 83 | 22.9 |
| 50 | 20 | 5.5 | 103 | 28.5 |
| 60 | 10 | 2.8 | 113 | 31.2 |
| 65 | 2 | 0.6 | 115 | 31.8 |
| 66 | 2 | 0.6 | 117 | 32.3 |
| 70 | 7 | 1.9 | 124 | 34.3 |
| 75 | 15 | 4.1 | 139 | 38.4 |
| 80 | 17 | 4.7 | 156 | 43.1 |
| 85 | 7 | 1.9 | 163 | 45.0 |
| 90 | 56 | 15.5 | 219 | 60.5 |
| 95 | 19 | 5.2 | 238 | 65.7 |
| 98 | 4 | 1.1 | 242 | 66.9 |
| 99 | 3 | 0.8 | 245 | 67.7 |
| 100 | 117 | 32.3 | 362 | 100.0 |

Frequency Missing = 117

% of burn out equip changed through prog

| IL005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 188 | 53.4 | 188 | 53.4 |
| 1 | 11 | 3.1 | 199 | 56.5 |
| 2 | 15 | 4.3 | 214 | 60.8 |
| 3 | 7 | 2.0 | 221 | 62.8 |
| 4 | 2 | 0.6 | 223 | 63.4 |
| 5 | 22 | 6.3 | 245 | 69.6 |
| 8 | 3 | 0.9 | 248 | 70.5 |
| 9 | 1 | 0.3 | 249 | 70.7 |
| 10 | 48 | 13.6 | 297 | 84.4 |
| 15 | 4 | 1.1 | 301 | 85.5 |
| 20 | 4 | 1.1 | 305 | 86.6 |
| 25 | 3 | 0.9 | 308 | 87.5 |
| 30 | 18 | 5.1 | 326 | 92.6 |
| 33 | 2 | 0.6 | 328 | 93.2 |
| 35 | 1 | 0.3 | 329 | 93.5 |
| 40 | 2 | 0.6 | 331 | 94.0 |
| 45 | 4 | 1.1 | 335 | 95.2 |
| 50 | 10 | 2.8 | 345 | 98.0 |
| 80 | 1 | 0.3 | 346 | 98.3 |
| 90 | 1 | 0.3 | 347 | 98.6 |
| 100 | 5 | 1.4 | 352 | 100.0 |

Frequency Missing = 127

Average age replaced fixtures

| SR010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 3.9 | 12 | 3.9 |
| 0.39996338 | 1 | 0.3 | 13 | 4.2 |
| 1 | 6 | 2.0 | 19 | 6.2 |
| 2 | 8 | 2.6 | 27 | 8.8 |
| 3 | 8 | 2.6 | 35 | 11.4 |
| 3.5 | 1 | 0.3 | 36 | 11.8 |
| 4 | 7 | 2.3 | 43 | 14.1 |
| 5 | 18 | 5.9 | 61 | 19.9 |
| 6 | 3 | 1.0 | 64 | 20.9 |
| 7 | 7 | 2.3 | 71 | 23.2 |
| 7.5 | 1 | 0.3 | 72 | 23.5 |
| 8 | 36 | 11.8 | 108 | 35.3 |
| 9 | 8 | 2.6 | 116 | 37.9 |
| 10 | 40 | 13.1 | 156 | 51.0 |
| 11 | 2 | 0.7 | 158 | 51.6 |
| 12 | 6 | 2.0 | 164 | 53.6 |
| 12.5 | 1 | 0.3 | 165 | 53.9 |
| 13 | 2 | 0.7 | 167 | 54.6 |
| 14 | 2 | 0.7 | 169 | 55.2 |
| 15 | 16 | 5.2 | 185 | 60.5 |
| 16 | 4 | 1.3 | 189 | 61.8 |
| 17 | 2 | 0.7 | 191 | 62.4 |
| 18 | 4 | 1.3 | 195 | 63.7 |
| 19 | 3 | 1.0 | 198 | 64.7 |
| 20 | 56 | 18.3 | 254 | 83.0 |
| 22 | 1 | 0.3 | 255 | 83.3 |
| 23 | 2 | 0.7 | 257 | 84.0 |
| 24 | 2 | 0.7 | 259 | 84.6 |
| 25 | 16 | 5.2 | 275 | 89.9 |
| 26 | 1 | 0.3 | 276 | 90.2 |
| 27 | 1 | 0.3 | 277 | 90.5 |
| 28 | 1 | 0.3 | 278 | 90.8 |
| 29 | 1 | 0.3 | 279 | 91.2 |
| 30 | 14 | 4.6 | 293 | 95.8 |
| 32 | 2 | 0.7 | 295 | 96.4 |
| 35 | 1 | 0.3 | 296 | 96.7 |
| 38 | 1 | 0.3 | 297 | 97.1 |
| 40 | 2 | 0.7 | 299 | 97.7 |
| 45 | 2 | 0.7 | 301 | 98.4 |
| 50 | 2 | 0.7 | 303 | 99.0 |
| 55 | 1 | 0.3 | 304 | 99.3 |
| 60 | 1 | 0.3 | 305 | 99.7 |
| 75 | 1 | 0.3 | 306 | 100.0 |

Frequency Missing = 173

Changed any indoor lighting?

| IL010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 409 | 93.0 | 409 | 93.0 |
| Yes | 31 | 7.0 | 440 | 100.0 |

Frequency Missing = 39

month/year indoor light change

| IL020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| AUG1992 | 1 | 5.9 | 1 | 5.9 |
| JUN1993 | 2 | 11.8 | 3 | 17.6 |
| AUG1993 | 1 | 5.9 | 4 | 23.5 |
| OCT1993 | 1 | 5.9 | 5 | 29.4 |
| DEC1993 | 1 | 5.9 | 6 | 35.3 |
| FEB1994 | 2 | 11.8 | 8 | 47.1 |
| APR1994 | 3 | 17.6 | 11 | 64.7 |
| JUL1994 | 1 | 5.9 | 12 | 70.6 |
| SEP1994 | 1 | 5.9 | 13 | 76.5 |
| NOV1994 | 2 | 11.8 | 15 | 88.2 |
| JAN1995 | 1 | 5.9 | 16 | 94.1 |
| MAR1995 | 1 | 5.9 | 17 | 100.0 |

Frequency Missing = 462

year indoor light change

| IL021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 4 | 44.4 | 4 | 44.4 |
| 1993 | 2 | 22.2 | 6 | 66.7 |
| 1994 | 2 | 22.2 | 8 | 88.9 |
| 1995 | 1 | 11.1 | 9 | 100.0 |

Frequency Missing = 470

month/year indoor light change-2

| IL025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1994 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

year indoor light change-2

| IL026 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1994 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Added or removed/4' T-8

| IL040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 11 | 52.4 | 11 | 52.4 |
| Added | 9 | 42.9 | 20 | 95.2 |
| Removed | 1 | 4.8 | 21 | 100.0 |

Frequency Missing = 458

Added or removed/8' T-8

| IL041 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 15 | 83.3 | 15 | 83.3 |
| Added | 2 | 11.1 | 17 | 94.4 |
| Removed | 1 | 5.6 | 18 | 100.0 |

Frequency Missing = 461

Added or removed/4' ES Fluor

| IL042 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 16 | 94.1 | 16 | 94.1 |
| Added | 1 | 5.9 | 17 | 100.0 |

Frequency Missing = 462

Added or removed/8' ES Fluor

| IL043 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 13 | 92.9 | 13 | 92.9 |
| Added | 1 | 7.1 | 14 | 100.0 |

Frequency Missing = 465

Added or removed/4' T-12

| IL044 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 15 | 100.0 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/8' T-12

| IL045 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 14 | 93.3 | 14 | 93.3 |
| Added | 1 | 6.7 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/Incandescent

| IL046 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 11 | 73.3 | 11 | 73.3 |
| Added | 2 | 13.3 | 13 | 86.7 |
| Removed | 2 | 13.3 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/Compact Fluor

| IL047 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 10 | 62.5 | 10 | 62.5 |
| Added | 6 | 37.5 | 16 | 100.0 |

Frequency Missing = 463

Added or removed/High pres sodium

| IL048 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 16 | 100.0 | 16 | 100.0 |

Frequency Missing = 463

Added or removed/Elec Ballasts

| IL049 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 14 | 82.4 | 14 | 82.4 |
| Added | 3 | 17.6 | 17 | 100.0 |

Frequency Missing = 462

Number changed/4' T-8

| IL040N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 1 | 1 | 11.1 | 1 | 11.1 |
| 4 | 1 | 11.1 | 2 | 22.2 |
| 6 | 1 | 11.1 | 3 | 33.3 |
| 7 | 1 | 11.1 | 4 | 44.4 |
| 8 | 1 | 11.1 | 5 | 55.6 |
| 9 | 1 | 11.1 | 6 | 66.7 |
| 20 | 1 | 11.1 | 7 | 77.8 |
| 21 | 1 | 11.1 | 8 | 88.9 |
| 40 | 1 | 11.1 | 9 | 100.0 |

Frequency Missing = 470

Number changed/8' T-8

| IL041N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 4 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Number changed/4' ES Fluor

| IL042N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
|--------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Number changed/8' ES Fluor

| IL043N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 8 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Number changed/4' T-12

| IL044N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
|--------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Number changed/8' T-12

| IL045N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 10 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Number changed/Incandescent

| IL046N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 4 | 1 | 25.0 | 1 | 25.0 |
| 12 | 1 | 25.0 | 2 | 50.0 |
| 50 | 1 | 25.0 | 3 | 75.0 |
| 82 | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 475

Number changed/Compact Fluor

| IL047N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 2 | 1 | 20.0 | 1 | 20.0 |
| 4 | 1 | 20.0 | 2 | 40.0 |
| 12 | 1 | 20.0 | 3 | 60.0 |
| 20 | 1 | 20.0 | 4 | 80.0 |
| 50 | 1 | 20.0 | 5 | 100.0 |

Frequency Missing = 474

Number changed/High pres sodium

| IL048N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 50.0 | 1 | 50.0 |
| 15 | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 477

Number changed/Elec Ballasts

| IL049N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 13 | 1 | 25.0 | 1 | 25.0 |
| 15 | 1 | 25.0 | 2 | 50.0 |
| 20 | 2 | 50.0 | 4 | 100.0 |

Frequency Missing = 475

Added or removed/Magnetic Ballasts

| IL050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 15 | 93.8 | 15 | 93.8 |
| Removed | 1 | 6.3 | 16 | 100.0 |

Frequency Missing = 463

Added or removed/Metal Halide

| IL051 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 13 | 86.7 | 13 | 86.7 |
| Added | 2 | 13.3 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/Mercury Vapor

| IL052 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 14 | 93.3 | 14 | 93.3 |
| Added | 1 | 6.7 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/Quartz

| IL053 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 13 | 86.7 | 13 | 86.7 |
| Added | 2 | 13.3 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/Reflectors

| IL054 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 15 | 100.0 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/LED Exit Lights

| IL055 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 15 | 93.8 | 15 | 93.8 |
| Added | 1 | 6.3 | 16 | 100.0 |

Frequency Missing = 463

Added or removed/Watt Saver-Power Choke

| IL056 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 15 | 100.0 | 15 | 100.0 |

Frequency Missing = 464

Added or removed/Other

| IL057 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 14 | 82.4 | 14 | 82.4 |
| Added | 3 | 17.6 | 17 | 100.0 |

Frequency Missing = 462

Number changed/Magnetic Ballasts

| IL050N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 13 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Number changed/Metal Halide

| IL051N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 16 | 1 | 50.0 | 1 | 50.0 |
| 100 | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 477

Number changed/Mercury Vapor

| IL052N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
|--------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Number changed/Quartz

| IL053N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 40 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Number changed/Reflectors

| IL054N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Number changed/LED Exit Lights

| IL055N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 65 | 1 | 100.0 | 1 | 100.0 |
| Frequency Missing = 478 | | | | |

Number changed/Watt Saver-Power Choke

| IL056N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Number changed/Other

| IL057N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 1 | 1 | 33.3 | 1 | 33.3 |
| 10 | 1 | 33.3 | 2 | 66.7 |
| 100 | 1 | 33.3 | 3 | 100.0 |
| Frequency Missing = 476 | | | | |

- OBS IL058
- 1 REPLACED LT COVERS
 - 2 SAFETY LIGHT
 - 3 PL BULBS
 - 4 20 WATT FLOR/T40

Problems with ballasts after retro?

| DS030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 153 | 78.5 | 153 | 78.5 |
| Yes | 42 | 21.5 | 195 | 100.0 |

Frequency Missing = 284

| DS045 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Any instld equip been removed

| LP010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 439 | 98.7 | 439 | 98.7 |
| Yes | 6 | 1.3 | 445 | 100.0 |

Frequency Missing = 34

month/year of new equip removed

| LP020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| APR1994 | 1 | 25.0 | 1 | 25.0 |
| SEP1994 | 1 | 25.0 | 2 | 50.0 |
| MAY1995 | 2 | 50.0 | 4 | 100.0 |

Frequency Missing = 475

year of new equip removed

| LP021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1995 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

month/year of new equip removed/2

| LP025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

year of new equip removed/2

| LP026 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Removed/4' T-8

| LP030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 4 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Removed/8' T-8

| LP031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/4' ES Fluor

| LP032 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/8' ES Fluor

| LP033 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/4' T-12

| LP034 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/8' T-12

| LP035 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/Incandescent

| LP036 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/Compact Fluor

| LP037 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 33.3 | 1 | 33.3 |
| 14 | 2 | 66.7 | 3 | 100.0 |

Frequency Missing = 476

Removed/High pres sodium

| LP038 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/Metal Halide

| LP039 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Removed/Mercury Vpr

| LP040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Removed/Quartz

| LP041 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Removed/Reflctrs Delmp

| LP042 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Removed/Elec Ballasts

| LP043 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Removed/Magnetic Ballasts

| LP044 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Removed/LED Exit Lights

| LP045 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Removed/Watt Saver-Power Choke

| LP046 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Removed/Other

| LP047 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 75.0 | 3 | 75.0 |
| 10 | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 475

OBS LP048

1 SENSORS

Occ Sensors

| LP049 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Why removed/poor light quality

| LP050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Why removed/not enough light

| LP051 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 75.0 | 3 | 75.0 |
| 1 | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 475

Why removed/equip not reliable

| LP052 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Why removed/harmonics problems

| LP053 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Why removed/ballasts failed

| LP054 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 476

Why removed/other

| LP055 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 5 | 100.0 | 5 | 100.0 |

Frequency Missing = 474

OBS LP056

- 1 MOVING WALLS DURING REMODE
- 2 PERSONNEL MOVED, LAYOUT DI
- 3 UPDATE EQUIPMENT
- 4 REMODEL
- 5 REMODEL

Why removed/refused

| LP057 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 75.0 | 3 | 75.0 |
| 1 | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 475

Why removed/dont know

| LP058 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 475

Remodeled

| LP059 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 475

Replace removed retrofit?

| LP060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 33.3 | 2 | 33.3 |
| 1 | 4 | 66.7 | 6 | 100.0 |

Frequency Missing = 473

Replcd w/4' T-8

| LP070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Replcd w/8' T-8

| LP071 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/4' ES Fluor

| LP072 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/8' ES Fluor

| LP073 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/4' T-12

| LP074 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/8' T-12

| LP075 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/Incandescent

| LP076 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/Compact Fluor

| LP077 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 14 | 2 | 100.0 | 2 | 100.0 |
| Frequency Missing = 477 | | | | |

Replcd w/High pres sodium

| LP078 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/Metal Halide

| LP079 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/Mercury Vpr

| LP080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/Quartz

| LP081 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Replcd w/Reflctrs Delmp

| LP082 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 0 | 2 | 100.0 | 2 | 100.0 |
| Frequency Missing = 477 | | | | |

Replcd w/Elec Ballasts

| LP083 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 0 | 2 | 100.0 | 2 | 100.0 |
| Frequency Missing = 477 | | | | |

Replcd w/Magnetic Ballasts

| LP084 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Replcd w/LED Exit Lights

| LP085 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Replcd w/Watt Saver-Power Choke

| LP086 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Replcd w/Other

| LP087 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 66.7 | 2 | 66.7 |
| 10 | 1 | 33.3 | 3 | 100.0 |

Frequency Missing = 476

OBS

LP088

1 TO STANDARD LIGHT SWITCHES

Glare: better, worse, same?

| SR070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| Better | 145 | 74.4 | 145 | 74.4 |
| Worse | 8 | 4.1 | 153 | 78.5 |
| Same | 41 | 21.0 | 194 | 99.5 |
| 7 | 1 | 0.5 | 195 | 100.0 |

Frequency Missing = 284

| SR075 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Less | 121 | 68.8 | 121 | 68.8 |
| More | 5 | 2.8 | 126 | 71.6 |
| Same | 48 | 27.3 | 174 | 98.9 |
| 7 | 2 | 1.1 | 176 | 100.0 |

Frequency Missing = 303

Is outdoor lighting on bill?

| OL010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 68 | 15.5 | 68 | 15.5 |
| Yes | 372 | 84.5 | 440 | 100.0 |

Frequency Missing = 39

Changed any outdoor lights

| OL020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 285 | 77.0 | 285 | 77.0 |
| Yes | 85 | 23.0 | 370 | 100.0 |

Frequency Missing = 109

Month/year change outdoor lights

| OL030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JUL1992 | 1 | 1.8 | 1 | 1.8 |
| JAN1993 | 2 | 3.6 | 3 | 5.4 |
| MAR1993 | 1 | 1.8 | 4 | 7.1 |
| APR1993 | 1 | 1.8 | 5 | 8.9 |
| AUG1993 | 3 | 5.4 | 8 | 14.3 |
| SEP1993 | 1 | 1.8 | 9 | 16.1 |
| NOV1993 | 1 | 1.8 | 10 | 17.9 |
| DEC1993 | 2 | 3.6 | 12 | 21.4 |
| JAN1994 | 1 | 1.8 | 13 | 23.2 |
| FEB1994 | 4 | 7.1 | 17 | 30.4 |
| MAR1994 | 3 | 5.4 | 20 | 35.7 |
| APR1994 | 1 | 1.8 | 21 | 37.5 |
| MAY1994 | 2 | 3.6 | 23 | 41.1 |
| JUN1994 | 5 | 8.9 | 28 | 50.0 |
| JUL1994 | 4 | 7.1 | 32 | 57.1 |
| AUG1994 | 3 | 5.4 | 35 | 62.5 |
| SEP1994 | 8 | 14.3 | 43 | 76.8 |
| OCT1994 | 1 | 1.8 | 44 | 78.6 |
| NOV1994 | 2 | 3.6 | 46 | 82.1 |
| DEC1994 | 1 | 1.8 | 47 | 83.9 |
| JAN1995 | 3 | 5.4 | 50 | 89.3 |
| FEB1995 | 2 | 3.6 | 52 | 92.9 |
| MAR1995 | 1 | 1.8 | 53 | 94.6 |
| APR1995 | 1 | 1.8 | 54 | 96.4 |
| MAY1995 | 2 | 3.6 | 56 | 100.0 |

Frequency Missing = 423

Year change outdoor lights

| OL031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 6 | 23.1 | 6 | 23.1 |
| 1993 | 10 | 38.5 | 16 | 61.5 |
| 1994 | 9 | 34.6 | 25 | 96.2 |
| 1995 | 1 | 3.8 | 26 | 100.0 |

Frequency Missing = 453

Add/replace/remove outdoor lights

| OL040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|-------------------------|-----------------------|
| Added | 21 | 24.7 | 21 | 24.7 |
| Replaced | 49 | 57.6 | 70 | 82.4 |
| Add and Replace | 13 | 15.3 | 83 | 97.6 |
| Removed | 2 | 2.4 | 85 | 100.0 |

Frequency Missing = 394

Cooling type

| CE010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| No AC | 88 | 20.8 | 88 | 20.8 |
| Centrl Plant | 93 | 21.9 | 181 | 42.7 |
| Sml Pack Sys | 162 | 38.2 | 343 | 80.9 |
| Wall/Wndo Unit | 18 | 4.2 | 361 | 85.1 |
| Heat Pump | 40 | 9.4 | 401 | 94.6 |
| Other | 8 | 1.9 | 409 | 96.5 |
| Evap Cooler | 5 | 1.2 | 414 | 97.6 |
| Swamp Cooler | 10 | 2.4 | 424 | 100.0 |

Frequency Missing = 55

OBS CE011

1 LATENT ICE
2 FANS
3 4 STAIR COOLING SYSTEM
4 SWAMP COOLERS
5 OLDER UNITS
6 ON EUNIT HAS EVAPORATIVE COOLE
7 ON EUNIT HAS EVAPORATIVE COOLE
8 SWAMP COOLERS
9 SWAMP COOLER
10 "TRAIN" ON TOP OF BUILDING
11 SWAMP COOLER
12 SWAMP COOLER
13 ELECTRIC ROOF AIR CONDITIONER
14 SWAMP COOLER
15 REFERGERATION
16 SWAMP COOLER
17 EVAPORATIVE COOLERS
18 SWAMP COOLERS
19 AIR HANLDERS & RECIPROCATING U
20 DUAL PACKS
21 SEVERAL MULTI TON UNITS
22 EVAPORATIVE
23 RELOCATABLES HAVE HEAT PUMPS
24 RELOCATABLES HAVE HEAT PUMPS
25 RELOCATABLES HAVE HEAT PUMPS
26 RELOCATABLES HAVE HEAT PUMPS
27 RELOCATABLES HAVE HEAT PUMPS
28 RELOCATABLES HAVE HEAT PUMPS
29 RELOCATABLES HAVE HEAT PUMPS
30 RELOCATABLES HAVE HEAT PUMPS
31 RELOCATABLES HAVE HEAT PUMPS
32 RELOCATABLES HAVE HEAT PUMPS
33 RELOCATABLES HAVE HEAT PUMPS
34 RELOCATABLES HAVE HEAT PUMPS
35 RELOCATABLES HAVE HEAT PUMPS
36 EVAPORATIVE COOLER
37 MULTY PACKAGE
38 5-TON UNITS
39 ROOF TOP CON.
40 PACKAGED SYSTEM
41 HIGH PRESSURE STEAM
42 15TON AC ON ROOF, MANY OF THEM
43 SWAMP COOLERS (OLD)
44 SWAMP COOLER
45 PACKAGE W\COMBO GAS & ELECTRIC

Cooling primary fuel

| CE015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Elec | 306 | 89.5 | 306 | 89.5 |
| Natural Gas | 27 | 7.9 | 333 | 97.4 |
| Other | 5 | 1.5 | 338 | 98.8 |
| Gas and Electric | 4 | 1.2 | 342 | 100.0 |

Frequency Missing = 137

OBS CE016

- 1 PROPANE
- 2 GAS & ELECTRIC
- 3 MIXTURE OF GAS AND ELECTRICITY
- 4 FREON
- 5 CEILING FANS
- 6 BOTH GAS & ELECTRIC
- 7 FUEL OIL
- 8 WATER
- 9 COMBINATION GAS & ELECTRIC

System include economizer?

| CE030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 150 | 53.6 | 150 | 53.6 |
| Yes | 130 | 46.4 | 280 | 100.0 |

Frequency Missing = 199

| CE050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 33 | 9.5 | 33 | 9.5 |
| 1-19 | 33 | 9.5 | 66 | 19.0 |
| 20-39 | 26 | 7.5 | 92 | 26.5 |
| 40-59 | 16 | 4.6 | 108 | 31.1 |
| 60-79 | 26 | 7.5 | 134 | 38.6 |
| 80-99 | 49 | 14.1 | 183 | 52.7 |
| 100 | 164 | 47.3 | 347 | 100.0 |

Frequency Missing = 132

Cooling operated/all year

| CE059 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 211 | 66.8 | 211 | 66.8 |
| Yes | 105 | 33.2 | 316 | 100.0 |

Frequency Missing = 163

Cooling operated/Jan

| CE060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 244 | 99.2 | 244 | 99.2 |
| Yes | 2 | 0.8 | 246 | 100.0 |

Frequency Missing = 233

Cooling operated/Feb

| CE061 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 244 | 99.2 | 244 | 99.2 |
| Yes | 2 | 0.8 | 246 | 100.0 |

Frequency Missing = 233

Cooling operated/Mar

| CE062 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 233 | 94.7 | 233 | 94.7 |
| Yes | 13 | 5.3 | 246 | 100.0 |

Frequency Missing = 233

Cooling operated/Apr

| CE063 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 170 | 71.7 | 170 | 71.7 |
| Yes | 67 | 28.3 | 237 | 100.0 |

Frequency Missing = 242

Cooling operated/May

| CE064 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 104 | 43.2 | 104 | 43.2 |
| Yes | 137 | 56.8 | 241 | 100.0 |

Frequency Missing = 238

Cooling operated/Jun

| CE065 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 29 | 11.6 | 29 | 11.6 |
| Yes | 221 | 88.4 | 250 | 100.0 |

Frequency Missing = 229

Cooling operated/Jul

| CE066 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 19 | 7.6 | 19 | 7.6 |
| Yes | 231 | 92.4 | 250 | 100.0 |

Frequency Missing = 229

Cooling operated/Aug

| CE067 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 13 | 5.2 | 13 | 5.2 |
| Yes | 237 | 94.8 | 250 | 100.0 |

Frequency Missing = 229

Cooling operated/Sep

| CE068 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 25 | 10.0 | 25 | 10.0 |
| Yes | 224 | 90.0 | 249 | 100.0 |

Frequency Missing = 230

Cooling operated/Oct

| CE069 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 129 | 53.1 | 129 | 53.1 |
| Yes | 114 | 46.9 | 243 | 100.0 |

Frequency Missing = 236

Cooling operated/Nov

| CE070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 219 | 90.9 | 219 | 90.9 |
| Yes | 22 | 9.1 | 241 | 100.0 |

Frequency Missing = 238

Cooling operated/Dec

| CE071 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 236 | 98.7 | 236 | 98.7 |
| Yes | 3 | 1.3 | 239 | 100.0 |

Frequency Missing = 240

Cooling operated/Ref

| CE072 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 225 | 100.0 | 225 | 100.0 |

Frequency Missing = 254

Cooling operated/DK

| CE073 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 215 | 95.1 | 215 | 95.1 |
| Yes | 11 | 4.9 | 226 | 100.0 |

Frequency Missing = 253

Added/replaced/removed cooling

| CE080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------------|-----------|---------|-------------------------|-----------------------|
| No chnge | 368 | 84.2 | 368 | 84.2 |
| Added | 29 | 6.6 | 397 | 90.8 |
| Replaced | 36 | 8.2 | 433 | 99.1 |
| Added/Replced | 3 | 0.7 | 436 | 99.8 |
| Removed | 1 | 0.2 | 437 | 100.0 |

Frequency Missing = 42

Month/year cooling changes

| CE090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JUN1992 | 1 | 3.2 | 1 | 3.2 |
| JUL1992 | 1 | 3.2 | 2 | 6.5 |
| DEC1992 | 1 | 3.2 | 3 | 9.7 |
| APR1993 | 1 | 3.2 | 4 | 12.9 |
| JUN1993 | 1 | 3.2 | 5 | 16.1 |
| JUL1993 | 1 | 3.2 | 6 | 19.4 |
| AUG1993 | 1 | 3.2 | 7 | 22.6 |
| NOV1993 | 1 | 3.2 | 8 | 25.8 |
| FEB1994 | 1 | 3.2 | 9 | 29.0 |
| MAY1994 | 1 | 3.2 | 10 | 32.3 |
| JUN1994 | 4 | 12.9 | 14 | 45.2 |
| JUL1994 | 8 | 25.8 | 22 | 71.0 |
| AUG1994 | 2 | 6.5 | 24 | 77.4 |
| JAN1995 | 1 | 3.2 | 25 | 80.6 |
| MAR1995 | 2 | 6.5 | 27 | 87.1 |
| APR1995 | 2 | 6.5 | 29 | 93.5 |
| MAY1995 | 1 | 3.2 | 30 | 96.8 |
| JUN1995 | 1 | 3.2 | 31 | 100.0 |

Frequency Missing = 448

Year cooling changes

| CE091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 6 | 19.4 | 6 | 19.4 |
| 1993 | 7 | 22.6 | 13 | 41.9 |
| 1994 | 15 | 48.4 | 28 | 90.3 |
| 1995 | 3 | 9.7 | 31 | 100.0 |

Frequency Missing = 448

Old cooling fuel type

| CE110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| ----- | ----- | ----- | ----- | ----- |
| Elec | 41 | 100.0 | 41 | 100.0 |

Frequency Missing = 438

OBS CE111

1 WATER

Cooling addition fuel type

| CE120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| ----- | ----- | ----- | ----- | ----- |
| Elec | 28 | 84.8 | 28 | 84.8 |
| Natural Gas | 5 | 15.2 | 33 | 100.0 |

Frequency Missing = 446

Type of main heating

| HE015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Cntrl elec fur | 25 | 6.0 | 25 | 6.0 |
| Cntrl HP | 55 | 13.2 | 80 | 19.2 |
| Cntrl Gas fur | 178 | 42.8 | 258 | 62.0 |
| Gas boiler | 29 | 7.0 | 287 | 69.0 |
| Oil boiler/fur | 6 | 1.4 | 293 | 70.4 |
| Elec strip heat | 1 | 0.2 | 294 | 70.7 |
| Basebrd elec hea | 2 | 0.5 | 296 | 71.2 |
| Rm/Wal AC w/stri | 5 | 1.2 | 301 | 72.4 |
| Perm non-elec ht | 4 | 1.0 | 305 | 73.3 |
| whlhs wl/flr ele | 2 | 0.5 | 307 | 73.8 |
| whlhs wl/flr gas | 10 | 2.4 | 317 | 76.2 |
| Port elec | 2 | 0.5 | 319 | 76.7 |
| Wood/Coal stove | 2 | 0.5 | 321 | 77.2 |
| Propane heat | 7 | 1.7 | 328 | 78.8 |
| Other | 21 | 5.0 | 349 | 83.9 |
| None | 52 | 12.5 | 401 | 96.4 |
| 20 | 15 | 3.6 | 416 | 100.0 |

Frequency Missing = 63

OBS HE016

- 1 DUAL PAK
- 2 DONT KNOW
- 3 PACKAGEDED SYUSTEM
- 4 HEAT PUMP
- 5 PACKAGED UNITS
- 6 EACH TENANT HAS THEIR OWN
- 7 ROOF UNITS
- 8 PACKAGED UNITS
- 9 FORCED AIR
- 10 DONT
- 11 PACKAGED SYSTEM
- 12 COMBINATION HEATING AND AIR
- 13 HEAT WITH COOLING PACKAGE
- 14 PACKAGED UNITS
- 15 PERMANENT CEILING HEATER
- 16 PORTABLE HEATERS
- 17 HEAT PUMP
- 18 5 GAS FURNACES
- 19 GAS FORCED AIR W/ ELEC. BLOWERS
- 20 RADIANT HEAT IN FLOORING
- 21 HEATER/AIR CONDITIONER ON THE ROOF
- 22 PACKAGED SYSTEMS
- 23 PACKAGED SYSTEMS
- 24 MOUNTED, DIRECT DISCHARGE
- 25 HEAT-PUMP
- 26 PART OF COOLING PACKAGE
- 27 DK
- 28 DUAL PACKS & EVAP COOLERS
- 29 PACKAGED SYSTEMS
- 30 PACKAGED UNITS
- 31 COMBINED
- 32 4 AND 3
- 33 GAS PACK.
- 34 IND. HEAT PUMPS
- 35 GAS PACK.
- 36 DUEL HEATING COOLING UNITS
- 37 50/50 GAS BOILER/GAS FURNACE
- 38 RECLAIMED HEAT
- 39 RECLAIMED HEAT
- 40 RECLAIMED HEAT
- 41 RECLAIMED HEAT
- 42 RECLAIMED HEAT
- 43 RECLAIMED HEAT
- 44 RECLAIMED HEAT
- 45 RECLAIMED HEAT
- 46 RECLAIMED HEAT
- 47 RECLAIMED HEAT
- 48 RECLAIMED HEAT
- 49 RECLAIMED HEAT
- 50 RECLAIMED HEAT
- 51 RECLAIMED HEAT
- 52 RECLAIMED HEAT
- 53 RECLAIMED HEAT

OBS HE016

54 RECLAIMED HEAT
55 RECLAIMED HEAT
56 HVC UNITS
57 PORTABLE UNITS
58 CENTRAL GAS SYSTEM
59 SMALL SYSTEM
60 STEAM BOILER IN THE FLOOR
61 INDIVID HEATER, NOT CENTRALIZED HEAT SYS
62 HIGH PRESSURE STEAM
63 MANY 15 TON HEATERS ON ROOF
64 ZZZ
65 INDIVIDUAL ROOM UNITS
66 HOT AIR GAS INDEPENDENT UNITS
67 FORCED AIR
68 ELECTRIC AREA HEATERS
69 COMBO UNIT GAS & ELECTRIC
70 BUILT INTO THE SAME PACKAGED UNIT (GAS)
71 COMBINATION OF GAS HEAT PUMP
72 DON'T KNOW

Primary fuel to heat facility

| HE020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 286 | 68.4 | 286 | 68.4 |
| Propane/Bottld g | 17 | 4.1 | 303 | 72.5 |
| Oil | 4 | 1.0 | 307 | 73.4 |
| Elec | 75 | 17.9 | 382 | 91.4 |
| Other | 6 | 1.4 | 388 | 92.8 |
| Reclaimed Heat | 18 | 4.3 | 406 | 97.1 |
| None | 11 | 2.6 | 417 | 99.8 |
| Combination | 1 | 0.2 | 418 | 100.0 |

Frequency Missing = 61

| | |
|-----|------------------------------|
| OBS | HE021 |
| 1 | GAS/ELECRTIC |
| 2 | NONE |
| 3 | NONE |
| 4 | WOOD |
| 5 | NONE |
| 6 | NONE |
| 7 | HEAT COMES FROM DRY CLEANING |
| 8 | NONE |
| 9 | NONE |
| 10 | NONE |
| 11 | NONE |
| 12 | NONE |
| 13 | NONE |
| 14 | NONE; NO HEATING. |
| 15 | DIESEL |
| 16 | PORTABLE ELECTRIC HEATER |
| 17 | NONE |
| 18 | RECLAIMED HEAT BLOWN BY FANS |
| 19 | RECLAIMED HEAT BLOWN BY FANS |
| 20 | RECLAIMED HEAT BLOWN BY FANS |
| 21 | RECLAIMED HEAT BLOWN BY FANS |
| 22 | RECLAIMED HEAT BLOWN BY FANS |
| 23 | RECLAIMED HEAT BLOWN BY FANS |
| 24 | RECLAIMED HEAT BLOWN BY FANS |
| 25 | RECLAIMED HEAT BLOWN BY FANS |
| 26 | RECLAIMED HEAT BLOWN BY FANS |
| 27 | RECLAIMED HEAT BLOWN BY FANS |
| 28 | RECLAIMED HEAT BLOWN BY FANS |
| 29 | RECLAIMED HEAT BLOWN BY FANS |
| 30 | RECLAIMED HEAT BLOWN BY FANS |
| 31 | RECLAIMED HEAT BLOWN BY FANS |
| 32 | RECLAIMED HEAT BLOWN BY FANS |
| 33 | RECLAIMED HEAT BLOWN BY FANS |
| 34 | RECLAIMED HEAT BLOWN BY FANS |
| 35 | RECLAIMED HEAT BLOWN BY FANS |
| 36 | PELLET |
| 37 | NONE |
| 38 | DO NOT HAVE |

% of facility heated - WTR WKDAY - 8AM

| HE050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 64 | 14.8 | 64 | 14.8 |
| 1-19 | 15 | 3.5 | 79 | 18.3 |
| 20-39 | 26 | 6.0 | 105 | 24.3 |
| 40-59 | 19 | 4.4 | 124 | 28.7 |
| 60-79 | 39 | 9.0 | 163 | 37.7 |
| 80-99 | 84 | 19.4 | 247 | 57.2 |
| 100 | 185 | 42.8 | 432 | 100.0 |

Frequency Missing = 47

Heating operated/all year

| HE059 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 288 | 76.4 | 288 | 76.4 |
| Yes | 89 | 23.6 | 377 | 100.0 |

Frequency Missing = 102

Heating operated/Jan

| HE060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 38 | 10.9 | 38 | 10.9 |
| Yes | 310 | 89.1 | 348 | 100.0 |

Frequency Missing = 131

Heating operated/Feb

| HE061 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 43 | 12.4 | 43 | 12.4 |
| Yes | 304 | 87.6 | 347 | 100.0 |

Frequency Missing = 132

Heating operated/Mar

| HE062 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 72 | 21.0 | 72 | 21.0 |
| Yes | 271 | 79.0 | 343 | 100.0 |

Frequency Missing = 136

Heating operated/Apr

| HE063 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 157 | 46.2 | 157 | 46.2 |
| Yes | 183 | 53.8 | 340 | 100.0 |

Frequency Missing = 139

Heating operated/May

| HE064 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 246 | 72.8 | 246 | 72.8 |
| Yes | 92 | 27.2 | 338 | 100.0 |

Frequency Missing = 141

Heating operated/Jun

| HE065 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 321 | 95.5 | 321 | 95.5 |
| Yes | 15 | 4.5 | 336 | 100.0 |

Frequency Missing = 143

Heating operated/Jul

| HE066 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 328 | 97.9 | 328 | 97.9 |
| Yes | 7 | 2.1 | 335 | 100.0 |

Frequency Missing = 144

Heating operated/Aug

| HE067 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 326 | 97.3 | 326 | 97.3 |
| Yes | 9 | 2.7 | 335 | 100.0 |

Frequency Missing = 144

Heating operated/Sep

| HE068 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 309 | 92.0 | 309 | 92.0 |
| Yes | 27 | 8.0 | 336 | 100.0 |

Frequency Missing = 143

Heating operated/Oct

| HE069 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 199 | 58.2 | 199 | 58.2 |
| Yes | 143 | 41.8 | 342 | 100.0 |

Frequency Missing = 137

Heating operated/Nov

| HE070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 63 | 18.3 | 63 | 18.3 |
| Yes | 282 | 81.7 | 345 | 100.0 |

Frequency Missing = 134

Heating operated/Dec

| HE071 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 43 | 12.4 | 43 | 12.4 |
| Yes | 303 | 87.6 | 346 | 100.0 |

Frequency Missing = 133

Heating operated/Ref

| HE072 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 284 | 94.7 | 284 | 94.7 |
| Yes | 16 | 5.3 | 300 | 100.0 |

Frequency Missing = 179

Heating operated/DK

| HE073 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 280 | 90.9 | 280 | 90.9 |
| Yes | 28 | 9.1 | 308 | 100.0 |

Frequency Missing = 171

Added/replaced/removed heating sys

| HE080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| No chnge | 377 | 86.5 | 377 | 86.5 |
| Added | 14 | 3.2 | 391 | 89.7 |
| Replaced | 42 | 9.6 | 433 | 99.3 |
| Added/Replaced | 3 | 0.7 | 436 | 100.0 |

Frequency Missing = 43

Month/Year changed heating

| HE090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| FEB1992 | 1 | 4.0 | 1 | 4.0 |
| JUN1992 | 1 | 4.0 | 2 | 8.0 |
| JUL1992 | 1 | 4.0 | 3 | 12.0 |
| DEC1992 | 1 | 4.0 | 4 | 16.0 |
| MAY1993 | 1 | 4.0 | 5 | 20.0 |
| JUN1993 | 1 | 4.0 | 6 | 24.0 |
| NOV1993 | 1 | 4.0 | 7 | 28.0 |
| DEC1993 | 1 | 4.0 | 8 | 32.0 |
| APR1994 | 1 | 4.0 | 9 | 36.0 |
| JUN1994 | 2 | 8.0 | 11 | 44.0 |
| JUL1994 | 8 | 32.0 | 19 | 76.0 |
| AUG1994 | 1 | 4.0 | 20 | 80.0 |
| OCT1994 | 1 | 4.0 | 21 | 84.0 |
| JAN1995 | 1 | 4.0 | 22 | 88.0 |
| MAR1995 | 1 | 4.0 | 23 | 92.0 |
| APR1995 | 2 | 8.0 | 25 | 100.0 |

Frequency Missing = 454

Year changed heating

| HE091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 5 | 13.5 | 5 | 13.5 |
| 1993 | 17 | 45.9 | 22 | 59.5 |
| 1994 | 12 | 32.4 | 34 | 91.9 |
| 1995 | 3 | 8.1 | 37 | 100.0 |

Frequency Missing = 442

Old heat fuel type

| HE110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 36 | 73.5 | 36 | 73.5 |
| Propane/Bottld g | 2 | 4.1 | 38 | 77.6 |
| Steam | 1 | 2.0 | 39 | 79.6 |
| Elec | 10 | 20.4 | 49 | 100.0 |

Frequency Missing = 430

heat addition fuel type

| HE120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 9 | 50.0 | 9 | 50.0 |
| Propane/Bottld g | 3 | 16.7 | 12 | 66.7 |
| Oil | 1 | 5.6 | 13 | 72.2 |
| Elec | 3 | 16.7 | 16 | 88.9 |
| Other | 2 | 11.1 | 18 | 100.0 |

Frequency Missing = 461

OBS HE121

- 1 PORTABLES, SOME GAS, SOME ELEC.
- 2 WOOD AND GAS

Changed top 10% equip?

| OE010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 401 | 90.9 | 401 | 90.9 |
| Yes | 40 | 9.1 | 441 | 100.0 |

Frequency Missing = 38

Changed H2O heat

| OE012 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 28 | 90.3 | 28 | 90.3 |
| Yes | 3 | 9.7 | 31 | 100.0 |

Frequency Missing = 448

Changed cooking equip

| OE013 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 29 | 93.5 | 29 | 93.5 |
| Yes | 2 | 6.5 | 31 | 100.0 |

Frequency Missing = 448

Changed refrigeration

| OE014 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 23 | 69.7 | 23 | 69.7 |
| Yes | 10 | 30.3 | 33 | 100.0 |

Frequency Missing = 446

Changed HVAC

| OE014B | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 1 | 5 | 100.0 | 5 | 100.0 |

Frequency Missing = 474

Changed mfg equip

| OE014C | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 1 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Changed computers

| OE014D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
|--------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Changed other1

| OE015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 11 | 26.8 | 11 | 26.8 |
| Yes | 30 | 73.2 | 41 | 100.0 |

Frequency Missing = 438

OBS OE016

- 1 TEMPORARY BUILDINGS W/HVAC
- 2 EXHAUST FANS
- 3 POOL HEATER
- 4 LIGHTING RETROFITS
- 5 LIGHTS
- 6 CLOSED SHOP
- 7 40 NEW WASHERS
- 8 PHOTO PROCESSING EQUIP
- 9 NEW A\C IN NEW OFFICE
- 10 AIR COMPRESSORS
- 11 CHANGED WELL PUMP
- 12 SEE ADITION OF RELOCATABLES
- 13 SEE ADITION OF RELOCATABLES
- 14 SEE ADITION OF RELOCATABLES
- 15 SEE ADITION OF RELOCATABLES
- 16 SEE ADITION OF RELOCATABLES
- 17 ADDED 2 PORT. CLASSROOMS
- 18 SEE ADITION OF RELOCATABLES
- 19 SEE ADITION OF RELOCATABLES
- 20 SEE ADITION OF RELOCATABLES
- 21 SEE ADITION OF RELOCATABLES
- 22 SEE ADITION OF RELOCATABLES
- 23 SEE ADITION OF RELOCATABLES
- 24 SEE ADITION OF RELOCATABLES
- 25 SEE ADITION OF RELOCATABLES
- 26 COOLERS
- 27 AC LOWER CEILING TO MAKE
- 28 EXCELLARATOR
- 29 SPACE HEATING
- 30 PROPANE HEAT

Changed other2

| OE017 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 34 | 89.5 | 34 | 89.5 |
| Yes | 4 | 10.5 | 38 | 100.0 |

Frequency Missing = 441

OBS OE018

- 1 COMPUTERS.
- 2 CONVEYER SYSTEM
- 3 COMPRESSORS
- 4 IT MORE SUFFIEICIENT.

Changed refused

| OE019 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 36 | 100.0 | 36 | 100.0 |

Frequency Missing = 443

Changed dont know

| OE011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 39 | 100.0 | 39 | 100.0 |

Frequency Missing = 440

Month/Year changed H2O heat

| OE020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| OCT1993 | 1 | 50.0 | 1 | 50.0 |
| APR1995 | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 477

Year changed H2O heat

| OE021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1994 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Added/replaced/removed H2O heat

| OE030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Added | 2 | 66.7 | 2 | 66.7 |
| Added/Replaced | 1 | 33.3 | 3 | 100.0 |

Frequency Missing = 476

Old H2O heat fuel type

| OE040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

H2O heat addition fuel type

| OE050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 1 | 33.3 | 1 | 33.3 |
| Elec | 2 | 66.7 | 3 | 100.0 |

Frequency Missing = 476

Month/Year changed cooking equip

| OE060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Year changed cooking equip

| OE061 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1993 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Added/replaced/removed cooking equip

| OE070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Added | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Old cooking equip fuel type

| OE080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

cooking equip addition fuel type

| OE090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Month/Year changed refrigeration equip

| OE100 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| NOV1992 | 1 | 16.7 | 1 | 16.7 |
| JAN1993 | 1 | 16.7 | 2 | 33.3 |
| OCT1993 | 1 | 16.7 | 3 | 50.0 |
| JUN1994 | 1 | 16.7 | 4 | 66.7 |
| SEP1994 | 1 | 16.7 | 5 | 83.3 |
| APR1995 | 1 | 16.7 | 6 | 100.0 |

Frequency Missing = 473

Year changed refrigeration equip

| OE101 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1993 | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 475

Added/replaced/removed refrig equip

| OE110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Added | 5 | 50.0 | 5 | 50.0 |
| Replaced | 1 | 10.0 | 6 | 60.0 |
| Added/Replaced | 3 | 30.0 | 9 | 90.0 |
| Removed | 1 | 10.0 | 10 | 100.0 |

Frequency Missing = 469

Old refrigeration equip fuel type

| OE120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 5 | 100.0 | 5 | 100.0 |

Frequency Missing = 474

refrigeration equip addition fuel type

| OE130 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 8 | 100.0 | 8 | 100.0 |

Frequency Missing = 471

Month/Year changed Other1 equip

| OE140 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| SEP1992 | 1 | 12.5 | 1 | 12.5 |
| NOV1992 | 1 | 12.5 | 2 | 25.0 |
| AUG1993 | 1 | 12.5 | 3 | 37.5 |
| DEC1993 | 2 | 25.0 | 5 | 62.5 |
| FEB1994 | 1 | 12.5 | 6 | 75.0 |
| MAY1994 | 1 | 12.5 | 7 | 87.5 |
| NOV1994 | 1 | 12.5 | 8 | 100.0 |

Frequency Missing = 471

Year changed Other1 equip

| OE141 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1993 | 17 | 85.0 | 17 | 85.0 |
| 1994 | 1 | 5.0 | 18 | 90.0 |
| 1995 | 2 | 10.0 | 20 | 100.0 |

Frequency Missing = 459

Added/replaced/removed Other1 equip

| OE150 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------|-----------|---------|-------------------------|-----------------------|
| Added | 3 | 75.0 | 3 | 75.0 |
| Replaced | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 475

Old Other1 equip fuel type

| OE160 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Other1 equip addition fuel type

| OE170 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 477

Month/Year changed Other2 equip

| OE180 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| AUG1994 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Year changed Other2 equip

| OE181 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1993 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Added/replaced/removed Other2 equip

| OE190 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Old Other2 equip fuel type

| OE200 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 479

Other2 equip addition fuel type

| OE202 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 479 | | | | |

Made any other energy using changes?

| OC010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 385 | 87.7 | 385 | 87.7 |
| Yes | 54 | 12.3 | 439 | 100.0 |
| Frequency Missing = 40 | | | | |

OBS OC020

1 DECREASE USAGE AT PEAK HRS W/PG&E PROGRA,
2 INSTALLED TERMAL PYNE WINDOWS
3 NEW WATER HEATER
4 ADDED COMPUTERS
5 TENANT LEFT WHICH REDUCED POWER USAGE
6 ADDED COMPUTERS
7 INSTALLED 4 INDIVIDUAL AIR CONDITIONER WALL UNITS
8 MORE ENERGY EFFICIENT LIGHT BULBS
9 ADDITION OF AIR COMPRESSOR
10 ADDED COMPUTERS
11 HIGHER WATTAGE PARKING LOT LIGHTS.
12 CHANGED EXIT LIGHTS TO LED LIGHTS
13 REMOVED PUMP,
14 MORE OF THE BUILDING IS OCCUPIED
15 ADDED A GENERATOR
16 ADDED MORE GAS STOVES
17 ADDED RADIANT BARRIER INSULATION
18 A COMPUTER SYSTEM WAS ADDED.
19 NEW WINDOWS AND MORE WINDOWS
20 ADDED CEILING FAN IN OFFICE
21 REPLACED 2 SINGLE DOOR DRYERS, WITH 2 DOUBLE STACK DRYERS.
22 PUT WATER COOLER ON DRY CLEANING MACHINE
23 INSTALLE AN ENERGY MANAGEMENT SYSTEM
24 ADDED SOME NEON SIGNS
25 RE-ENFORCED ENERGY STANDARDS & GUIDELINES
26 ADDITIONAL OFFICE SPACE
27 ADDITIONAL PLUG-IN EQUIPMENT
28 ADDED COMPUTERS
29 CHANGED 4 ROOFTOP HEATING/COOLING UNITS
30 NEW WALK IN FRIDGES
31 CHANGED ENERGY MANAGEMENT SYSTEM
32 CHANGED TO HIGH EFF. BOILER AT SWIMMING POOL
33 ENERGY MANAGEMENT SYSTEM INSTALLED
34 ADDED PCS
35 MORE EQUIPMENT
36 ADDED SMALL COOLER
37 ADDED GAS EQUIP.
38 NEW FRIDGE
39 NEW FRIDGE
40 ELIMINTED SOME EQUIPMENTS
41 ADDED GAS EQUIP.
42 NEW ROOF
43 ADDED A WALK IN BOX
44 REPLACED WALK-IN FREEZER COMPRESSOR WITH LARGER, MORE EFFICIENT UNIT
45 CHANGED LIGHTING OUTSIDE OF PROGRAM, MOTION SENSORS
46 ADDED TIME CLOCKS FOR GARAGE LIGHTING
47 CHANGED BASEBOARD HEATERS
48 NEW WATER HEATERS
49 MORE PEOPLE/ LIGHTS ARE ON MORE OFTEN.
50 PUT SUN SHADES UP AND VERTICLE BLINDS
51 ADDITION OF FAX MACHINE, COMPUTER AND PRINTER, AND VIDEO CAMERA AND
52 RETROFIT
53 ADDED A STERIALIZER THAT USES A LOT OF ENERGY, HAS 390 AMP, PRETTY INT

OBS OC020
 54 ADDED A HOT WATER HEATER
 55 ADDED NEW COMPUTERS
 56 REMOVED PUMP,

OBS OC021

1 AND IS ADDING TWO MORE DRYERS, TODAY (8/9/95). {TOTAL CHANGE = +4 }
 2 TV MONTIOR
 3 ENSE ON HEAT USAGES

Month/Year of other change

| OC030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1992 | 1 | 3.6 | 1 | 3.6 |
| JUL1992 | 2 | 7.1 | 3 | 10.7 |
| JUN1993 | 3 | 10.7 | 6 | 21.4 |
| JUL1993 | 1 | 3.6 | 7 | 25.0 |
| NOV1993 | 1 | 3.6 | 8 | 28.6 |
| JAN1994 | 1 | 3.6 | 9 | 32.1 |
| APR1994 | 1 | 3.6 | 10 | 35.7 |
| JUN1994 | 2 | 7.1 | 12 | 42.9 |
| AUG1994 | 2 | 7.1 | 14 | 50.0 |
| SEP1994 | 2 | 7.1 | 16 | 57.1 |
| OCT1994 | 2 | 7.1 | 18 | 64.3 |
| NOV1994 | 1 | 3.6 | 19 | 67.9 |
| DEC1994 | 3 | 10.7 | 22 | 78.6 |
| JAN1995 | 2 | 7.1 | 24 | 85.7 |
| MAR1995 | 1 | 3.6 | 25 | 89.3 |
| APR1995 | 2 | 7.1 | 27 | 96.4 |
| JUN1995 | 1 | 3.6 | 28 | 100.0 |

Frequency Missing = 451

Year of other change

| OC031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 2 | 9.1 | 2 | 9.1 |
| 1993 | 6 | 27.3 | 8 | 36.4 |
| 1994 | 10 | 45.5 | 18 | 81.8 |
| 1995 | 4 | 18.2 | 22 | 100.0 |

Frequency Missing = 457

Is there an EMS system?

| EM010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 365 | 83.9 | 365 | 83.9 |
| Yes | 70 | 16.1 | 435 | 100.0 |

Frequency Missing = 44

Month/Year EMS installed

| EM020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| FEB1970 | 1 | 6.3 | 1 | 6.3 |
| APR1982 | 1 | 6.3 | 2 | 12.5 |
| MAR1986 | 1 | 6.3 | 3 | 18.8 |
| APR1992 | 1 | 6.3 | 4 | 25.0 |
| JUL1992 | 1 | 6.3 | 5 | 31.3 |
| JAN1994 | 1 | 6.3 | 6 | 37.5 |
| FEB1994 | 1 | 6.3 | 7 | 43.8 |
| APR1994 | 1 | 6.3 | 8 | 50.0 |
| JUN1994 | 2 | 12.5 | 10 | 62.5 |
| JUL1994 | 1 | 6.3 | 11 | 68.8 |
| AUG1994 | 1 | 6.3 | 12 | 75.0 |
| SEP1994 | 1 | 6.3 | 13 | 81.3 |
| OCT1994 | 1 | 6.3 | 14 | 87.5 |
| APR1995 | 1 | 6.3 | 15 | 93.8 |
| MAY1995 | 1 | 6.3 | 16 | 100.0 |

Frequency Missing = 463

Year EMS installed

| EM021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1970 | 1 | 1.7 | 1 | 1.7 |
| 1980 | 1 | 1.7 | 2 | 3.4 |
| 1984 | 1 | 1.7 | 3 | 5.2 |
| 1985 | 1 | 1.7 | 4 | 6.9 |
| 1986 | 2 | 3.4 | 6 | 10.3 |
| 1987 | 2 | 3.4 | 8 | 13.8 |
| 1988 | 1 | 1.7 | 9 | 15.5 |
| 1989 | 2 | 3.4 | 11 | 19.0 |
| 1991 | 3 | 5.2 | 14 | 24.1 |
| 1992 | 5 | 8.6 | 19 | 32.8 |
| 1993 | 22 | 37.9 | 41 | 70.7 |
| 1994 | 15 | 25.9 | 56 | 96.6 |
| 1995 | 2 | 3.4 | 58 | 100.0 |

Frequency Missing = 421

Is there a cogeneration plant?

| CP010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 416 | 99.0 | 416 | 99.0 |
| Yes | 4 | 1.0 | 420 | 100.0 |

Frequency Missing = 59

Month/Year cogeneration installed

| CP020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| DEC1991 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 478

Year cogeneration installed

| CP021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1983 | 1 | 33.3 | 1 | 33.3 |
| 1993 | 2 | 66.7 | 3 | 100.0 |

Frequency Missing = 476

Appendix I

NONPARTICIPANTS TELEPHONE SURVEY RESPONSE FREQUENCIES

audit OK?

| MN001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 2 | 0.4 | 2 | 0.4 |
| Yes | 448 | 99.6 | 450 | 100.0 |

Frequency Missing = 8

Own building?/Decis

| SC001D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 205 | 46.1 | 205 | 46.1 |
| Yes | 240 | 53.9 | 445 | 100.0 |

Frequency Missing = 13

Firm occupies space/Decis

| FI001D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 18 | 4.0 | 18 | 4.0 |
| Yes | 432 | 96.0 | 450 | 100.0 |

Frequency Missing = 8

Firm manages prop/Decis

| FI002D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| No | 111 | 24.9 | 111 | 24.9 |
| Yes | 335 | 75.1 | 446 | 100.0 |

Frequency Missing = 12

Own building?/Tech

| SC001T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| No | 5 | 71.4 | 5 | 71.4 |
| Yes | 2 | 28.6 | 7 | 100.0 |

Frequency Missing = 451

Firm occupies space/Tech

| FI001T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| No | 2 | 28.6 | 2 | 28.6 |
| Yes | 5 | 71.4 | 7 | 100.0 |

Frequency Missing = 451

Firm manages prop/Tech

| FI002T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| No | 3 | 33.3 | 3 | 33.3 |
| Yes | 6 | 66.7 | 9 | 100.0 |

Frequency Missing = 449

Own building?/Light

| SC001L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| No | 1 | 50.0 | 1 | 50.0 |
| Yes | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 456

Firm occupies space/Light

| FI001L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| No | 1 | 50.0 | 1 | 50.0 |
| Yes | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 456

Firm manages prop/Light

| FI002L | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| No | 1 | 50.0 | 1 | 50.0 |
| Yes | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 456

Is there a PM firm?

| SC016 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 76 | 69.1 | 76 | 69.1 |
| Yes | 34 | 30.9 | 110 | 100.0 |

Frequency Missing = 348

Are you the sole occupant?

| FI003 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| No | 147 | 33.9 | 147 | 33.9 |
| Yes | 286 | 66.1 | 433 | 100.0 |

Frequency Missing = 25

Is any part of building leased?

| FI004 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 169 | 68.7 | 169 | 68.7 |
| Yes | 77 | 31.3 | 246 | 100.0 |

Frequency Missing = 212

Is person decision maker

| SC003 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Yes | 450 | 100.0 | 450 | 100.0 |

Frequency Missing = 8

Is person Tech person

| SC005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 5 | 1.1 | 5 | 1.1 |
| Yes | 444 | 98.9 | 449 | 100.0 |

Frequency Missing = 9

Is person Light person

| SC006 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 4 | 0.9 | 4 | 0.9 |
| Yes | 446 | 99.1 | 450 | 100.0 |

Frequency Missing = 8

Recall participation?

| SC020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 408 | 90.7 | 408 | 90.7 |
| Yes | 42 | 9.3 | 450 | 100.0 |

Frequency Missing = 8

Lights instald pre/post Jan1992

| SC021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|-------------------------|-----------------------|
| After Jan 1992 | 2 | 4.2 | 2 | 4.2 |
| Before Jan 1992 | 46 | 95.8 | 48 | 100.0 |

Frequency Missing = 410

Changed any indoor lighting?

| IL010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 303 | 68.6 | 303 | 68.6 |
| Yes | 139 | 31.4 | 442 | 100.0 |

Frequency Missing = 16

month/year indoor light change

| IL020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| FEB1992 | 1 | 1.6 | 1 | 1.6 |
| JUN1992 | 1 | 1.6 | 2 | 3.3 |
| SEP1992 | 1 | 1.6 | 3 | 4.9 |
| OCT1992 | 1 | 1.6 | 4 | 6.6 |
| JAN1993 | 1 | 1.6 | 5 | 8.2 |
| MAR1993 | 1 | 1.6 | 6 | 9.8 |
| APR1993 | 2 | 3.3 | 8 | 13.1 |
| JUN1993 | 2 | 3.3 | 10 | 16.4 |
| AUG1993 | 1 | 1.6 | 11 | 18.0 |
| SEP1993 | 1 | 1.6 | 12 | 19.7 |
| FEB1994 | 2 | 3.3 | 14 | 23.0 |
| MAR1994 | 1 | 1.6 | 15 | 24.6 |
| MAY1994 | 1 | 1.6 | 16 | 26.2 |
| JUL1994 | 3 | 4.9 | 19 | 31.1 |
| AUG1994 | 2 | 3.3 | 21 | 34.4 |
| SEP1994 | 2 | 3.3 | 23 | 37.7 |
| NOV1994 | 3 | 4.9 | 26 | 42.6 |
| DEC1994 | 2 | 3.3 | 28 | 45.9 |
| JAN1995 | 5 | 8.2 | 33 | 54.1 |
| FEB1995 | 3 | 4.9 | 36 | 59.0 |
| MAR1995 | 4 | 6.6 | 40 | 65.6 |
| APR1995 | 8 | 13.1 | 48 | 78.7 |
| MAY1995 | 5 | 8.2 | 53 | 86.9 |
| JUN1995 | 2 | 3.3 | 55 | 90.2 |
| JUL1995 | 6 | 9.8 | 61 | 100.0 |

Frequency Missing = 397

year indoor light change

| IL021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 12 | 17.4 | 12 | 17.4 |
| 1993 | 31 | 44.9 | 43 | 62.3 |
| 1994 | 17 | 24.6 | 60 | 87.0 |
| 1995 | 9 | 13.0 | 69 | 100.0 |

Frequency Missing = 389

month/year indoor light change-2

| IL025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| MAY1994 | 1 | 33.3 | 1 | 33.3 |
| NOV1994 | 1 | 33.3 | 2 | 66.7 |
| APR1995 | 1 | 33.3 | 3 | 100.0 |

Frequency Missing = 455

year indoor light change-2

| IL026 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 1 | 8.3 | 1 | 8.3 |
| 1993 | 2 | 16.7 | 3 | 25.0 |
| 1994 | 9 | 75.0 | 12 | 100.0 |

Frequency Missing = 446

Added or removed/4' T-8

| IL040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 79 | 76.0 | 79 | 76.0 |
| Added | 23 | 22.1 | 102 | 98.1 |
| Removed | 2 | 1.9 | 104 | 100.0 |

Frequency Missing = 354

Added or removed/8' T-8

| IL041 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 92 | 88.5 | 92 | 88.5 |
| Added | 9 | 8.7 | 101 | 97.1 |
| Removed | 3 | 2.9 | 104 | 100.0 |

Frequency Missing = 354

Added or removed/4' ES Fluor

| IL042 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 103 | 97.2 | 103 | 97.2 |
| Added | 3 | 2.8 | 106 | 100.0 |

Frequency Missing = 352

Added or removed/8' ES Fluor

| IL043 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 106 | 99.1 | 106 | 99.1 |
| Added | 1 | 0.9 | 107 | 100.0 |

Frequency Missing = 351

Added or removed/4' T-12

| IL044 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 96 | 92.3 | 96 | 92.3 |
| Added | 7 | 6.7 | 103 | 99.0 |
| Removed | 1 | 1.0 | 104 | 100.0 |

Frequency Missing = 354

Added or removed/8' T-12

| IL045 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 96 | 92.3 | 96 | 92.3 |
| Added | 5 | 4.8 | 101 | 97.1 |
| Removed | 3 | 2.9 | 104 | 100.0 |

Frequency Missing = 354

Added or removed/Incandescent

| IL046 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 82 | 78.1 | 82 | 78.1 |
| Added | 15 | 14.3 | 97 | 92.4 |
| Removed | 8 | 7.6 | 105 | 100.0 |

Frequency Missing = 353

Added or removed/Compact Fluor

| IL047 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 92 | 88.5 | 92 | 88.5 |
| Added | 11 | 10.6 | 103 | 99.0 |
| Removed | 1 | 1.0 | 104 | 100.0 |

Frequency Missing = 354

Added or removed/High pres sodium

| IL048 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 93 | 89.4 | 93 | 89.4 |
| Added | 11 | 10.6 | 104 | 100.0 |

Frequency Missing = 354

Added or removed/Elec Ballasts

| IL049 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 95 | 91.3 | 95 | 91.3 |
| Added | 9 | 8.7 | 104 | 100.0 |

Frequency Missing = 354

Number changed/4' T-8

| IL040N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 10.0 | 2 | 10.0 |
| 4 | 2 | 10.0 | 4 | 20.0 |
| 6 | 4 | 20.0 | 8 | 40.0 |
| 10 | 2 | 10.0 | 10 | 50.0 |
| 14 | 1 | 5.0 | 11 | 55.0 |
| 15 | 1 | 5.0 | 12 | 60.0 |
| 20 | 1 | 5.0 | 13 | 65.0 |
| 24 | 1 | 5.0 | 14 | 70.0 |
| 32 | 1 | 5.0 | 15 | 75.0 |
| 40 | 1 | 5.0 | 16 | 80.0 |
| 100 | 2 | 10.0 | 18 | 90.0 |
| 200 | 1 | 5.0 | 19 | 95.0 |
| 500 | 1 | 5.0 | 20 | 100.0 |

Frequency Missing = 438

Number changed/8' T-8

| IL041N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 3 | 1 | 14.3 | 1 | 14.3 |
| 4 | 1 | 14.3 | 2 | 28.6 |
| 8 | 1 | 14.3 | 3 | 42.9 |
| 14 | 1 | 14.3 | 4 | 57.1 |
| 20 | 2 | 28.6 | 6 | 85.7 |
| 25 | 1 | 14.3 | 7 | 100.0 |

Frequency Missing = 451

Number changed/4' ES Fluor

| IL042N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 33.3 | 1 | 33.3 |
| 2 | 1 | 33.3 | 2 | 66.7 |
| 40 | 1 | 33.3 | 3 | 100.0 |

Frequency Missing = 455

Number changed/8' ES Fluor

| IL043N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
|--------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Number changed/4' T-12

| IL044N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 2 | 1 | 16.7 | 1 | 16.7 |
| 6 | 2 | 33.3 | 3 | 50.0 |
| 8 | 1 | 16.7 | 4 | 66.7 |
| 12 | 1 | 16.7 | 5 | 83.3 |
| 3000 | 1 | 16.7 | 6 | 100.0 |

Frequency Missing = 452

Number changed/8' T-12

| IL045N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| 6 | 1 | 16.7 | 1 | 16.7 |
| 10 | 3 | 50.0 | 4 | 66.7 |
| 50 | 1 | 16.7 | 5 | 83.3 |
| 72 | 1 | 16.7 | 6 | 100.0 |

Frequency Missing = 452

Number changed/Incandescent

| IL046N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|----------------------|--------------------|
| 1 | 1 | 4.5 | 1 | 4.5 |
| 2 | 2 | 9.1 | 3 | 13.6 |
| 3 | 3 | 13.6 | 6 | 27.3 |
| 4 | 1 | 4.5 | 7 | 31.8 |
| 6 | 1 | 4.5 | 8 | 36.4 |
| 7 | 1 | 4.5 | 9 | 40.9 |
| 10 | 4 | 18.2 | 13 | 59.1 |
| 12 | 1 | 4.5 | 14 | 63.6 |
| 15 | 1 | 4.5 | 15 | 68.2 |
| 20 | 1 | 4.5 | 16 | 72.7 |
| 24 | 1 | 4.5 | 17 | 77.3 |
| 30 | 1 | 4.5 | 18 | 81.8 |
| 50 | 1 | 4.5 | 19 | 86.4 |
| 100 | 1 | 4.5 | 20 | 90.9 |
| 215 | 1 | 4.5 | 21 | 95.5 |
| 500 | 1 | 4.5 | 22 | 100.0 |

Frequency Missing = 436

Number changed/Compact Fluor

| IL047N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 3 | 1 | 8.3 | 1 | 8.3 |
| 4 | 3 | 25.0 | 4 | 33.3 |
| 6 | 1 | 8.3 | 5 | 41.7 |
| 8 | 1 | 8.3 | 6 | 50.0 |
| 14 | 2 | 16.7 | 8 | 66.7 |
| 24 | 1 | 8.3 | 9 | 75.0 |
| 50 | 1 | 8.3 | 10 | 83.3 |
| 215 | 1 | 8.3 | 11 | 91.7 |
| 2000 | 1 | 8.3 | 12 | 100.0 |

Frequency Missing = 446

Number changed/High pres sodium

| IL048N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 2 | 1 | 10.0 | 1 | 10.0 |
| 3 | 1 | 10.0 | 2 | 20.0 |
| 4 | 3 | 30.0 | 5 | 50.0 |
| 6 | 1 | 10.0 | 6 | 60.0 |
| 10 | 1 | 10.0 | 7 | 70.0 |
| 20 | 1 | 10.0 | 8 | 80.0 |
| 40 | 1 | 10.0 | 9 | 90.0 |
| 50 | 1 | 10.0 | 10 | 100.0 |

Frequency Missing = 448

Number changed/Elec Ballasts

| IL049N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 11.1 | 1 | 11.1 |
| 1 | 1 | 11.1 | 2 | 22.2 |
| 2 | 2 | 22.2 | 4 | 44.4 |
| 4 | 3 | 33.3 | 7 | 77.8 |
| 6 | 1 | 11.1 | 8 | 88.9 |
| 10 | 1 | 11.1 | 9 | 100.0 |

Frequency Missing = 449

Added or removed/Magnetic Ballasts

| IL050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 92 | 94.8 | 92 | 94.8 |
| Added | 4 | 4.1 | 96 | 99.0 |
| Removed | 1 | 1.0 | 97 | 100.0 |

Frequency Missing = 361

Added or removed/Metal Halide

| IL051 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 95 | 95.0 | 95 | 95.0 |
| Added | 4 | 4.0 | 99 | 99.0 |
| Removed | 1 | 1.0 | 100 | 100.0 |

Frequency Missing = 358

Added or removed/Mercury Vapor

| IL052 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 97 | 98.0 | 97 | 98.0 |
| Added | 2 | 2.0 | 99 | 100.0 |

Frequency Missing = 359

Added or removed/Quartz

| IL053 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 93 | 94.9 | 93 | 94.9 |
| Added | 5 | 5.1 | 98 | 100.0 |

Frequency Missing = 360

Added or removed/Reflectors

| IL054 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 97 | 98.0 | 97 | 98.0 |
| Added | 2 | 2.0 | 99 | 100.0 |

Frequency Missing = 359

Added or removed/LED Exit Lights

| IL055 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 97 | 97.0 | 97 | 97.0 |
| Added | 3 | 3.0 | 100 | 100.0 |

Frequency Missing = 358

Added or removed/Watt Saver-Power Choke

| IL056 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 98 | 100.0 | 98 | 100.0 |

Frequency Missing = 360

Added or removed/Other

| IL057 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| No change | 86 | 78.9 | 86 | 78.9 |
| Added | 23 | 21.1 | 109 | 100.0 |

Frequency Missing = 349

Number changed/Magnetic Ballasts

| IL050N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 1 | 1 | 20.0 | 1 | 20.0 |
| 3 | 1 | 20.0 | 2 | 40.0 |
| 4 | 3 | 60.0 | 5 | 100.0 |

Frequency Missing = 453

Number changed/Metal Halide

| IL051N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 3 | 1 | 20.0 | 1 | 20.0 |
| 4 | 2 | 40.0 | 3 | 60.0 |
| 6 | 1 | 20.0 | 4 | 80.0 |
| 12 | 1 | 20.0 | 5 | 100.0 |

Frequency Missing = 453

Number changed/Mercury Vapor

| IL052N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 3 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 457

Number changed/Quartz

| IL053N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 3 | 1 | 25.0 | 1 | 25.0 |
| 8 | 1 | 25.0 | 2 | 50.0 |
| 72 | 1 | 25.0 | 3 | 75.0 |
| 100 | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 454

Number changed/Reflectors

| IL054N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 700 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 457

Number changed/LED Exit Lights

| IL055N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 9 | 2 | 50.0 | 2 | 50.0 |
| 14 | 1 | 25.0 | 3 | 75.0 |
| 40 | 1 | 25.0 | 4 | 100.0 |

Frequency Missing = 454

Number changed/Watt Saver-Power Choke

| IL056N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |

Frequency Missing = 458

Number changed/Other

| IL057N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 6 | 37.5 | 6 | 37.5 |
| 1 | 3 | 18.8 | 9 | 56.3 |
| 3 | 3 | 18.8 | 12 | 75.0 |
| 10 | 3 | 18.8 | 15 | 93.8 |
| 12 | 1 | 6.3 | 16 | 100.0 |

Frequency Missing = 442

| | |
|-----|------------------------|
| OBS | IL058 |
| 1 | CENTURY 21 SIGN |
| 2 | BALLASTS |
| 3 | GROUND LIGHTS |
| 4 | 1 |
| 5 | DID NOT KNOW... |
| 6 | OIUTSIDE SECURITY LITE |
| 7 | 0 |
| 8 | NEW REFLECTORS |
| 9 | PHOTOCELL SENSORS |
| 10 | LOW PRESSURE SODIUM |
| 11 | HALOGEN |
| 12 | FLOURESCENT FIXTURE |
| 13 | 1 |
| 14 | 1 |
| 15 | 1 |
| 16 | . |
| 17 | 1 |
| 18 | . |
| 19 | HI PRESSURE SODIUM |
| 20 | HALLOGENS |
| 21 | HALOGEN LOW DRAW |
| 22 | FLORESCENT TYPE UNKWN |
| 23 | HALOGEN |
| 24 | METAL ARC LAMPS |
| 25 | 1 |
| 26 | NEON SIGNS |
| 27 | 0 |
| 28 | 999 |
| 29 | HEAT SENSITIVE |
| 30 | PHOTO CELL CONTROLS |
| 31 | NEON LTG. |
| 32 | NEON |
| 33 | TIMER |
| 34 | NEON LIGHTS |
| 35 | NEON SIGN |
| 36 | 999 |
| 37 | OUTSIDE |
| 38 | 0 |
| 39 | "BI-AX FLOURESCENT" |
| 40 | PHOTO SENSORS |
| 41 | 1 |
| 42 | 1 |
| 43 | 1 |
| 44 | 1 |

Single/Multiple/Portion of Build

| FI005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| One building | 356 | 81.8 | 356 | 81.8 |
| Multiple buildin | 65 | 14.9 | 421 | 96.8 |
| Portion of a bui | 14 | 3.2 | 435 | 100.0 |

Frequency Missing = 23

Multiple acnts for addr?

| FI007 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 33 | 41.8 | 33 | 41.8 |
| Yes | 46 | 58.2 | 79 | 100.0 |

Frequency Missing = 379

Num buildings covered by address

| FI010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 17 | 21.3 | 17 | 21.3 |
| 2 | 29 | 36.3 | 46 | 57.5 |
| 3 | 9 | 11.3 | 55 | 68.8 |
| 4 | 8 | 10.0 | 63 | 78.8 |
| 5 | 4 | 5.0 | 67 | 83.8 |
| 6 | 3 | 3.8 | 70 | 87.5 |
| 8 | 3 | 3.8 | 73 | 91.3 |
| 9 | 1 | 1.3 | 74 | 92.5 |
| 10 | 2 | 2.5 | 76 | 95.0 |
| 11 | 1 | 1.3 | 77 | 96.3 |
| 13 | 1 | 1.3 | 78 | 97.5 |
| 16 | 1 | 1.3 | 79 | 98.8 |
| 40 | 1 | 1.3 | 80 | 100.0 |

Frequency Missing = 378

Separate bills for buildings?

| FI015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 40 | 66.7 | 40 | 66.7 |
| Yes | 20 | 33.3 | 60 | 100.0 |

Frequency Missing = 398

Other firms in building?

| FI020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 321 | 72.6 | 321 | 72.6 |
| Yes | 121 | 27.4 | 442 | 100.0 |

Frequency Missing = 16

Number other firms in building

| FI025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 157 | 57.5 | 157 | 57.5 |
| 1 | 37 | 13.6 | 194 | 71.1 |
| 2 | 21 | 7.7 | 215 | 78.8 |
| 3 | 9 | 3.3 | 224 | 82.1 |
| 4 | 4 | 1.5 | 228 | 83.5 |
| 5 | 9 | 3.3 | 237 | 86.8 |
| 6 | 7 | 2.6 | 244 | 89.4 |
| 7 | 5 | 1.8 | 249 | 91.2 |
| 8 | 3 | 1.1 | 252 | 92.3 |
| 9 | 3 | 1.1 | 255 | 93.4 |
| 10 | 2 | 0.7 | 257 | 94.1 |
| 11 | 1 | 0.4 | 258 | 94.5 |
| 12 | 2 | 0.7 | 260 | 95.2 |
| 14 | 1 | 0.4 | 261 | 95.6 |
| 15 | 1 | 0.4 | 262 | 96.0 |
| 16 | 2 | 0.7 | 264 | 96.7 |
| 18 | 2 | 0.7 | 266 | 97.4 |
| 20 | 1 | 0.4 | 267 | 97.8 |
| 27 | 1 | 0.4 | 268 | 98.2 |
| 30 | 1 | 0.4 | 269 | 98.5 |
| 50 | 2 | 0.7 | 271 | 99.3 |
| 120 | 1 | 0.4 | 272 | 99.6 |
| 125 | 1 | 0.4 | 273 | 100.0 |

Frequency Missing = 185

Organizational Structure

| FI040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Chain/Multifacil | 59 | 13.2 | 59 | 13.2 |
| Franchise | 29 | 6.5 | 88 | 19.7 |
| Independant | 358 | 80.3 | 446 | 100.0 |

Frequency Missing = 12

OBS FI045

1 OIL, CHEM & ATOMIC INTERNATIONAL
2 ELECTRO SKILLS
3 AMERICAN BAPTIST HOMES OF THE WEST
4 BIBETT CORP.
5 LA PETITE ACADEMY INC
6 PATRICK JAMES CLOTHES
7 WORLDCOMM
8 TITAN CORP
9 CITY AND COUNTY GOVERNMENT
10 CHARLES SCHWAB
11 BAYCOM
12 PRIORITY HEALTH SERVICES
13 AUTOMOBILE CLUB OF SO. CAL
14 DESTEC ENERGY INC.
15 BRYANS TRUCK AND AUTO
16 BS&E INC
17 J E HIGGINS LUMBER
18 CLASSIC PARKING
19 CHARMING SHOPS
20 EDISON BROS.
21 TILT
22 BAKERSFIELD CENTER'S, INC.
23 NW TRANSPORTS
24 BLUMENFELD SAN FRANCISCO THEATRES
25 COMPAS
26 GOODYEAR TIRE AND RUBBER CO.
27 GREAT WORKS INC
28 CINEMERICA
29 DAIICHI & LA SLLE
30 GOODYEAR TIRE
31 BT OFFICE PRODUCTS INTL.
32 LOEHMANN'S
33 CHALLENGER SCHOOLS
34 CHILDREN'S DISCOVERY CENTERS OF AMERICA, INC.
35 COMMUNITY SCHOOLS OF KERN CO.
36 FAIRFAX SCHOOL DISTRICT
37 A.R.C., FRESNO
38 DIANDAS ITAL. AMER. PASTRY INC.
39 BOUMIS ASSOCIATES
40 DEJAVU INC.
41 GORDON BIERSCHE BREWING CO. INC.
42 SISTERS OF ST. JOSEPH OF ORANGE COUNTY
43 PHYSICIANS RESOURCE GROUP
44 UNILAB
45 CRESTWOOD HOSPITALS INC
46 SURGICAL CARE AFFILIATESL
47 TEACHERS MANAGEMENT ?-----TMI
48 COMFORT CALIFORNIA, INC. OF MANOR CARE, INC.
49 ALLEN & O'HARA INC.
50 APPLE CO.
51 HOTEL GROUP OF AMERICA
52 SECURITY PACIFIC / INSIGNIA
53 KIMTON HOTEL MNGT CO.

OBS FI045

54 HILLENBRAND INDUSTRIES
 55 REED EQUIPMENT
 56 LEO'S PROFESSIONAL AUDIO INC
 57 W W GRAINGER, INC
 58 ARROW ELECTRONICS

Legal Tax Status

| FI050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------|-----------|---------|----------------------|--------------------|
| For-Profit | 349 | 80.6 | 349 | 80.6 |
| Public | 14 | 3.2 | 363 | 83.8 |
| 501(c3)Non-profit | 70 | 16.2 | 433 | 100.0 |

Frequency Missing = 25

Tax status of parent company

| FI055 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
|-------|-----------|---------|----------------------|--------------------|

Frequency Missing = 458

Where are energy decisions made

| FI060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|----------------------|--------------------|
| Locally on site | 369 | 82.4 | 369 | 82.4 |
| Regional head of | 29 | 6.5 | 398 | 88.8 |
| National head of | 23 | 5.1 | 421 | 94.0 |
| Internat headoff | 1 | 0.2 | 422 | 94.2 |
| PM firm/build ow | 19 | 4.2 | 441 | 98.4 |
| Other | 2 | 0.4 | 443 | 98.9 |
| both local and n | 4 | 0.9 | 447 | 99.8 |
| 13 | 1 | 0.2 | 448 | 100.0 |

Frequency Missing = 10

OBS FI062

- 1 SCHOOL BOARD MEETING
- 2 CORPORATE HEAD CORTERES
- 3 MADE AT AN OWNERS' MEETING
- 4 LOCAL AND CORPORATE
- 5 MUTUAL AGREEMENT
- 6 MADE COMBO LOCAL AND NATIONAL
- 7 COMBO LOC AND REG
- 8 O-SIT + PRES & VP

Number people currently employed

| EI010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 0.7 | 3 | 0.7 |
| 1 | 23 | 5.3 | 26 | 6.0 |
| 2 | 25 | 5.8 | 51 | 11.8 |
| 3 | 29 | 6.7 | 80 | 18.5 |
| 4 | 31 | 7.2 | 111 | 25.6 |
| 5 | 24 | 5.5 | 135 | 31.2 |
| 6 | 16 | 3.7 | 151 | 34.9 |
| 7 | 8 | 1.8 | 159 | 36.7 |
| 8 | 18 | 4.2 | 177 | 40.9 |
| 9 | 4 | 0.9 | 181 | 41.8 |
| 10 | 15 | 3.5 | 196 | 45.3 |
| 11 | 4 | 0.9 | 200 | 46.2 |
| 12 | 10 | 2.3 | 210 | 48.5 |
| 13 | 3 | 0.7 | 213 | 49.2 |
| 14 | 8 | 1.8 | 221 | 51.0 |
| 15 | 17 | 3.9 | 238 | 55.0 |
| 16 | 3 | 0.7 | 241 | 55.7 |
| 17 | 5 | 1.2 | 246 | 56.8 |
| 18 | 6 | 1.4 | 252 | 58.2 |
| 19 | 2 | 0.5 | 254 | 58.7 |
| 20 | 18 | 4.2 | 272 | 62.8 |
| 21 | 1 | 0.2 | 273 | 63.0 |
| 22 | 5 | 1.2 | 278 | 64.2 |
| 23 | 3 | 0.7 | 281 | 64.9 |
| 25 | 16 | 3.7 | 297 | 68.6 |
| 26 | 2 | 0.5 | 299 | 69.1 |
| 27 | 1 | 0.2 | 300 | 69.3 |
| 28 | 2 | 0.5 | 302 | 69.7 |
| 30 | 11 | 2.5 | 313 | 72.3 |
| 31 | 1 | 0.2 | 314 | 72.5 |
| 34 | 2 | 0.5 | 316 | 73.0 |
| 35 | 11 | 2.5 | 327 | 75.5 |
| 36 | 2 | 0.5 | 329 | 76.0 |
| 37 | 2 | 0.5 | 331 | 76.4 |
| 38 | 3 | 0.7 | 334 | 77.1 |
| 39 | 2 | 0.5 | 336 | 77.6 |
| 40 | 8 | 1.8 | 344 | 79.4 |
| 42 | 1 | 0.2 | 345 | 79.7 |
| 45 | 4 | 0.9 | 349 | 80.6 |
| 46 | 1 | 0.2 | 350 | 80.8 |
| 50 | 25 | 5.8 | 375 | 86.6 |
| 54 | 1 | 0.2 | 376 | 86.8 |
| 55 | 2 | 0.5 | 378 | 87.3 |
| 56 | 1 | 0.2 | 379 | 87.5 |
| 60 | 10 | 2.3 | 389 | 89.8 |
| 65 | 5 | 1.2 | 394 | 91.0 |
| 67 | 1 | 0.2 | 395 | 91.2 |
| 70 | 3 | 0.7 | 398 | 91.9 |
| 75 | 2 | 0.5 | 400 | 92.4 |
| 77 | 1 | 0.2 | 401 | 92.6 |

Number people currently employed

| EI010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 80 | 4 | 0.9 | 405 | 93.5 |
| 85 | 1 | 0.2 | 406 | 93.8 |
| 90 | 2 | 0.5 | 408 | 94.2 |
| 100 | 8 | 1.8 | 416 | 96.1 |
| 120 | 2 | 0.5 | 418 | 96.5 |
| 125 | 2 | 0.5 | 420 | 97.0 |
| 134 | 1 | 0.2 | 421 | 97.2 |
| 150 | 3 | 0.7 | 424 | 97.9 |
| 160 | 1 | 0.2 | 425 | 98.2 |
| 170 | 1 | 0.2 | 426 | 98.4 |
| 190 | 1 | 0.2 | 427 | 98.6 |
| 200 | 1 | 0.2 | 428 | 98.8 |
| 250 | 1 | 0.2 | 429 | 99.1 |
| 350 | 1 | 0.2 | 430 | 99.3 |
| 400 | 1 | 0.2 | 431 | 99.5 |
| 500 | 1 | 0.2 | 432 | 99.8 |
| 1000 | 1 | 0.2 | 433 | 100.0 |

Frequency Missing = 25

Any change in number of employees?

| EI020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 314 | 71.9 | 314 | 71.9 |
| Yes | 123 | 28.1 | 437 | 100.0 |

Frequency Missing = 21

Mon/Year of change in employees

| EI030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1992 | 2 | 4.8 | 2 | 4.8 |
| MAR1992 | 1 | 2.4 | 3 | 7.1 |
| JUN1992 | 1 | 2.4 | 4 | 9.5 |
| AUG1992 | 2 | 4.8 | 6 | 14.3 |
| OCT1992 | 1 | 2.4 | 7 | 16.7 |
| JAN1993 | 2 | 4.8 | 9 | 21.4 |
| FEB1993 | 1 | 2.4 | 10 | 23.8 |
| APR1993 | 1 | 2.4 | 11 | 26.2 |
| JUN1993 | 1 | 2.4 | 12 | 28.6 |
| NOV1993 | 2 | 4.8 | 14 | 33.3 |
| DEC1993 | 1 | 2.4 | 15 | 35.7 |
| FEB1994 | 1 | 2.4 | 16 | 38.1 |
| APR1994 | 3 | 7.1 | 19 | 45.2 |
| JUN1994 | 1 | 2.4 | 20 | 47.6 |
| AUG1994 | 1 | 2.4 | 21 | 50.0 |
| SEP1994 | 1 | 2.4 | 22 | 52.4 |
| NOV1994 | 2 | 4.8 | 24 | 57.1 |
| JAN1995 | 5 | 11.9 | 29 | 69.0 |
| FEB1995 | 1 | 2.4 | 30 | 71.4 |
| MAR1995 | 1 | 2.4 | 31 | 73.8 |
| APR1995 | 2 | 4.8 | 33 | 78.6 |
| MAY1995 | 2 | 4.8 | 35 | 83.3 |
| JUN1995 | 5 | 11.9 | 40 | 95.2 |
| JUL1995 | 2 | 4.8 | 42 | 100.0 |

Frequency Missing = 416

Year of change in employees

| EI031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 12 | 30.0 | 12 | 30.0 |
| 1993 | 13 | 32.5 | 25 | 62.5 |
| 1994 | 11 | 27.5 | 36 | 90.0 |
| 1995 | 4 | 10.0 | 40 | 100.0 |

Frequency Missing = 418

Number people employed B4 chng

| ----- | ----- | ----- | ----- | ----- | ----- |
|------------------|-----------|---------|-------------------------|-----------------------|-------|
| EI040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent | |
| 1 | 1 | 0.9 | 1 | 0.9 | |
| 2 | 6 | 5.6 | 7 | 6.5 | |
| 3 | 3 | 2.8 | 10 | 9.3 | |
| 4 | 2 | 1.9 | 12 | 11.1 | |
| 5 | 4 | 3.7 | 16 | 14.8 | |
| 6 | 3 | 2.8 | 19 | 17.6 | |
| 7 | 3 | 2.8 | 22 | 20.4 | |
| 8 | 4 | 3.7 | 26 | 24.1 | |
| 9 | 2 | 1.9 | 28 | 25.9 | |
| 10 | 2 | 1.9 | 30 | 27.8 | |
| 11 | 2 | 1.9 | 32 | 29.6 | |
| 12 | 3 | 2.8 | 35 | 32.4 | |
| 13 | 3 | 2.8 | 38 | 35.2 | |
| 15 | 3 | 2.8 | 41 | 38.0 | |
| 17 | 2 | 1.9 | 43 | 39.8 | |
| 18 | 1 | 0.9 | 44 | 40.7 | |
| 19 | 1 | 0.9 | 45 | 41.7 | |
| 20 | 3 | 2.8 | 48 | 44.4 | |
| 21 | 3 | 2.8 | 51 | 47.2 | |
| 22 | 2 | 1.9 | 53 | 49.1 | |
| 23 | 1 | 0.9 | 54 | 50.0 | |
| 24 | 1 | 0.9 | 55 | 50.9 | |
| 25 | 5 | 4.6 | 60 | 55.6 | |
| 30 | 2 | 1.9 | 62 | 57.4 | |
| 35 | 5 | 4.6 | 67 | 62.0 | |
| 40 | 6 | 5.6 | 73 | 67.6 | |
| 50 | 3 | 2.8 | 76 | 70.4 | |
| 55 | 1 | 0.9 | 77 | 71.3 | |
| 60 | 1 | 0.9 | 78 | 72.2 | |
| 67 | 1 | 0.9 | 79 | 73.1 | |
| 70 | 1 | 0.9 | 80 | 74.1 | |
| 74 | 1 | 0.9 | 81 | 75.0 | |
| 80 | 1 | 0.9 | 82 | 75.9 | |
| 90 | 1 | 0.9 | 83 | 76.9 | |
| 100 | 1 | 0.9 | 84 | 77.8 | |
| 120 | 1 | 0.9 | 85 | 78.7 | |
| 137 | 1 | 0.9 | 86 | 79.6 | |
| 175 | 1 | 0.9 | 87 | 80.6 | |
| Season Workforce | 21 | 19.4 | 108 | 100.0 | |

Frequency Missing = 350

OBS EI041

1 SUMMER CLERKSHIPS
2 INCREASE IN SUMMER; MANY PART TIME
3 THERE IS NO SINGLE TIME WHEN THE NUMBER OF EMPLOYEES CHANGED
4 SHE SAID THE NUMBER OF EMPLOYEES HAS CHANGED SEVERAL TIMES, BUT
5 NUMBER LOW FROM OCT TO MAY WHEN WEATHER IS LESS GOOD (= 20
6 DUE TO SUMMER SCHOOL SESSIONS, THE NUMBER OF EMPLOYEES FLUCTUAT
7 THERE USED TO BE 2 PEOPLE, ONE WAS LAID OFF.
8 THE NUMBER OF EMPLOYEES HAS GONE UP AND DOWN BY ONE OR TWO
9 # OF EMPLOYEES FLUCTUATES
10 BETWEEN 1 AND 500
11 THE NUMBER OF EMPLOYEES HAS GRADUALLY DECLINED FROM 50, STARTIN
12 SHE SAID THE NUMBER OF EMPLOYEES FLUCTUATES BUT ONLY BY A COUPL
13 WINTER IS SKIING RETAIL
14 THE NUMBER HAS GONE DOWN AND UP, ABOUT 30 AT ITS LOWEST
15 THE NUMBER OF EMPLOYEES FLUCTUATES, IT HAS GONE UP AND DOWN
16 THE NUMBER OF EMPLOYEES FLUCTUATES FROM 50, IN THE SLOW
17 IT FLUCTUATES BETWEEN 40 AND 50 PEOPLE
18 NUMBER OF EMPLOYEES FLUCTUATES
19 RETAIL BUSINESS...
20 MORE IN THE SUMMER AND LESS IN THE WINTER
21 THE NUMBER HAS CHANGED BY MAYBE 1 OR 2 BUT THERE WAS NO
22 FLUCTUATES BETWEEN 7 AND 10 PEOPLE
23 "WE'RE SEASONAL,SO IT FLUCTUATES, WE MAKE DELI SALADS, WE'RE
24 SEASONAL ADDITION OF CLEANING PERSONEL

OBS EI042

1 THE MAXIMUM NUMBER WAS 60, BUT IT IS CHANGING CONSTANTLY
2 NEVER BY VERY MUCH. SHE SAID BEFORE 1992, THERE WERE PROBABLY
3 EMPLOYEES). THEN GOES TO 35 FOR THE OTHER MONTHS.
4 E
5 SINCE JAN 1992
6 G IN 1992, THE COMPANY USED TO OIL RELATED WORK,
7 OF PEOPLE
8 SEASONS, TO 95 IN SUMMERTIME.
9 DATE OF CHANGE, FLUCTUATES
10 BUSIER IN SUMMER THAN IN WINTER".

OBS EI043

1 22 PEOPLE EMPLOYED THERE

Are utilities payed thru lease?

| FI080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|-------------------------|-----------------------|
| All included | 39 | 14.2 | 39 | 14.2 |
| Some included | 13 | 4.7 | 52 | 19.0 |
| All paid direct | 222 | 81.0 | 274 | 100.0 |

Frequency Missing = 184

Indoor Light paid thru lease

| FI090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 3 | 27.3 | 3 | 27.3 |
| Yes | 8 | 72.7 | 11 | 100.0 |

Frequency Missing = 447

Heat paid thru lease

| FI091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 5 | 41.7 | 5 | 41.7 |
| Yes | 7 | 58.3 | 12 | 100.0 |

Frequency Missing = 446

Ventilation paid thru lease

| FI092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 6 | 50.0 | 6 | 50.0 |
| Yes | 6 | 50.0 | 12 | 100.0 |

Frequency Missing = 446

Elec to outlets paid thru lease

| FI093 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 5 | 41.7 | 5 | 41.7 |
| Yes | 7 | 58.3 | 12 | 100.0 |

Frequency Missing = 446

Cooking paid thru lease

| FI094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 9 | 75.0 | 9 | 75.0 |
| Yes | 3 | 25.0 | 12 | 100.0 |

Frequency Missing = 446

Outdoor Light paid thru lease

| FI095 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 5 | 41.7 | 5 | 41.7 |
| Yes | 7 | 58.3 | 12 | 100.0 |

Frequency Missing = 446

Cooling paid thru lease

| FI096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 6 | 50.0 | 6 | 50.0 |
| Yes | 6 | 50.0 | 12 | 100.0 |

Frequency Missing = 446

H2O heat paid thru lease

| FI097 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 4 | 33.3 | 4 | 33.3 |
| Yes | 8 | 66.7 | 12 | 100.0 |

Frequency Missing = 446

Refridgeration paid thru lease

| FI098 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 6 | 50.0 | 6 | 50.0 |
| Yes | 6 | 50.0 | 12 | 100.0 |

Frequency Missing = 446

Other paid thru lease

| FI099 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 9 | 81.8 | 9 | 81.8 |
| Yes | 2 | 18.2 | 11 | 100.0 |

Frequency Missing = 447

OBS FI100
 1 PORTION OF ALL
 2 999

Length of current lease

| FI110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Years left on lease

| FI115 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Is it first lease?

| FI120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 121 | 49.2 | 121 | 49.2 |
| Yes | 125 | 50.8 | 246 | 100.0 |
| ----- | | | | |
| Frequency Missing = 212 | | | | |

Have a regular light contr?

| IS001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 344 | 77.3 | 344 | 77.3 |
| Yes | 101 | 22.7 | 445 | 100.0 |
| ----- | | | | |
| Frequency Missing = 13 | | | | |

Reg Light Contr inform bout prog?

| IS002 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 68 | 77.3 | 68 | 77.3 |
| Yes | 20 | 22.7 | 88 | 100.0 |

Frequency Missing = 370

Heard of program?

| AW005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 265 | 62.2 | 265 | 62.2 |
| Yes | 161 | 37.8 | 426 | 100.0 |

Frequency Missing = 32

Mon/Year first aware of prog

| AW010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| APR1990 | 1 | 3.8 | 1 | 3.8 |
| JUN1990 | 1 | 3.8 | 2 | 7.7 |
| AUG1991 | 1 | 3.8 | 3 | 11.5 |
| SEP1992 | 1 | 3.8 | 4 | 15.4 |
| JAN1993 | 2 | 7.7 | 6 | 23.1 |
| JUN1993 | 1 | 3.8 | 7 | 26.9 |
| JUL1993 | 3 | 11.5 | 10 | 38.5 |
| NOV1993 | 1 | 3.8 | 11 | 42.3 |
| JAN1994 | 1 | 3.8 | 12 | 46.2 |
| MAR1994 | 1 | 3.8 | 13 | 50.0 |
| JUL1994 | 2 | 7.7 | 15 | 57.7 |
| SEP1994 | 1 | 3.8 | 16 | 61.5 |
| NOV1994 | 2 | 7.7 | 18 | 69.2 |
| DEC1994 | 1 | 3.8 | 19 | 73.1 |
| JAN1995 | 1 | 3.8 | 20 | 76.9 |
| FEB1995 | 1 | 3.8 | 21 | 80.8 |
| MAY1995 | 1 | 3.8 | 22 | 84.6 |
| JUL1995 | 4 | 15.4 | 26 | 100.0 |

Frequency Missing = 432

Year frist aware of prog

| AW011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1990 | 26 | 30.6 | 26 | 30.6 |
| 1991 | 9 | 10.6 | 35 | 41.2 |
| 1992 | 15 | 17.6 | 50 | 58.8 |
| 1993 | 20 | 23.5 | 70 | 82.4 |
| 1994 | 11 | 12.9 | 81 | 95.3 |
| 1995 | 4 | 4.7 | 85 | 100.0 |

Frequency Missing = 373

Hear about prog before or after purch

| AW015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| After | 10 | 22.7 | 10 | 22.7 |
| Before | 34 | 77.3 | 44 | 100.0 |

Frequency Missing = 414

How first learned of Prog

| IS010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Resp aproch vend | 1 | 0.9 | 1 | 0.9 |
| Resp aproch PG_E | 4 | 3.5 | 5 | 4.4 |
| Contd by acct re | 30 | 26.3 | 35 | 30.7 |
| Contd by lit con | 10 | 8.8 | 45 | 39.5 |
| Contd by elec co | 1 | 0.9 | 46 | 40.4 |
| Brochure n mail | 33 | 28.9 | 79 | 69.3 |
| Bill insert | 25 | 21.9 | 104 | 91.2 |
| TV/Radio/News | 5 | 4.4 | 109 | 95.6 |
| Other | 5 | 4.4 | 114 | 100.0 |

Frequency Missing = 344

OBS IS020

- 1 NEWSLETTER
- 2 AT THE SCHOOL HIS CHILDREN ATTEND
- 3 SOMEONE DID A STUDY
- 4 WENT TO PG&E SEMINAR
- 5 SPOUSE WORKS FOR PG&E

Firm Part in any PG&E prog?

| PP010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|-------------------------|-----------------------|
| No | 348 | 82.1 | 348 | 82.1 |
| Yes | 70 | 16.5 | 418 | 98.6 |
| Not awar others | 6 | 1.4 | 424 | 100.0 |

Frequency Missing = 34

Year firm part in PG_E prog

| PP020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1985 | 4 | 7.4 | 4 | 7.4 |
| 1987 | 2 | 3.7 | 6 | 11.1 |
| 1988 | 1 | 1.9 | 7 | 13.0 |
| 1989 | 2 | 3.7 | 9 | 16.7 |
| 1990 | 10 | 18.5 | 19 | 35.2 |
| 1991 | 4 | 7.4 | 23 | 42.6 |
| 1992 | 8 | 14.8 | 31 | 57.4 |
| 1993 | 11 | 20.4 | 42 | 77.8 |
| 1994 | 6 | 11.1 | 48 | 88.9 |
| 1995 | 6 | 11.1 | 54 | 100.0 |

Frequency Missing = 404

Most important changeout factor

| PD010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Get latest tech | 7 | 5.4 | 7 | 5.4 |
| Save \$ on bills | 43 | 33.3 | 50 | 38.8 |
| Replc old/brokn | 13 | 10.1 | 63 | 48.8 |
| Imprv qual lite | 44 | 34.1 | 107 | 82.9 |
| Obtn advce in fr | 2 | 1.6 | 109 | 84.5 |
| Other | 14 | 10.9 | 123 | 95.3 |
| Security | 6 | 4.7 | 129 | 100.0 |

Frequency Missing = 329

OBS PD011

- 1 EYE STAIN.
- 2 USAGE
- 3 SECURITY (OUTDOOR LIGHTS)
- 4 SECURITY REASONS
- 5 NEW MGMT/ NEW STRUCTURE OF RADIO
- 6 MORE LIGHT!
- 7 AVAILABILITY OF EQUIPMENT
- 8 MATCH FIXTURES W/ EXISTING
- 9 SPACE ADDITION
- 10 PLEASING CORP OFFICE
- 11 SAVING ENERGY
- 12 #'S 2 AND 6
- 13 ALSO #2
- 14 DID NOT PURCHASE NEW LIGHTING!!!
- 15 COST EFFICIENCY
- 16 FEDERAL STANDARDS
- 17 ADDED STORAGE, OFFICES W/ LIGHTS
- 18 SECURITY & IMPROVE LIGHTING
- 19 SECURITY
- 20 THERE WAS A NEED FOR MORE LIGHTS
- 21 WHAT I WANTED
- 22 SAFETY AND POWER USE ISSUES
- 23 DECORATIVE
- 24 BETTER EXPOSURE TO PUBLIC
- 25 GAVE CONTRACTOR DISCRETION
- 26 SECURITY
- 27 OBTAINING THE REBATE
- 28 ESTHETICS
- 29 COST OF FIXTURE

Didn't do prior/Lack \$

| FR100 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 39 | 95.1 | 39 | 95.1 |
| Yes | 2 | 4.9 | 41 | 100.0 |

Frequency Missing = 417

Didn't do prior/payback not enuf

| FR101 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 50 | 89.3 | 50 | 89.3 |
| Yes | 6 | 10.7 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/not save as much

| FR102 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 56 | 100.0 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/unaware about EE light

| FR103 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 53 | 94.6 | 53 | 94.6 |
| Yes | 3 | 5.4 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/didn't know where/how

| FR104 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 54 | 96.4 | 54 | 96.4 |
| Yes | 2 | 3.6 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/hadn't had time

| | FR105 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-------|-----------|---------|-------------------------|-----------------------|
| No | | 50 | 89.3 | 50 | 89.3 |
| Yes | | 6 | 10.7 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/concern w/ bright

| | FR106 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-------|-----------|---------|-------------------------|-----------------------|
| No | | 55 | 98.2 | 55 | 98.2 |
| Yes | | 1 | 1.8 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/tenants didn't want

| | FR107 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----|-------|-----------|---------|-------------------------|-----------------------|
| No | | 55 | 100.0 | 55 | 100.0 |

Frequency Missing = 403

Didn't do prior/decision made elsewhere

| | FR108 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----|-------|-----------|---------|-------------------------|-----------------------|
| No | | 56 | 100.0 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/was planning to do

| FR109 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 55 | 98.2 | 55 | 98.2 |
| Yes | 1 | 1.8 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/2 part 2 big a hassle

| FR110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 47 | 83.9 | 47 | 83.9 |
| Yes | 9 | 16.1 | 56 | 100.0 |

Frequency Missing = 402

Didn't do prior/just remodeled

| FR111 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Didn't do prior/moving soon

| FR112 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Didn't do prior/did it <5 years ago

| FR113 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Didn't do prior/Other specified

| FR114 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 27 | 52.9 | 27 | 52.9 |
| Yes | 24 | 47.1 | 51 | 100.0 |

Frequency Missing = 407

OBS FR115

- 1 DIDN'T KNOW ENOUGH ABOUT IT!
- 2 DID NOT KNOW IT PERTAINED TO
- 3 HANDLED THROUGH CORPORATE
- 4 THEY DIDN'T KEEP APPT
- 5 HADN'T DECIDED TO PARTICIPAT
- 6 DIDN'T KNOW IT QUALIFIED
- 7 CHOSE ACCORDNG TO CRITERIA
- 8 HAD A NEED AND FILLED IT.
- 9 IT WAS WHAT WE WANTED
- 10 NOT ENOUTH REPLACEMENT NEEDE
- 11 OFFER NOT TEMPTING
- 12 DID NOT BUY NEW LIGHTING!!!
- 13 DIDN'T QUALIFY FOR PROGRAM
- 14 NO PROBLEM W/ CONTRACTOR.
- 15 VOLUNTEERS PROVIDED SERVICE.
- 16 RECIEVED DONATIONS
- 17 I DON'T QUALIFY
- 18 DIND'T KNOW ENOUGH OF PROGRA
- 19 VICTIM OF SCAM
- 20 EQUIPMENT NOT APPROPRIATE
- 21 WAS INSIDE PROGRAM
- 22 NO ONE THOUGHT ABOUT IT
- 23 FORGOT ABOUT PROGRAM
- 24 WENT THROUGH CONTRACTOR

Didn't do prior/Refused

| FR116 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 52 | 100.0 | 52 | 100.0 |

Frequency Missing = 406

Didn't do prior/Don't Know

| FR117 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 45 | 80.4 | 45 | 80.4 |
| Yes | 11 | 19.6 | 56 | 100.0 |

Frequency Missing = 402

How many estimates or quotes B4 purchase

| FR011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 15 | 28.8 | 15 | 28.8 |
| 1 | 13 | 25.0 | 28 | 53.8 |
| 2 | 8 | 15.4 | 36 | 69.2 |
| 3 | 11 | 21.2 | 47 | 90.4 |
| 4 | 3 | 5.8 | 50 | 96.2 |
| 5 | 1 | 1.9 | 51 | 98.1 |
| 9 | 1 | 1.9 | 52 | 100.0 |

Frequency Missing = 406

Get est 4 bth high and stand eff lights?

| FR012 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Yes | 17 | 53.1 | 17 | 53.1 |
| 2 | 4 | 12.5 | 21 | 65.6 |
| 3 | 11 | 34.4 | 32 | 100.0 |

Frequency Missing = 426

number people involved in decision

| FR014 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 19 | 32.8 | 19 | 32.8 |
| 2 | 14 | 24.1 | 33 | 56.9 |
| 3 | 16 | 27.6 | 49 | 84.5 |
| 4 | 3 | 5.2 | 52 | 89.7 |
| 5 | 1 | 1.7 | 53 | 91.4 |
| 6 | 2 | 3.4 | 55 | 94.8 |
| 7 | 1 | 1.7 | 56 | 96.6 |
| 8 | 2 | 3.4 | 58 | 100.0 |

Frequency Missing = 400

Is this person final decision maker

| FR015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 23 | 37.7 | 23 | 37.7 |
| Yes | 38 | 62.3 | 61 | 100.0 |

Frequency Missing = 397

job title of final decision maker

| FR016 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

How active a role do tenants have in dec

| FI065 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Very active | 109 | 56.8 | 109 | 56.8 |
| Somewhat active | 25 | 13.0 | 134 | 69.8 |
| Slight role | 20 | 10.4 | 154 | 80.2 |
| None | 38 | 19.8 | 192 | 100.0 |
| ----- | | | | |
| Frequency Missing = 266 | | | | |

Retorft if 0 rebate/1%<prime financing

| TR030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 178 | 50.7 | 178 | 50.7 |
| Yes | 173 | 49.3 | 351 | 100.0 |
| ----- | | | | |
| Frequency Missing = 107 | | | | |

Retorft if 0 rebate/1.5%<prime financing

| TR040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 157 | 90.2 | 157 | 90.2 |
| Yes | 17 | 9.8 | 174 | 100.0 |
| ----- | | | | |
| Frequency Missing = 284 | | | | |

Retorft if 50% rebate/1%<prime financing

| TR050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 130 | 76.0 | 130 | 76.0 |
| Yes | 41 | 24.0 | 171 | 100.0 |

Frequency Missing = 287

Retorft if 50% rebate/on-site audit

| TR070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 125 | 35.5 | 125 | 35.5 |
| Yes | 227 | 64.5 | 352 | 100.0 |

Frequency Missing = 106

Intrstd in operate/maintain lights

| PR020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| No | 282 | 68.4 | 282 | 68.4 |
| Yes | 75 | 18.2 | 357 | 86.7 |
| Depends on price | 55 | 13.3 | 412 | 100.0 |

Frequency Missing = 46

Intrstd in building recommissioning

| PR040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 115 | 28.8 | 115 | 28.8 |
| Yes | 285 | 71.3 | 400 | 100.0 |

Frequency Missing = 58

Intrstd in future equip selection hlp

| PR060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 135 | 32.7 | 135 | 32.7 |
| Yes | 278 | 67.3 | 413 | 100.0 |

Frequency Missing = 45

Times have contact w/ account rep

| PR001 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 329 | 76.2 | 329 | 76.2 |
| 0.1 | 2 | 0.5 | 331 | 76.6 |
| 0.5 | 3 | 0.7 | 334 | 77.3 |
| 1 | 60 | 13.9 | 394 | 91.2 |
| 2 | 21 | 4.9 | 415 | 96.1 |
| 3 | 8 | 1.9 | 423 | 97.9 |
| 4 | 6 | 1.4 | 429 | 99.3 |
| 5 | 1 | 0.2 | 430 | 99.5 |
| 6 | 2 | 0.5 | 432 | 100.0 |

Frequency Missing = 26

time period have contact w/ account rep

| PR002 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Never | 335 | 76.1 | 335 | 76.1 |
| Week | 2 | 0.5 | 337 | 76.6 |
| Month | 21 | 4.8 | 358 | 81.4 |
| Year | 82 | 18.6 | 440 | 100.0 |

Frequency Missing = 18

Someone else have contact w/ acct rep

| PR005 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 303 | 94.1 | 303 | 94.1 |
| Yes | 19 | 5.9 | 322 | 100.0 |

Frequency Missing = 136

Times other has contact w/ account rep

| PR010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 25.0 | 3 | 25.0 |
| 1 | 7 | 58.3 | 10 | 83.3 |
| 2 | 2 | 16.7 | 12 | 100.0 |

Frequency Missing = 446

time period othr has contct w/ acct rep

| PR011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Month | 1 | 11.1 | 1 | 11.1 |
| Year | 8 | 88.9 | 9 | 100.0 |

Frequency Missing = 449

Any other services would like

| PR090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 299 | 80.6 | 299 | 80.6 |
| Yes | 72 | 19.4 | 371 | 100.0 |

Frequency Missing = 87

Any other services would like

| PR092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 317 | 92.2 | 317 | 92.2 |
| Yes | 27 | 7.8 | 344 | 100.0 |

Frequency Missing = 114

Any other services would like

| PR094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 322 | 94.7 | 322 | 94.7 |
| Yes | 18 | 5.3 | 340 | 100.0 |

Frequency Missing = 118

OBS PR091

1 GOOD IDEA TO TAKE SURVEYS LIKE THESE!
2 EASIER TO REGULATE CENTRAL GAS
3 BROWN OUT--SURGE PROTECTION
4 KISSES
5 WANTS CHANGE IN USAGE STATUS
6 WOULD LIKE HELP FROM PG&E TO INSTALL
7 AIR CONDITION INFORMATION
8 CHEAPER RATES
9 EASE UP A LITTLE UP
10 REBATE AND FINANCING FOR HVAC!
11 PROGRAM W/VERY LOW INTEREST RATES
12 RESPOND TO CUSTOMER REQUESTS TO LOOK
13 HELP SAVE ENERGY/COST
14 MORE KNOWLEGE OF PROGRAMS
15 FREE POWER
16 RATE SUMMARY FOR GAS USAGE
17 EVALUATE AC ZONING (FOR FREE)
18 FIBEROPTIC COMMUNICATION CHANNELS
19 LOWER RATES
20 FREE LIGHTBULB REPLACEMENT
21 SPECIAL RATES FOR NON PROFITS
22 FASTER PAYMENT PROCESSING
23 REBATE IS THE BEST
24 MORE ACCURATE
25 COST FOR 3 PHASE FOR STAND BY
26 EASIER TO GET A HOLD OF
27 LOWER RATES
28 ONE DAY FREE SERVICE
29 ANALYSIS OF WHEN PEAK USE PERIODS ARE.
30 CHEAPER RATES
31 HELP SMALL BUSINESSES SAVE ENERGY BY
32 BETTER EXPLANATION OF BILLS
33 OUR COMPANY SOMETIMES HAS PROBLEMS W/
34 LIST OF SERVICES WILLING PROVIDE
35 ON SITE VISIT TO EXPLAIN EXTERNAL
36 COMPLETE SITE SURVEY TO SUGGEST
37 BILL BASED ON HOURS OF OPERATION
38 QUICKER RESPONSE TO EMERGENCIES
39 ID
40 LOWER RATES
41 CHEEPEER GAS & ELECTRIC BILLS
42 BETTER CONACT WITH REPRESENTATIVES
43 PG&E SHOULD PROVIDE CUSTOMERS WITH
44 LOWER PRICES
45 INFORMATION ABOUT ENERGY SAVINGS
46 NEED CLEARER INFO ABOUT BILLING PROCED
47 TO STOP USING NUCLEAR ENERGY IN CAL.
48 FREE POWER !!!
49 FREQUENT ENERGY EFFICIENCY ADVICE
50 ALTERNATIVES TO AIR CONDITIONING AT A
51 FREE ELECTRICITY!
52 WARNINGS BEFORE POWER SHUTOFF
53 GIVE INFO ON BILL AMT CHANGES -- WHY

OBS PR091

54 INFO ON HVAC
55 CUT DOWN OUT POWER USAGE
56 PHONE WITH HUMAN RESPONDEE
57 TAKE CARE OF TREE GROWTH THAT
58 WARNINGS ABOUT POWER FAILIURES
59 WOULD LIKE ASSISTANCE IN DTERMINING
60 CHEAPER RATES
61 PHAMPLETS
62 ENERGY AUDIT DONE THERE
63 NEED BETTER INFO ON ESTHETIC CONCERNS.
64 JBETTER PUBLICIZE REBATE PROGRAMS
65 WOULD LIKE TO BE ABLE TO SELF VERIFY
66 BETTER STREET LIGHTING
67 REPLACEMENT OF REFLECTIVE WINDOWS
68 HE GETS 5 BILLS NOW AND WONDERS IF
69 WOULD LIKE TO SEE SOMETHING LIKE TIME
70 IMPROVE QUALITY OF POWER IN NEIGHBORHO
71 LARGER TRANSFORMER

OBS PR093

1 ON-SITE INSPECTIONS AND AUDITS TO
2 WE NEED KISSING TO GO ALONG WITH THE S
3 WANTS HELP WITH HIGH VOLTAGE WIRES
4 A LINE TO SOME OUTDOOR LIGHTING THEY
5 AT METERS (POWER SURGES)
6 EVAL EFFICIENCY OF WINDOWS (FOR FREE)
7 MAKE SURE STREET LIGHTING WORKS
8 ALL BILLING SHOULD BE DONE AT THE SAME
9 MORE KNOWLEDGE ABOUT PROGRAMS
10 GOING DIRECTLY TO THEM, HELP THEM
11 COMPUTRS BECAUSE OF POWER FLUCTUATIONS
12 LIGHTING AND TIMING SYSTEM
13 MORE ENERGY EFFICIENCY
14 PROGRAM Z???

15 BILLING CLARIFICATION SERVICE
16 INFORMATION ON SOLAR CELLS, SECONDARY
17 URES
18 NEW TECHNOLOGY UPDATES
19 REDUCED RATE.
20 LOW RATES!
21 THEY ARE CHANGING
22 INTERFERES WITH POWER LINES.
23 WHETHER RTROFITTING IS COST EFFECTIVE
24 USE OF MORE EE BULBS, FOR EXAMPLE
25 METER READING AND POWER USAGE
26 LOW E-VALUE WINDOW REPLACEMENTS
27 THERE IS SOME WAY TO COMPACT THAT INTO
28 OF USE PROGRAM ..TO SEE INCENTIVE TO
29 OOD..
30 DOUBLING OF EXISTING SERVICES

OBS PR095

- 1 SURVEY ELECTRICITY USAGE.
- 2 ANY SAVINGS-AIDS, EE OR OTHERWISE...
- 3 SCREWING
- 4 WOULD LIKE TO INSTALL.
- 5 MORE CONTACT W/REP
- 6 NEED AUDIT FROM PGE INSTEAD OF BROKER
- 7 TIME
- 8 MORE RESPONSIVE, LET THEM KNOW
- 9 CHOOSE AND INSTALL EQUIPMENT
- 10 PG&E COULD HELP OFFER SOLUTIONS
- 11 FREE ELECTRICITY
- 12 MORE FAIR BILLING RATINGS
- 13 LIGHTING AND OTHER ENERGY OPTIONS!
- 14 DISCOUNTS FOR EE EFFORTS BY CUSTOMERS
- 15 MORE EE/REBATE INFO...
- 16 LOWER RATES
- 17 BEFORE SIGNING NEW LEASES
- 18 ONE BILLING STATEMENT
- 19 SAVE ENGERY FOR BUS. DURING PEAK HRS.

More EE info and energy audits

| PR096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Financial Criteria/Payback

| DC010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 147 | 43.4 | 147 | 43.4 |
| Yes | 192 | 56.6 | 339 | 100.0 |

Frequency Missing = 119

Financial Criteria/Internal ROR

| DC011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 250 | 72.9 | 250 | 72.9 |
| Yes | 93 | 27.1 | 343 | 100.0 |

Frequency Missing = 115

Financial Criteria/Net Pres Value

| DC012 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 262 | 75.9 | 262 | 75.9 |
| Yes | 83 | 24.1 | 345 | 100.0 |

Frequency Missing = 113

Financial Criteria/Other

| DC013 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 336 | 90.8 | 336 | 90.8 |
| Yes | 34 | 9.2 | 370 | 100.0 |

Frequency Missing = 88

OBS DC014

1 ?
 2 ESTHETICS DESIGN ISSUES
 3 INITIAL OUTLAY
 4 SAVING MONEY
 5 CASH FLOW
 6 WHAT EVER KEEPS LIGHTS ON
 7 QUALITY OF LIGHTING
 8 DEPENDS ON HOW IT LOOKS!
 9 AVAILABILITY OF EQUIPMENT
 10 SAVINGS
 11 OPERATING COSTS
 12 EFFICIENCY, LONG-TERM COST
 13 COST EFFECTIVENESS
 14 9
 15 IMPROVING LIGHTING
 16 TIME OF PAYBACK, RETURN ON INVE
 17 FUNCTIONALITY
 18 PLEASE VISUAL MERCHANDISERS
 19 MADE BY CORPORATE OFFICE
 20 OPERATING COSTS
 21 COST SAVINGS
 22 VERY COST EFFICIENT
 23 REDUCES LTG. BILL
 24 QUALITY OF LIGHT
 25 BUDGET
 26 AESTHETICS
 27 INITIAL COST OF PROGRAM
 28 INITIAL OUTLAY OF CAS
 29 BASED ON NEED ONLY
 30 EFFICIENCY AND COST
 31 LOOKING AT GENERAL SAVINGS
 32 EQUIPMENT LIFESPAN
 33 COST
 34 IS IT A WISE INVESTMENT

Savings

| DC015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 5 | 100.0 | 5 | 100.0 |

Frequency Missing = 453

Initial cost

| DC016 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 455

Operating cost

| DC017 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1 | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 456

What is payback period

| DC020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 1 yr or < | 37 | 24.7 | 37 | 24.7 |
| 2 yr or < | 56 | 37.3 | 93 | 62.0 |
| 3 yr or < | 21 | 14.0 | 114 | 76.0 |
| 4 yr or < | 5 | 3.3 | 119 | 79.3 |
| 5 yr or < | 18 | 12.0 | 137 | 91.3 |
| 6 yr or < | 1 | 0.7 | 138 | 92.0 |
| 7 yr or < | 3 | 2.0 | 141 | 94.0 |
| 10 yr or < | 1 | 0.7 | 142 | 94.7 |
| Other | 8 | 5.3 | 150 | 100.0 |

Frequency Missing = 308

OBS DC021

- 1 DONT REQUIRE
- 2 DEPENDS ON PURCHASE
- 3 MONTH
- 4 DEPENDS ON COST AND TYPE
- 5 DEPENDS ON EQUIPMENT
- 6 DEPENDS ON PROJECT & COST
- 7 MUST CONSIDER EACH SEPARATELY.
- 8 DEPENDS ON PURCHASE SIZE

What is IROR

| DC030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 3 | 1 | 7.1 | 1 | 7.1 |
| 8 | 1 | 7.1 | 2 | 14.3 |
| 10 | 1 | 7.1 | 3 | 21.4 |
| 12 | 1 | 7.1 | 4 | 28.6 |
| 12.5 | 1 | 7.1 | 5 | 35.7 |
| 15 | 3 | 21.4 | 8 | 57.1 |
| 25 | 2 | 14.3 | 10 | 71.4 |
| 50 | 1 | 7.1 | 11 | 78.6 |
| 99 | 1 | 7.1 | 12 | 85.7 |
| 100 | 2 | 14.3 | 14 | 100.0 |

Frequency Missing = 444

What is discount rate

| DC040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 8 | 1 | 11.1 | 1 | 11.1 |
| 9 | 1 | 11.1 | 2 | 22.2 |
| 11 | 1 | 11.1 | 3 | 33.3 |
| 14.28 | 1 | 11.1 | 4 | 44.4 |
| 15 | 1 | 11.1 | 5 | 55.6 |
| 20 | 2 | 22.2 | 7 | 77.8 |
| 30 | 1 | 11.1 | 8 | 88.9 |
| 99 | 1 | 11.1 | 9 | 100.0 |

Frequency Missing = 449

Use diff financl critera for EE vs other

| DC050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 233 | 75.2 | 233 | 75.2 |
| Yes | 77 | 24.8 | 310 | 100.0 |

Frequency Missing = 148

EE critera high/short or lower/long

| DC051 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Higher/Shorter | 41 | 74.5 | 41 | 74.5 |
| Lower/Longer | 14 | 25.5 | 55 | 100.0 |

Frequency Missing = 403

Any locats of bisns part n RE/CI

| BC021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 385 | 93.7 | 385 | 93.7 |
| 1 | 26 | 6.3 | 411 | 100.0 |

Frequency Missing = 47

Number othr locats part in RE/CI

| BC022 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 3.8 | 1 | 3.8 |
| 1 | 10 | 38.5 | 11 | 42.3 |
| 2 | 7 | 26.9 | 18 | 69.2 |
| 3 | 4 | 15.4 | 22 | 84.6 |
| 5 | 2 | 7.7 | 24 | 92.3 |
| 10 | 1 | 3.8 | 25 | 96.2 |
| 13 | 1 | 3.8 | 26 | 100.0 |

Frequency Missing = 432

Planning any future retrofits

| FR070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 337 | 82.4 | 337 | 82.4 |
| Yes | 72 | 17.6 | 409 | 100.0 |

Frequency Missing = 49

Future lights/high or standard EE

| FR075 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Standard EE | 4 | 6.8 | 4 | 6.8 |
| High EE | 55 | 93.2 | 59 | 100.0 |

Frequency Missing = 399

Future retrofit through program?

| FR077 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 13 | 27.7 | 13 | 27.7 |
| Yes | 34 | 72.3 | 47 | 100.0 |

Frequency Missing = 411

Future Lights/4' T-8

| FR080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 28 | 70.0 | 28 | 70.0 |
| 1 | 1 | 2.5 | 29 | 72.5 |
| 9 | 1 | 2.5 | 30 | 75.0 |
| 46 | 1 | 2.5 | 31 | 77.5 |
| 50 | 2 | 5.0 | 33 | 82.5 |
| 84 | 1 | 2.5 | 34 | 85.0 |
| 100 | 1 | 2.5 | 35 | 87.5 |
| 200 | 1 | 2.5 | 36 | 90.0 |
| 300 | 1 | 2.5 | 37 | 92.5 |
| 1050 | 1 | 2.5 | 38 | 95.0 |
| 3500 | 1 | 2.5 | 39 | 97.5 |
| 10000 | 1 | 2.5 | 40 | 100.0 |

Frequency Missing = 418

Future Lights/8' T-8

| FR081 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 33 | 84.6 | 33 | 84.6 |
| 4 | 1 | 2.6 | 34 | 87.2 |
| 9 | 1 | 2.6 | 35 | 89.7 |
| 50 | 1 | 2.6 | 36 | 92.3 |
| 75 | 1 | 2.6 | 37 | 94.9 |
| 100 | 1 | 2.6 | 38 | 97.4 |
| 770 | 1 | 2.6 | 39 | 100.0 |

Frequency Missing = 419

Future Lights/4' ES Fluor

| FR082 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 33 | 91.7 | 33 | 91.7 |
| 9 | 1 | 2.8 | 34 | 94.4 |
| 40 | 1 | 2.8 | 35 | 97.2 |
| 200 | 1 | 2.8 | 36 | 100.0 |

Frequency Missing = 422

Future Lights/8' ES Fluor

| FR083 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 35 | 97.2 | 35 | 97.2 |
| 9 | 1 | 2.8 | 36 | 100.0 |

Frequency Missing = 422

Future Lights/4' T-12

| FR084 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 35 | 97.2 | 35 | 97.2 |
| 9 | 1 | 2.8 | 36 | 100.0 |

Frequency Missing = 422

Future Lights/8' T-12

| FR085 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 34 | 94.4 | 34 | 94.4 |
| 6 | 1 | 2.8 | 35 | 97.2 |
| 9 | 1 | 2.8 | 36 | 100.0 |

Frequency Missing = 422

Future Lights/Incandescent

| FR086 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 36 | 97.3 | 36 | 97.3 |
| 9 | 1 | 2.7 | 37 | 100.0 |

Frequency Missing = 421

Future Lights/Compact Fluor

| FR087 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 34 | 82.9 | 34 | 82.9 |
| 3 | 1 | 2.4 | 35 | 85.4 |
| 9 | 1 | 2.4 | 36 | 87.8 |
| 50 | 1 | 2.4 | 37 | 90.2 |
| 180 | 1 | 2.4 | 38 | 92.7 |
| 200 | 2 | 4.9 | 40 | 97.6 |
| 400 | 1 | 2.4 | 41 | 100.0 |

Frequency Missing = 417

Future Lights/High pres sodium

| FR088 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 30 | 76.9 | 30 | 76.9 |
| 1 | 1 | 2.6 | 31 | 79.5 |
| 8 | 1 | 2.6 | 32 | 82.1 |
| 9 | 1 | 2.6 | 33 | 84.6 |
| 14 | 1 | 2.6 | 34 | 87.2 |
| 17 | 1 | 2.6 | 35 | 89.7 |
| 30 | 2 | 5.1 | 37 | 94.9 |
| 40 | 1 | 2.6 | 38 | 97.4 |
| 159 | 1 | 2.6 | 39 | 100.0 |

Frequency Missing = 419

Future Lights/Elec Ballasts

| FR089 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 32 | 84.2 | 32 | 84.2 |
| 9 | 1 | 2.6 | 33 | 86.8 |
| 120 | 1 | 2.6 | 34 | 89.5 |
| 345 | 1 | 2.6 | 35 | 92.1 |
| 778 | 1 | 2.6 | 36 | 94.7 |
| 3500 | 1 | 2.6 | 37 | 97.4 |
| 10000 | 1 | 2.6 | 38 | 100.0 |

Frequency Missing = 420

Future Lights/Magnetic Ballasts

| FR090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 35 | 94.6 | 35 | 94.6 |
| 4 | 1 | 2.7 | 36 | 97.3 |
| 9 | 1 | 2.7 | 37 | 100.0 |

Frequency Missing = 421

Future Lights/Metal Halide

| FR091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 34 | 94.4 | 34 | 94.4 |
| 9 | 1 | 2.8 | 35 | 97.2 |
| 12 | 1 | 2.8 | 36 | 100.0 |

Frequency Missing = 422

Future Lights/Mercury Vapor

| FR092 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 34 | 89.5 | 34 | 89.5 |
| 9 | 1 | 2.6 | 35 | 92.1 |
| 12 | 1 | 2.6 | 36 | 94.7 |
| 30 | 1 | 2.6 | 37 | 97.4 |
| 100 | 1 | 2.6 | 38 | 100.0 |

Frequency Missing = 420

Future Lights/Quartz

| FR093 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 36 | 90.0 | 36 | 90.0 |
| 1 | 1 | 2.5 | 37 | 92.5 |
| 9 | 1 | 2.5 | 38 | 95.0 |
| 12 | 1 | 2.5 | 39 | 97.5 |
| 20 | 1 | 2.5 | 40 | 100.0 |

Frequency Missing = 418

Future Lights/Reflectors

| FR094 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 39 | 92.9 | 39 | 92.9 |
| 9 | 1 | 2.4 | 40 | 95.2 |
| 2000 | 1 | 2.4 | 41 | 97.6 |
| 3500 | 1 | 2.4 | 42 | 100.0 |

Frequency Missing = 416

Future Lights/LED Exit Lights

| FR095 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 38 | 92.7 | 38 | 92.7 |
| 1 | 1 | 2.4 | 39 | 95.1 |
| 9 | 1 | 2.4 | 40 | 97.6 |
| 12 | 1 | 2.4 | 41 | 100.0 |

Frequency Missing = 417

Future Lights/Watt Saver-Power Choke

| FR096 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 40 | 100.0 | 40 | 100.0 |

Frequency Missing = 418

Future Lights/Other

| FR097 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 31 | 72.1 | 31 | 72.1 |
| 1 | 7 | 16.3 | 38 | 88.4 |
| 9 | 1 | 2.3 | 39 | 90.7 |
| 10 | 1 | 2.3 | 40 | 93.0 |
| 28 | 1 | 2.3 | 41 | 95.3 |
| 36 | 1 | 2.3 | 42 | 97.7 |
| 300 | 1 | 2.3 | 43 | 100.0 |

Frequency Missing = 415

OBS FR098

1 EARLY PLANNING STAGE
2 EARLY PLANNING STAGE
3 HAVEN'T DECIDED
4 CENSORED CONTROLLEC
5 CHANGE TO NEW LIGHT SOCKET
6 WOULD HAVE TO TALK TO PG&E
7 HALOGEN??
8 METAL ARC LAMPS
9 COST EFFECTIVE \$\$\$
10 LOW VOLTAGE BULBS
11 9
12 UNSPECIFIED FLOUR

Future Lights/Refused

| FR099R | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 45 | 100.0 | 45 | 100.0 |

Frequency Missing = 413

Future Lights/Don't Know

| FR099D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 0 | 25 | 100.0 | 25 | 100.0 |

Frequency Missing = 433

Main business activity

| BC011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Office | 91 | 20.8 | 91 | 20.8 |
| Retail (no-food) | 53 | 12.1 | 144 | 33.0 |
| Manuf/Assmbly | 7 | 1.6 | 151 | 34.6 |
| Warehouse | 10 | 2.3 | 161 | 36.8 |
| Restaurant | 21 | 4.8 | 182 | 41.6 |
| Grocery Store | 13 | 3.0 | 195 | 44.6 |
| School | 33 | 7.6 | 228 | 52.2 |
| Hotel/Motel | 31 | 7.1 | 259 | 59.3 |
| Hospital | 1 | 0.2 | 260 | 59.5 |
| Collg/Univ | 4 | 0.9 | 264 | 60.4 |
| Health Care | 10 | 2.3 | 274 | 62.7 |
| Municipalnty | 2 | 0.5 | 276 | 63.2 |
| Indust procss | 3 | 0.7 | 279 | 63.8 |
| Other | 158 | 36.2 | 437 | 100.0 |

Frequency Missing = 21

OBS BC012

- 1 AIRCRAFT MAINTENANCE
- 2 SOCIAL CLUB
- 3 ALL LEASED SPACE
- 4 RENTAL
- 5 MEETING OF GIRL SCOUTS
- 6 APARTMENT RENTALS
- 7 APARTMENT
- 8 CHURCH LIBRARY
- 9 CHURCH HALL
- 10 LEGAL SERVICES
- 11 CONSTRUCTION, GEOTECHNICAL
- 12 THEATRE
- 13 TESTING & INSPECTIONS
- 14 RADIO STATION
- 15 RADIO STATION
- 16 UNION OFFICE
- 17 MEETINGS
- 18 MEETING & BANDQUET & SPA FACIL.
- 19 BANKING
- 20 HELICOPTER OPERATIONS
- 21 RADIO STATIONS
- 22 RADIO BROADCASTING
- 23 APARTMENT BUILDING
- 24 LABOR UNION
- 25 AGRICULTURAL CONSULTING&TESTING
- 26 ENGINEERING AND TESTING
- 27 CHILD CARE
- 28 ALCOHOL AND DRUG DETOX
- 29 RV PARK
- 30 DAY CARE CENTER
- 31 TRANSPORTATION
- 32 SR. CITIZEN RESIDENCE
- 33 SPACE RENTAL 4 SPECIAL OCCASION
- 34 RESEARCH & DEVELOPMENT
- 35 R&
- 36 CREDIT UNION
- 37 MARINA BOAT STORAGE FACILITY
- 38 OFFICE AND MEALS FOR HOMELESS
- 39 TV BROADCASTING
- 40 TRANSMITTER SITE
- 41 MISSION
- 42 BUSINESS SERVICES
- 43 SHIP PILOTING STATION
- 44 TRAINING, WAREHOUSE, ADMIN.
- 45 LIBRARY
- 46 CHAPEL
- 47 REPAIR ELECTRIC MOTORS
- 48 DISTRIBUTION
- 49 HARDWARE/CLEANING GEAR
- 50 BEAUTY SALON
- 51 SERVICE COMPANY
- 52 BARBER SHOP
- 53 MASSAGE

OBS BC012

54 HAIR SALON
55 EDUCATION
56 VIDIO PRODUCTION
57 SHIRT LAUNDRY, DRY CLEANING
58 ALSO BEAUTY SERVICES
59 TRAVEL AGENCY
60 SELLING ANTIQUES
61 PHOTOGRAPHY
62 LAUNDRY MAT
63 LEASE AND SELL DUMPSTERS
64 BICYCLE SHOP
65 AUTO BODY/PAINTING
66 DISPATCH CENTER/TOW TRUCK SVCS
67 AUTO REPAIR
68 ATTORNEY SUPPORT GROUP
69 RENT EQUIPMENT
70 SALEA AND SERVICE
71 TRANSPORTATION BROKER
72 FRUIT PROCESSING
73 LUMBER YARD
74 PHOTO FINISHING
75 LUMBER DISTRIBUTION
76 PHARMACY
77 SERVICE STATION
78 SERVICE STATION
79 PARKING GARAGE
80 PARTS SALES
81 TRUCKING AND CRANE SERVIC
82 TRUCKING COMPANY
83 AUTO SVCS AND GASOLINE
84 SERVICE STATION
85 SERVICE STATION
86 CLEANERS
87 MANUFACTURING
88 COLLISION REPAIR
89 HARDWARE
90 FAMILY ENTERTAINMENT
91 BAR, COFFEE SHOP, & BOWLING CTR
92 TRUCKING
93 TRUCK STOP /RETAIL
94 CAR DEALER
95 AUTO DEALERSHIP
96 ENTERTAINMENT-MOVIE THEATRE
97 UNOCAL GAS/CARWASH
98 EMPLOYING PEOPLE
99 BOWLING CENTER
100 TRUCK STOP
101 FOOD AND VENDING COMPANY
102 SELL LUMBER BUILDING
103 RETREADING TRUCK TIRES
104 PHARMACY
105 AUTO ELECTRICAL REBUILDER
106 CAR WASH/GAS STATION

| | |
|-----|---------------------------------|
| OBS | BC012 |
| 107 | AUTO BODY |
| 108 | MOVIE THEATRE |
| 109 | PARKING FACILITY |
| 110 | MALL |
| 111 | TIRE SALES/RETREAD |
| 112 | BOWLING ALLEY |
| 113 | OFFICE PRODUCTS DISTRIBUTION |
| 114 | PARKING SERVICE |
| 115 | GOLF COURSE |
| 116 | LAUNDRY STORE |
| 117 | CAR WASH |
| 118 | GOLF COURSE |
| 119 | SCHOOL |
| 120 | SCHOOL |
| 121 | CHURC |
| 122 | SCHOOL |
| 123 | LIQUOR AND CONVENIENCE STORE |
| 124 | BAKERY |
| 125 | BAKERY |
| 126 | MEAT SALES |
| 127 | DELI BAKERY |
| 128 | PIZZA PRODUCTION |
| 129 | MEAT PROCESSING PLANT |
| 130 | LIQUOR STORE |
| 131 | RETAIL FISH AND POULTRY |
| 132 | BAKERY |
| 133 | WHOLESALE BAKERY |
| 134 | COCKTAIL LOUNGE |
| 135 | BAR |
| 136 | NIGHTCLUB |
| 137 | BLUES CLUB |
| 138 | BAR |
| 139 | CONCERT HALL |
| 140 | EVENT PRODUCTION |
| 141 | SPORTS BAR |
| 142 | NIGHTCLUB |
| 143 | NIGHTCLUB |
| 144 | BOWLING! |
| 145 | DENTAL |
| 146 | REST HOME |
| 147 | PLASTIC SURGERY |
| 148 | COUNTRY CLUB |
| 149 | LABORATORY & OFFICE |
| 150 | HEALTH CLUB & CHIROPRACTIC |
| 151 | WOMAN'S GYM |
| 152 | CONVALESENT HOME\HOSP |
| 153 | YACHT CLUB |
| 154 | MEDICAL LAB |
| 155 | OUTPATIENT SURGERY |
| 156 | FITNESS CLUB |
| 157 | RV PARK |
| 158 | RENT RV SITES OVERNIGHT. |
| 159 | EXPORT COMPANY FOR BLDG MATERIA |

OBS BC012

160 WRECKING YARD
 161 WHOLESALE PRODUCE
 162 RECYCLE OPERATION
 163 INDUS. EQUIP RENTAL
 164 WHOLESALE MEAT
 165 DISTRIBUTION FACILITY
 166 WHOLESALE MEAT
 167 WHOLESALE PRODUCE
 168 SALE CASH REGISTER
 169 WHOLESALE PRODUCE
 170 SHIP * RECEIV AUTO WAREHOUSE
 171 RESTAURANT SUPPLY SALES
 172 BUS REPAIR
 173 DISTRIBUTION
 174 TRANSMISSION TOWER
 175 INDUS/COMMER SUPPLY COMPANY
 176 GROWERS, PACKER, & SHIPPERS

Since Jan1992, size changed

| FC110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Increasd space | 29 | 6.5 | 29 | 6.5 |
| Decreasd space | 2 | 0.4 | 31 | 6.9 |
| Stayed same | 416 | 93.1 | 447 | 100.0 |

Frequency Missing = 11

Area of size change

| FC120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
| 32 | 1 | 3.8 | 1 | 3.8 |
| 200 | 1 | 3.8 | 2 | 7.7 |
| 400 | 1 | 3.8 | 3 | 11.5 |
| 450 | 1 | 3.8 | 4 | 15.4 |
| 500 | 1 | 3.8 | 5 | 19.2 |
| 800 | 1 | 3.8 | 6 | 23.1 |
| 1000 | 1 | 3.8 | 7 | 26.9 |
| 1200 | 1 | 3.8 | 8 | 30.8 |
| 1500 | 1 | 3.8 | 9 | 34.6 |
| 1600 | 1 | 3.8 | 10 | 38.5 |
| 1800 | 2 | 7.7 | 12 | 46.2 |
| 2000 | 1 | 3.8 | 13 | 50.0 |
| 2400 | 1 | 3.8 | 14 | 53.8 |
| 2500 | 2 | 7.7 | 16 | 61.5 |
| 2700 | 1 | 3.8 | 17 | 65.4 |
| 3000 | 2 | 7.7 | 19 | 73.1 |
| 5000 | 1 | 3.8 | 20 | 76.9 |
| 6000 | 1 | 3.8 | 21 | 80.8 |
| 8000 | 2 | 7.7 | 23 | 88.5 |
| 9000 | 1 | 3.8 | 24 | 92.3 |
| 15000 | 1 | 3.8 | 25 | 96.2 |
| 500000 | 1 | 3.8 | 26 | 100.0 |

Frequency Missing = 432

Month/Year of area change

| FC130 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| FEB1992 | 1 | 10.0 | 1 | 10.0 |
| AUG1992 | 1 | 10.0 | 2 | 20.0 |
| OCT1992 | 1 | 10.0 | 3 | 30.0 |
| JAN1993 | 1 | 10.0 | 4 | 40.0 |
| APR1993 | 1 | 10.0 | 5 | 50.0 |
| AUG1993 | 1 | 10.0 | 6 | 60.0 |
| NOV1994 | 1 | 10.0 | 7 | 70.0 |
| JAN1995 | 1 | 10.0 | 8 | 80.0 |
| MAY1995 | 1 | 10.0 | 9 | 90.0 |
| JUL1995 | 1 | 10.0 | 10 | 100.0 |

Frequency Missing = 448

Year of area change

| FC131 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 3 | 21.4 | 3 | 21.4 |
| 1993 | 5 | 35.7 | 8 | 57.1 |
| 1994 | 4 | 28.6 | 12 | 85.7 |
| 1995 | 2 | 14.3 | 14 | 100.0 |

Frequency Missing = 444

Month/Year of area increase occupied

| FC140 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| NOV1992 | 1 | 10.0 | 1 | 10.0 |
| JAN1993 | 1 | 10.0 | 2 | 20.0 |
| MAR1993 | 1 | 10.0 | 3 | 30.0 |
| APR1993 | 1 | 10.0 | 4 | 40.0 |
| AUG1994 | 1 | 10.0 | 5 | 50.0 |
| NOV1994 | 1 | 10.0 | 6 | 60.0 |
| APR1995 | 1 | 10.0 | 7 | 70.0 |
| MAY1995 | 1 | 10.0 | 8 | 80.0 |
| AUG1995 | 1 | 10.0 | 9 | 90.0 |
| SEP1995 | 1 | 10.0 | 10 | 100.0 |

Frequency Missing = 448

Year of area increase occupied

| FC141 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 3 | 27.3 | 3 | 27.3 |
| 1993 | 5 | 45.5 | 8 | 72.7 |
| 1994 | 2 | 18.2 | 10 | 90.9 |
| 1995 | 1 | 9.1 | 11 | 100.0 |

Frequency Missing = 447

Month/Year of last major space remodel

| FR033 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1970 | 1 | 2.0 | 1 | 2.0 |
| AUG1980 | 1 | 2.0 | 2 | 4.1 |
| JUL1981 | 1 | 2.0 | 3 | 6.1 |
| MAR1988 | 1 | 2.0 | 4 | 8.2 |
| FEB1989 | 1 | 2.0 | 5 | 10.2 |
| MAR1989 | 1 | 2.0 | 6 | 12.2 |
| OCT1989 | 1 | 2.0 | 7 | 14.3 |
| DEC1989 | 1 | 2.0 | 8 | 16.3 |
| APR1990 | 1 | 2.0 | 9 | 18.4 |
| JUN1990 | 1 | 2.0 | 10 | 20.4 |
| SEP1990 | 1 | 2.0 | 11 | 22.4 |
| JUL1991 | 1 | 2.0 | 12 | 24.5 |
| OCT1991 | 1 | 2.0 | 13 | 26.5 |
| JAN1992 | 1 | 2.0 | 14 | 28.6 |
| FEB1992 | 1 | 2.0 | 15 | 30.6 |
| JUN1992 | 1 | 2.0 | 16 | 32.7 |
| AUG1992 | 2 | 4.1 | 18 | 36.7 |
| JAN1993 | 1 | 2.0 | 19 | 38.8 |
| MAY1993 | 1 | 2.0 | 20 | 40.8 |
| AUG1993 | 3 | 6.1 | 23 | 46.9 |
| FEB1994 | 1 | 2.0 | 24 | 49.0 |
| MAR1994 | 2 | 4.1 | 26 | 53.1 |
| MAY1994 | 1 | 2.0 | 27 | 55.1 |
| JUN1994 | 1 | 2.0 | 28 | 57.1 |
| JUL1994 | 3 | 6.1 | 31 | 63.3 |
| AUG1994 | 1 | 2.0 | 32 | 65.3 |
| OCT1994 | 2 | 4.1 | 34 | 69.4 |
| DEC1994 | 1 | 2.0 | 35 | 71.4 |
| JAN1995 | 2 | 4.1 | 37 | 75.5 |
| FEB1995 | 3 | 6.1 | 40 | 81.6 |
| APR1995 | 1 | 2.0 | 41 | 83.7 |
| MAY1995 | 1 | 2.0 | 42 | 85.7 |
| JUN1995 | 3 | 6.1 | 45 | 91.8 |
| JUL1995 | 4 | 8.2 | 49 | 100.0 |

Frequency Missing = 409

Year of last major space remodel

| FR034 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| 0 | 1 | 0.3 | 1 | 0.3 |
| Never remodded | 197 | 57.9 | 198 | 58.2 |
| 10 | 1 | 0.3 | 199 | 58.5 |
| 85 | 1 | 0.3 | 200 | 58.8 |
| 1954 | 1 | 0.3 | 201 | 59.1 |
| 1956 | 2 | 0.6 | 203 | 59.7 |
| 1965 | 1 | 0.3 | 204 | 60.0 |
| 1970 | 3 | 0.9 | 207 | 60.9 |
| 1971 | 1 | 0.3 | 208 | 61.2 |
| 1973 | 2 | 0.6 | 210 | 61.8 |
| 1975 | 1 | 0.3 | 211 | 62.1 |
| 1978 | 1 | 0.3 | 212 | 62.4 |
| 1979 | 3 | 0.9 | 215 | 63.2 |
| 1980 | 5 | 1.5 | 220 | 64.7 |
| 1982 | 1 | 0.3 | 221 | 65.0 |
| 1983 | 1 | 0.3 | 222 | 65.3 |
| 1984 | 2 | 0.6 | 224 | 65.9 |
| 1985 | 14 | 4.1 | 238 | 70.0 |
| 1986 | 5 | 1.5 | 243 | 71.5 |
| 1987 | 4 | 1.2 | 247 | 72.6 |
| 1988 | 7 | 2.1 | 254 | 74.7 |
| 1989 | 14 | 4.1 | 268 | 78.8 |
| 1990 | 7 | 2.1 | 275 | 80.9 |
| 1991 | 8 | 2.4 | 283 | 83.2 |
| 1992 | 20 | 5.9 | 303 | 89.1 |
| 1993 | 16 | 4.7 | 319 | 93.8 |
| 1994 | 12 | 3.5 | 331 | 97.4 |
| 1995 | 9 | 2.6 | 340 | 100.0 |

Frequency Missing = 118

Did remodel cover space retrofitted

| FR035 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 38 | 58.5 | 38 | 58.5 |
| Yes | 27 | 41.5 | 65 | 100.0 |

Frequency Missing = 393

light hours/from: Dec Week

| LF1F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 65 | 14.9 | 65 | 14.9 |
| 1:00 | 4 | 0.9 | 69 | 15.9 |
| 2:00 | 3 | 0.7 | 72 | 16.6 |
| 3:00 | 1 | 0.2 | 73 | 16.8 |
| 4:00 | 2 | 0.5 | 75 | 17.2 |
| 4:30 | 1 | 0.2 | 76 | 17.5 |
| 5:00 | 11 | 2.5 | 87 | 20.0 |
| 5:15 | 1 | 0.2 | 88 | 20.2 |
| 5:30 | 3 | 0.7 | 91 | 20.9 |
| 6:00 | 37 | 8.5 | 128 | 29.4 |
| 6:30 | 13 | 3.0 | 141 | 32.4 |
| 6:45 | 2 | 0.5 | 143 | 32.9 |
| 7:00 | 58 | 13.3 | 201 | 46.2 |
| 7:30 | 26 | 6.0 | 227 | 52.2 |
| 7:45 | 1 | 0.2 | 228 | 52.4 |
| 8:00 | 83 | 19.1 | 311 | 71.5 |
| 8:15 | 2 | 0.5 | 313 | 72.0 |
| 8:30 | 25 | 5.7 | 338 | 77.7 |
| 9:00 | 43 | 9.9 | 381 | 87.6 |
| 9:14 | 1 | 0.2 | 382 | 87.8 |
| 9:30 | 5 | 1.1 | 387 | 89.0 |
| 10:00 | 26 | 6.0 | 413 | 94.9 |
| 11:00 | 9 | 2.1 | 422 | 97.0 |
| 11:30 | 1 | 0.2 | 423 | 97.2 |
| 12:00 | 2 | 0.5 | 425 | 97.7 |
| 13:30 | 1 | 0.2 | 426 | 97.9 |
| 14:00 | 1 | 0.2 | 427 | 98.2 |
| 15:00 | 2 | 0.5 | 429 | 98.6 |
| 16:00 | 1 | 0.2 | 430 | 98.9 |
| 16:30 | 1 | 0.2 | 431 | 99.1 |
| 18:00 | 1 | 0.2 | 432 | 99.3 |
| 19:30 | 1 | 0.2 | 433 | 99.5 |
| 24:00 | 2 | 0.5 | 435 | 100.0 |

Frequency Missing = 23

light hours/from: Dec Sat

| LF2F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 230 | 54.8 | 230 | 54.8 |
| 1:00 | 3 | 0.7 | 233 | 55.5 |
| 2:00 | 1 | 0.2 | 234 | 55.7 |
| 4:00 | 1 | 0.2 | 235 | 56.0 |
| 4:30 | 1 | 0.2 | 236 | 56.2 |
| 5:00 | 4 | 1.0 | 240 | 57.1 |
| 5:30 | 1 | 0.2 | 241 | 57.4 |
| 6:00 | 18 | 4.3 | 259 | 61.7 |
| 6:30 | 3 | 0.7 | 262 | 62.4 |
| 7:00 | 22 | 5.2 | 284 | 67.6 |
| 7:30 | 2 | 0.5 | 286 | 68.1 |
| 8:00 | 38 | 9.0 | 324 | 77.1 |
| 8:30 | 6 | 1.4 | 330 | 78.6 |
| 9:00 | 33 | 7.9 | 363 | 86.4 |
| 9:14 | 1 | 0.2 | 364 | 86.7 |
| 9:30 | 7 | 1.7 | 371 | 88.3 |
| 10:00 | 25 | 6.0 | 396 | 94.3 |
| 11:00 | 10 | 2.4 | 406 | 96.7 |
| 12:00 | 4 | 1.0 | 410 | 97.6 |
| 13:00 | 1 | 0.2 | 411 | 97.9 |
| 14:00 | 1 | 0.2 | 412 | 98.1 |
| 16:00 | 2 | 0.5 | 414 | 98.6 |
| 16:30 | 1 | 0.2 | 415 | 98.8 |
| 19:30 | 1 | 0.2 | 416 | 99.0 |
| 24:00 | 4 | 1.0 | 420 | 100.0 |

Frequency Missing = 38

light hours/from: Dec Sun

| LF3F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 287 | 68.8 | 287 | 68.8 |
| 1:00 | 3 | 0.7 | 290 | 69.5 |
| 2:00 | 1 | 0.2 | 291 | 69.8 |
| 4:00 | 1 | 0.2 | 292 | 70.0 |
| 5:00 | 3 | 0.7 | 295 | 70.7 |
| 5:30 | 1 | 0.2 | 296 | 71.0 |
| 6:00 | 16 | 3.8 | 312 | 74.8 |
| 6:30 | 2 | 0.5 | 314 | 75.3 |
| 7:00 | 15 | 3.6 | 329 | 78.9 |
| 8:00 | 13 | 3.1 | 342 | 82.0 |
| 8:30 | 4 | 1.0 | 346 | 83.0 |
| 9:00 | 16 | 3.8 | 362 | 86.8 |
| 10:00 | 23 | 5.5 | 385 | 92.3 |
| 11:00 | 14 | 3.4 | 399 | 95.7 |
| 11:30 | 2 | 0.5 | 401 | 96.2 |
| 12:00 | 5 | 1.2 | 406 | 97.4 |
| 13:00 | 1 | 0.2 | 407 | 97.6 |
| 14:00 | 1 | 0.2 | 408 | 97.8 |
| 16:00 | 1 | 0.2 | 409 | 98.1 |
| 16:30 | 1 | 0.2 | 410 | 98.3 |
| 17:00 | 1 | 0.2 | 411 | 98.6 |
| 19:30 | 1 | 0.2 | 412 | 98.8 |
| 23:00 | 1 | 0.2 | 413 | 99.0 |
| 24:00 | 4 | 1.0 | 417 | 100.0 |

Frequency Missing = 41

light hours/from: Apr Week

| LF4F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 54 | 13.3 | 54 | 13.3 |
| 1:00 | 4 | 1.0 | 58 | 14.3 |
| 2:00 | 3 | 0.7 | 61 | 15.0 |
| 3:00 | 1 | 0.2 | 62 | 15.3 |
| 4:00 | 2 | 0.5 | 64 | 15.8 |
| 4:30 | 1 | 0.2 | 65 | 16.0 |
| 5:00 | 11 | 2.7 | 76 | 18.7 |
| 5:15 | 1 | 0.2 | 77 | 19.0 |
| 5:30 | 2 | 0.5 | 79 | 19.5 |
| 6:00 | 33 | 8.1 | 112 | 27.6 |
| 6:30 | 13 | 3.2 | 125 | 30.8 |
| 6:45 | 1 | 0.2 | 126 | 31.0 |
| 7:00 | 58 | 14.3 | 184 | 45.3 |
| 7:30 | 26 | 6.4 | 210 | 51.7 |
| 7:45 | 1 | 0.2 | 211 | 52.0 |
| 8:00 | 79 | 19.5 | 290 | 71.4 |
| 8:15 | 2 | 0.5 | 292 | 71.9 |
| 8:30 | 23 | 5.7 | 315 | 77.6 |
| 9:00 | 40 | 9.9 | 355 | 87.4 |
| 9:14 | 1 | 0.2 | 356 | 87.7 |
| 9:30 | 4 | 1.0 | 360 | 88.7 |
| 10:00 | 26 | 6.4 | 386 | 95.1 |
| 11:00 | 8 | 2.0 | 394 | 97.0 |
| 11:30 | 1 | 0.2 | 395 | 97.3 |
| 12:00 | 2 | 0.5 | 397 | 97.8 |
| 14:00 | 1 | 0.2 | 398 | 98.0 |
| 15:00 | 2 | 0.5 | 400 | 98.5 |
| 18:00 | 2 | 0.5 | 402 | 99.0 |
| 18:30 | 1 | 0.2 | 403 | 99.3 |
| 19:30 | 1 | 0.2 | 404 | 99.5 |
| 24:00 | 2 | 0.5 | 406 | 100.0 |

Frequency Missing = 52

light hours/from: Apr Sat

| LF5F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 223 | 55.5 | 223 | 55.5 |
| 1:00 | 3 | 0.7 | 226 | 56.2 |
| 2:00 | 1 | 0.2 | 227 | 56.5 |
| 4:00 | 1 | 0.2 | 228 | 56.7 |
| 4:30 | 1 | 0.2 | 229 | 57.0 |
| 5:00 | 4 | 1.0 | 233 | 58.0 |
| 5:30 | 1 | 0.2 | 234 | 58.2 |
| 6:00 | 15 | 3.7 | 249 | 61.9 |
| 6:30 | 3 | 0.7 | 252 | 62.7 |
| 7:00 | 23 | 5.7 | 275 | 68.4 |
| 7:30 | 2 | 0.5 | 277 | 68.9 |
| 8:00 | 36 | 9.0 | 313 | 77.9 |
| 8:30 | 6 | 1.5 | 319 | 79.4 |
| 9:00 | 31 | 7.7 | 350 | 87.1 |
| 9:14 | 1 | 0.2 | 351 | 87.3 |
| 9:30 | 5 | 1.2 | 356 | 88.6 |
| 10:00 | 24 | 6.0 | 380 | 94.5 |
| 11:00 | 9 | 2.2 | 389 | 96.8 |
| 12:00 | 3 | 0.7 | 392 | 97.5 |
| 13:00 | 1 | 0.2 | 393 | 97.8 |
| 14:00 | 1 | 0.2 | 394 | 98.0 |
| 16:00 | 1 | 0.2 | 395 | 98.3 |
| 18:00 | 1 | 0.2 | 396 | 98.5 |
| 18:30 | 1 | 0.2 | 397 | 98.8 |
| 19:30 | 1 | 0.2 | 398 | 99.0 |
| 24:00 | 4 | 1.0 | 402 | 100.0 |

Frequency Missing = 56

light hours/from: Apr Sun

| LF6F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 279 | 69.9 | 279 | 69.9 |
| 1:00 | 3 | 0.8 | 282 | 70.7 |
| 2:00 | 1 | 0.3 | 283 | 70.9 |
| 4:00 | 1 | 0.3 | 284 | 71.2 |
| 5:00 | 3 | 0.8 | 287 | 71.9 |
| 5:30 | 1 | 0.3 | 288 | 72.2 |
| 6:00 | 11 | 2.8 | 299 | 74.9 |
| 6:30 | 2 | 0.5 | 301 | 75.4 |
| 7:00 | 15 | 3.8 | 316 | 79.2 |
| 8:00 | 13 | 3.3 | 329 | 82.5 |
| 8:30 | 4 | 1.0 | 333 | 83.5 |
| 9:00 | 16 | 4.0 | 349 | 87.5 |
| 10:00 | 21 | 5.3 | 370 | 92.7 |
| 11:00 | 15 | 3.8 | 385 | 96.5 |
| 11:30 | 1 | 0.3 | 386 | 96.7 |
| 12:00 | 4 | 1.0 | 390 | 97.7 |
| 13:00 | 1 | 0.3 | 391 | 98.0 |
| 14:00 | 1 | 0.3 | 392 | 98.2 |
| 17:00 | 1 | 0.3 | 393 | 98.5 |
| 18:00 | 1 | 0.3 | 394 | 98.7 |
| 18:30 | 1 | 0.3 | 395 | 99.0 |
| 19:30 | 1 | 0.3 | 396 | 99.2 |
| 24:00 | 3 | 0.8 | 399 | 100.0 |

Frequency Missing = 59

light hours/from: Aug Week

| LF7F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 56 | 14.0 | 56 | 14.0 |
| 1:00 | 4 | 1.0 | 60 | 15.0 |
| 2:00 | 3 | 0.7 | 63 | 15.7 |
| 3:00 | 1 | 0.2 | 64 | 16.0 |
| 4:00 | 2 | 0.5 | 66 | 16.5 |
| 4:30 | 1 | 0.2 | 67 | 16.7 |
| 5:00 | 11 | 2.7 | 78 | 19.5 |
| 5:15 | 1 | 0.2 | 79 | 19.7 |
| 5:30 | 2 | 0.5 | 81 | 20.2 |
| 6:00 | 33 | 8.2 | 114 | 28.4 |
| 6:30 | 13 | 3.2 | 127 | 31.7 |
| 6:45 | 1 | 0.2 | 128 | 31.9 |
| 7:00 | 57 | 14.2 | 185 | 46.1 |
| 7:30 | 27 | 6.7 | 212 | 52.9 |
| 7:45 | 1 | 0.2 | 213 | 53.1 |
| 8:00 | 75 | 18.7 | 288 | 71.8 |
| 8:15 | 1 | 0.2 | 289 | 72.1 |
| 8:30 | 24 | 6.0 | 313 | 78.1 |
| 9:00 | 39 | 9.7 | 352 | 87.8 |
| 9:14 | 1 | 0.2 | 353 | 88.0 |
| 9:30 | 3 | 0.7 | 356 | 88.8 |
| 10:00 | 25 | 6.2 | 381 | 95.0 |
| 11:00 | 8 | 2.0 | 389 | 97.0 |
| 11:30 | 1 | 0.2 | 390 | 97.3 |
| 12:00 | 2 | 0.5 | 392 | 97.8 |
| 14:00 | 1 | 0.2 | 393 | 98.0 |
| 15:00 | 2 | 0.5 | 395 | 98.5 |
| 18:00 | 1 | 0.2 | 396 | 98.8 |
| 19:30 | 1 | 0.2 | 397 | 99.0 |
| 20:00 | 1 | 0.2 | 398 | 99.3 |
| 20:15 | 1 | 0.2 | 399 | 99.5 |
| 24:00 | 2 | 0.5 | 401 | 100.0 |

Frequency Missing = 57

light hours/from: Aug Sat

| LF8F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 223 | 55.8 | 223 | 55.8 |
| 1:00 | 3 | 0.8 | 226 | 56.5 |
| 2:00 | 1 | 0.3 | 227 | 56.8 |
| 4:00 | 1 | 0.3 | 228 | 57.0 |
| 4:30 | 1 | 0.3 | 229 | 57.3 |
| 5:00 | 4 | 1.0 | 233 | 58.3 |
| 5:30 | 1 | 0.3 | 234 | 58.5 |
| 6:00 | 14 | 3.5 | 248 | 62.0 |
| 6:30 | 3 | 0.8 | 251 | 62.8 |
| 7:00 | 22 | 5.5 | 273 | 68.3 |
| 7:30 | 3 | 0.8 | 276 | 69.0 |
| 8:00 | 36 | 9.0 | 312 | 78.0 |
| 8:30 | 6 | 1.5 | 318 | 79.5 |
| 9:00 | 30 | 7.5 | 348 | 87.0 |
| 9:14 | 1 | 0.3 | 349 | 87.3 |
| 9:30 | 5 | 1.3 | 354 | 88.5 |
| 10:00 | 24 | 6.0 | 378 | 94.5 |
| 11:00 | 9 | 2.3 | 387 | 96.8 |
| 12:00 | 3 | 0.8 | 390 | 97.5 |
| 13:00 | 1 | 0.3 | 391 | 97.8 |
| 14:00 | 1 | 0.3 | 392 | 98.0 |
| 16:00 | 1 | 0.3 | 393 | 98.3 |
| 19:30 | 1 | 0.3 | 394 | 98.5 |
| 20:00 | 1 | 0.3 | 395 | 98.8 |
| 20:15 | 1 | 0.3 | 396 | 99.0 |
| 24:00 | 4 | 1.0 | 400 | 100.0 |

Frequency Missing = 58

light hours/from: Aug Sun

| LF9F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 279 | 69.9 | 279 | 69.9 |
| 1:00 | 3 | 0.8 | 282 | 70.7 |
| 2:00 | 1 | 0.3 | 283 | 70.9 |
| 4:00 | 1 | 0.3 | 284 | 71.2 |
| 5:00 | 3 | 0.8 | 287 | 71.9 |
| 5:30 | 1 | 0.3 | 288 | 72.2 |
| 6:00 | 11 | 2.8 | 299 | 74.9 |
| 6:30 | 2 | 0.5 | 301 | 75.4 |
| 7:00 | 15 | 3.8 | 316 | 79.2 |
| 7:30 | 1 | 0.3 | 317 | 79.4 |
| 8:00 | 12 | 3.0 | 329 | 82.5 |
| 8:30 | 4 | 1.0 | 333 | 83.5 |
| 9:00 | 16 | 4.0 | 349 | 87.5 |
| 10:00 | 21 | 5.3 | 370 | 92.7 |
| 11:00 | 15 | 3.8 | 385 | 96.5 |
| 11:30 | 1 | 0.3 | 386 | 96.7 |
| 12:00 | 4 | 1.0 | 390 | 97.7 |
| 13:00 | 1 | 0.3 | 391 | 98.0 |
| 14:00 | 1 | 0.3 | 392 | 98.2 |
| 17:00 | 1 | 0.3 | 393 | 98.5 |
| 19:30 | 1 | 0.3 | 394 | 98.7 |
| 20:00 | 1 | 0.3 | 395 | 99.0 |
| 20:15 | 1 | 0.3 | 396 | 99.2 |
| 24:00 | 3 | 0.8 | 399 | 100.0 |

Frequency Missing = 59

light hours/from: Oct Week

| LF10F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 53 | 13.3 | 53 | 13.3 |
| 1:00 | 4 | 1.0 | 57 | 14.3 |
| 2:00 | 3 | 0.8 | 60 | 15.0 |
| 3:00 | 1 | 0.3 | 61 | 15.3 |
| 4:00 | 2 | 0.5 | 63 | 15.8 |
| 4:30 | 1 | 0.3 | 64 | 16.0 |
| 5:00 | 11 | 2.8 | 75 | 18.8 |
| 5:15 | 1 | 0.3 | 76 | 19.0 |
| 5:30 | 2 | 0.5 | 78 | 19.5 |
| 6:00 | 32 | 8.0 | 110 | 27.5 |
| 6:30 | 13 | 3.3 | 123 | 30.8 |
| 6:45 | 1 | 0.3 | 124 | 31.0 |
| 7:00 | 58 | 14.5 | 182 | 45.5 |
| 7:30 | 25 | 6.3 | 207 | 51.8 |
| 7:45 | 1 | 0.3 | 208 | 52.0 |
| 8:00 | 80 | 20.0 | 288 | 72.0 |
| 8:15 | 2 | 0.5 | 290 | 72.5 |
| 8:30 | 22 | 5.5 | 312 | 78.0 |
| 9:00 | 39 | 9.8 | 351 | 87.8 |
| 9:14 | 1 | 0.3 | 352 | 88.0 |
| 9:30 | 3 | 0.8 | 355 | 88.8 |
| 10:00 | 25 | 6.3 | 380 | 95.0 |
| 11:00 | 8 | 2.0 | 388 | 97.0 |
| 11:30 | 1 | 0.3 | 389 | 97.3 |
| 12:00 | 2 | 0.5 | 391 | 97.8 |
| 14:00 | 1 | 0.3 | 392 | 98.0 |
| 15:00 | 2 | 0.5 | 394 | 98.5 |
| 18:00 | 2 | 0.5 | 396 | 99.0 |
| 18:30 | 1 | 0.3 | 397 | 99.3 |
| 19:30 | 1 | 0.3 | 398 | 99.5 |
| 24:00 | 2 | 0.5 | 400 | 100.0 |

Frequency Missing = 58

light hours/from: Oct Sat

| LF11F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 222 | 55.8 | 222 | 55.8 |
| 1:00 | 3 | 0.8 | 225 | 56.5 |
| 2:00 | 1 | 0.3 | 226 | 56.8 |
| 4:00 | 1 | 0.3 | 227 | 57.0 |
| 4:30 | 1 | 0.3 | 228 | 57.3 |
| 5:00 | 3 | 0.8 | 231 | 58.0 |
| 5:30 | 1 | 0.3 | 232 | 58.3 |
| 6:00 | 15 | 3.8 | 247 | 62.1 |
| 6:30 | 3 | 0.8 | 250 | 62.8 |
| 7:00 | 22 | 5.5 | 272 | 68.3 |
| 7:30 | 2 | 0.5 | 274 | 68.8 |
| 8:00 | 37 | 9.3 | 311 | 78.1 |
| 8:30 | 6 | 1.5 | 317 | 79.6 |
| 9:00 | 29 | 7.3 | 346 | 86.9 |
| 9:14 | 1 | 0.3 | 347 | 87.2 |
| 9:30 | 5 | 1.3 | 352 | 88.4 |
| 10:00 | 24 | 6.0 | 376 | 94.5 |
| 11:00 | 9 | 2.3 | 385 | 96.7 |
| 12:00 | 3 | 0.8 | 388 | 97.5 |
| 13:00 | 1 | 0.3 | 389 | 97.7 |
| 14:00 | 1 | 0.3 | 390 | 98.0 |
| 16:00 | 1 | 0.3 | 391 | 98.2 |
| 18:00 | 1 | 0.3 | 392 | 98.5 |
| 18:30 | 1 | 0.3 | 393 | 98.7 |
| 19:30 | 1 | 0.3 | 394 | 99.0 |
| 24:00 | 4 | 1.0 | 398 | 100.0 |

Frequency Missing = 60

light hours/from: Oct Sun

| LF12F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 277 | 69.8 | 277 | 69.8 |
| 1:00 | 3 | 0.8 | 280 | 70.5 |
| 2:00 | 1 | 0.3 | 281 | 70.8 |
| 4:00 | 1 | 0.3 | 282 | 71.0 |
| 5:00 | 2 | 0.5 | 284 | 71.5 |
| 5:30 | 1 | 0.3 | 285 | 71.8 |
| 6:00 | 11 | 2.8 | 296 | 74.6 |
| 6:30 | 2 | 0.5 | 298 | 75.1 |
| 7:00 | 15 | 3.8 | 313 | 78.8 |
| 8:00 | 13 | 3.3 | 326 | 82.1 |
| 8:30 | 4 | 1.0 | 330 | 83.1 |
| 9:00 | 17 | 4.3 | 347 | 87.4 |
| 10:00 | 21 | 5.3 | 368 | 92.7 |
| 11:00 | 15 | 3.8 | 383 | 96.5 |
| 11:30 | 1 | 0.3 | 384 | 96.7 |
| 12:00 | 4 | 1.0 | 388 | 97.7 |
| 13:00 | 1 | 0.3 | 389 | 98.0 |
| 14:00 | 1 | 0.3 | 390 | 98.2 |
| 17:00 | 1 | 0.3 | 391 | 98.5 |
| 18:00 | 1 | 0.3 | 392 | 98.7 |
| 18:30 | 1 | 0.3 | 393 | 99.0 |
| 19:30 | 1 | 0.3 | 394 | 99.2 |
| 24:00 | 3 | 0.8 | 397 | 100.0 |

Frequency Missing = 61

light hours/from: Holiday

| LF13F | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 321 | 77.9 | 321 | 77.9 |
| 1:00 | 3 | 0.7 | 324 | 78.6 |
| 3:00 | 1 | 0.2 | 325 | 78.9 |
| 4:00 | 1 | 0.2 | 326 | 79.1 |
| 5:00 | 2 | 0.5 | 328 | 79.6 |
| 5:30 | 1 | 0.2 | 329 | 79.9 |
| 6:00 | 11 | 2.7 | 340 | 82.5 |
| 6:30 | 3 | 0.7 | 343 | 83.3 |
| 7:00 | 11 | 2.7 | 354 | 85.9 |
| 7:30 | 2 | 0.5 | 356 | 86.4 |
| 8:00 | 9 | 2.2 | 365 | 88.6 |
| 8:30 | 4 | 1.0 | 369 | 89.6 |
| 9:00 | 13 | 3.2 | 382 | 92.7 |
| 10:00 | 11 | 2.7 | 393 | 95.4 |
| 11:00 | 8 | 1.9 | 401 | 97.3 |
| 12:00 | 1 | 0.2 | 402 | 97.6 |
| 13:00 | 1 | 0.2 | 403 | 97.8 |
| 14:00 | 1 | 0.2 | 404 | 98.1 |
| 15:00 | 1 | 0.2 | 405 | 98.3 |
| 16:00 | 1 | 0.2 | 406 | 98.5 |
| 18:00 | 1 | 0.2 | 407 | 98.8 |
| 18:30 | 1 | 0.2 | 408 | 99.0 |
| 19:30 | 1 | 0.2 | 409 | 99.3 |
| 24:00 | 3 | 0.7 | 412 | 100.0 |

Frequency Missing = 46

light hours/am or pm: Dec Week

| LF1M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 425 | 97.0 | 425 | 97.0 |
| D | 3 | 0.7 | 428 | 97.7 |
| P | 10 | 2.3 | 438 | 100.0 |

Frequency Missing = 20

light hours/am or pm: Dec Sat

| LF2M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 410 | 96.9 | 410 | 96.9 |
| D | 3 | 0.7 | 413 | 97.6 |
| P | 10 | 2.4 | 423 | 100.0 |

Frequency Missing = 35

light hours/am or pm: Dec Sun

| LF3M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 405 | 96.4 | 405 | 96.4 |
| D | 3 | 0.7 | 408 | 97.1 |
| P | 12 | 2.9 | 420 | 100.0 |

Frequency Missing = 38

light hours/am or pm: Apr Week

| LF4M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 396 | 97.1 | 396 | 97.1 |
| D | 3 | 0.7 | 399 | 97.8 |
| P | 9 | 2.2 | 408 | 100.0 |

Frequency Missing = 50

light hours/am or pm: Apr Sat

| LF5M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 393 | 97.0 | 393 | 97.0 |
| D | 3 | 0.7 | 396 | 97.8 |
| P | 9 | 2.2 | 405 | 100.0 |

Frequency Missing = 53

light hours/am or pm: Apr Sun

| LF6M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 389 | 96.5 | 389 | 96.5 |
| D | 4 | 1.0 | 393 | 97.5 |
| P | 10 | 2.5 | 403 | 100.0 |

Frequency Missing = 55

light hours/am or pm: Aug Week

| LF7M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 392 | 97.3 | 392 | 97.3 |
| D | 2 | 0.5 | 394 | 97.8 |
| P | 9 | 2.2 | 403 | 100.0 |

Frequency Missing = 55

light hours/am or pm: Aug Sat

| LF8M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 391 | 97.3 | 391 | 97.3 |
| D | 2 | 0.5 | 393 | 97.8 |
| P | 9 | 2.2 | 402 | 100.0 |

Frequency Missing = 56

light hours/am or pm: Aug Sun

| LF9M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 389 | 96.8 | 389 | 96.8 |
| D | 3 | 0.7 | 392 | 97.5 |
| P | 10 | 2.5 | 402 | 100.0 |

Frequency Missing = 56

light hours/am or pm: Oct Week

| LF10M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 391 | 97.3 | 391 | 97.3 |
| D | 2 | 0.5 | 393 | 97.8 |
| P | 9 | 2.2 | 402 | 100.0 |

Frequency Missing = 56

light hours/am or pm: Oct Sat

| LF11M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 389 | 97.3 | 389 | 97.3 |
| D | 2 | 0.5 | 391 | 97.8 |
| P | 9 | 2.3 | 400 | 100.0 |

Frequency Missing = 58

light hours/am or pm: Oct Sun

| LF12M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 387 | 96.8 | 387 | 96.8 |
| D | 3 | 0.8 | 390 | 97.5 |
| P | 10 | 2.5 | 400 | 100.0 |

Frequency Missing = 58

light hours/am or pm: Holiday

| LF13M | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 404 | 96.2 | 404 | 96.2 |
| D | 8 | 1.9 | 412 | 98.1 |
| P | 8 | 1.9 | 420 | 100.0 |

Frequency Missing = 38

light hours/to: Dec Week

| LF1T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 2 | 0.5 | 2 | 0.5 |
| 1:00 | 5 | 1.1 | 7 | 1.6 |
| 2:00 | 16 | 3.7 | 23 | 5.3 |
| 3:00 | 1 | 0.2 | 24 | 5.5 |
| 6:00 | 1 | 0.2 | 25 | 5.7 |
| 6:30 | 1 | 0.2 | 26 | 6.0 |
| 7:00 | 2 | 0.5 | 28 | 6.4 |
| 7:30 | 1 | 0.2 | 29 | 6.7 |
| 12:00 | 3 | 0.7 | 32 | 7.4 |
| 12:30 | 1 | 0.2 | 33 | 7.6 |
| 13:00 | 1 | 0.2 | 34 | 7.8 |
| 13:30 | 2 | 0.5 | 36 | 8.3 |
| 14:00 | 4 | 0.9 | 40 | 9.2 |
| 14:30 | 1 | 0.2 | 41 | 9.4 |
| 15:00 | 4 | 0.9 | 45 | 10.3 |
| 15:30 | 5 | 1.1 | 50 | 11.5 |
| 16:00 | 13 | 3.0 | 63 | 14.5 |
| 16:30 | 18 | 4.1 | 81 | 18.6 |
| 16:45 | 1 | 0.2 | 82 | 18.9 |
| 17:00 | 87 | 20.0 | 169 | 38.9 |
| 17:30 | 23 | 5.3 | 192 | 44.1 |
| 17:45 | 1 | 0.2 | 193 | 44.4 |
| 18:00 | 58 | 13.3 | 251 | 57.7 |
| 18:30 | 9 | 2.1 | 260 | 59.8 |
| 19:00 | 29 | 6.7 | 289 | 66.4 |
| 19:30 | 1 | 0.2 | 290 | 66.7 |
| 20:00 | 13 | 3.0 | 303 | 69.7 |
| 20:30 | 2 | 0.5 | 305 | 70.1 |
| 21:00 | 20 | 4.6 | 325 | 74.7 |
| 21:30 | 1 | 0.2 | 326 | 74.9 |
| 22:00 | 18 | 4.1 | 344 | 79.1 |
| 22:30 | 1 | 0.2 | 345 | 79.3 |
| 23:00 | 12 | 2.8 | 357 | 82.1 |
| 23:30 | 2 | 0.5 | 359 | 82.5 |
| 24:00 | 76 | 17.5 | 435 | 100.0 |

Frequency Missing = 23

light hours/to: Dec Sat

| LF2T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 177 | 42.1 | 177 | 42.1 |
| 1:00 | 7 | 1.7 | 184 | 43.8 |
| 2:00 | 17 | 4.0 | 201 | 47.9 |
| 3:00 | 2 | 0.5 | 203 | 48.3 |
| 6:00 | 1 | 0.2 | 204 | 48.6 |
| 7:00 | 2 | 0.5 | 206 | 49.0 |
| 7:30 | 1 | 0.2 | 207 | 49.3 |
| 9:00 | 1 | 0.2 | 208 | 49.5 |
| 11:00 | 1 | 0.2 | 209 | 49.8 |
| 12:00 | 14 | 3.3 | 223 | 53.1 |
| 12:30 | 1 | 0.2 | 224 | 53.3 |
| 13:00 | 6 | 1.4 | 230 | 54.8 |
| 13:30 | 1 | 0.2 | 231 | 55.0 |
| 14:00 | 10 | 2.4 | 241 | 57.4 |
| 15:00 | 4 | 1.0 | 245 | 58.3 |
| 15:30 | 2 | 0.5 | 247 | 58.8 |
| 16:00 | 2 | 0.5 | 249 | 59.3 |
| 16:30 | 1 | 0.2 | 250 | 59.5 |
| 17:00 | 18 | 4.3 | 268 | 63.8 |
| 17:30 | 3 | 0.7 | 271 | 64.5 |
| 17:45 | 1 | 0.2 | 272 | 64.8 |
| 18:00 | 26 | 6.2 | 298 | 71.0 |
| 18:30 | 7 | 1.7 | 305 | 72.6 |
| 19:00 | 15 | 3.6 | 320 | 76.2 |
| 19:30 | 1 | 0.2 | 321 | 76.4 |
| 20:00 | 9 | 2.1 | 330 | 78.6 |
| 20:30 | 1 | 0.2 | 331 | 78.8 |
| 21:00 | 12 | 2.9 | 343 | 81.7 |
| 22:00 | 6 | 1.4 | 349 | 83.1 |
| 22:30 | 1 | 0.2 | 350 | 83.3 |
| 23:00 | 7 | 1.7 | 357 | 85.0 |
| 23:30 | 2 | 0.5 | 359 | 85.5 |
| 24:00 | 61 | 14.5 | 420 | 100.0 |

Frequency Missing = 38

light hours/to: Dec Sun

| LF3T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 234 | 56.3 | 234 | 56.3 |
| 1:00 | 4 | 1.0 | 238 | 57.2 |
| 2:00 | 16 | 3.8 | 254 | 61.1 |
| 3:00 | 1 | 0.2 | 255 | 61.3 |
| 6:00 | 1 | 0.2 | 256 | 61.5 |
| 7:00 | 2 | 0.5 | 258 | 62.0 |
| 7:30 | 1 | 0.2 | 259 | 62.3 |
| 12:00 | 9 | 2.2 | 268 | 64.4 |
| 13:00 | 4 | 1.0 | 272 | 65.4 |
| 13:30 | 1 | 0.2 | 273 | 65.6 |
| 14:00 | 5 | 1.2 | 278 | 66.8 |
| 15:00 | 3 | 0.7 | 281 | 67.5 |
| 16:00 | 2 | 0.5 | 283 | 68.0 |
| 17:00 | 16 | 3.8 | 299 | 71.9 |
| 17:30 | 1 | 0.2 | 300 | 72.1 |
| 18:00 | 17 | 4.1 | 317 | 76.2 |
| 18:30 | 2 | 0.5 | 319 | 76.7 |
| 19:00 | 12 | 2.9 | 331 | 79.6 |
| 19:30 | 1 | 0.2 | 332 | 79.8 |
| 20:00 | 4 | 1.0 | 336 | 80.8 |
| 20:30 | 1 | 0.2 | 337 | 81.0 |
| 21:00 | 7 | 1.7 | 344 | 82.7 |
| 22:00 | 6 | 1.4 | 350 | 84.1 |
| 22:30 | 1 | 0.2 | 351 | 84.4 |
| 23:00 | 8 | 1.9 | 359 | 86.3 |
| 23:30 | 2 | 0.5 | 361 | 86.8 |
| 24:00 | 55 | 13.2 | 416 | 100.0 |

Frequency Missing = 42

light hours/to: Apr Week

| LF4T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 1 | 0.2 | 1 | 0.2 |
| 1:00 | 4 | 1.0 | 5 | 1.2 |
| 2:00 | 15 | 3.7 | 20 | 4.9 |
| 3:00 | 1 | 0.2 | 21 | 5.2 |
| 6:00 | 2 | 0.5 | 23 | 5.7 |
| 6:30 | 1 | 0.2 | 24 | 5.9 |
| 7:00 | 1 | 0.2 | 25 | 6.2 |
| 7:30 | 1 | 0.2 | 26 | 6.4 |
| 12:00 | 6 | 1.5 | 32 | 7.9 |
| 12:30 | 1 | 0.2 | 33 | 8.1 |
| 13:00 | 1 | 0.2 | 34 | 8.4 |
| 13:30 | 2 | 0.5 | 36 | 8.9 |
| 14:00 | 4 | 1.0 | 40 | 9.9 |
| 14:30 | 1 | 0.2 | 41 | 10.1 |
| 15:00 | 3 | 0.7 | 44 | 10.9 |
| 15:30 | 5 | 1.2 | 49 | 12.1 |
| 16:00 | 13 | 3.2 | 62 | 15.3 |
| 16:30 | 17 | 4.2 | 79 | 19.5 |
| 16:45 | 1 | 0.2 | 80 | 19.8 |
| 17:00 | 81 | 20.0 | 161 | 39.8 |
| 17:30 | 21 | 5.2 | 182 | 44.9 |
| 17:45 | 1 | 0.2 | 183 | 45.2 |
| 18:00 | 57 | 14.1 | 240 | 59.3 |
| 18:30 | 8 | 2.0 | 248 | 61.2 |
| 19:00 | 28 | 6.9 | 276 | 68.1 |
| 19:30 | 1 | 0.2 | 277 | 68.4 |
| 20:00 | 12 | 3.0 | 289 | 71.4 |
| 20:30 | 2 | 0.5 | 291 | 71.9 |
| 21:00 | 19 | 4.7 | 310 | 76.5 |
| 21:30 | 2 | 0.5 | 312 | 77.0 |
| 22:00 | 18 | 4.4 | 330 | 81.5 |
| 22:30 | 1 | 0.2 | 331 | 81.7 |
| 23:00 | 12 | 3.0 | 343 | 84.7 |
| 23:30 | 1 | 0.2 | 344 | 84.9 |
| 24:00 | 61 | 15.1 | 405 | 100.0 |

Frequency Missing = 53

light hours/to: Apr Sat

| LF5T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 168 | 41.8 | 168 | 41.8 |
| 1:00 | 7 | 1.7 | 175 | 43.5 |
| 2:00 | 16 | 4.0 | 191 | 47.5 |
| 3:00 | 2 | 0.5 | 193 | 48.0 |
| 6:00 | 2 | 0.5 | 195 | 48.5 |
| 7:00 | 1 | 0.2 | 196 | 48.8 |
| 7:30 | 1 | 0.2 | 197 | 49.0 |
| 9:00 | 1 | 0.2 | 198 | 49.3 |
| 11:00 | 1 | 0.2 | 199 | 49.5 |
| 12:00 | 14 | 3.5 | 213 | 53.0 |
| 12:30 | 1 | 0.2 | 214 | 53.2 |
| 13:00 | 5 | 1.2 | 219 | 54.5 |
| 13:30 | 1 | 0.2 | 220 | 54.7 |
| 14:00 | 9 | 2.2 | 229 | 57.0 |
| 15:00 | 5 | 1.2 | 234 | 58.2 |
| 15:30 | 2 | 0.5 | 236 | 58.7 |
| 16:00 | 2 | 0.5 | 238 | 59.2 |
| 16:30 | 1 | 0.2 | 239 | 59.5 |
| 17:00 | 15 | 3.7 | 254 | 63.2 |
| 17:30 | 3 | 0.7 | 257 | 63.9 |
| 17:45 | 1 | 0.2 | 258 | 64.2 |
| 18:00 | 26 | 6.5 | 284 | 70.6 |
| 18:30 | 6 | 1.5 | 290 | 72.1 |
| 19:00 | 13 | 3.2 | 303 | 75.4 |
| 19:30 | 1 | 0.2 | 304 | 75.6 |
| 20:00 | 8 | 2.0 | 312 | 77.6 |
| 20:30 | 1 | 0.2 | 313 | 77.9 |
| 21:00 | 13 | 3.2 | 326 | 81.1 |
| 22:00 | 7 | 1.7 | 333 | 82.8 |
| 22:30 | 1 | 0.2 | 334 | 83.1 |
| 23:00 | 6 | 1.5 | 340 | 84.6 |
| 23:30 | 1 | 0.2 | 341 | 84.8 |
| 24:00 | 61 | 15.2 | 402 | 100.0 |

Frequency Missing = 56

light hours/to: Apr Sun

| LF6T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 225 | 56.4 | 225 | 56.4 |
| 1:00 | 4 | 1.0 | 229 | 57.4 |
| 2:00 | 15 | 3.8 | 244 | 61.2 |
| 3:00 | 1 | 0.3 | 245 | 61.4 |
| 6:00 | 2 | 0.5 | 247 | 61.9 |
| 7:00 | 1 | 0.3 | 248 | 62.2 |
| 7:30 | 1 | 0.3 | 249 | 62.4 |
| 12:00 | 8 | 2.0 | 257 | 64.4 |
| 13:00 | 4 | 1.0 | 261 | 65.4 |
| 13:30 | 1 | 0.3 | 262 | 65.7 |
| 14:00 | 5 | 1.3 | 267 | 66.9 |
| 15:00 | 3 | 0.8 | 270 | 67.7 |
| 16:00 | 2 | 0.5 | 272 | 68.2 |
| 17:00 | 11 | 2.8 | 283 | 70.9 |
| 17:30 | 1 | 0.3 | 284 | 71.2 |
| 18:00 | 17 | 4.3 | 301 | 75.4 |
| 18:30 | 2 | 0.5 | 303 | 75.9 |
| 19:00 | 10 | 2.5 | 313 | 78.4 |
| 19:30 | 1 | 0.3 | 314 | 78.7 |
| 20:00 | 4 | 1.0 | 318 | 79.7 |
| 20:30 | 1 | 0.3 | 319 | 79.9 |
| 21:00 | 7 | 1.8 | 326 | 81.7 |
| 22:00 | 8 | 2.0 | 334 | 83.7 |
| 22:30 | 1 | 0.3 | 335 | 84.0 |
| 23:00 | 7 | 1.8 | 342 | 85.7 |
| 23:30 | 2 | 0.5 | 344 | 86.2 |
| 24:00 | 55 | 13.8 | 399 | 100.0 |

Frequency Missing = 59

light hours/to: Aug Week

| LF7T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 4 | 1.0 | 4 | 1.0 |
| 1:00 | 4 | 1.0 | 8 | 2.0 |
| 2:00 | 16 | 4.0 | 24 | 6.0 |
| 3:00 | 1 | 0.2 | 25 | 6.2 |
| 6:00 | 1 | 0.2 | 26 | 6.5 |
| 6:15 | 1 | 0.2 | 27 | 6.7 |
| 6:30 | 1 | 0.2 | 28 | 7.0 |
| 7:00 | 1 | 0.2 | 29 | 7.2 |
| 7:30 | 1 | 0.2 | 30 | 7.5 |
| 12:00 | 6 | 1.5 | 36 | 9.0 |
| 12:30 | 2 | 0.5 | 38 | 9.5 |
| 13:00 | 1 | 0.2 | 39 | 9.7 |
| 13:30 | 3 | 0.7 | 42 | 10.5 |
| 14:00 | 4 | 1.0 | 46 | 11.5 |
| 15:00 | 4 | 1.0 | 50 | 12.5 |
| 15:30 | 5 | 1.2 | 55 | 13.7 |
| 16:00 | 13 | 3.2 | 68 | 17.0 |
| 16:30 | 14 | 3.5 | 82 | 20.4 |
| 16:45 | 1 | 0.2 | 83 | 20.7 |
| 17:00 | 77 | 19.2 | 160 | 39.9 |
| 17:30 | 22 | 5.5 | 182 | 45.4 |
| 17:45 | 1 | 0.2 | 183 | 45.6 |
| 18:00 | 56 | 14.0 | 239 | 59.6 |
| 18:30 | 8 | 2.0 | 247 | 61.6 |
| 19:00 | 28 | 7.0 | 275 | 68.6 |
| 19:30 | 2 | 0.5 | 277 | 69.1 |
| 20:00 | 12 | 3.0 | 289 | 72.1 |
| 20:30 | 2 | 0.5 | 291 | 72.6 |
| 21:00 | 16 | 4.0 | 307 | 76.6 |
| 21:30 | 2 | 0.5 | 309 | 77.1 |
| 22:00 | 18 | 4.5 | 327 | 81.5 |
| 22:30 | 1 | 0.2 | 328 | 81.8 |
| 23:00 | 12 | 3.0 | 340 | 84.8 |
| 23:30 | 1 | 0.2 | 341 | 85.0 |
| 24:00 | 60 | 15.0 | 401 | 100.0 |

Frequency Missing = 57

light hours/to: Aug Sat

| LF8T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 167 | 41.8 | 167 | 41.8 |
| 1:00 | 7 | 1.8 | 174 | 43.5 |
| 2:00 | 17 | 4.3 | 191 | 47.8 |
| 3:00 | 2 | 0.5 | 193 | 48.3 |
| 6:00 | 1 | 0.3 | 194 | 48.5 |
| 6:15 | 1 | 0.3 | 195 | 48.8 |
| 7:00 | 1 | 0.3 | 196 | 49.0 |
| 7:30 | 1 | 0.3 | 197 | 49.3 |
| 9:00 | 1 | 0.3 | 198 | 49.5 |
| 11:00 | 1 | 0.3 | 199 | 49.8 |
| 12:00 | 14 | 3.5 | 213 | 53.3 |
| 12:30 | 1 | 0.3 | 214 | 53.5 |
| 13:00 | 5 | 1.3 | 219 | 54.8 |
| 13:30 | 1 | 0.3 | 220 | 55.0 |
| 14:00 | 9 | 2.3 | 229 | 57.3 |
| 15:00 | 4 | 1.0 | 233 | 58.3 |
| 15:30 | 2 | 0.5 | 235 | 58.8 |
| 16:00 | 2 | 0.5 | 237 | 59.3 |
| 16:30 | 1 | 0.3 | 238 | 59.5 |
| 17:00 | 14 | 3.5 | 252 | 63.0 |
| 17:30 | 3 | 0.8 | 255 | 63.8 |
| 17:45 | 1 | 0.3 | 256 | 64.0 |
| 18:00 | 25 | 6.3 | 281 | 70.3 |
| 18:30 | 6 | 1.5 | 287 | 71.8 |
| 19:00 | 13 | 3.3 | 300 | 75.0 |
| 19:30 | 2 | 0.5 | 302 | 75.5 |
| 20:00 | 8 | 2.0 | 310 | 77.5 |
| 20:30 | 1 | 0.3 | 311 | 77.8 |
| 21:00 | 11 | 2.8 | 322 | 80.5 |
| 22:00 | 7 | 1.8 | 329 | 82.3 |
| 22:30 | 1 | 0.3 | 330 | 82.5 |
| 23:00 | 7 | 1.8 | 337 | 84.3 |
| 23:30 | 1 | 0.3 | 338 | 84.5 |
| 24:00 | 62 | 15.5 | 400 | 100.0 |

Frequency Missing = 58

light hours/to: Aug Sun

| LF9T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 224 | 56.1 | 224 | 56.1 |
| 1:00 | 4 | 1.0 | 228 | 57.1 |
| 2:00 | 16 | 4.0 | 244 | 61.2 |
| 3:00 | 1 | 0.3 | 245 | 61.4 |
| 6:00 | 1 | 0.3 | 246 | 61.7 |
| 6:15 | 1 | 0.3 | 247 | 61.9 |
| 7:00 | 1 | 0.3 | 248 | 62.2 |
| 7:30 | 1 | 0.3 | 249 | 62.4 |
| 12:00 | 8 | 2.0 | 257 | 64.4 |
| 13:00 | 4 | 1.0 | 261 | 65.4 |
| 13:30 | 1 | 0.3 | 262 | 65.7 |
| 14:00 | 5 | 1.3 | 267 | 66.9 |
| 15:00 | 3 | 0.8 | 270 | 67.7 |
| 16:00 | 2 | 0.5 | 272 | 68.2 |
| 17:00 | 11 | 2.8 | 283 | 70.9 |
| 17:30 | 1 | 0.3 | 284 | 71.2 |
| 18:00 | 16 | 4.0 | 300 | 75.2 |
| 18:30 | 2 | 0.5 | 302 | 75.7 |
| 19:00 | 10 | 2.5 | 312 | 78.2 |
| 19:30 | 2 | 0.5 | 314 | 78.7 |
| 20:00 | 4 | 1.0 | 318 | 79.7 |
| 20:30 | 1 | 0.3 | 319 | 79.9 |
| 21:00 | 6 | 1.5 | 325 | 81.5 |
| 22:00 | 7 | 1.8 | 332 | 83.2 |
| 22:30 | 1 | 0.3 | 333 | 83.5 |
| 23:00 | 8 | 2.0 | 341 | 85.5 |
| 23:30 | 2 | 0.5 | 343 | 86.0 |
| 24:00 | 56 | 14.0 | 399 | 100.0 |

Frequency Missing = 59

light hours/to: Oct Week

| LF10T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 1 | 0.3 | 1 | 0.3 |
| 1:00 | 4 | 1.0 | 5 | 1.3 |
| 2:00 | 15 | 3.8 | 20 | 5.0 |
| 3:00 | 1 | 0.3 | 21 | 5.3 |
| 6:00 | 2 | 0.5 | 23 | 5.8 |
| 6:30 | 1 | 0.3 | 24 | 6.0 |
| 7:00 | 1 | 0.3 | 25 | 6.3 |
| 7:30 | 1 | 0.3 | 26 | 6.5 |
| 12:00 | 6 | 1.5 | 32 | 8.0 |
| 12:30 | 1 | 0.3 | 33 | 8.3 |
| 13:00 | 1 | 0.3 | 34 | 8.5 |
| 13:30 | 2 | 0.5 | 36 | 9.0 |
| 14:00 | 4 | 1.0 | 40 | 10.0 |
| 14:30 | 1 | 0.3 | 41 | 10.3 |
| 15:00 | 3 | 0.8 | 44 | 11.0 |
| 15:30 | 5 | 1.3 | 49 | 12.3 |
| 16:00 | 13 | 3.3 | 62 | 15.5 |
| 16:30 | 17 | 4.3 | 79 | 19.8 |
| 16:45 | 1 | 0.3 | 80 | 20.0 |
| 17:00 | 82 | 20.5 | 162 | 40.5 |
| 17:30 | 20 | 5.0 | 182 | 45.5 |
| 17:45 | 1 | 0.3 | 183 | 45.8 |
| 18:00 | 54 | 13.5 | 237 | 59.3 |
| 18:30 | 8 | 2.0 | 245 | 61.3 |
| 19:00 | 28 | 7.0 | 273 | 68.3 |
| 19:30 | 1 | 0.3 | 274 | 68.5 |
| 20:00 | 12 | 3.0 | 286 | 71.5 |
| 20:30 | 2 | 0.5 | 288 | 72.0 |
| 21:00 | 17 | 4.3 | 305 | 76.3 |
| 21:30 | 2 | 0.5 | 307 | 76.8 |
| 22:00 | 19 | 4.8 | 326 | 81.5 |
| 22:30 | 1 | 0.3 | 327 | 81.8 |
| 23:00 | 12 | 3.0 | 339 | 84.8 |
| 23:30 | 1 | 0.3 | 340 | 85.0 |
| 24:00 | 60 | 15.0 | 400 | 100.0 |

Frequency Missing = 58

light hours/to: Oct Sat

| LF11T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 167 | 42.0 | 167 | 42.0 |
| 1:00 | 7 | 1.8 | 174 | 43.7 |
| 2:00 | 16 | 4.0 | 190 | 47.7 |
| 3:00 | 2 | 0.5 | 192 | 48.2 |
| 6:00 | 2 | 0.5 | 194 | 48.7 |
| 7:00 | 1 | 0.3 | 195 | 49.0 |
| 7:30 | 1 | 0.3 | 196 | 49.2 |
| 9:00 | 1 | 0.3 | 197 | 49.5 |
| 11:00 | 1 | 0.3 | 198 | 49.7 |
| 12:00 | 13 | 3.3 | 211 | 53.0 |
| 12:30 | 1 | 0.3 | 212 | 53.3 |
| 13:00 | 5 | 1.3 | 217 | 54.5 |
| 13:30 | 1 | 0.3 | 218 | 54.8 |
| 14:00 | 9 | 2.3 | 227 | 57.0 |
| 15:00 | 4 | 1.0 | 231 | 58.0 |
| 15:30 | 2 | 0.5 | 233 | 58.5 |
| 16:00 | 2 | 0.5 | 235 | 59.0 |
| 16:30 | 1 | 0.3 | 236 | 59.3 |
| 17:00 | 14 | 3.5 | 250 | 62.8 |
| 17:30 | 3 | 0.8 | 253 | 63.6 |
| 17:45 | 1 | 0.3 | 254 | 63.8 |
| 18:00 | 26 | 6.5 | 280 | 70.4 |
| 18:30 | 6 | 1.5 | 286 | 71.9 |
| 19:00 | 15 | 3.8 | 301 | 75.6 |
| 19:30 | 1 | 0.3 | 302 | 75.9 |
| 20:00 | 8 | 2.0 | 310 | 77.9 |
| 20:30 | 1 | 0.3 | 311 | 78.1 |
| 21:00 | 10 | 2.5 | 321 | 80.7 |
| 22:00 | 7 | 1.8 | 328 | 82.4 |
| 22:30 | 1 | 0.3 | 329 | 82.7 |
| 23:00 | 7 | 1.8 | 336 | 84.4 |
| 23:30 | 1 | 0.3 | 337 | 84.7 |
| 24:00 | 61 | 15.3 | 398 | 100.0 |

Frequency Missing = 60

light hours/to: Oct Sun

| LF12T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 222 | 55.9 | 222 | 55.9 |
| 1:00 | 4 | 1.0 | 226 | 56.9 |
| 2:00 | 15 | 3.8 | 241 | 60.7 |
| 3:00 | 1 | 0.3 | 242 | 61.0 |
| 6:00 | 2 | 0.5 | 244 | 61.5 |
| 7:00 | 1 | 0.3 | 245 | 61.7 |
| 7:30 | 1 | 0.3 | 246 | 62.0 |
| 12:00 | 8 | 2.0 | 254 | 64.0 |
| 13:00 | 4 | 1.0 | 258 | 65.0 |
| 13:30 | 1 | 0.3 | 259 | 65.2 |
| 14:00 | 5 | 1.3 | 264 | 66.5 |
| 15:00 | 3 | 0.8 | 267 | 67.3 |
| 16:00 | 2 | 0.5 | 269 | 67.8 |
| 17:00 | 12 | 3.0 | 281 | 70.8 |
| 17:30 | 1 | 0.3 | 282 | 71.0 |
| 18:00 | 17 | 4.3 | 299 | 75.3 |
| 18:30 | 2 | 0.5 | 301 | 75.8 |
| 19:00 | 11 | 2.8 | 312 | 78.6 |
| 19:30 | 1 | 0.3 | 313 | 78.8 |
| 20:00 | 4 | 1.0 | 317 | 79.8 |
| 20:30 | 1 | 0.3 | 318 | 80.1 |
| 21:00 | 5 | 1.3 | 323 | 81.4 |
| 22:00 | 7 | 1.8 | 330 | 83.1 |
| 22:30 | 1 | 0.3 | 331 | 83.4 |
| 23:00 | 8 | 2.0 | 339 | 85.4 |
| 23:30 | 2 | 0.5 | 341 | 85.9 |
| 24:00 | 56 | 14.1 | 397 | 100.0 |

Frequency Missing = 61

light hours/to: Holiday

| LF13T | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0:00 | 258 | 62.6 | 258 | 62.6 |
| 1:00 | 5 | 1.2 | 263 | 63.8 |
| 2:00 | 11 | 2.7 | 274 | 66.5 |
| 3:00 | 1 | 0.2 | 275 | 66.7 |
| 6:00 | 2 | 0.5 | 277 | 67.2 |
| 7:00 | 1 | 0.2 | 278 | 67.5 |
| 7:30 | 1 | 0.2 | 279 | 67.7 |
| 12:00 | 5 | 1.2 | 284 | 68.9 |
| 13:00 | 2 | 0.5 | 286 | 69.4 |
| 13:30 | 2 | 0.5 | 288 | 69.9 |
| 14:00 | 3 | 0.7 | 291 | 70.6 |
| 15:30 | 2 | 0.5 | 293 | 71.1 |
| 16:00 | 1 | 0.2 | 294 | 71.4 |
| 17:00 | 8 | 1.9 | 302 | 73.3 |
| 17:30 | 1 | 0.2 | 303 | 73.5 |
| 18:00 | 9 | 2.2 | 312 | 75.7 |
| 19:00 | 10 | 2.4 | 322 | 78.2 |
| 20:00 | 3 | 0.7 | 325 | 78.9 |
| 20:30 | 1 | 0.2 | 326 | 79.1 |
| 21:00 | 5 | 1.2 | 331 | 80.3 |
| 22:00 | 4 | 1.0 | 335 | 81.3 |
| 22:30 | 1 | 0.2 | 336 | 81.6 |
| 23:00 | 9 | 2.2 | 345 | 83.7 |
| 23:30 | 1 | 0.2 | 346 | 84.0 |
| 24:00 | 66 | 16.0 | 412 | 100.0 |

Frequency Missing = 46

light hours/am or pm: Dec Week

| LF1N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 40 | 9.1 | 40 | 9.1 |
| D | 3 | 0.7 | 43 | 9.8 |
| P | 395 | 90.2 | 438 | 100.0 |

Frequency Missing = 20

light hours/am or pm: Dec Sat

| LF2N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 46 | 10.9 | 46 | 10.9 |
| D | 3 | 0.7 | 49 | 11.6 |
| P | 374 | 88.4 | 423 | 100.0 |

Frequency Missing = 35

light hours/am or pm: Dec Sun

| LF3N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 35 | 8.4 | 35 | 8.4 |
| D | 3 | 0.7 | 38 | 9.1 |
| P | 381 | 90.9 | 419 | 100.0 |

Frequency Missing = 39

light hours/am or pm: Apr Week

| LF4N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 39 | 9.6 | 39 | 9.6 |
| D | 3 | 0.7 | 42 | 10.3 |
| P | 366 | 89.7 | 408 | 100.0 |

Frequency Missing = 50

light hours/am or pm: Apr Sat

| LF5N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 45 | 11.1 | 45 | 11.1 |
| D | 3 | 0.7 | 48 | 11.9 |
| P | 357 | 88.1 | 405 | 100.0 |

Frequency Missing = 53

light hours/am or pm: Apr Sun

| LF6N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 33 | 8.2 | 33 | 8.2 |
| D | 4 | 1.0 | 37 | 9.2 |
| P | 366 | 90.8 | 403 | 100.0 |

Frequency Missing = 55

light hours/am or pm: Aug Week

| LF7N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 40 | 9.9 | 40 | 9.9 |
| D | 2 | 0.5 | 42 | 10.4 |
| P | 361 | 89.6 | 403 | 100.0 |

Frequency Missing = 55

light hours/am or pm: Aug Sat

| LF8N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 46 | 11.4 | 46 | 11.4 |
| D | 2 | 0.5 | 48 | 11.9 |
| P | 354 | 88.1 | 402 | 100.0 |

Frequency Missing = 56

light hours/am or pm: Aug Sun

| LF9N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| A | 34 | 8.5 | 34 | 8.5 |
| D | 3 | 0.7 | 37 | 9.2 |
| P | 365 | 90.8 | 402 | 100.0 |

Frequency Missing = 56

light hours/am or pm: Oct Week

| LF10N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 39 | 9.7 | 39 | 9.7 |
| D | 2 | 0.5 | 41 | 10.2 |
| P | 361 | 89.8 | 402 | 100.0 |

Frequency Missing = 56

light hours/am or pm: Oct Sat

| LF11N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 45 | 11.3 | 45 | 11.3 |
| D | 2 | 0.5 | 47 | 11.8 |
| P | 353 | 88.3 | 400 | 100.0 |

Frequency Missing = 58

light hours/am or pm: Oct Sun

| LF12N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 33 | 8.3 | 33 | 8.3 |
| D | 3 | 0.8 | 36 | 9.0 |
| P | 364 | 91.0 | 400 | 100.0 |

Frequency Missing = 58

light hours/am or pm: Holiday

| LF13N | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| A | 32 | 7.6 | 32 | 7.6 |
| D | 8 | 1.9 | 40 | 9.5 |
| P | 380 | 90.5 | 420 | 100.0 |

Frequency Missing = 38

light hours/percent on: Dec Week

| LW1 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 0.5 | 2 | 0.5 |
| 1 | 2 | 0.5 | 4 | 1.0 |
| 2 | 2 | 0.5 | 6 | 1.5 |
| 5 | 2 | 0.5 | 8 | 2.0 |
| 8 | 1 | 0.2 | 9 | 2.2 |
| 10 | 1 | 0.2 | 10 | 2.5 |
| 20 | 4 | 1.0 | 14 | 3.4 |
| 25 | 3 | 0.7 | 17 | 4.2 |
| 30 | 4 | 1.0 | 21 | 5.1 |
| 33 | 3 | 0.7 | 24 | 5.9 |
| 35 | 1 | 0.2 | 25 | 6.1 |
| 40 | 5 | 1.2 | 30 | 7.4 |
| 45 | 1 | 0.2 | 31 | 7.6 |
| 50 | 20 | 4.9 | 51 | 12.5 |
| 60 | 9 | 2.2 | 60 | 14.7 |
| 65 | 3 | 0.7 | 63 | 15.4 |
| 66 | 3 | 0.7 | 66 | 16.2 |
| 67 | 1 | 0.2 | 67 | 16.4 |
| 70 | 5 | 1.2 | 72 | 17.6 |
| 75 | 26 | 6.4 | 98 | 24.0 |
| 80 | 21 | 5.1 | 119 | 29.2 |
| 82.390625 | 1 | 0.2 | 120 | 29.4 |
| 85 | 6 | 1.5 | 126 | 30.9 |
| 87 | 1 | 0.2 | 127 | 31.1 |
| 90 | 27 | 6.6 | 154 | 37.7 |
| 95 | 18 | 4.4 | 172 | 42.2 |
| 98 | 4 | 1.0 | 176 | 43.1 |
| 99 | 1 | 0.2 | 177 | 43.4 |
| 100 | 231 | 56.6 | 408 | 100.0 |

Frequency Missing = 50

light hours/percent on: Dec Sat

| LW2 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 67 | 17.4 | 67 | 17.4 |
| 1 | 17 | 4.4 | 84 | 21.8 |
| 2 | 12 | 3.1 | 96 | 24.9 |
| 3 | 4 | 1.0 | 100 | 25.9 |
| 5 | 21 | 5.4 | 121 | 31.3 |
| 8 | 2 | 0.5 | 123 | 31.9 |
| 10 | 33 | 8.5 | 156 | 40.4 |
| 15 | 3 | 0.8 | 159 | 41.2 |
| 20 | 8 | 2.1 | 167 | 43.3 |
| 25 | 7 | 1.8 | 174 | 45.1 |
| 30 | 7 | 1.8 | 181 | 46.9 |
| 33 | 4 | 1.0 | 185 | 47.9 |
| 35 | 1 | 0.3 | 186 | 48.2 |
| 40 | 4 | 1.0 | 190 | 49.2 |
| 50 | 20 | 5.2 | 210 | 54.4 |
| 60 | 9 | 2.3 | 219 | 56.7 |
| 65 | 1 | 0.3 | 220 | 57.0 |
| 66 | 1 | 0.3 | 221 | 57.3 |
| 70 | 3 | 0.8 | 224 | 58.0 |
| 75 | 10 | 2.6 | 234 | 60.6 |
| 77 | 1 | 0.3 | 235 | 60.9 |
| 80 | 11 | 2.8 | 246 | 63.7 |
| 85 | 5 | 1.3 | 251 | 65.0 |
| 90 | 12 | 3.1 | 263 | 68.1 |
| 95 | 5 | 1.3 | 268 | 69.4 |
| 98 | 1 | 0.3 | 269 | 69.7 |
| 99 | 2 | 0.5 | 271 | 70.2 |
| 100 | 115 | 29.8 | 386 | 100.0 |

Frequency Missing = 72

light hours/percent on: Dec Sun

| LW3 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 98 | 26.2 | 98 | 26.2 |
| 1 | 21 | 5.6 | 119 | 31.8 |
| 2 | 15 | 4.0 | 134 | 35.8 |
| 3 | 4 | 1.1 | 138 | 36.9 |
| 5 | 28 | 7.5 | 166 | 44.4 |
| 8 | 2 | 0.5 | 168 | 44.9 |
| 10 | 34 | 9.1 | 202 | 54.0 |
| 15 | 2 | 0.5 | 204 | 54.5 |
| 20 | 7 | 1.9 | 211 | 56.4 |
| 25 | 5 | 1.3 | 216 | 57.8 |
| 30 | 7 | 1.9 | 223 | 59.6 |
| 33 | 3 | 0.8 | 226 | 60.4 |
| 35 | 2 | 0.5 | 228 | 61.0 |
| 40 | 4 | 1.1 | 232 | 62.0 |
| 50 | 13 | 3.5 | 245 | 65.5 |
| 60 | 9 | 2.4 | 254 | 67.9 |
| 65 | 1 | 0.3 | 255 | 68.2 |
| 66 | 1 | 0.3 | 256 | 68.4 |
| 70 | 4 | 1.1 | 260 | 69.5 |
| 75 | 10 | 2.7 | 270 | 72.2 |
| 80 | 8 | 2.1 | 278 | 74.3 |
| 85 | 3 | 0.8 | 281 | 75.1 |
| 90 | 11 | 2.9 | 292 | 78.1 |
| 95 | 3 | 0.8 | 295 | 78.9 |
| 98 | 1 | 0.3 | 296 | 79.1 |
| 100 | 78 | 20.9 | 374 | 100.0 |

Frequency Missing = 84

light hours/percent on: Apr Week

| LW4 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 0.5 | 2 | 0.5 |
| 1 | 2 | 0.5 | 4 | 1.0 |
| 2 | 1 | 0.3 | 5 | 1.3 |
| 5 | 1 | 0.3 | 6 | 1.6 |
| 8 | 1 | 0.3 | 7 | 1.8 |
| 10 | 1 | 0.3 | 8 | 2.1 |
| 20 | 4 | 1.0 | 12 | 3.1 |
| 25 | 4 | 1.0 | 16 | 4.2 |
| 30 | 3 | 0.8 | 19 | 4.9 |
| 33 | 3 | 0.8 | 22 | 5.7 |
| 35 | 2 | 0.5 | 24 | 6.3 |
| 40 | 3 | 0.8 | 27 | 7.0 |
| 45 | 1 | 0.3 | 28 | 7.3 |
| 50 | 21 | 5.5 | 49 | 12.8 |
| 60 | 9 | 2.3 | 58 | 15.1 |
| 65 | 2 | 0.5 | 60 | 15.6 |
| 66 | 3 | 0.8 | 63 | 16.4 |
| 67 | 1 | 0.3 | 64 | 16.7 |
| 70 | 5 | 1.3 | 69 | 18.0 |
| 75 | 25 | 6.5 | 94 | 24.5 |
| 80 | 21 | 5.5 | 115 | 29.9 |
| 82.390625 | 1 | 0.3 | 116 | 30.2 |
| 85 | 4 | 1.0 | 120 | 31.3 |
| 90 | 27 | 7.0 | 147 | 38.3 |
| 95 | 15 | 3.9 | 162 | 42.2 |
| 98 | 4 | 1.0 | 166 | 43.2 |
| 100 | 218 | 56.8 | 384 | 100.0 |

Frequency Missing = 74

light hours/percent on: Apr Sat

| LW5 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 63 | 17.2 | 63 | 17.2 |
| 1 | 16 | 4.4 | 79 | 21.6 |
| 2 | 13 | 3.6 | 92 | 25.1 |
| 3 | 3 | 0.8 | 95 | 26.0 |
| 5 | 21 | 5.7 | 116 | 31.7 |
| 8 | 2 | 0.5 | 118 | 32.2 |
| 10 | 30 | 8.2 | 148 | 40.4 |
| 15 | 4 | 1.1 | 152 | 41.5 |
| 20 | 8 | 2.2 | 160 | 43.7 |
| 25 | 7 | 1.9 | 167 | 45.6 |
| 30 | 8 | 2.2 | 175 | 47.8 |
| 33 | 4 | 1.1 | 179 | 48.9 |
| 35 | 1 | 0.3 | 180 | 49.2 |
| 40 | 5 | 1.4 | 185 | 50.5 |
| 50 | 21 | 5.7 | 206 | 56.3 |
| 60 | 8 | 2.2 | 214 | 58.5 |
| 66 | 1 | 0.3 | 215 | 58.7 |
| 70 | 3 | 0.8 | 218 | 59.6 |
| 75 | 10 | 2.7 | 228 | 62.3 |
| 80 | 11 | 3.0 | 239 | 65.3 |
| 85 | 3 | 0.8 | 242 | 66.1 |
| 90 | 11 | 3.0 | 253 | 69.1 |
| 95 | 4 | 1.1 | 257 | 70.2 |
| 98 | 1 | 0.3 | 258 | 70.5 |
| 100 | 108 | 29.5 | 366 | 100.0 |

Frequency Missing = 92

light hours/percent on: Apr Sun

| LW6 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 93 | 26.0 | 93 | 26.0 |
| 1 | 21 | 5.9 | 114 | 31.8 |
| 2 | 15 | 4.2 | 129 | 36.0 |
| 3 | 3 | 0.8 | 132 | 36.9 |
| 5 | 27 | 7.5 | 159 | 44.4 |
| 8 | 2 | 0.6 | 161 | 45.0 |
| 10 | 34 | 9.5 | 195 | 54.5 |
| 15 | 3 | 0.8 | 198 | 55.3 |
| 20 | 7 | 2.0 | 205 | 57.3 |
| 25 | 6 | 1.7 | 211 | 58.9 |
| 30 | 7 | 2.0 | 218 | 60.9 |
| 33 | 3 | 0.8 | 221 | 61.7 |
| 35 | 2 | 0.6 | 223 | 62.3 |
| 40 | 4 | 1.1 | 227 | 63.4 |
| 50 | 13 | 3.6 | 240 | 67.0 |
| 60 | 8 | 2.2 | 248 | 69.3 |
| 66 | 1 | 0.3 | 249 | 69.6 |
| 70 | 4 | 1.1 | 253 | 70.7 |
| 75 | 9 | 2.5 | 262 | 73.2 |
| 80 | 8 | 2.2 | 270 | 75.4 |
| 85 | 2 | 0.6 | 272 | 76.0 |
| 90 | 10 | 2.8 | 282 | 78.8 |
| 95 | 2 | 0.6 | 284 | 79.3 |
| 98 | 1 | 0.3 | 285 | 79.6 |
| 100 | 73 | 20.4 | 358 | 100.0 |

Frequency Missing = 100

light hours/percent on: Aug Week

| LW7 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| 0 | 3 | 0.8 | 3 | 0.8 |
| 1 | 1 | 0.3 | 4 | 1.1 |
| 2 | 2 | 0.5 | 6 | 1.6 |
| 5 | 3 | 0.8 | 9 | 2.4 |
| 8 | 1 | 0.3 | 10 | 2.6 |
| 10 | 3 | 0.8 | 13 | 3.4 |
| 20 | 5 | 1.3 | 18 | 4.7 |
| 25 | 5 | 1.3 | 23 | 6.1 |
| 30 | 5 | 1.3 | 28 | 7.4 |
| 33 | 3 | 0.8 | 31 | 8.2 |
| 35 | 3 | 0.8 | 34 | 8.9 |
| 40 | 3 | 0.8 | 37 | 9.7 |
| 50 | 20 | 5.3 | 57 | 15.0 |
| 60 | 8 | 2.1 | 65 | 17.1 |
| 65 | 1 | 0.3 | 66 | 17.4 |
| 66 | 3 | 0.8 | 69 | 18.2 |
| 67 | 1 | 0.3 | 70 | 18.4 |
| 70 | 5 | 1.3 | 75 | 19.7 |
| 75 | 25 | 6.6 | 100 | 26.3 |
| 80 | 19 | 5.0 | 119 | 31.3 |
| 82.390625 | 1 | 0.3 | 120 | 31.6 |
| 85 | 5 | 1.3 | 125 | 32.9 |
| 90 | 25 | 6.6 | 150 | 39.5 |
| 95 | 16 | 4.2 | 166 | 43.7 |
| 98 | 4 | 1.1 | 170 | 44.7 |
| 100 | 210 | 55.3 | 380 | 100.0 |

Frequency Missing = 78

light hours/percent on: Aug Sat

| LW8 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 65 | 17.9 | 65 | 17.9 |
| 1 | 13 | 3.6 | 78 | 21.5 |
| 2 | 13 | 3.6 | 91 | 25.1 |
| 3 | 3 | 0.8 | 94 | 25.9 |
| 5 | 21 | 5.8 | 115 | 31.7 |
| 8 | 2 | 0.6 | 117 | 32.2 |
| 10 | 28 | 7.7 | 145 | 39.9 |
| 15 | 5 | 1.4 | 150 | 41.3 |
| 20 | 8 | 2.2 | 158 | 43.5 |
| 25 | 7 | 1.9 | 165 | 45.5 |
| 30 | 7 | 1.9 | 172 | 47.4 |
| 33 | 4 | 1.1 | 176 | 48.5 |
| 35 | 1 | 0.3 | 177 | 48.8 |
| 40 | 5 | 1.4 | 182 | 50.1 |
| 50 | 21 | 5.8 | 203 | 55.9 |
| 60 | 8 | 2.2 | 211 | 58.1 |
| 66 | 1 | 0.3 | 212 | 58.4 |
| 70 | 2 | 0.6 | 214 | 59.0 |
| 75 | 10 | 2.8 | 224 | 61.7 |
| 80 | 12 | 3.3 | 236 | 65.0 |
| 85 | 4 | 1.1 | 240 | 66.1 |
| 90 | 11 | 3.0 | 251 | 69.1 |
| 95 | 4 | 1.1 | 255 | 70.2 |
| 98 | 1 | 0.3 | 256 | 70.5 |
| 100 | 107 | 29.5 | 363 | 100.0 |

Frequency Missing = 95

light hours/percent on: Aug Sun

| LW9 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----|-----------|---------|-------------------------|-----------------------|
| 0 | 90 | 25.2 | 90 | 25.2 |
| 1 | 20 | 5.6 | 110 | 30.8 |
| 2 | 16 | 4.5 | 126 | 35.3 |
| 3 | 3 | 0.8 | 129 | 36.1 |
| 5 | 28 | 7.8 | 157 | 44.0 |
| 8 | 2 | 0.6 | 159 | 44.5 |
| 10 | 34 | 9.5 | 193 | 54.1 |
| 15 | 4 | 1.1 | 197 | 55.2 |
| 20 | 7 | 2.0 | 204 | 57.1 |
| 25 | 6 | 1.7 | 210 | 58.8 |
| 30 | 7 | 2.0 | 217 | 60.8 |
| 33 | 3 | 0.8 | 220 | 61.6 |
| 35 | 2 | 0.6 | 222 | 62.2 |
| 40 | 4 | 1.1 | 226 | 63.3 |
| 50 | 13 | 3.6 | 239 | 66.9 |
| 60 | 8 | 2.2 | 247 | 69.2 |
| 66 | 1 | 0.3 | 248 | 69.5 |
| 70 | 3 | 0.8 | 251 | 70.3 |
| 75 | 9 | 2.5 | 260 | 72.8 |
| 80 | 8 | 2.2 | 268 | 75.1 |
| 85 | 3 | 0.8 | 271 | 75.9 |
| 90 | 10 | 2.8 | 281 | 78.7 |
| 95 | 2 | 0.6 | 283 | 79.3 |
| 98 | 1 | 0.3 | 284 | 79.6 |
| 100 | 73 | 20.4 | 357 | 100.0 |

Frequency Missing = 101

light hours/percent on: Oct Week

| LW10 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 0.5 | 2 | 0.5 |
| 1 | 1 | 0.3 | 3 | 0.8 |
| 2 | 2 | 0.5 | 5 | 1.3 |
| 5 | 1 | 0.3 | 6 | 1.6 |
| 8 | 1 | 0.3 | 7 | 1.8 |
| 10 | 1 | 0.3 | 8 | 2.1 |
| 20 | 4 | 1.1 | 12 | 3.2 |
| 25 | 3 | 0.8 | 15 | 4.0 |
| 30 | 4 | 1.1 | 19 | 5.0 |
| 33 | 3 | 0.8 | 22 | 5.8 |
| 35 | 1 | 0.3 | 23 | 6.1 |
| 40 | 2 | 0.5 | 25 | 6.6 |
| 45 | 1 | 0.3 | 26 | 6.9 |
| 50 | 20 | 5.3 | 46 | 12.1 |
| 60 | 7 | 1.8 | 53 | 14.0 |
| 65 | 2 | 0.5 | 55 | 14.5 |
| 66 | 3 | 0.8 | 58 | 15.3 |
| 67 | 1 | 0.3 | 59 | 15.6 |
| 70 | 5 | 1.3 | 64 | 16.9 |
| 75 | 27 | 7.1 | 91 | 24.0 |
| 80 | 21 | 5.5 | 112 | 29.6 |
| 82.390625 | 1 | 0.3 | 113 | 29.8 |
| 85 | 5 | 1.3 | 118 | 31.1 |
| 90 | 28 | 7.4 | 146 | 38.5 |
| 95 | 16 | 4.2 | 162 | 42.7 |
| 98 | 4 | 1.1 | 166 | 43.8 |
| 100 | 213 | 56.2 | 379 | 100.0 |

Frequency Missing = 79

light hours/percent on: Oct Sat

| LW11 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 64 | 17.7 | 64 | 17.7 |
| 1 | 14 | 3.9 | 78 | 21.6 |
| 2 | 13 | 3.6 | 91 | 25.2 |
| 3 | 3 | 0.8 | 94 | 26.0 |
| 5 | 21 | 5.8 | 115 | 31.9 |
| 8 | 2 | 0.6 | 117 | 32.4 |
| 10 | 30 | 8.3 | 147 | 40.7 |
| 15 | 5 | 1.4 | 152 | 42.1 |
| 20 | 8 | 2.2 | 160 | 44.3 |
| 25 | 6 | 1.7 | 166 | 46.0 |
| 30 | 7 | 1.9 | 173 | 47.9 |
| 33 | 4 | 1.1 | 177 | 49.0 |
| 35 | 1 | 0.3 | 178 | 49.3 |
| 40 | 4 | 1.1 | 182 | 50.4 |
| 50 | 21 | 5.8 | 203 | 56.2 |
| 60 | 7 | 1.9 | 210 | 58.2 |
| 65 | 1 | 0.3 | 211 | 58.4 |
| 66 | 1 | 0.3 | 212 | 58.7 |
| 70 | 2 | 0.6 | 214 | 59.3 |
| 75 | 11 | 3.0 | 225 | 62.3 |
| 80 | 11 | 3.0 | 236 | 65.4 |
| 85 | 4 | 1.1 | 240 | 66.5 |
| 90 | 11 | 3.0 | 251 | 69.5 |
| 95 | 4 | 1.1 | 255 | 70.6 |
| 98 | 1 | 0.3 | 256 | 70.9 |
| 100 | 105 | 29.1 | 361 | 100.0 |

Frequency Missing = 97

light hours/percent on: Oct Sun

| LW12 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 90 | 25.2 | 90 | 25.2 |
| 1 | 20 | 5.6 | 110 | 30.8 |
| 2 | 16 | 4.5 | 126 | 35.3 |
| 3 | 3 | 0.8 | 129 | 36.1 |
| 5 | 28 | 7.8 | 157 | 44.0 |
| 8 | 2 | 0.6 | 159 | 44.5 |
| 10 | 33 | 9.2 | 192 | 53.8 |
| 15 | 4 | 1.1 | 196 | 54.9 |
| 20 | 8 | 2.2 | 204 | 57.1 |
| 25 | 5 | 1.4 | 209 | 58.5 |
| 30 | 7 | 2.0 | 216 | 60.5 |
| 33 | 3 | 0.8 | 219 | 61.3 |
| 35 | 2 | 0.6 | 221 | 61.9 |
| 40 | 3 | 0.8 | 224 | 62.7 |
| 50 | 13 | 3.6 | 237 | 66.4 |
| 60 | 8 | 2.2 | 245 | 68.6 |
| 65 | 1 | 0.3 | 246 | 68.9 |
| 66 | 1 | 0.3 | 247 | 69.2 |
| 70 | 3 | 0.8 | 250 | 70.0 |
| 75 | 11 | 3.1 | 261 | 73.1 |
| 80 | 8 | 2.2 | 269 | 75.4 |
| 85 | 2 | 0.6 | 271 | 75.9 |
| 90 | 10 | 2.8 | 281 | 78.7 |
| 95 | 2 | 0.6 | 283 | 79.3 |
| 98 | 1 | 0.3 | 284 | 79.6 |
| 100 | 73 | 20.4 | 357 | 100.0 |

Frequency Missing = 101

light hours/percent on: Holiday

| LW13 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------|-----------|---------|-------------------------|-----------------------|
| 0 | 139 | 34.3 | 139 | 34.3 |
| 1 | 30 | 7.4 | 169 | 41.7 |
| 2 | 16 | 4.0 | 185 | 45.7 |
| 3 | 4 | 1.0 | 189 | 46.7 |
| 5 | 32 | 7.9 | 221 | 54.6 |
| 8 | 1 | 0.2 | 222 | 54.8 |
| 10 | 37 | 9.1 | 259 | 64.0 |
| 15 | 5 | 1.2 | 264 | 65.2 |
| 20 | 9 | 2.2 | 273 | 67.4 |
| 25 | 4 | 1.0 | 277 | 68.4 |
| 30 | 5 | 1.2 | 282 | 69.6 |
| 33 | 3 | 0.7 | 285 | 70.4 |
| 40 | 2 | 0.5 | 287 | 70.9 |
| 50 | 11 | 2.7 | 298 | 73.6 |
| 60 | 7 | 1.7 | 305 | 75.3 |
| 66 | 1 | 0.2 | 306 | 75.6 |
| 70 | 2 | 0.5 | 308 | 76.0 |
| 75 | 10 | 2.5 | 318 | 78.5 |
| 80 | 4 | 1.0 | 322 | 79.5 |
| 85 | 1 | 0.2 | 323 | 79.8 |
| 87 | 1 | 0.2 | 324 | 80.0 |
| 90 | 6 | 1.5 | 330 | 81.5 |
| 95 | 2 | 0.5 | 332 | 82.0 |
| 98 | 1 | 0.2 | 333 | 82.2 |
| 100 | 72 | 17.8 | 405 | 100.0 |

Frequency Missing = 53

percent cond space lit durn busines hrs

| LF015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 27 | 6.0 | 27 | 6.0 |
| 0.5 | 1 | 0.2 | 28 | 6.2 |
| 1 | 2 | 0.4 | 30 | 6.7 |
| 3 | 1 | 0.2 | 31 | 6.9 |
| 5 | 2 | 0.4 | 33 | 7.3 |
| 10 | 7 | 1.6 | 40 | 8.9 |
| 12 | 1 | 0.2 | 41 | 9.1 |
| 15 | 3 | 0.7 | 44 | 9.8 |
| 20 | 7 | 1.6 | 51 | 11.4 |
| 25 | 4 | 0.9 | 55 | 12.2 |
| 30 | 4 | 0.9 | 59 | 13.1 |
| 33 | 3 | 0.7 | 62 | 13.8 |
| 35 | 3 | 0.7 | 65 | 14.5 |
| 40 | 10 | 2.2 | 75 | 16.7 |
| 50 | 17 | 3.8 | 92 | 20.5 |
| 60 | 7 | 1.6 | 99 | 22.0 |
| 66 | 1 | 0.2 | 100 | 22.3 |
| 70 | 7 | 1.6 | 107 | 23.8 |
| 75 | 16 | 3.6 | 123 | 27.4 |
| 80 | 23 | 5.1 | 146 | 32.5 |
| 85 | 3 | 0.7 | 149 | 33.2 |
| 90 | 32 | 7.1 | 181 | 40.3 |
| 95 | 19 | 4.2 | 200 | 44.5 |
| 98 | 3 | 0.7 | 203 | 45.2 |
| 99 | 5 | 1.1 | 208 | 46.3 |
| 100 | 219 | 48.8 | 427 | 95.1 |
| 888 | 1 | 0.2 | 428 | 95.3 |
| 999 | 21 | 4.7 | 449 | 100.0 |

Frequency Missing = 9

Average age replaced fixtures

| SR010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 0 | 15 | 15.3 | 15 | 15.3 |
| 0.29999995 | 1 | 1.0 | 16 | 16.3 |
| 1 | 2 | 2.0 | 18 | 18.4 |
| 2 | 1 | 1.0 | 19 | 19.4 |
| 3 | 4 | 4.1 | 23 | 23.5 |
| 5 | 3 | 3.1 | 26 | 26.5 |
| 6 | 3 | 3.1 | 29 | 29.6 |
| 7 | 2 | 2.0 | 31 | 31.6 |
| 8 | 2 | 2.0 | 33 | 33.7 |
| 9 | 2 | 2.0 | 35 | 35.7 |
| 10 | 9 | 9.2 | 44 | 44.9 |
| 12 | 1 | 1.0 | 45 | 45.9 |
| 15 | 7 | 7.1 | 52 | 53.1 |
| 17 | 2 | 2.0 | 54 | 55.1 |
| 18 | 2 | 2.0 | 56 | 57.1 |
| 19 | 1 | 1.0 | 57 | 58.2 |
| 20 | 13 | 13.3 | 70 | 71.4 |
| 21 | 1 | 1.0 | 71 | 72.4 |
| 24 | 1 | 1.0 | 72 | 73.5 |
| 25 | 8 | 8.2 | 80 | 81.6 |
| 27 | 1 | 1.0 | 81 | 82.7 |
| 30 | 5 | 5.1 | 86 | 87.8 |
| 35 | 1 | 1.0 | 87 | 88.8 |
| 40 | 1 | 1.0 | 88 | 89.8 |
| 44 | 1 | 1.0 | 89 | 90.8 |
| 50 | 2 | 2.0 | 91 | 92.9 |
| 999 | 7 | 7.1 | 98 | 100.0 |

Frequency Missing = 360

Average age existing fixtures

| SR100 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------|-----------|---------|-------------------------|-----------------------|
| 0 | 2 | 0.5 | 2 | 0.5 |
| 0.17999995 | 1 | 0.3 | 3 | 0.8 |
| 0.19999993 | 1 | 0.3 | 4 | 1.1 |
| 0.29999995 | 1 | 0.3 | 5 | 1.3 |
| 1 | 15 | 4.0 | 20 | 5.4 |
| 1.5 | 1 | 0.3 | 21 | 5.6 |
| 2 | 16 | 4.3 | 37 | 9.9 |
| 2.5 | 1 | 0.3 | 38 | 10.2 |
| 3 | 21 | 5.6 | 59 | 15.9 |
| 4 | 16 | 4.3 | 75 | 20.2 |
| 5 | 19 | 5.1 | 94 | 25.3 |
| 6 | 20 | 5.4 | 114 | 30.6 |
| 6.5 | 1 | 0.3 | 115 | 30.9 |
| 7 | 9 | 2.4 | 124 | 33.3 |
| 7.5 | 1 | 0.3 | 125 | 33.6 |
| 8 | 14 | 3.8 | 139 | 37.4 |
| 9 | 9 | 2.4 | 148 | 39.8 |
| 10 | 48 | 12.9 | 196 | 52.7 |
| 11 | 4 | 1.1 | 200 | 53.8 |
| 12 | 10 | 2.7 | 210 | 56.5 |
| 13 | 4 | 1.1 | 214 | 57.5 |
| 14 | 2 | 0.5 | 216 | 58.1 |
| 15 | 36 | 9.7 | 252 | 67.7 |
| 16 | 4 | 1.1 | 256 | 68.8 |
| 17 | 5 | 1.3 | 261 | 70.2 |
| 18 | 4 | 1.1 | 265 | 71.2 |
| 19 | 2 | 0.5 | 267 | 71.8 |
| 20 | 39 | 10.5 | 306 | 82.3 |
| 22 | 2 | 0.5 | 308 | 82.8 |
| 23 | 3 | 0.8 | 311 | 83.6 |
| 25 | 18 | 4.8 | 329 | 88.4 |
| 26 | 1 | 0.3 | 330 | 88.7 |
| 27 | 1 | 0.3 | 331 | 89.0 |
| 28 | 2 | 0.5 | 333 | 89.5 |
| 30 | 20 | 5.4 | 353 | 94.9 |
| 31 | 1 | 0.3 | 354 | 95.2 |
| 35 | 2 | 0.5 | 356 | 95.7 |
| 38 | 1 | 0.3 | 357 | 96.0 |
| 40 | 4 | 1.1 | 361 | 97.0 |
| 45 | 1 | 0.3 | 362 | 97.3 |
| 47 | 1 | 0.3 | 363 | 97.6 |
| 50 | 4 | 1.1 | 367 | 98.7 |
| 57 | 1 | 0.3 | 368 | 98.9 |
| 60 | 2 | 0.5 | 370 | 99.5 |
| 100 | 2 | 0.5 | 372 | 100.0 |

Frequency Missing = 86

Any instld equip been removed

| LP010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 123 | 89.8 | 123 | 89.8 |
| Yes | 14 | 10.2 | 137 | 100.0 |

Frequency Missing = 321

month/year of new equip removed

| LP020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| DEC1994 | 1 | 20.0 | 1 | 20.0 |
| APR1995 | 1 | 20.0 | 2 | 40.0 |
| JUN1995 | 1 | 20.0 | 3 | 60.0 |
| JUL1995 | 2 | 40.0 | 5 | 100.0 |

Frequency Missing = 453

year of new equip removed

| LP021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1993 | 2 | 40.0 | 2 | 40.0 |
| 1994 | 1 | 20.0 | 3 | 60.0 |
| 1995 | 2 | 40.0 | 5 | 100.0 |

Frequency Missing = 453

month/year of new equip removed/2

| LP025 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

year of new equip removed/2

| LP026 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Removed/4' T-8

| LP030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 0 | 7 | 87.5 | 7 | 87.5 |
| 1 | 1 | 12.5 | 8 | 100.0 |
| Frequency Missing = 450 | | | | |

Removed/8' T-8

| LP031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 0 | 9 | 100.0 | 9 | 100.0 |
| Frequency Missing = 449 | | | | |

Removed/4' ES Fluor

| LP032 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 0 | 9 | 100.0 | 9 | 100.0 |
| Frequency Missing = 449 | | | | |

Removed/8' ES Fluor

| LP033 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 9 | 100.0 | 9 | 100.0 |

Frequency Missing = 449

Removed/4' T-12

| LP034 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 9 | 100.0 | 9 | 100.0 |

Frequency Missing = 449

Removed/8' T-12

| LP035 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 9 | 100.0 | 9 | 100.0 |

Frequency Missing = 449

Removed/Incandescent

| LP036 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 0 | 8 | 80.0 | 8 | 80.0 |
| 1 | 1 | 10.0 | 9 | 90.0 |
| 35 | 1 | 10.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Compact Fluor

| LP037 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 9 | 100.0 | 9 | 100.0 |

Frequency Missing = 449

Removed/High pres sodium

| LP038 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 8 | 88.9 | 8 | 88.9 |
| 4 | 1 | 11.1 | 9 | 100.0 |

Frequency Missing = 449

Removed/Metal Halide

| LP039 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 9 | 100.0 | 9 | 100.0 |

Frequency Missing = 449

Removed/Mercury Vpr

| LP040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 100.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Quartz

| LP041 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 9 | 90.0 | 9 | 90.0 |
| 20 | 1 | 10.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Reflctrs Delmp

| LP042 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 100.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Elec Ballasts

| LP043 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 100.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Magnetic Ballasts

| LP044 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 100.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/LED Exit Lights

| LP045 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 100.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Watt Saver-Power Choke

| LP046 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 100.0 | 10 | 100.0 |

Frequency Missing = 448

Removed/Other

| LP047 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 9 | 81.8 | 9 | 81.8 |
| 1 | 1 | 9.1 | 10 | 90.9 |
| 20 | 1 | 9.1 | 11 | 100.0 |

Frequency Missing = 447

| OBS | LP048 |
|-----|---------------------|
| 1 | GAS BULB SHOWROOM |
| 2 | "BI-AX FLOURESCENT" |

Replcd w/4' T-8

| LP070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 90.9 | 10 | 90.9 |
| 1 | 1 | 9.1 | 11 | 100.0 |

Frequency Missing = 447

Replcd w/8' T-8

| LP071 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/4' ES Fluor

| LP072 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/8' ES Fluor

| LP073 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/4' T-12

| LP074 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/8' T-12

| LP075 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Incandescent

| LP076 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 10 | 83.3 | 10 | 83.3 |
| 1 | 1 | 8.3 | 11 | 91.7 |
| 20 | 1 | 8.3 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Compact Fluor

| LP077 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/High pres sodium

| LP078 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 11 | 91.7 | 11 | 91.7 |
| 4 | 1 | 8.3 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Metal Halide

| LP079 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Mercury Vpr

| LP080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Quartz

| LP081 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Reflctrs Delmp

| LP082 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Elec Ballasts

| LP083 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 11 | 91.7 | 11 | 91.7 |
| 20 | 1 | 8.3 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Magnetic Ballasts

| LP084 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/LED Exit Lights

| LP085 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Watt Saver-Power Choke

| LP086 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 12 | 100.0 | 12 | 100.0 |

Frequency Missing = 446

Replcd w/Other

| LP087 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 0 | 11 | 91.7 | 11 | 91.7 |
| 1 | 1 | 8.3 | 12 | 100.0 |

Frequency Missing = 446

OBS LP088

1 NOT EXACTLY SURE

Is outdoor lighting on bill?

| OL010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 108 | 24.5 | 108 | 24.5 |
| Yes | 332 | 75.5 | 440 | 100.0 |

Frequency Missing = 18

Changed any outdoor lights

| OL020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 256 | 81.3 | 256 | 81.3 |
| Yes | 59 | 18.7 | 315 | 100.0 |

Frequency Missing = 143

Month/year change outdoor lights

| OL030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JUN1992 | 1 | 5.0 | 1 | 5.0 |
| APR1993 | 1 | 5.0 | 2 | 10.0 |
| SEP1993 | 1 | 5.0 | 3 | 15.0 |
| DEC1993 | 1 | 5.0 | 4 | 20.0 |
| JAN1994 | 1 | 5.0 | 5 | 25.0 |
| MAR1994 | 1 | 5.0 | 6 | 30.0 |
| MAY1994 | 1 | 5.0 | 7 | 35.0 |
| JUN1994 | 1 | 5.0 | 8 | 40.0 |
| JUL1994 | 1 | 5.0 | 9 | 45.0 |
| SEP1994 | 1 | 5.0 | 10 | 50.0 |
| NOV1994 | 1 | 5.0 | 11 | 55.0 |
| DEC1994 | 1 | 5.0 | 12 | 60.0 |
| JAN1995 | 2 | 10.0 | 14 | 70.0 |
| APR1995 | 1 | 5.0 | 15 | 75.0 |
| MAY1995 | 3 | 15.0 | 18 | 90.0 |
| JUN1995 | 1 | 5.0 | 19 | 95.0 |
| JUL1995 | 1 | 5.0 | 20 | 100.0 |

Frequency Missing = 438

Year change outdoor lights

| OL031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 1992 | 7 | 23.3 | 7 | 23.3 |
| 1993 | 13 | 43.3 | 20 | 66.7 |
| 1994 | 9 | 30.0 | 29 | 96.7 |
| 1995 | 1 | 3.3 | 30 | 100.0 |

Frequency Missing = 428

Add/replace/remove outdoor lights

| OL040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-----------------|-----------|---------|----------------------|--------------------|
| Added | 40 | 67.8 | 40 | 67.8 |
| Replaced | 13 | 22.0 | 53 | 89.8 |
| Add and Replace | 6 | 10.2 | 59 | 100.0 |

Frequency Missing = 399

Cooling type

| CE010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|----------------------|--------------------|
| No AC | 130 | 29.7 | 130 | 29.7 |
| Centrl Plant | 107 | 24.5 | 237 | 54.2 |
| Sml Pack Sys | 130 | 29.7 | 367 | 84.0 |
| Wall/Wndo Unit | 26 | 5.9 | 393 | 89.9 |
| Heat Pump | 12 | 2.7 | 405 | 92.7 |
| Other | 25 | 5.7 | 430 | 98.4 |
| Evap Cooler | 1 | 0.2 | 431 | 98.6 |
| Swamp Cooler | 6 | 1.4 | 437 | 100.0 |

Frequency Missing = 21

OBS CE011

- 1 AIR CONDITIONER/HEATERS
- 2 FORCED AIR
- 3 0
- 4 REFRIGERATION UNIT
- 5 ANTIQUE
- 6 SWAMP COOLER
- 7 COOLERS
- 8 SWAMP COOLER
- 9 REFRIGIRATION UNIT
- 10 WATER COOLER
- 11 SWAMP COOLERS
- 12 FORCED AIR
- 13 FORCED AIR COMPRESSOR
- 14 CENTRAL AIR COOLING
- 15 MULTIPLE/FAN/AC/WINDOW COMBO
- 16 20 TON FORCED AIR
- 17 REFRIGERATION
- 18 SWAMP COOLER
- 19 SWAMP COOLER 421
- 20 40= HVAC
- 21 FORCED AIR
- 22 FAN
- 23 HEATER COOLERS
- 24 CHILLER
- 25 COMBO OF ALL OF THE ABOVE
- 26 SWAMP COOLER
- 27 CEILING FANS
- 28 EVAPORATIVE COOLER
- 29 WATER COOLER
- 30 ROOF UNITS
- 31 HVAC
- 32 COMMERCIAL UNITS
- 33 WEATHER CARRIERS
- 34 CHILLING TOWER
- 35 CONGLOMERATION
- 36 2 PIPE SYSTEM
- 37 4 PIPE SYSTEM
- 38 COMPRESSOR UNIT
- 39 6 ROOF UNITS

Cooling primary fuel

| CE015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Elec | 285 | 92.5 | 285 | 92.5 |
| Natural Gas | 15 | 4.9 | 300 | 97.4 |
| Other | 4 | 1.3 | 304 | 98.7 |
| Gas and Electric | 4 | 1.3 | 308 | 100.0 |

Frequency Missing = 150

| OBS | CE016 |
|-----|---------------------------|
| 1 | BOTH 1 AND 2 |
| 2 | WATER |
| 3 | WATER |
| 4 | WATER |
| 5 | BOTH 1 AND 2 |
| 6 | GAS 4 TON FORCED/ELECTRIC |
| 7 | BOTH ELECTRICITY & GAS |
| 8 | ELECTRIC W\FREON |
| 9 | ELECTRICITY & GAS |

System include economizer?

| CE030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| Frequency Missing = 458 | | | | |

| CE050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| Frequency Missing = 458 | | | | |

Cooling operated/all year

| CE059 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 125 | 48.8 | 125 | 48.8 |
| Yes | 131 | 51.2 | 256 | 100.0 |

Frequency Missing = 202

Cooling operated/Jan

| CE060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 147 | 97.4 | 147 | 97.4 |
| Yes | 4 | 2.6 | 151 | 100.0 |

Frequency Missing = 307

Cooling operated/Feb

| CE061 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 147 | 98.7 | 147 | 98.7 |
| Yes | 2 | 1.3 | 149 | 100.0 |

Frequency Missing = 309

Cooling operated/Mar

| CE062 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 138 | 92.0 | 138 | 92.0 |
| Yes | 12 | 8.0 | 150 | 100.0 |

Frequency Missing = 308

Cooling operated/Apr

| CE063 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 116 | 74.8 | 116 | 74.8 |
| Yes | 39 | 25.2 | 155 | 100.0 |

Frequency Missing = 303

Cooling operated/May

| CE064 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 57 | 32.8 | 57 | 32.8 |
| Yes | 117 | 67.2 | 174 | 100.0 |

Frequency Missing = 284

Cooling operated/Jun

| CE065 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 24 | 13.0 | 24 | 13.0 |
| Yes | 160 | 87.0 | 184 | 100.0 |

Frequency Missing = 274

Cooling operated/Jul

| CE066 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 12 | 6.5 | 12 | 6.5 |
| Yes | 172 | 93.5 | 184 | 100.0 |

Frequency Missing = 274

Cooling operated/Aug

| CE067 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 9 | 4.8 | 9 | 4.8 |
| Yes | 177 | 95.2 | 186 | 100.0 |

Frequency Missing = 272

Cooling operated/Sep

| CE068 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 22 | 12.1 | 22 | 12.1 |
| Yes | 160 | 87.9 | 182 | 100.0 |

Frequency Missing = 276

Cooling operated/Oct

| CE069 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 89 | 51.7 | 89 | 51.7 |
| Yes | 83 | 48.3 | 172 | 100.0 |

Frequency Missing = 286

Cooling operated/Nov

| CE070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 154 | 91.7 | 154 | 91.7 |
| Yes | 14 | 8.3 | 168 | 100.0 |

Frequency Missing = 290

Cooling operated/Dec

| CE071 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 162 | 96.4 | 162 | 96.4 |
| Yes | 6 | 3.6 | 168 | 100.0 |

Frequency Missing = 290

Cooling operated/Ref

| CE072 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 139 | 100.0 | 139 | 100.0 |

Frequency Missing = 319

Cooling operated/DK

| CE073 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 140 | 94.0 | 140 | 94.0 |
| Yes | 9 | 6.0 | 149 | 100.0 |

Frequency Missing = 309

Added/replaced/removed cooling

| CE080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------------|-----------|---------|-------------------------|-----------------------|
| No chnge | 378 | 85.3 | 378 | 85.3 |
| Added | 25 | 5.6 | 403 | 91.0 |
| Replaced | 32 | 7.2 | 435 | 98.2 |
| Added/Replced | 7 | 1.6 | 442 | 99.8 |
| Removed | 1 | 0.2 | 443 | 100.0 |

Frequency Missing = 15

Month/year cooling changes

| CE090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| FEB1992 | 1 | 3.7 | 1 | 3.7 |
| MAR1992 | 1 | 3.7 | 2 | 7.4 |
| MAY1992 | 2 | 7.4 | 4 | 14.8 |
| OCT1992 | 1 | 3.7 | 5 | 18.5 |
| APR1993 | 1 | 3.7 | 6 | 22.2 |
| JUN1993 | 2 | 7.4 | 8 | 29.6 |
| JUL1993 | 1 | 3.7 | 9 | 33.3 |
| DEC1993 | 1 | 3.7 | 10 | 37.0 |
| FEB1994 | 1 | 3.7 | 11 | 40.7 |
| JUL1994 | 1 | 3.7 | 12 | 44.4 |
| OCT1994 | 2 | 7.4 | 14 | 51.9 |
| NOV1994 | 2 | 7.4 | 16 | 59.3 |
| DEC1994 | 1 | 3.7 | 17 | 63.0 |
| FEB1995 | 1 | 3.7 | 18 | 66.7 |
| APR1995 | 1 | 3.7 | 19 | 70.4 |
| MAY1995 | 2 | 7.4 | 21 | 77.8 |
| JUN1995 | 2 | 7.4 | 23 | 85.2 |
| JUL1995 | 4 | 14.8 | 27 | 100.0 |

Frequency Missing = 431

Year cooling changes

| CE091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 10 | 28.6 | 10 | 28.6 |
| 1993 | 8 | 22.9 | 18 | 51.4 |
| 1994 | 11 | 31.4 | 29 | 82.9 |
| 1995 | 6 | 17.1 | 35 | 100.0 |

Frequency Missing = 423

Old cooling fuel type

| CE110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Elec | 36 | 94.7 | 36 | 94.7 |
| Natural Gas | 2 | 5.3 | 38 | 100.0 |

Frequency Missing = 420

Cooling addition fuel type

| CE120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Elec | 59 | 93.7 | 59 | 93.7 |
| Natural Gas | 1 | 1.6 | 60 | 95.2 |
| Other | 3 | 4.8 | 63 | 100.0 |

Frequency Missing = 395

- OBS CE121
- 1 BOTH
 - 2 ELECTRICITY AND GA
 - 3 ELEC & GAS

Type of main heating

| HE015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Cntrl elec fur | 39 | 9.4 | 39 | 9.4 |
| Cntrl HP | 35 | 8.4 | 74 | 17.8 |
| Cntrl Gas fur | 156 | 37.6 | 230 | 55.4 |
| Gas boiler | 34 | 8.2 | 264 | 63.6 |
| Elec boiler | 1 | 0.2 | 265 | 63.9 |
| Oil boiler/fur | 2 | 0.5 | 267 | 64.3 |
| Elec strip heat | 2 | 0.5 | 269 | 64.8 |
| Basebrd elec hea | 5 | 1.2 | 274 | 66.0 |
| Rm/Wal AC w/stri | 11 | 2.7 | 285 | 68.7 |
| Perm non-elec ht | 4 | 1.0 | 289 | 69.6 |
| whlhs wl/flr ele | 8 | 1.9 | 297 | 71.6 |
| whlhs wl/flr gas | 12 | 2.9 | 309 | 74.5 |
| Port elec | 11 | 2.7 | 320 | 77.1 |
| Wood/Coal stove | 2 | 0.5 | 322 | 77.6 |
| Propane heat | 4 | 1.0 | 326 | 78.6 |
| Other | 35 | 8.4 | 361 | 87.0 |
| None | 44 | 10.6 | 405 | 97.6 |
| Packaged Systems | 10 | 2.4 | 415 | 100.0 |

Frequency Missing = 43

OBS HE016

- 1 STEAM HEAT
- 2 INDUSTRIAL BLOWERS
- 3 FORCED AIR THRU ROOFTOP UNITS
- 4 PACKAGED HEATING SYSTEMS ELECTRIC
- 5 PACKAGED SYSTEMS
- 6 PACKAGED UNITS
- 7 BOILER
- 8 SAME AS AC
- 9 FORST AIR
- 10 GAS WALL UNIT
- 11 RADIANT HEATERS
- 12 ROOF MOUNTED UNIT
- 13 GAS RANGE
- 14 GAS BLOW HEATER
- 15 GAS FORCED AIR
- 16 FORCED AIR-GAS
- 17 SAME SYSTEM AS COOLING
- 18 PACKAGED SYSTEM
- 19 SAME SYSTEM AS COOLING
- 20 SAME AS COOLING
- 21 ATLAS TAKES CARE OF IT
- 22 FORCED AIR SAME AS AC
- 23 NOT SURE BUT ELECTRIC
- 24 SAME AS ABOVE
- 25 FORCED AIR HEAT; GAS BLOWER
- 26 GAS - INFRARED, CATALYTIC, CERAMIC
- 27 4 FORCED AIR 20 TN
- 28 GAS FURNACE WITH SPACE HEATERS
- 29 ELECTRIC SPACE HEATER
- 30 COMBINATION AIR COND./HEATING UNITS!
- 31 FORSTARE
- 32 VARIOUS; EACH CLASSROOM HAS SOMETHING.
- 33 AIR BLOWERS
- 34 SAME AS AIR
- 35 DON'T KNOW, BUT IT'S GAS SOMETHING
- 36 DUAL PACK / GAS HEATERS
- 37 SPACE HEATER
- 38 FORCED AIR GAS
- 39 GAS POWERED
- 40 DUAL ROOFTOP UNITS
- 41 HVAC
- 42 CENTRAL FURNACE
- 43 PACKAGED UNITS
- 44 PACKAGED SYSTEMS
- 45 PACKAGED SYSTEMS
- 46 PACKAGED SYSTEMS
- 47 INDIVIDUAL ELECTRIC ROOM HEATERS
- 48 INDIVIDUAL ROOM HEATING
- 49 4 PIPE SYSTEM
- 50 ELECTRIC HEATER
- 51 PORTABLE GAS HEATERS.

Primary fuel to heat facility

| HE020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

% of facility heated - WTR WKDAY - 8AM

| HE050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Heating operated/all year

| HE059 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 164 | 56.2 | 164 | 56.2 |
| Yes | 128 | 43.8 | 292 | 100.0 |

Frequency Missing = 166

Heating operated/Jan

| HE060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 19 | 6.9 | 19 | 6.9 |
| Yes | 256 | 93.1 | 275 | 100.0 |

Frequency Missing = 183

Heating operated/Feb

| HE061 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 34 | 12.7 | 34 | 12.7 |
| Yes | 233 | 87.3 | 267 | 100.0 |

Frequency Missing = 191

Heating operated/Mar

| HE062 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 90 | 34.2 | 90 | 34.2 |
| Yes | 173 | 65.8 | 263 | 100.0 |

Frequency Missing = 195

Heating operated/Apr

| HE063 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 173 | 67.8 | 173 | 67.8 |
| Yes | 82 | 32.2 | 255 | 100.0 |

Frequency Missing = 203

Heating operated/May

| HE064 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 230 | 92.0 | 230 | 92.0 |
| Yes | 20 | 8.0 | 250 | 100.0 |

Frequency Missing = 208

Heating operated/Jun

| HE065 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 242 | 97.6 | 242 | 97.6 |
| Yes | 6 | 2.4 | 248 | 100.0 |

Frequency Missing = 210

Heating operated/Jul

| HE066 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 246 | 99.6 | 246 | 99.6 |
| Yes | 1 | 0.4 | 247 | 100.0 |

Frequency Missing = 211

Heating operated/Aug

| HE067 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 246 | 99.2 | 246 | 99.2 |
| Yes | 2 | 0.8 | 248 | 100.0 |

Frequency Missing = 210

Heating operated/Sep

| HE068 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 237 | 94.4 | 237 | 94.4 |
| Yes | 14 | 5.6 | 251 | 100.0 |

Frequency Missing = 207

Heating operated/Oct

| HE069 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 166 | 65.1 | 166 | 65.1 |
| Yes | 89 | 34.9 | 255 | 100.0 |

Frequency Missing = 203

Heating operated/Nov

| HE070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 51 | 19.0 | 51 | 19.0 |
| Yes | 217 | 81.0 | 268 | 100.0 |

Frequency Missing = 190

Heating operated/Dec

| HE071 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 18 | 6.6 | 18 | 6.6 |
| Yes | 255 | 93.4 | 273 | 100.0 |

Frequency Missing = 185

Heating operated/Ref

| HE072 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 189 | 96.9 | 189 | 96.9 |
| Yes | 6 | 3.1 | 195 | 100.0 |

Frequency Missing = 263

Heating operated/DK

| HE073 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 195 | 94.2 | 195 | 94.2 |
| Yes | 12 | 5.8 | 207 | 100.0 |

Frequency Missing = 251

Added/replaced/removed heating sys

| HE080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| No chnge | 345 | 85.6 | 345 | 85.6 |
| Added | 22 | 5.5 | 367 | 91.1 |
| Replaced | 30 | 7.4 | 397 | 98.5 |
| Added/Replaced | 3 | 0.7 | 400 | 99.3 |
| Removed | 3 | 0.7 | 403 | 100.0 |

Frequency Missing = 55

Month/Year changed heating

| HE090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| FEB1992 | 1 | 3.8 | 1 | 3.8 |
| AUG1992 | 1 | 3.8 | 2 | 7.7 |
| OCT1992 | 2 | 7.7 | 4 | 15.4 |
| APR1993 | 1 | 3.8 | 5 | 19.2 |
| JUN1993 | 1 | 3.8 | 6 | 23.1 |
| JUL1993 | 1 | 3.8 | 7 | 26.9 |
| MAR1994 | 1 | 3.8 | 8 | 30.8 |
| MAY1994 | 1 | 3.8 | 9 | 34.6 |
| JUN1994 | 1 | 3.8 | 10 | 38.5 |
| JUL1994 | 2 | 7.7 | 12 | 46.2 |
| SEP1994 | 1 | 3.8 | 13 | 50.0 |
| NOV1994 | 1 | 3.8 | 14 | 53.8 |
| DEC1994 | 2 | 7.7 | 16 | 61.5 |
| JAN1995 | 3 | 11.5 | 19 | 73.1 |
| FEB1995 | 2 | 7.7 | 21 | 80.8 |
| MAR1995 | 1 | 3.8 | 22 | 84.6 |
| APR1995 | 1 | 3.8 | 23 | 88.5 |
| JUN1995 | 2 | 7.7 | 25 | 96.2 |
| JUL1995 | 1 | 3.8 | 26 | 100.0 |

Frequency Missing = 432

Year changed heating

| HE091 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 7 | 24.1 | 7 | 24.1 |
| 1993 | 7 | 24.1 | 14 | 48.3 |
| 1994 | 12 | 41.4 | 26 | 89.7 |
| 1995 | 3 | 10.3 | 29 | 100.0 |

Frequency Missing = 429

Old heat fuel type

| HE110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|------------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 19 | 55.9 | 19 | 55.9 |
| Propane/Bottld g | 1 | 2.9 | 20 | 58.8 |
| Steam | 1 | 2.9 | 21 | 61.8 |
| Elec | 13 | 38.2 | 34 | 100.0 |

Frequency Missing = 424

heat addition fuel type

| HE120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 32 | 60.4 | 32 | 60.4 |
| Oil | 1 | 1.9 | 33 | 62.3 |
| Elec | 18 | 34.0 | 51 | 96.2 |
| Other | 2 | 3.8 | 53 | 100.0 |

Frequency Missing = 405

OBS HE121

- 1 ELECRCICITY & NATURAL GAS
- 2 GAS & ELECTRIC

Changed top 10% equip?

| OE010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 410 | 92.6 | 410 | 92.6 |
| Yes | 33 | 7.4 | 443 | 100.0 |

Frequency Missing = 15

Changed H2O heat

| OE012 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 15 | 78.9 | 15 | 78.9 |
| Yes | 4 | 21.1 | 19 | 100.0 |

Frequency Missing = 439

Changed cooking equip

| OE013 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 17 | 94.4 | 17 | 94.4 |
| Yes | 1 | 5.6 | 18 | 100.0 |

Frequency Missing = 440

Changed refrigeration

| OE014 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 13 | 65.0 | 13 | 65.0 |
| Yes | 7 | 35.0 | 20 | 100.0 |

Frequency Missing = 438

Changed HVAC

| OE014B | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|--------|-----------|---------|-------------------------|-----------------------|
|--------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Changed mfg equip

| OE014C | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| Frequency Missing = 458 | | | | |

Changed computers

| OE014D | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| 1 | 5 | 100.0 | 5 | 100.0 |
| Frequency Missing = 453 | | | | |

Changed other1

| OE015 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------------------|-----------|---------|-------------------------|-----------------------|
| ----- | | | | |
| No | 10 | 33.3 | 10 | 33.3 |
| Yes | 20 | 66.7 | 30 | 100.0 |
| Frequency Missing = 428 | | | | |

OBS OE016

- 1 TESTING EQUIP (COMPRESSOR)
- 2 REPLACED COMPUTERS
- 3 COMPUTER
- 4 GOT SMALLER POWER TOOLS
- 5 ADDED COMPUTERS
- 6 ADDING COMPUTERS
- 7 COMMUNICATIONS EQUIPMENT
- 8 ADDED MAINFRAMES
- 9 NEW UPS SYSTEM FOR COMPS
- 10 2 GAS DRYERS
- 11 GAS DISPENSERS
- 12 SOFT START ON 60 HP MOTOR
- 13 BLOWTHERM, HEATING MECH.
- 14 ELECTRIC MOTOR
- 15 4 VEHICLE LIFTS DETAIL SHOP
- 16 ALL KINDS OF MACHINERY
- 17 NEW ELECTRICAL SYSTEM
- 18 ADDED COMPRESSORS
- 19 DISHWASHER
- 20 ADDED CLINICAL LAB
- 21 REPLACED POOL AREA COOLERS

Changed other2

| OE017 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 24 | 92.3 | 24 | 92.3 |
| Yes | 2 | 7.7 | 26 | 100.0 |

Frequency Missing = 432

OBS OE018

- 1 COMPUTERS
- 2 ICE MACHINE

Changed refused

| OE019 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 26 | 100.0 | 26 | 100.0 |

Frequency Missing = 432

Changed dont know

| OE011 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 32 | 97.0 | 32 | 97.0 |
| Yes | 1 | 3.0 | 33 | 100.0 |

Frequency Missing = 425

Month/Year changed H2O heat

| OE020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| DEC1994 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 457

Year changed H2O heat

| OE021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 1 | 33.3 | 1 | 33.3 |
| 1994 | 2 | 66.7 | 3 | 100.0 |

Frequency Missing = 455

Added/replaced/removed H2O heat

| OE030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------|-----------|---------|-------------------------|-----------------------|
| Replaced | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 454

Old H2O heat fuel type

| OE040 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 455

H2O heat addition fuel type

| OE050 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 455

Month/Year changed cooking equip

| OE060 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Year changed cooking equip

| OE061 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1994 | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 457

Added/replaced/removed cooking equip

| OE070 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Added | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 457

Old cooking equip fuel type

| OE080 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

cooking equip addition fuel type

| OE090 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 1 | 100.0 | 1 | 100.0 |

Frequency Missing = 457

Month/Year changed refrigeration equip

| OE100 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|----------------------|--------------------|
| MAR1994 | 1 | 33.3 | 1 | 33.3 |
| DEC1994 | 1 | 33.3 | 2 | 66.7 |
| JUN1995 | 1 | 33.3 | 3 | 100.0 |

Frequency Missing = 455

Year changed refrigeration equip

| OE101 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| 1994 | 3 | 100.0 | 3 | 100.0 |

Frequency Missing = 455

Added/replaced/removed refrig equip

| OE110 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------|-----------|---------|----------------------|--------------------|
| Added | 3 | 42.9 | 3 | 42.9 |
| Replaced | 4 | 57.1 | 7 | 100.0 |

Frequency Missing = 451

Old refrigeration equip fuel type

| OE120 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|----------------------|--------------------|
| Elec | 4 | 100.0 | 4 | 100.0 |

Frequency Missing = 454

refrigeration equip addition fuel type

| OE130 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 7 | 100.0 | 7 | 100.0 |

Frequency Missing = 451

Month/Year changed Other1 equip

| OE140 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1992 | 1 | 12.5 | 1 | 12.5 |
| JUN1992 | 1 | 12.5 | 2 | 25.0 |
| JUL1992 | 1 | 12.5 | 3 | 37.5 |
| MAY1993 | 1 | 12.5 | 4 | 50.0 |
| JUN1994 | 2 | 25.0 | 6 | 75.0 |
| JAN1995 | 1 | 12.5 | 7 | 87.5 |
| APR1995 | 1 | 12.5 | 8 | 100.0 |

Frequency Missing = 450

Year changed Other1 equip

| OE141 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1993 | 3 | 33.3 | 3 | 33.3 |
| 1994 | 4 | 44.4 | 7 | 77.8 |
| 1995 | 2 | 22.2 | 9 | 100.0 |

Frequency Missing = 449

Added/replaced/removed Other1 equip

| OE150 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|----------------|-----------|---------|-------------------------|-----------------------|
| Added | 6 | 30.0 | 6 | 30.0 |
| Replaced | 10 | 50.0 | 16 | 80.0 |
| Added/Replaced | 4 | 20.0 | 20 | 100.0 |

Frequency Missing = 438

Old Other1 equip fuel type

| OE160 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 1 | 7.1 | 1 | 7.1 |
| Elec | 13 | 92.9 | 14 | 100.0 |

Frequency Missing = 444

Other1 equip addition fuel type

| OE170 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------------|-----------|---------|-------------------------|-----------------------|
| Natural Gas | 3 | 15.0 | 3 | 15.0 |
| Elec | 17 | 85.0 | 20 | 100.0 |

Frequency Missing = 438

Month/Year changed Other2 equip

| OE180 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| MAR1994 | 1 | 50.0 | 1 | 50.0 |
| FEB1995 | 1 | 50.0 | 2 | 100.0 |

Frequency Missing = 456

Year changed Other2 equip

| OE181 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Added/replaced/removed Other2 equip

| OE190 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Added | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 456

Old Other2 equip fuel type

| OE200 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Other2 equip addition fuel type

| OE202 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| Elec | 2 | 100.0 | 2 | 100.0 |

Frequency Missing = 456

Made any other energy using changes?

| OC010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 385 | 86.5 | 385 | 86.5 |
| Yes | 60 | 13.5 | 445 | 100.0 |

Frequency Missing = 13

OBS OC020

1 ADDED COMPUTER
2 NEW COMPUTER SYSTEM
3 NEW COMPUTERS AND COPY MACHINES
4 ADDED COMPUERS & PRINTERS
5 ADDED SOME COMPUTERS, ETC.
6 REPLACED COMPUTERS
7 LEAVING LIGHTS FOR RESTAURANT ON ALL NIGHT LONG FOR ADVERTISEMENT
8 ADDED 64 NEW "APARTMENTS" IN 1993
9 REPLACE WATER HEATER
10 NEW TENANTS ON FIRST FLOOR REQUIRE MORE HEAT AND LIGHT
11 CHANGES FROM ATOMIC ABSORPTION TO ICP UNIT
12 COMPUTERS
13 COPY MACHINE
14 NEW TESTING EQUIPMENT
15 COPY MACHINE WAS ADDED
16 RENTED OUT MORE OF THE SPACE
17 ADDITIONAL SPACE OCCUPIED
18 PEOPLE MOVING INTO PREVIOUSLY UNOCCUPIED SPACES
19 COMPUTER SYSTEM & MANUFACTURING EQUIP
20 VACATED BUILDING
21 ADDED MORE MACHINERY
22 CHANGED THERMOSTATS
23 ADDED COMPUTERS
24 MECHANICAL MANAGEMENT
25 ADDED AN AIR VENT FAN
26 TOOK OUT TRACK LIGHTS AND PUT IN FLOURESCENTS
27 SUMMER SCHOOL MEANS INCREASED ENERGY CONSUMPTION
28 PURCHASE OF ENERGY-EFFICIENT WELDING EQUIPMENT
29 NEW LIGHTS ???
30 5 HUGE BULBS IN SHOWROOM; UNCERTAIN OF TYPE, BUT NOT FLORESCENT
31 INSTALLED A COMPUTER NETWORK..w/ 10 WORK STATIONS
32 INSTALLED IN-HOUSE ENERGY MANAGEMENT SYSTEM
33 ELECTRIC CARTS ARE ON A SPECIAL TIME METER
34 ADDED COMPUTERS
35 NEW BOILER IS MORE EFFICIENT.
36 ADDED PORTABLE CLASSROOMS (3) BUILDINGS.
37 HE TOLD ME HERE THAT HE ADDED A SWAMP COOLER
38 REFRIGERATION
39 A SECOND COOLER UNIT WAS ADDED
40 REPLACED ICE MACHINE
41 INSULATED BOILERS FOR HOT WATER
42 ADDED EQUIPMENT FOR MORE POWER
43 REPLACE ICE MACHINE
44 ADDED FREEZER
45 INSTALLED NEW SERVICE PANELS
46 NEW KITCHEN AND STOVES
47 MORE HOURS OF OPERATION
48 BETTER WATER HEATER
49 ADDED SWAMP COOLERS (2 6500 UNITS)
50 CLOSED KITCHEN AREA. NO LONGER USING GAS THERE.
51 INSTALLED A MORE EFFICIENT THERMASTAT & CONSERVATION MEASURES
52 MORE EMPLOYEES USING MORE ENERGY
53 ADDED 4 COMPUTER TERMINALS,ADDED 2 FAX MACHINES, ADDED 2 COPIERS

OBS OC020

- 54 ADDED X-RAY MACHINE
- 55 ADDED COMPUTERS
- 56 ADDED A SOLAR HEATER FOR SWIMMING POOL
- 57 POOL PUMPS, SAUNA HEATING REPLACED.
- 58 INSTALLED SENSORS TO TURN ON AND OFF LIGHTS
- 59 BOUGHT A SMOKE HOUSE
- 60 PUT IN NEW 75 HORSE COMPRESSORS

OBS OC021

- 1 TO LET PEOPLE KNOW THAT THEY ARE THERE.

Month/Year of other change

| OC030 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| JAN1992 | 1 | 4.5 | 1 | 4.5 |
| JUN1992 | 1 | 4.5 | 2 | 9.1 |
| AUG1992 | 1 | 4.5 | 3 | 13.6 |
| JAN1993 | 1 | 4.5 | 4 | 18.2 |
| MAR1993 | 2 | 9.1 | 6 | 27.3 |
| MAY1993 | 2 | 9.1 | 8 | 36.4 |
| OCT1993 | 1 | 4.5 | 9 | 40.9 |
| JAN1994 | 1 | 4.5 | 10 | 45.5 |
| JUL1994 | 1 | 4.5 | 11 | 50.0 |
| SEP1994 | 1 | 4.5 | 12 | 54.5 |
| NOV1994 | 2 | 9.1 | 14 | 63.6 |
| DEC1994 | 2 | 9.1 | 16 | 72.7 |
| JAN1995 | 1 | 4.5 | 17 | 77.3 |
| APR1995 | 1 | 4.5 | 18 | 81.8 |
| MAY1995 | 2 | 9.1 | 20 | 90.9 |
| JUN1995 | 1 | 4.5 | 21 | 95.5 |
| JUL1995 | 1 | 4.5 | 22 | 100.0 |

Frequency Missing = 436

Year of other change

| OC031 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1992 | 4 | 12.5 | 4 | 12.5 |
| 1993 | 13 | 40.6 | 17 | 53.1 |
| 1994 | 13 | 40.6 | 30 | 93.8 |
| 1995 | 2 | 6.3 | 32 | 100.0 |

Frequency Missing = 426

Is there an EMS system?

| EM010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 410 | 92.8 | 410 | 92.8 |
| Yes | 32 | 7.2 | 442 | 100.0 |

Frequency Missing = 16

Month/Year EMS installed

| EM020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|---------|-----------|---------|-------------------------|-----------------------|
| AUG1984 | 1 | 14.3 | 1 | 14.3 |
| NOV1985 | 1 | 14.3 | 2 | 28.6 |
| JUN1987 | 1 | 14.3 | 3 | 42.9 |
| SEP1990 | 1 | 14.3 | 4 | 57.1 |
| AUG1992 | 1 | 14.3 | 5 | 71.4 |
| FEB1995 | 1 | 14.3 | 6 | 85.7 |
| JUN1995 | 1 | 14.3 | 7 | 100.0 |

Frequency Missing = 451

Year EMS installed

| EM021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 1977 | 2 | 11.1 | 2 | 11.1 |
| 1982 | 1 | 5.6 | 3 | 16.7 |
| 1983 | 1 | 5.6 | 4 | 22.2 |
| 1986 | 1 | 5.6 | 5 | 27.8 |
| 1988 | 2 | 11.1 | 7 | 38.9 |
| 1989 | 2 | 11.1 | 9 | 50.0 |
| 1990 | 2 | 11.1 | 11 | 61.1 |
| 1991 | 2 | 11.1 | 13 | 72.2 |
| 1992 | 2 | 11.1 | 15 | 83.3 |
| 1994 | 2 | 11.1 | 17 | 94.4 |
| 1995 | 1 | 5.6 | 18 | 100.0 |

Frequency Missing = 440

Is there a cogeneration plant?

| CP010 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| No | 443 | 98.9 | 443 | 98.9 |
| Yes | 5 | 1.1 | 448 | 100.0 |

Frequency Missing = 10

Month/Year cogeneration installed

| CP020 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
|-------|-----------|---------|-------------------------|-----------------------|

Frequency Missing = 458

Year cogeneration installed

| CP021 | Frequency | Percent | Cumulative Frequency | Cumulative Percent |
|-------|-----------|---------|-------------------------|-----------------------|
| 9 | 1 | 20.0 | 1 | 20.0 |
| 1978 | 1 | 20.0 | 2 | 40.0 |
| 1988 | 1 | 20.0 | 3 | 60.0 |
| 1991 | 2 | 40.0 | 5 | 100.0 |

Frequency Missing = 453

Appendix J

PURCHASE DECISION LOGISTIC REGRESSION MODEL

Appendix J

PURCHASE DECISION LOGISTIC REGRESSION MODEL

A logistic regression model predicting free ridership was developed using self-report data in a pooled model incorporating data from all surveyed Lighting Program participants in the commercial sector. *Section 3 (Methodology)* contains a description of the superset of variables included in the model and rationale for their inclusion. This appendix describes the analytical steps undertaken in the model selection, building, and refinement process and presents the final model results.

Exhibit J-1 presents the variables used in the decision logistic regression model.

Exhibit J-1
Self-Reported Free Ridership: Superset of Model Variables

| Model Variable | Wording of Question | Predicted Direction | | In Final Model |
|---|---|--------------------------------------|---|----------------|
| | | Net Participant | Free Rider | |
| TIMING OF PLANS | | | | |
| PERIOD_ BEFORE_ AWARE | How long were you considering <the measure> before you heard about the program? | short- moderate period | longer period | |
| NO_PLANS | Wasn't planning on purchase until approached | yes | no | x |
| PERIOD_ AFTER_ AWARE | How long did you take to decide to participate after becoming aware of the program? | longer period | shorter period | x |
| WAIT_NO_ PGM | How long would you have waited to <take the measure> without the program? | longer period | shorter period | x |
| WAIT_FOR_ PGM | Did you delay a retrofit in order to participate? | no | yes | |
| OPTIONS | | | | |
| QUOTES | How many estimates or quotes did you obtain before purchasing your new equipment? | few | many | |
| STD_EQUIP | Did you consider purchasing standard-efficiency equipment? | yes | no | x |
| BROKEN | (Did the customer mention broken equipment?) | yes | no | |
| PROGRAM INFORMATION AND BENEFITS | | | | |
| PGE_CONTA | How many times a year do you have contact with your PG&E rep? | few | many | |
| REBATE | (Did the customer mention the rebate?) | yes | no | |
| BILL_ SAVINGS | (Did the customer mention bill savings?) | yes | no | |
| FREE_RIDE | Before you knew about the program, which of the following statements best describes your company's plans to <take the measure>? | had consi- dered, but no plans | planning to do it within the next 12 months | |

J.1 Variables Excluded from Model

With the exclusion of PERIOD_BEFORE_AWARE, bivariate relationships between independent variables and FREE_RIDE (examined through cross-tabs and bivariate logistic regressions) showed them to be sufficiently associated. (i.e., they were at least marginally statistically significant.) These variables were therefore included in initial model runs. Variable PERIOD_BEFORE_AWARE was dichotomized, classifying customers into two groups: those who were and those who were not in the market for energy efficient lighting equipment before they heard about the program.

J.2 Functional Form of Variables Included in Free Ridership Model

“Yes” or “No” questions were entered into the initial model as dummy variables coded either “1” or “0.” Continuous variables WAIT_NO_PGM, QUOTES, PERIOD_AFTER_AWARE, and PGE_CONTACT were initially entered as continuous covariates with Box-Tidwell transformation terms. The Box-Tidwell terms allow one to test for nonlinearity in the logit; they are formed by creating an additional variable, “xlnx,” for each continuous variable. A logistic regression is then run with just two covariates: x and xlnx. When the xlnx term is statistically significant, there is evidence of nonlinearity. This data screening process was carried out for each of the continuous variables in the model. Results of these tests showed that WAIT_NO_PGM could be entered as a continuous variable, but QUOTES, PERIOD_AFTER_AWARE, and PGE_CONTACT demonstrated nonlinear components and needed recoding. Techniques following Hosmer and Lemeshow¹ were used to identify the correct functional forms of QUOTES, PERIOD_AFTER_AWARE, and PGE_CONTACT. A variable was created for PERIOD_AFTER_AWARE, which was set equal to the natural logarithm of PERIOD_AFTER_AWARE². Further follow-up tests showed that QUOTES and PGE_CONTACT should be provisionally retained in the model as a continuous, untransformed variables.

¹ Hosmer, D., and Lemeshow, S. (1989). *Applied Logistic Regression*. Wiley, New York.

² In order to account for the many “0” responses, values of “0” were set to 1×10^{-6} before taking their natural logarithm. This resulted in minimum values equal to -14 for this variable.

J.3 Variables Dropped from Model During Model Building

The initial, full model contained all variables mentioned previously. The model-building process involved testing subsets of variables until stable results were obtained. Criteria used to drop variables from the model included nonsignificant regression coefficients (e.g., the Wald Chi-Square test was not significant in a multivariate model) and nonsignificant change in model log-likelihood ratios with the inclusion or omission of the variable.³

The QUOTES, WAIT_FOR_PGM, PGE_CONTACT, REBATE, BILL_SAVINGS, and BROKEN variables proved consistently nonsignificant and were dropped.

J.4 Goodness-of-Fit Tests: Outliers, High Leverage Values, and Influential Observations

Pearson residuals, deviance residuals, and hat values resulting from the later model specifications were examined. In the final model, Pearson residuals had an average value of 0.025, and a variance of 0.938. This quantity is thought to be $N(0,1)$ ⁴ when the model is correctly specified. Deviance residuals followed the same pattern as the Pearson residuals, with the same observations showing extreme values. Overall, fourteen cases had Pearson or deviance residuals greater than 2 or less than -2. This represents just over 5% of the sample used in the final model. Hat values showed that high-leverage values were not also influential outliers. Large hat values indicate points with undue weight on regression results and/or parameter estimates. Using a criterion of hat values exceeding $2k/n$ [where k is the number of independent variables and n is the number of observations in the model], only 10% of the cases demonstrated high leverage. Six of the fourteen outliers (or 2% of the sample) had leverage values greater than the criterion.

An examination of outliers revealed that the model tended to underpredict free ridership by anywhere from 2% to 20%. For this reason, an adjustment was made to the predicted free ridership values using the following adjustments: If 2% of the H.I.D. cases were underpredicted, the “adjusted” free ridership value for the H.I.D. technology group was increased by 2%.

³ Hosmer, D., and Lemeshow, S. (1989). *Applied Logistic Regression*. Wiley, New York.

⁴ Normally distributed with a mean=0 and a variance=1.

J.5 Collinearity

Correlations between the continuous independent variables were checked, as well as the correlation matrix of regression coefficients.

J.6 Missing Data

Because many of the survey questions used in the model required the customer to recall various decision-making stages, there was a fair amount of missing data. Rather than including missing data with mean or median values, the model was run with fewer observations. If the sample size had permitted, cross-validation of model results on a hold-out dataset would have been performed, but these data were not available. The final model was run with sample weights. The weighted model was statistically significant, but individual variables differed in their statistical significance from the unweighted model. The final free ridership estimates were made using the coefficients obtained from the weighted commercial model.

J.7 Precision of Results

Results presented in *Section 4* are shown with 90% confidence intervals. Error levels used correspond to predicted average values for the technology group.

Exhibit J-2

Descriptive Statistics for Variables Included in Final Model

| Variable | N | Mean | Std | Min | Max |
|--------------------------------|-----|--------|-------|-----|-----|
| NO_PLANS (0,1) | 407 | 0.763 | 0.416 | 0 | 1 |
| WAIT_NO_PGM (years) | 304 | 7.505 | 5.083 | 0 | 20 |
| STD_EQUIP (0,1) | 422 | 0.246 | 0.421 | 0 | 1 |
| PERIOD_AFTER_AWARE [ln(weeks)] | 409 | -3.437 | 7.120 | -14 | 4 |
| FREE_RIDE (0,1) | 431 | 0.116 | 0.314 | 0 | 1 |

Source: Telephone Survey Data

J.8 Descriptive Statistics

All but one of the independent variables in the model are continuous. Mean values for dummy variables are the percentage of customers reporting, "yes," or otherwise responding affirmatively.

As shown in Exhibit J-2, many customers mentioned that they were not even in the market for lighting products when they were approached about the program (NO_PLANS = 76%). Further evidence that the program is contractor driven is provided by the retrofit plans of program participants: customers on average would have waited over 7 years to replace their lighting equipment. Consistent with these results is a low univariate self-reported free ridership rate: according to question FREE_RIDE, fewer than 12% of the sample members were classified as free riders.

Exhibit J-3
Final Model Results

Unweighted

| <u>Variable</u> | <u>B</u> | <u>SE</u> | <u>Wald Chi-Square</u> | <u>P</u> |
|------------------------|-----------------|------------------|-------------------------------|-----------------|
| NO_PLANS | -0.9210 | 0.5003 | 3.3888 | 0.0656 |
| WAIT_NO_PGM | -0.1982 | 0.0534 | 13.7665 | 0.0002 |
| STD_EQUIP | -0.7028 | 0.5713 | 1.5133 | 0.2186 |
| PERIOD_AFTER_AWARE | -0.0555 | 0.0316 | 3.0713 | 0.0797 |
| INTERCEPT | -0.5377 | 0.4515 | 1.4185 | 0.2336 |
| N | 257 | | | |
| -2LLR | 26.018 | | | |
| P | 0.0001 | | | |

Weighted

| <u>Variable</u> | <u>B</u> | <u>SE</u> | <u>Wald Chi-Square</u> | <u>P</u> |
|------------------------|-----------------|------------------|-------------------------------|-----------------|
| NO_PLANS | -0.5787 | 0.5256 | 1.2123 | 0.2709 |
| WAIT_NO_PGM | -0.2247 | 0.0625 | 12.9201 | 0.0003 |
| STD_EQUIP | -0.4777 | 0.5758 | 0.6884 | 0.4067 |
| PERIOD_AFTER_AWARE | -0.0431 | 0.0340 | 1.6044 | 0.2053 |
| INTERCEPT | -0.8329 | 0.4647 | 3.213 | 0.0731 |
| N | 257 | | | |
| -2LLR | 23.598 | | | |
| P | 0.0001 | | | |

Source: Telephone Survey Data

J.9 Model Results

Results shown in Exhibit J-3 show the logistic regression coefficients (B), their standard errors (SE), Wald Chi-Square values⁵, and the probability associated with the parameter estimate for each variable included in the model. All variables retained in the final unweighted model were significant at the $p < .10$ level, except STD_EQUIP which was marginally significant. The overall weighted model-2 log-likelihood ratio, a measure of goodness-of-fit, was 23.60, with four degrees of freedom ($p < .0001$). This indicates a statistically significant model. Data contributed to the final model came from 257 customers, from a possible 440 customers. As stated above, we elected to run the model with fewer data points rather than drop interesting variables with higher percentages of missing data. As with all behavioral models, results should be considered provisional and viewed in context. Cross-validation of the model on a separate dataset would test the reliability of the model in predicting free ridership and help strengthen conclusions.

All variables showed effects in the direction predicted (see *Section 3*, pages 3-38 and 3-39 of the report). The natural logarithm of PERIOD_AFTER_AWARE (PERIOD_AFTER_AWARE_LN) term showed a monotonic effect, with the probability of being a free rider decreasing as the amount of time to reach a decision to participate increased.

J.10 Predicted Free Ridership

Model results were used to obtain probabilities of free ridership for each lighting technology group. These probabilities were calculated in SAS using Proc Logistic. The probability of being a free rider, for any given technology group is

$$\hat{p} = \frac{e^{bX}}{1 + e^{bX}}$$

where b is a vector of regression coefficients and X is a vector of mean values for the different explanatory variables. A probability for free ridership was assigned to each technology group by calculating the mean values for all the independent variables included in the model, for that technology group. These were then multiplied by their respective regression coefficients to yield the term “ bX ”. This term was exponentiated and the ratio of $e^{bX}/(1+e^{bX})$ formed the predicted probability of free ridership for each technology group. These were then combined with spillover estimates (as described in *Section 3*) to yield NTG ratios.

⁵ analogous to a t statistic

Appendix K

GROSS ENERGY AND DEMAND IMPACTS BY COSTING PERIOD

Appendix K

SUMMARY OF GROSS PROGRAM IMPACTS BY COSTING PERIOD

Unadjusted program gross demand and energy impacts are summarized by time-of-use (TOU) costing periods in Exhibit K-1, yielding important H-factor information in support of Pacific Gas and Electric Company's (PG&E's) cost-effectiveness calculations. The following hours were selected from the PG&E costing periods when generating demand figures:

- Summer on-peak is defined as the weekday hour 3:00 PM to 4:00 PM.
- Summer partial-peak is defined for two distinct weekday hours: 11:00 AM to noon, and 6:00 PM to 7:00 PM.
- Summer off-peak is defined as the weekday hour 8:30 AM to 9:30 AM. To estimate this impact for this hour, a mean impact was generated using the hours 7:00 AM to 8:00 AM, and 8:00 AM to 9:00 AM.
- Winter partial-peak is defined as the weekday hour 5:00 PM to 6:00 PM.
- Winter off-peak is defined as the weekday hour 8:30 AM to 9:30 AM. To estimate this impact for this hour, a mean impact was generated using the hours 7:00 AM to 8:00 AM, and 8:00 AM to 9:00 AM.

The results presented in Exhibit K-1 were generated using evaluation program impact estimates for every hour in a year (8,760 hours). In general, the estimates provided are based upon only those specific hours that comprise a particular row (or costing period) in the exhibit. Whether demand or energy, the impacts presented reflect all contributing hours during that period, a mean or total, respectively. The following describes in greater detail how each column in the exhibit was calculated using evaluation impact results:

- Program gross unadjusted kW impacts are presented in the first column for a single specified hour of the day. In all cases, the hour specified occurs on a weekday. Each impact is the mean impact for a particular hour of the day, across all contributing days and customers. To achieve this, customer- or measure-specific mean estimates were taken across all contributing days; these intermediate mean estimates were then summed across all contributing customers and/or measures.

Summary of Gross Program Impacts by Costing Period

- The second column, the kW adjustment factor, is the ratio of each program demand impact (column 1 kW savings) to the summer on-peak demand estimate.
- The third column, kWh savings, is the sum of all hourly impacts during each costing period for all applicable daytypes. Note that some costing periods only contain weekdays, while others include both weekdays and weekends. The sum of all contributing rows is equal to the annual program impact.
- The fourth column, kWh adjustment factor, is the ratio of each program energy impact (column 3 kWh savings) to annual total energy savings.

Exhibit K-1
Gross Demand and Energy Savings by Costing Period
For COMMERCIAL Indoor and Outdoor Lighting Measures

| PG&E Cost Period | INDOOR Lighting | | | | OUTDOOR Lighting | | | |
|---|--|----------------------|-------------|-----------------------|--|----------------------|-------------|-----------------------|
| | Program kW Savings Coin. with System Max in Period | kW Adjustment Factor | kWh Savings | kWh Adjustment Factor | Program kW Savings Coin. with System Max in Period | kW Adjustment Factor | kWh Savings | kWh Adjustment Factor |
| Summer On-Peak: May 1 to Oct. 31 12:00 - 6:00 PM Weekdays | 62,389 | 1.00 | 48,148,944 | 0.16 | 782 | 1.00 | 782,958 | 0.04 |
| Summer Partial Peak: May 1 to Oct. 31 8:30 AM - 12:00 PM Weekdays | 63,075 | 1.01 | 27,823,952 | 0.09 | 1,884 | 2.41 | 857,913 | 0.05 |
| Summer Partial Peak: May 1 to Oct. 31 6:00 PM - 9:30 PM Weekdays | 41,847 | 0.67 | 15,178,433 | 0.05 | 502 | 0.64 | 832,926 | 0.05 |
| Summer Off-Peak: May to Oct. 31 Other | 46,227 | 0.74 | 72,952,950 | 0.24 | 2,030 | 2.59 | 6,628,869 | 0.37 |
| Winter Partial Peak: Nov. 1 to April 31 8:30 AM - 9:30 PM Weekdays | 47,804 | 0.77 | 79,112,554 | 0.26 | 933 | 1.19 | 2,436,030 | 0.13 |
| Winter Off-Peak: Nov. 1 to April 31 9:30 PM - 8:30 AM Other | 41,394 | 0.66 | 61,163,621 | 0.20 | 2,030 | 2.59 | 6,519,670 | 0.36 |

Appendix L

EX ANTE NET-TO-GROSS RATIOS

Appendix L

EX ANTE NET-TO-GROSS RATIOS

The attached print-outs list the net-to-gross ratios that are being applied in the MDSS as a function of the business type, the application (indoor vs. outdoor), and the technology. Also listed is the frequency of occurrence.

These are enclosed to document discussions of varying MDSS net-to-gross ratios in *Sections 4 and 5* of the main body of the report.

Appendix M

COMMERCIAL REFUSAL COMMENTS

Appendix M

RE/CUSTOMIZED PROGRAM PARTICIPANTS: REASONS FOR REFUSING THE SURVEY

The following pages present comments made by participants at the time they refused to participate. The comments begin on the top half of the page and, if necessary, continue on the bottom half of the page under the same observation (OBS) number.

OBS COMMENT1

1 PREFERS NOT TO SPEND A LOT OF TIME ANSWERING QUESTIONS, PREFERS TO*
2 THE OTHER DATA SETS WERE ON CATI 12 AND IT WAS CODED AS A PARTIAL
3 They liked the program very much except for the long survey at**MYT
4 SEE QC 50 FOR THE COMMENTS
5 Bruce was getting irate about the questions asked because**DET
6 Susan says that survey is too long and really can't take the time t
7 VIRGINIA NEVER ASKED HOW LONG IT WOULD TAKE WHEN I CALLED BACK SHE*
8 Trish at Marin Office for DCOMP and Tom Tantriella for TCOMP**JRJ**
9 did not really want to answer any more questions, but did; had a**C
10 THAT ASKING ABOUT ST #A WAS POINTLESS, IT'S SMALL PART OF FACIL.**J
11 Mr. R was irritated w/ c/b, thinking he'd completed it already**JRJ
12 PHS is happy with PG&E's services but does not have time to**MYT
13 Trudy did part, got started, then was interupted, said to c\b**SGW
14 (6-21)Mr. Singh wants hardcopy to complete survey, stopped @**REJ
15 Mr. Singh had difficulty understanding the questions;had customers*
16 Need to completed TCOMP section.-gv--**REJ
17 Matthew Duran got to sc. 88 before he refused to continue.
18 Mr. Clark didn't know exactly when the work was done,**REJ
19 Mr. Respini stated that the questions were to personal did not care*
20 Ted said that "you're just gonna have to live with that" he has no*
21 Mr. Yablon said he was very happy w/ his metal halide lights and th
22 he does not want to continue.**CG
23 completed decision maker questions w\Tom Ritter. He didn't know**RE
24 Tim did LCOMP referred us to Comptroller Jan Petersen for rest**JRJ
25 **CG

OBS COMMENT2

1 DO WORK. STOPPED AT SCREEN 47.**CJG
2 REFUSED ON THAT CATI.
3 the end...suggest to cut down on length of survey*
4
5 he insisted that they do not qualify b/c are multi tenant.**DET
6 o finish it. She apologizes but suggests a 10 min. survey.**HEM
7 SAID IT HAD BEEN LONG ENOUGH ALREADY.**CG
8 **JRJ
9 skip problem. ***KAY Survey seems to have stopped at screen 80.**SG
10 MAILED SURVEY. DO *NOT* CALL THIS GENTLEMAN BACK.**JTM
11 Requests we not call again, he "has no time"**JRJ
12 complete survey***MYT
13 CALLED BACK, SHE REFUSED TO CONTINUE BECAUSE "TOO MANY QUESTIONS".*
14 sc 47. ***REJ
15 wanted a print out of the rest of the questions**REJ
16 lcomp not complete, but John was very irritated 2 being called(SC2)
17
18 and didn't have time to complete the survey**REJ
19 to continue.**JS
20 more time to spend on this***MYT
21 e good PR but has no time for a phone survey.SC34***JRJ
22 **CG
23 who good tech contact would be.
24 Jan said they are moving so a survey is not helpful at this time**J
25 **CG

OBS COMMENT1

26 see qc 358 for the comments
27 The survey skipped to the on-site scheduling, when only the "DCOMP"
28 Left off on screen 87. Gary will NOT call 800 # to continue survey.
29 Mr. Holtzinger became very agitated at the financial questions**REJ
30 he said that he is a very BUSY man.**MYT
31 refused to continue fr sc35
32 MR. MOHAMED STARTED SURVEY STOPPED ON SCR. 28 HE COULDN'T UNDERSTAN
33 Started w\Mr. Anast. He had some difficulty understanding the**REJ
34 DID NOT WANT OT FINISH SURVEY FELT ? WERE IRRELEVANT. BECAUSE HE ON
35 mr. stanhor got to scr. 91 and decided to stop the survey said that
36 Johanna completed decision making and lighting ques..for technical*
37 the Office Manager completed l&2; said Dr. Williams didn't take
38 Dr. Liebowitz does not wish to give more time to the survey. Got to
39 doctor does not want to continue the survey**CG
40 see msfd293 for the comments.
41 completed first 2 sections w\Mr. Tom; there is no contact for
42 DID NOT HAVE TIME TO COMPLETE SURVEY.**ALS
43 Terry Turner sounds irritated and didn't want to go on b/c he did**
44 GREG COMPLETED PART OF THE SURVEY,WAS INTERESTED IN FINISHING THE**
45 He's too busy today to do survey so he suggested that we call until
46 Mr. Baker says they just redid the lighting again through PG&E &**J
47 REFUSED TO COMPLETE SURVEY**LMC
48 he said that he could answer the questions for the descision makein
49 HE DOES NOT WANT TO DO THE SURVEY AT ALL.**CJG
50 mr olson stated that he didn't have time for a survey and will

OBS COMMENT2

26
27 section was competed.**KAY On-Site Refused, so its a PARTIAL... **KA
28 No time; refused to continue: PARTIAL.
29 Had to T&T stopped @ sc 32**REJ
30 **MYT
31
32 D ENGLISH TOO WELL.**RRF
33 questions, had to leave. did not want c\b**REJ
34 LY PURCHASED A FEW LIGHT BULBS.**ALS
35 it was entirley too long and how did we expect someone(see scr. 2)*
36 call Rona Griego @ (714)721-8000**MYT left 800# on machine**MYT
37 ph calls. therefore don't c\b.**REJ
38 screen 88.**BB
39 **CGthe secretary scolded me**CG
40 do not call.**DSH
41 tech questions.**REJ
42
43 not know the answers to some questions**MYT
44 OTHER HALF BUT JUST HAS NO TIME SO SEND HIM A HARD COPY.**DET
45 we catch him w/some time to spare.**HEM Refused on 6/13**HEM
46 says this survey is just "flogging a dead horse"**JRJ
47
48 g part but there is no one else for the other sections of the surve
49
50 never have time for one.

OBS COMMENT1

51 MRS. CALVERT SAID THAT SHE DON'T THINK THEY WOULD HAVE MUCH INFO. T
52 Wasn't interested in doing a survey that takes so long b/c he is a*
53 adele refused to do survey b/c she said that she doesn't have time*
54 spoke w\Chuck Carpenter, who was dissatisfied with PG&E and**REJ
55 see qc 114 for comments**
56 Dave said that he's sure that he had already completed this**MYT
57 see qc 114 for comments**
58 Martha said she does not have the time, she has three children and
59 see qc 114 for comments**
60 MR. KIMBALL KEPT SAYING HE REMEMBER GETTING A REBATE AND DOING**CJG
61 see qc 114 for comments**
62 Mr. Calatto (owner of building) was not interested in doing the**HE
63 Refused b/c she can't take that much time out of her day to answer*
64 Charlaotte says her boss does not want her to complete the survey**
65 Mr. Bal said that he is too busy and refuses to take survey**MYT
66 MR. SEILER SAID THAT HE DOSEN'T LIKE TO DO THINGS OVER THE PHONE
67 see qc 114 for comments**
68 Liked the program and would do the survey if we can consolidate it*
69 Lou said that they have already done the survey***MYT
70 Said he's busy and does not want to participate in a survey**MJP
71 1st # is wrong. Sec said Doug is volunteer, send something in the**
72 ty shettron is no longer with the company and mary hunter took his*
73 BUNNIE JUST DOESN'T HAVE THE TIME TO DO ANY SURVEYS.**JGP
74 Office mgr said she would never have the time to do a survey**MJP
75 see qc 42 for the comments.**DSH

OBS COMMENT2

51 O HELP US OUT BECAUSE THEY ARE A SMALL FIRM**RRF
52 one man show at this address.**HEM
53
54 refused survey**REJ
55
56 survey.**MYT
57
58 is just too busy.
59
60 THE PAPER WORK, BUT HE CLAIMS THERE IS NO ONE TO DO SURVEY.**CJG
61
62 survey. Ezekiel Contreras referred us to Mr. Calatto for info.**HE
63 questions.**HEM
64 please send hard copy**JRJ
65
66 AND JUST ended the call
67
68 to a 1 minute survey.**HEM
69 **MYT
70
71 mail & he'll get it.**REJ
72 place and stated that she had no time and didn't know (see scr 2)**
73 **JGP
74
75

OBS COMMENT1

76 refused b/c he was too busy to participate***MYT
77 LOGGED ON TWICE BY MISTAKE CHUCK DECLINED TO DO THE SURVEY IT WOULD
78 John said "I don't have 15 min for a survey."
79 see qc 114 for comments**
80 see qc 114 for comments**
81 see qc 114 for comments**
82 Kathy said she didn't have time, they have just two lines, and**REJ
83 CHARLES YOZSA HAD A STROKE AND CANNOT SUCCESSFULLY COMPLETE THE SUR
84 DO NOT CALL BACK. STATED HE DID SURVEY WITH ANOTHER COMPANY.**SMB
85 Mr.Lucke said he had no time for survey He had already completed**R
86 DO NOT CALL HIM BACK; HE SAID HE WAS ALREADY CONTACTED BY ANOTHER**
87 DON NOT CALL BACK. STATED HE ALREADY DID A SURVEY WITH ANOTHER**SM
88 DO NOT CALL BACK. STATED HE DID THE SURVEY WITH ANOTHER**SMB
89 DO NOT CALL. HE STATED THAT HE HAD DONE A SURVEY WITH ANOTHER COMP.
90 DO NOT CALL. HE STATED THAT HE HAD DONE A SURVEY WITH ANOTHER COMP.
91 DO NOT CALL. HE STATED THAT HE HAD DONE A SURVEY WITH ANOTHER COMP.
92 GARY SAID "I DONT DO SURVEYS THAT LONG OVER THE PHONE" THAK YOU**CG
93 ms. kimber didn't want to participate in the survey, she was too**D
94 DO NOT CALL. HE STATED THAT HE DONE A SURVEY WITH ANOTHER COMPANY.*
95 He isn't interested and claims that he has already participated in*
96 Asked who is paying for survey, when told it was for PG&E he refuse
97 This is a pager #, not an answering machine.**DT**DT
98 busy no time to do survey**LMC
99 larry does not have time to answer questions at all**KYS
100 DO NOT CALL. HE HAD STATED THAT HE HAD DONE A SURVEY WITH ANOTHER**

OBS COMMENT2

76 **MYT
77 TAKE TO LONG.**CG
78
79
80
81
82 she'd preffer that we send the survey through the mail**REJ
83 VEY**JGP
84
85 one survey, didn't want to be involved in another**REJ
86 COMPANY WHO DID A SURVEY WITH HIM THIS MORNING.
87 COMPANY
88 COMPANY.**SMB
89
90
91
92
93 busy.**DSH
94
95 this survey.**HEM
96 d to take survey or offer explanation for his refusal**MJP**MJP
97 Mr. Mannina, Sr declined to answer most questions, then terminated.
98
99 **KYS
100 COMPANY.**AD

OBS COMMENT1

101 see qc 376 for comments**
102 DO NOT CALL. HE STATED THAT HE HAD DONE A SURVEY WITH ANOTHER COMP.
103 mr. WATSON SAID that THEY HAVE LIGHTING CONTRACTORS THAT DO SURVEYS
104 Mickie says they've just started their harvest season and will have
105 DO NOT CALL. HE STATED THAT HE HAD DONE A SURVEY WITH ANOTHER COMP.
106 DO NOT CALL. HE STATED THAT HE HAD DONE A SURVEY WITH ANOTHER COMP.
107 SAID THAT HE'S NOT INTERESTED IN DOING SURVEY, HE SAID THAT HE'S**R
108 DO NOT CALL. HE STATED THAT HE HAD DONE ANOTHER SURVEY WITH ANOTHER
109 see qc 81 for the comments**
110 DO NOT CALL. HE STATED THAT HE HAD DONE ANOTHER SURVEY WITH**AD
111 DO NOT CALL. HE STATED THAT THEY HAD DONE A SURVEY WITH ANOTHER**AD
112 too busy, pg&e has surveyed him very recently, not us., he thinks
113 Pete was in a serious hurry. refused oral survey, wanted written**R
114 see qc 114 for comments**
115 see qc 114 for comments *****
116 MR. ZIEGLAR PREFERS NOT TO ANSWER ANY QUESTIONS.**CJG
117 see qc 114 for comments**
118 see qc 114 for comments**
119 John said he did not have time after I told him it would take 20-25
120 DO NOT CALL BACK. HE STATED THAT HE DID SURVEY WITH ANOTHER COMP.*
121 Said she had taken survey and didn't feel it applied to her, so ref
122 Chuck refused after I told him it would take 20-25 min.
123 Jim Hamlin is no longer there, manager that was there knew nothing
124 bob does not do surveys**JGP
125 SHE FEELS THAT IT IS JUST TO MUCH TIME (ABOUT 20 MIN. OR SO) TO

OBS COMMENT2

101
102
103 FOR THEM AND THAT HE REALLY DIDN'T THINK THAT THEY(SEE SCR. 2)**DSH
104 no time for a survey until late NOV or DEC**JRJ
105
106
107 VERRY HAPPY WITH PROGRAM.**RRF
108 COMPANY.**AD
109
110 ANOTHER COMPANY.**AD
111 COMPANY.**AD
112
113 one***REJ
114
115
116
117
118
119 min.
120
121 used.**MJP
122
123 about program.**DET
124 **JGP
125 TAKE UP ANSWERING QUESTIONS.**CJG

OBS COMMENT1

126 DO NOT CALLBACK. STATED THAT HE DID SURVEY WITH ANOTHER COMPANY.**
127 DO NOT CALL BACK. STATED HE DID SURVEY WITH ANOTHER COMPANY**SMB
128 He's hard to get a hold of so I left the 800#. Piero is the buildi
129 LARRY SAID THAT HE HAS ALREADY DONE A SURVEY REGARDING THE LIGHTING
130 Bob Lycette recomended Jenny Scarlet who refused the survey because
131 Spoke to Brett who said he couldn't spend 20 minutes on a survey.**
132 mr. webb stated that he was just too busy at the time so he chose t
133 MS. UNDERWOOD PUT ME THROUGH TO A WOMAN NAMED IRENE. doesn't have t
134 Carl says he already did a survey on this and hasn't had any new li
135 Irene said she wants a survey in the mail, but is not willing to
136 JAN SAID THAT THE SURVEY IS ENTIRELY TOO LONG BUT SHE DID HAVE A
137 PAM ABRUPTLY ended the call AND STATED THAT SHE WAS NOT INTERESTED IN**KAY
138 Refused to take a survey for 20 min even if done in parts**MJP
139 Kim said it would be impossible to do survey on ph, but if we**REJ
140 MAUREEN SAID SHE DOES NOT HAVE 15 MIN.SHE SAID THERE WAS NO GOOD TI
141 JOHN WAS BUSY. HE SAID IT TAKES TOO MUCH TIME & TIME IS**JLG
142 MAGNUS SAID HIS CO. WAS TO SMALL. REFUSED TO DO SURVEY.**KAY
143 CONNIE SAYS SHE HAS CUSTOMERS ALL DAY AND DOES NOT HAVE THE TIME TO
144 Mrs. Theile stated that its a small business and they do not have t
145 BEFORE I COULD EXPLAIN WHO I WAS CALLING FOR HE SAID HE WAS ALL**KY
146 I ONLY HAVE ONE SET OF LIGHTS AND DONT CARE TO PARTICIPATE.**CG
147 Mr. Olivera had already done this survey with another interviewer**
148 Mr. West refused to do the evaluation on the phone b/c he can not**
149 Mary Lou not in, new secretary doesn't know her schedule**JRJ
150 joe's out of town today will be back in tomorrow morning.**DSH

OBS COMMENT2

126
127
128 ng manager.**HEM SECT'Y SAID HE GOT THE MESSAGE. WAIT A WHILE,C/B.*
129 RETROFIT WITH SOMEONE ELSE..AND DOENS'T WISH TO DO THIS ONE.**MYT
130 she did not have 20-25 min.
131
132 o decline the survey.**DSH
133 time until Sept--refused***lmc**LMC
134 ghting done since that survey**JRJ Mistaken entry**156
135 complete the survey over the phone.
136 GOOD DISPOSITION.
137 DOING THIS SURVEY**KAY
138
139 send her something, she'd gladly fill it out**REJ**REJ
140 ME TO CALL HER BACK**CG tried to find someone else no luck**CG
141 MONEY. DID NOT WANT TO CONTINUE.
142
143 DO THE SURVEY**JGP
144 he 20-30 min. They are assisting customers.**JMS
145 TAKEN CARE OF AND ended the call**KYS
146 **AD
147 so he refused to do this one because it would be a repeat***MYT
148 stay on the phone that long,he said to send him hard copy, (sc2)**M
149 Mary did not know date of installation & refused to continue***KAY
150 husan said whats the big deal we changed the lights goodbye**CGH

OBS COMMENT1

151 Mike doesn't "that kind of time" and refused to do survey***MYT
152 mr. seiler refused to do the survey. his reasoning was that he
153 Mr.Simmons said,'that he does not have the time now or in the futur
154 sec. stated he didn't have any time to answer questions.**DSH
155 Subash Rane (mngr) claims he completed the survey yesterday.**JRJ
156 SAID THAT 20 MIN. ON THE PHONE IS TOO EXCESSIVE AND HE WOULD HELP**
157 SEE QC 379 FOR THE COMMENTS**DSH
158 Mr.Carpenter did not want to be bothered.**JMS
159 SAYS THAT HE HAS NO TIME TO PARTICIPATE IN THE SURVEY.***KAY
160 HE COULDN'T DEVOTE THE TIME TO THE SURVEY. IF WE SEND HIM SOMETHING
161 Lee Lohff said he could't think of a more convenient time, sounded
162 HE SAID THAT HE REALLY WANTS TO HELP BUT HE RUNS HIS OWN BUSINESS**
163 SCOTT SAID HE DOESN'T HAVE TIME TO ANSWER QUESTIONS HE SAID WE CAN*
164 MR. RALPH SAID HE WASN'T INTERESTED**RRF
165 MR. WALKER STATED THAT 15 MINUTES OR SO IS ENTIRELY TOO LONG AND
166 MR. MELVIN WAS VERY BRASH AND STATED THAT HE DOSEN'T HAVE TIME AND
167 SEE QC 160 FOR THE COMMENTS
168 SEE QC 48 FOR THE COMMENTS**
169 SEE QC 406 FOR THE COMMENTS**DSH
170 Call correct number first if no answer call this number**JMS
171 dan seemed upset b/c the retrofit program went bad...had to replace
172 "We're too busy to do a telephone survey," said Fran.
173 THEY DO NOT HAVE TIME TO DO SURVEY**JGP
174 GREG asked if HE HAD TO PARTICIPATE I SAID NO SO HE DECLINED**CG
175 NEW MANAGEMENT KNOWS NOTHING ABOUT THE PROGRAM**JGP

OBS COMMENT2

151
152 dosen't "do survey's over the phone" and ended the call**DSH
153 e to take time for the survey.**JMS
154
155 **JRJ
156 US IF WE MAILED HIM SOMETHING**LDB
157
158
159
160 IN WRITING HE WILL DO IT.**LDB
161 testy. this is a refusal, per Dante.
162 AND HAS A NEWBORN BABY HE JUST DOES NOT HAVE ANY TIME**JMT**JMT
163 SEND HIM SOMETHING IN THE MAIL**KYS
164
165 THAT HE WILL NEVER HAVE THAT MUCH TIME, SO HE DECLINED THE SURVEY
166 WILL NEVER HAVE TIME AND ended the call.
167
168
169
170 (510) 475 0481**JMS Not interested she refused.**JMS
171 20% of ballasts w/in 1st yr of retrofit...refused to do survey.**MY
172
173 **JGP
174
175 **JGP

OBS COMMENT1

176 secretary said, "to be honest, Randy just won't do it."**MYT
177 Mr. Harless says he is happy with the program and his PG&E rep, but
178 ms. forbes said that someone else already contacted her with a
179 Mr. Walker said he wasn't interested**REJ
180 was not interested in taking survey.**ALS
181 Not eligible for survey. See sc 2 for comment**REJ
182 Mr. Pierre didn't "want to spend any mor time on this".
183 SEE QC 96 FOR THE COMMENTS
184 mr. becker said that he already did a survey for one of his sights
185 SEE QC 406 FOR THE COMMENTS
186 see qc 78 for the comments
187 spoke w\Mrs Muentner, who said "this is a retail business, we're
188 see qc 78 for the comments
189 SEE QC 476 FOR THE COMMENTS**
190 ans machine**LMC moving location & will be unable to do survey, sai
191 ROY BEGAN THE SURVEY KNOWING HE COULD JUST SPARE AROUND 10 MIN. ROY
192 SEE QC 160 FOR THE COMMENTS
193 SEE QC 406 FOR THE COMMENTS
194 MR. BAKER DIDN'T WANT TO DO A SURVEY BECAUSE HE WOULD HAVE TO DIG
195 Ernie felt the survey was a waste of time. He refused interview.
196 FEELS HE HAS DONE TO MANY SURVEYS ALREADY DOES NOT CARE TO PARTICIP
197 MR. BURGESS said that pg&e already sent him out a lengthy questiona
198 Laura says no one there would have the time or inclination to do
199 DIDN'T KNOW WHEN LIGHTING WAS INSTALLED - SUGGESTED WE "PASS" ON
200 he said that he has a million people from electrical companies call

OBS COMMENT2

176 **MYT
177 has no time for a survey**JRJ
178 survey regarding her lights. so i coded it as a refusal**DSH
179
180 **ALS
181 **REJ
182
183
184 so he didn't want to participate.
185 **DSH
186
187 very busy, send a questionnaire and I'll try to fill it out."
188
189 **DSH
190 d it was ok to call in July when relocated**KAY**KAY
191 DID NOT KNOW WHEN THE LIGHTING WAS INSTALLED. THANKED AND TERM.**AD
192
193
194 UP ALL THE INFO ON THOSE LOCATIONS AND HE DIDN'T HAVE TIME.
195 see sc 2 for comment*
196 ATE.**CG
197 ire and he feels as though he's done enough as far as this program.
198 the survey, so just " take us off your list."
199 DOING SURVEY WITH THEM.
200 ing him about surveys and he just does not have the time**JMT

OBS COMMENT1

201 do not call.**CG
202 I spoke to Callie and she just didn't have enough time at the**CJG
203 **CG
204 Sam is extremely happy with the program but refuses to do the survey
205 Mr. Coyle says he has no time for survey**JRJ
206 **DSH
207 SEE QC 476 FOR THE COMMENTS**
208 this was a multi site but you should see qc 65 it is a refusal; .
209 I WAS TOLD THAT NO MS.WINTERS WORKS THERE. THE LADY THAT I WAS SPEA
210 SEE QC 160 FOR THE COMMENTS
211 MS. CLARK SAID SHE DOESN'T HAVE TIME FOR THIS AND ended the call**RRF
212 SEE QC 160 FOR THE COMMENTS**DSH
213 MS.SPENCER SAID THAT THE PERSON WHO HAD THE PROG. INSTALLED NO LONG
214 SEE QC. 407**CG
215 GAVE SECRETARY 800 NUMBER FOR THE NEW CONTACT MAGGIE TONINI.
216 JERRY SAID THAT "I DO NOT DO PHONE SURVEYS" THEN ended the call***CG
217 **HEM
218 Mr. Morgan is brand new in job, doesn't know anything about program
219 hard man to reach b/c he is in between 6:45 and 7:15 only then he**
220 HUGE CUTBACKS IN PERSONEL JUST NO TIME**CG
221 CHARLES MEADORS DIRECTOR HAS 800 NUM**CG
222 Spoke to her. She said she has other surveys from salespeople, so I
223 SEE QC.200**CG
224 SEE QC. 200
225 SEC. SAID THAT HE TOLD HER TO TELL US THAT HE IS JUST TOO BUSY TO**

OBS COMMENT2

201
202 moment to complete survey.**CJG
203 mr.jenson was short with me and did not have 20 mins.**CG
204 y over the phone.Wants me t send hard copy.
205 **JRJ
206 **DSH
207
208 Do Not Call Ross Stores. ***DSH
209 KING TO SAID THAT SHE WAS NOT INTERESTED AND ended the call.**CJG
210
211
212
213 ER WORKS HERE AND GO TO SCR. 2 FOR MOR INFO.**RRF
214
215 MAGGIE CALLED BACK AND SAID I HAVE NO TIME**CG
216
217 **HEM
218 refused**LMC
219 roams around the different job sites..left 800# with sec***MYT
220
221 OUR SURVEY IS WRITTEN IN SUCH A WAY THESE PEOPLE WANT A CONFERENCE
222 told her we weren't selling anything, but she still refused.
223
224
225 COMPLETE A PHONE SURVEY AT THIS TIME**JMT

OBS COMMENT1

226 *****
227 CLAIMED TO HAVE COMPLETED THE SURVEY ALREADY.***MYT
228 ext 219**CGH left our 800number on the voice mail**CGH
229 LEFT 800 NUM. WITH HIS SEC.**CG
230 SEE QC 440 FOR THE COMMENTS**
231 AMRIK SAID HE DID NOT HAVE TIME FOR SURVEY.**ALS
232 SEE QC. 442**CG
233 AFTER TELLING PERSON WHO I WAS AND WHAT CALL WAS REGARDING HE SAID
234 SEE QC 442**CG
235 MS. SHANAHAN SAID That she's not interested in doing a survey
236 SEE QC 442**CG
237 SAL SAID THAT HE WAS NOT INTERESTED IN TAKING ANY SURVEY.**ALS**ALS
238 SEE QC 422**CG
239 SEE QC 440 FOR THE COMMENTS**
240 SEE QC 440 FOR THE COMMENTS**
241 SEE QC 440 FOR THE COMMENTS**
242 See QC 14.**
243 CALL BACK LATE NEXT WEEK 7/6 HE ASKED FOR ELSIA'S NUMBER.**CG
244 See QC 14.**
245 SPOKE WITH RUSS HE IS SATISFIED WITH RETROFIT PROGRAM.**ALS
246 SEE QC.402
247 See QC 14.**
248 MR WOOD WOULD NOT EVEN LET ME SPEAK HE WAS HOSTILE AND NOT INTERESTED.**CG
249 See QC 14.**
250 See QC 14.**

OBS COMMENT2

226 Mr. Omran said he didn't have time for survey.
227
228 WE DONT DO PHONE SURVEYS IT IS AGAINST OUR POLICY**CG
229
230
231
232
233 HE HAD NO TIME**ALS
234
235 **JGP
236
237
238
239
240
241
242
243
244
245 BUT DOES NOT HAVE TIME TO DO SURVEY.**ALS
246
247
248
249
250

OBS COMMENT1

251 See QC 14.**
252 SEE QC. 294**CG
253 See QC 14.**
254 See QC 14.**
255 See QC 14.**
256 See QC 14.**
257 See QC 14.**
258 See QC 14.**
259 See QC 14.**
260 See QC 14.**
261 See QC 14.**
262 See QC 14.**
263 See QC 14.**
264 See QC 14.**
265 call jim wood on friday**CG
266 See QC 14.**
267 THIS PLACE IS A DAIRY QUEEN AND MR. DAYA SAID THAT HE HAS NO TIME
268 MR. ANOMA IS NEVER THERE BETWEEN BUSINESS HOURS (8AM-5PM)**MYT
269 henry said that he didn't understand and was eager to hang up befor
270 **CG
271 Naomi said that she was the only one at the store and doesn't have*
272 HE PREFERS NOT TO DO SURVEY B/C HE IS VERY BUSY**MYT
273 HE SAID THAT HE WAS NOT INTERESTED AT THIS TIME IN DOING A SURVEY.
274 DID NOT HAVE TIME TO DO SURVEY.**ALS
275 HELEN SAID SHE CHECKED INTO THE PROGRAM AND WAS NOT INTERESTED**ALS

OBS COMMENT2

251
252
253
254
255
256
257
258
259
260
261
262
263
264
265 see qc#14**CG
266
267 TO DO A SURVEY BECAUSE HE HAS TOO MANY CUSTOMERS TO TEND TO.
268 **MYT
269 e i got a chance to explain, he doesn't remember the program**KAY
270 **CG
271 any time to talk on the phone and ended the call b4 I could proceed**MYT
272
273 **CJG
274
275

OBS COMMENT1

276 CLIFFORD CHOW. COMPANY OWNED STORE**CG
277 they just do not have time to do phone survey**LMC
278 was SATISFIED WITH PROGRAM DID NOT WANT TO DO SURVEY.**ALS
279 Lori said she did not have the time,no time was good.**CG
280 no time, happy with lights**LMC
281 DR. NUCKTON WAS AN EXTREMELY NOT INTERESTED INDIVIDUAL WHO REFUSED IN A LESS
282 SPOKE WITH MR. COSART DID NOT WANT ONSITE VISIT.**ALS
283 sent hard copy and Denise(sec) knows that we need phone survey**ALS
284 DR. FUNK SAID THAT HE REALLY DOESN'T HAVE THE LENGTH OF TIME THIS**
285 **REJ
286 Dr Joseph has asked for hard copy, he has 800 number. do not call**
287 Barbara Barstow, ofc mgr for 191 W. Shaw, call her at corr phone**L
288 cindy office mngr felt like question. were not necessary for light*
289 C/B SPOKE WITH MR. ROSS SAID HE WAS HAPPY WITH LIGHTS BUT DOES NOT*
290 DOES NOT HAVE TIME TO LOOK IT UP WE SHOULD KNOW THE DATE SINCE IT IS
291 Calvin refused to do the survey after I told him it would take 20-25
292 REFUSED--HAD JSUT COMPLETED ANOTHER SURVEY FOR ANOTHER ACCOUNT***LM
293 does not want to be bothered***KAY
294 Mr. patel was confused by the relationship between Quantum & PG&E**
295 Chris said he does not answer questions over the phone, but ended the call
296 Her partner says PG&E refuses to pay for equipment damaged there by
297 MR. PATEL SAID THEY DID NOT PARTICIPATE.**CG
298 only vaguely remembers participating, but claims that he wouldn't k
299 Mr. Onaga wants PG&E call him direct, & ask him the questions.
300 John Randall has replaced Marv Samuelson.**BB john knows nothing ab

OBS COMMENT2

276 **CG
277 **LMC
278
279 **CG
280 **LMC
281 THAN POLITE FASHION
282
283 SEC SAID THAT DR. LEY THREW OUT THE HARDCOPY & DID NOT HAVE TIME**K
284 REQUIRES HE HAS A LOT OF PATIENTS HE'S A VERY BUSY DOCTOR**RRF
285 Dr. Don said he had no time for survey**REJ
286 him back--no time to do phone survey.**LMC
287 BARBARA SAID THAT THEY DO NOT DO ANY TELEPHONE SURVEYS*****
288 program and refused to answer anymore.**ALS
289 HAVE TIME FOR SURVEY.**ALS
290 ON THE APPLICATION FOR THE REBATE**CG
291 min. But He wants a hard copy.
292
293
294 he declined survey**REJ
295 before I could offer to send a hard copy.
296 bad voltage. Says until PG&E makes good, don't wish to do survey.**
297
298 now adequate info to answer survey questions, so don't cb***KAY
299
300 out stockton location, he couldn't refer me to another contact t&t*

OBS COMMENT1

301 RON SAID HE DID NOT HAVE TIME IT. AND ended the call.**ALS
302 HE SAID THAT HE JUST WILL NEVER HAVE 20 MINUTES TO CHAT ON THE PHON
303 sharon said that she didn't have time to answer a 20minute survey
304 MR. JOHN HANSEN DID NOT WANT TO DO THE SURVEY***ALS
305 BEFORE I SAID WHAT I WAS CALLING ABOUT SHE SAID THAT SHE WASN'T
306 BEFORE I HAD A REAL CHANCE TO EXPLAIN HE SAID THAT HE HAD NO INTERE
307 SENT A HARD COPY**CG
308 ANNA SAID SHE WAS NOT INTERESTED IN ANY MANAGEMENT, WHEN I TOLD HER
309 MR. BORODKIN SAID HE WAS NOT INTERESTED.**ALS
310 BOB SAID HE IS SHORT STAFFED.I GAVE HIM OUR 800# FOR HIM TO CALL US
311 MR. HARPERS SEC. STATED THAT HE SAID HE WAS NOT INTERESTED IN DOING
312 WAS NOT INTERESTED IN DOING SURVEY. REFUSED.....
313 JOEL SAID THAT HE DID ONE ALREADY AND ended the call.**DET
314 said that that would be too much time on the phone to do a
315 DID NOT HAVE TIME TO DO SURVEY.**ALS**ALS
316 HE SAID THAT HE WILL NEVER HAVE TIME TO DO A TELEPHONE INTERVIEW
317 **ALS
318 Les said he does not have 20-25 minutes to give me, and that he nev
319 WAS SATISFIED WITH RETRO LIGHTS BUT DID NOT HAVE TIME FOR SURVEY.**
320 Jean said that she'd contacted PG&E & she was sent the form
321 no time ever**LMC
322 MUST CALL ON THE 11TH AT 1PM**CG
323 JOE SAID HE IS NOT INTERESTED IN ANSWERING ANY QUESTIONS. HE ALSO**
324 MR. DOUGLAS SAID THAT A GUY FROM PG&E IS COMING OUT TODAY THEIR PLA
325 Mr. Hughes wants his PG&E acct. rep to verbally give him**REJ

OBS COMMENT2

301
302 E NOT EVEN IN SEGMENTS**JMT
303 **KAY
304
305 INTERESTED AND ended the call.
306 ST **JMT**JMT
307
308 IT WAS JUST A SURVEY SAID SHE HAD NO TIME.**D
309 REFUSAL.**ALS
310 BACK WHEN HE HAS TIME. CHECK ABOVE INFORMATION.**DET
311 A SURVEY AT THIS TIME.
312
313 **DET
314 survey so he would rather not participate.
315
316 BUT HE REALLY APPRECIATES THE PROGRAM**JMT
317 WAS NOT INTERESTED IN TAKING SURVEY.**ALS
318 er will.**DET
319 **ALS
320 to fill out; she has no time for phone survey.**REJ
321 **LMC
322 .
323 SAID HE DOESN'T KNOW WHAT I'M GOING TO ASK BUT HE'S NOT INTERESTED*
324 NNING ON DOING SOME MORE RETROFITS--DON'T HAVE TIME TO DO SURVEY
325 survey, he says he has no time for ph survey***REJ

OBS COMMENT1

326 ART SAID THAT HE DOESN'T HAVE TIME FOR THE SURVEY***ALS

OBS COMMENT2

326

Appendix N

NONPARTICIPANT REFUSAL COMMENTS

Appendix N

NONPARTICIPANTS: REASONS FOR REFUSING THE SURVEY

The following pages present comments made by nonparticipants at the time they refused to participate. The comments begin on the top half of the page and, if necessary, continue on the bottom half of the page under the same observation (OBS) number.

OBS COMMENT1

1 Ms. Woo said she didn't have time to do a survey over the phone. S
2 talked with Annete from NMPC, michael and gary own the building**RS
3 now is not a good time for L. to take the survey and there is no**
4 TECH CALL NEEDS TO BE MADE IN THE AFTERNOON. SCREEN 4**JQS
5 MS. ACUNA SAID SHE REALLY DOESN'T HAVE TIME TO COMPLETE SHE'S REALL
6 MR WANG ANSWERED 3 QUESTIONS, THEN HE SAID THAT HE DIDN'T WANT**MJP
7 CEO Deborah Tarbat refused DCOMP**JRJ
8 THE SEC. TREASURER WAS NO HELP AT ALL HE EVENTUALLY REFUSED TO ANSW
9 REFUSED BY MR HARM**JQS
10 Walt Hoefler went through all of decis. questions, and then**BAC
11 SEE SC2**CLK
12 This may be a 40, but we should talk to Bill Diman to be sure.**JRJ
13 refused**MJP
14 REBECCA THE RECEPTIONIST WAS KIND ENOUGH TO TRY TO ANSWER OUR QUEST
15 modified field more than twice therefore didn't skip appropriately.
16 started w\Vijay, got to sc 66. got cut off there
17 Dave said lighting ques.needs to be directed to the landlord....**M
18 went through some of the survey then refused to finish**LMT
19 Mark (see screen 2) did not want us to continue survey.**BAC
20 Got to sc. 87 with Mike before he said the survey was a waste of**J
21 Jerry Swenson said, "It's terrible that you don't do this by mail.*
22 Evelyn at corp. office said they were not interested.**JCM
23 Did not complete lighting and technical. Was pretty impatient.**CL
24 STARTED DOING SURVEY AND THEN SIS. KATHLEEN EXPLAINED THAT THEY DO*
25 Very nice man who wanted to help, but he is under a lot of pressure

OBS COMMENT2

1 She requested a hard copy but did not want anyone to call back.**RS
2
3 better time.**
4 DECISION MAKER ETHAN ALLEN REFUSED TO PARTICIPATE.**JQS
5 Y BUSY STOPPED ON SCR#53**RRF
6 TO PARTICIPATE.---REFUSAL---**MJP
7 at (209) 472-3465 for D/M. Left 800# for them to call.**JCM
8 ER B/C HE THOUGHT WE WERE TRYING TO SELL HIM A SERVICE.
9 **JQS
10 decided he had enough information.**BAC
11 LADY REFUSED, BUT IT WOULD'VE BEEN A #40 ANYWAY.**CLK
12 Maries' answers prompted a 40, but when Mr. Diman confirmed them**J
13
14 IONS, BUT SHE WAS NOT THE DECISION MAKER AND THE OWNER WAS NOT (SC2
15 .did not c/b for a third time to prevent upsetting Richard***MYT
16 *
17 Landlord is "an unusual fella" and so dave said they have to pass**
18
19
20 time.**JCM
21 I'm not interested." Partial, because Betty Souza did Ltg.**JCM
22
23 **CLK
24 NOT HAVE ANYTHING TO DO W/SCHOOL THE SIS. LIVE AT THIS ADDRESS SCR2
25 and could not find the time. We got to screen 17 and had to stop.

OBS COMMENT1

26 Was referred to Vuth at the corr. phone # by Barbara at original**R
27 Pam did LCOMP but referred us to the building owner who is the
28 Jim terminated call @ SC69 saying survey was too long**JRJ
29 Mr Sambuceti was somewhat cooperative, but refused to answer ques-
30 Got through SC40, but Mr. Burns said he'd given us all the time he
31 Barbara wanted to know why we didn't have "info in our files"**REJ
32 stopped at sc59**JRJ
33 I contacted Mrs. Brooks, she was able to answer some questions but*
34 Called 7/18; afternoon.Did a partial/refused, but lost data due to*
35 Rich is the Manager.
36 D.F. said that since we were calling lots of people he would prefer
37 Tim informed that he was swamped and didn't have the time.
38 Business is being sold.**SGW
39 She didn't have the time to participate and the company is moving.
40 We are very busy and wouldn't have the time to take part in the sur
41 Not interested in doing survey. Refusal.
42 WANTED TO HELP BUT IS TOO BUSY**JQS
43 Secretary said Mr. Roberts is in process of selling business and**B
44 FINALLY REACHED MR COLLINS, FOUND OUT THEY HAVE CHANGED THEIR LIGHT
45 NOT INTERESTED SECRETARY SAID HE WAS NOT AVAILABLE, TRY BACK AT ANOTHER TIME*
46 Woman who answered did not really understand me, and did not**BAC
47 REFUSED**CLK
48 Janet said the company was too small to benefit from PG&E programs*
49 H.P. said he was entirely too busy to participate in any surveys.**
50 Claims that he told previous interviewer he was not interested,**RE

OBS COMMENT2

26 number. Neither one seemed to know anything, and Vuth wanted F10**
27 PREVIOUS owner of the business (as of april), but he won't talk**JR
28
29 tions about Decisions or technical questions.
30 was willing to**JRJ
31 She didn't want to continue Stopped @ sc 33**REJ
32
33 not all, the person to contact is Mr. Harper.**KAR
34 CATI crash**JRJ
35
36 if we got the information from someone else.**RSD
37
38
39
40 vey.
41 **REZ
42 **JQS
43 building. There is no good time where I could talk to him.**BAC
44 S SINCE 92 BUT HE DID NOT WANT TO MAKE THE TIME FOR THE SURVEY**JQS
45 Brian will have no time, nobody else can answer Q's.**BAC
46 know who I should talk to.**BAC
47
48 so she did not want to participate in the survey.**RSD
49
50 but I doubt that... Sounds like he just didn't want to do it.**REZ

OBS COMMENT1

51 Recept says her company already did this survey a few weeks ago,**B
52 Gale did not give a reason for refusal; she just said she wasn't**R
53 LANGUAGE BARRIER, CLIENT DOES NOT SPEAK ENGLISH**JGP
54 TOO BUSY, NOT INTERESTED**JQS
55 WILL IS DEAD, AND MANAGER SAID "NO" TO SURVEY.**JRC
56 Steve Remmington told me that he did not have time to answer**BAC
57 OLINDA WAS NOT IN; ROBERTO SAID HE DID NOT HAVE THE TIME TO TAKE**J
58 THE WOMAN WHO ANSWERED THE PHONE WAS TOTALLY CLUELESS. SHE DIDN'T**
59 SPOKE WITH THE OFFICE MANAGER. HE WAS NOT INTERESTED IN TAKING PAR
60 "Yes, I'm the person but I don't have time to answer the questions"
61 no reason for refusal given.**RSD
62 refused**JGP
63 Mr. Martin's time is worth 250-300\$ per hour and it is ridiculous**
64 NOT INTERESTED SINCE IT DOES NOT DIRECTLY SAVE THEM MONEY**JQS
65 Olivia could not answer the questions and could not give the names*
66 mr. marks CHOSE TO DECLINE THE SURVEY.**DSH
67 she stated that she runs a daycare and will never have time for
68 RESPONDENT DIDN'T HAVE TIME**JQS
69 Ms. Lau was on her way out the door. She didn't think it would be*
70 DIANA IS OUT OF THE OFFICE ALL WEEK AND THE OFFICE IS TOO BUSY TO**
71 call back later; Sharon is on another line**LMC She did another sur
72 jon stated that he really didn't have any time for this. but he sai
73 AFTER 6 RINGS A SULLEN WOMAN ANSWERED AND WHEN TOLD IT WAS A PG&E**
74 office manager**
75 **DSH

OBS COMMENT2

51 At any rate, refused to answer questions.**BAC
52 interested.**RSD
53
54
55
56 any questions, but "thank you"**BAC
57 PART IN A SURVEY OVER THE PHONE**JQS
58 OF ANYBODY WHO COULD HELP US.**MJP
59 T IN THE SURVEY NOR REFERRING IT TO ANYONE ELSE THERE.**JQS
60
61
62
63 to expect him to do a survey over the phone.**RSD
64
65 of any contacts.**RSD
66
67 this, and ended the call
68
69 worth it for her to participate in survey. Politely refused.**REZ
70 HAVE TIME FOR THE SURVEY**JQS
71 vey a while back and is not going to waste a further 20 minutes now
72 d it in a polite way.
73 SURVEY, SAID "OH FORGET IT"**JQS
74 OVER THE WEEKEND, SHE WAS FIRED. RESPONDENT REFUSED TO TAKE PART**
75 He said that he DIDN'T WANT TO PARTICIPATE. ***DSH

OBS COMMENT1

76 Spoke to a woman who was VERY defensive toward PG&E. Had all kinds
77 Spoke to a man who said he did not want to spend the time on the**R
78 MR. BORTON stated that he didn't have time and just ended the call.*DSH**D
79 Didn't want to take part in survey because office is very small and
80 1ST # DOES NOT COVER LOCATION IN SAN JOSE. AT 2ND #, THEY WERE BUS
81 Debra said "we don't participate in telephone surveys. Thank you**
82 REFUSED**CLK
83 REFUSED.**CLK
84 NOT INTERESTED AT THIS TIME IN PARTICIPATING**RRF
85 Recept says call Irene, office coordinator.**BB She said she was no
86 TOO BUSY. TAMMY SAID THEY WOULDN'T HAVE ANY TIME FOR AT LEAST A**J
87 secretary said mr. Redy wouldn't have time.
88 this is mr. yu home #; does not wish to participate**CLK**CLK
89 Amy said she didn't have the time**REJ
90 SPOKE WITH A NOT INTERESTED LADY WHO WOULDN'T HARDLY LET ME EXPLAIN BE-F
91 "DON'T HAVE TIME FOR THIS, THANK YOU"**JQS
92 Ended the call before I could explain.**RSD
93 Mr. Vu'duc just said he would pass on this survey.**RSD
94 suman & starr**CLK
95 Refused.**MJP
96 MS. LEVINSON WAS BUSY W/ A CLIENT SPOKE TO WALTER WHO SAID THAT THE
97 A "one-girl office", and she is 'way too busy to help...**SGW
98 LADY SAID SHE DOESN'T HAVE TIME TO SPEND 15MIN. DOING A TEL. INTER-
99 Rosalee does not wish to participate in a survey.**RSD
100 REFUSED.**CLK

OBS COMMENT2

76 of questions about the survey before deciding for herself (F10)**RE
77 survey right now. He ended the call before I could arrange a C/B.**REZ
78
79 would be of no use.
80 Y AND I WAS TOLD TO TRY IN THE AFTERNOON**JQS
81 very much." Then she ended the call***MYT
82
83
84
85 t decision contact and did not want to indicate who might be the co
86 COUPLE OF WEEKS**JQS
87
88
89 **REJ
90 ORE SHE SAID SHE WASN'T INTERESTED AND ended the call**RRF
91
92
93 **RSD
94 REFUSED.**CLK
95
96 Y ARE A SMALL CO. AND THEY DON'T THINK THEY ARE INTERSTED**RRF
97
98 VIEW**RRF
99
100

OBS COMMENT1

101 receptionist was polite but did not want to give out contact info-
102 HE'S VERY BUSY. HE SUGGESTED AFTERNOON BUT IS MOST LIKELY TO DO IT
103 Phil said that "we are three or four levels down in the chain of**R
104 She says they are very busy and would not have time for the survey.
105 He said he'd rather not participate in the survey. Small company.**
106 "It wouldn't be pertinent because I split the bill or something**BA
107 DO NOT CALL THIS COMPANY**BAC
108 use correct ph #. this is prestige properties**REJ The recep said**
109 spoke w\Cami, who asked for a c\b for the end of the day.
110 spoke w\Rachel Rodriguez, who wants a hard copy**REJ
111 spoke w\Michael, and he said they are moving w\in two weeks,**REJ
112 "Billy" said that building engineer was always very busy and she**
113 The bevanda company**MYT
114 MR WILSON IS TOO BUSY TO ANSWER QUESTIONS AND NO ONE ELSE HAS THE**
115 spoke w\Jocelyne Chute who said she was TOO BUSY to help out.
116 MARY SAID THAT WE WOULD HAVE TO SPEAK TO PROP. MANAGEMENT CO. TRIED
117 REFUSED.**KAR
118 dir asst 415 code gave me 415-957-1622; refused***CLK
119 Emily Palmer apologizes not having the time to answer survey questi
120 REFUSAL.**KAR
121 REFUSED -- THEY MANAGE MANY LARGE OFC BUILDINGS & HAVE REG REP TO**
122 Radio Station KGST.Mr Crotty refeused the survey because they**JRJ
123 Finally talked to Barbara, but she claims they have hundreds of
124 THEIR OLD BUILDING BURNT DOWN. SO SHE DIDN'T FEEL IT WAS NECESARY**
125 refused.**KAR

OBS COMMENT2

101 **RSD
102 BIT BY BIT.**JQS DECIDED HE DID NOT HAVE TIME TO COMMIT**JQS
103 command on this property, we won't be able to answer questions."**R
104
105
106 like that" In other words, Don't call back**BAC
107
108 "we have had this interview atleast a couple of times"**MYT
109 "I don't have the time."
110
111 wouldn't be time effective to do survey**REJ
112 knows he doesn't want to do a survey.**
113 they are not interested***MYT
114 KNOWLEDGE**JQS
115 ***REJ
116 TO GET NAME AND # OF PERSON AND SHE SAID SHE COULDN'T GIVE THAT OUT
117
118
119 ons and would prefer if no one calls back.**KAR
120
121 HANDLE ALL PGE COMMUNICATIONS**LMC
122 lease and have no control of the lighting equipment. GOTO SC2**JRJ
123 heating/cooling units and it would take thousands of hours of (F10)
124 TO ANSWER OUR QUESTIONS.**MJP
125

OBS COMMENT1

126 1st # is for the Ventura Co. Sherrif's dept.**REJ
127 Person on ph wanted a hard copy, then he changed his mind when
128 refused nicely
129 THIS MAN WAS SOOO BUSY THAT HE COULD HARDLY TAKE THE TIME TO TELL**
130 REFUSAL.**CLK
131 REFUSED.**KAR
132 CURRENTLY UNDERGOING A PG&E AUDIT SO FELT NO NEED TO PARTICIPATE IN
133 Jerry Burgess refused politely**LMC
134 David Shallenberger is their chief engineer, says he's done such a
135 REFUSED**KAR
136 REFUSED.**KAR
137 A series of run-arounds culminating in refusal by property mngr**JR
138 OOPS. Failed to not the 6. Fortunately I did not reach anyone thi
139 REFUSED.**KAR
140 NORMA IS ON VACATION AND THEY DON'T KNOW WHEN SHE'S GETTING BACK.**
141 REFUSED
142 REFUSAL.**KAR
143 REFUSED**MJP
144 sec said that mgr was not interested in taking a survey**KAY
145 REFUSED.**MYT
146 person on ph said that they "have everything, retrofitted lights,
147 REFUSED.**KAR
148 arthur said that he wasn't interested in answering any questions**K
149 not interested to do the survey***MYT
150 REFUSED.**KAR

OBS COMMENT2

126 Receptionist said "We don't answer any questions over ph."**REJ
127 he realized it wouldn't come direct from PG&E**REJ
128
129 ME NO.**MJP
130 **CLK
131
132 THIS STUDY**JQS
133 **LMC
134 survey, just in the last month or so...
135
136
137 Ed Lau, saying, "we don' 'ave nothing to ask"**JRJ
138 s call.**JRJ
139
140 SOUNDS LIKE A MAJOR BLOW-OFF TO ME, BUT TRY BACK LATER IN THE WEEK.
141
142
143 **MJP
144
145 **MYT
146 energy saving stuff, everything"
147
148
149
150

OBS COMMENT1

151 see sc2**CLK
152 KEN WILSON'S SECRETARY FREAKED ON ME. SHE ASKED WHO I WAS WITH, THEN
153 Thought that it would be a waste of our time and of their time**REZ
154 REFUSAL**KAR
155 sec said that no one in that office wants to take the time to**KAY
156 THE WOMAN WAS NICE, BUT SHE HAD TO REFUSE. WHEN SHE ANSWERED THE**M
157 refused politely -- no time -- not sure if they retrofitted since
158 RECEPTIONIST WAS VERY UNCOOPERATIVE, AND RELUCTANT TO GIVE ANY**REJ
159 REFUSED, THEY ARE TOO BUSY TO ANSWER OUR QUESTIONS.**MJP
160 REFUSED.**KAR
161 Mike says they wouldn't be interested in doing any surveys. Nobody h
162 WHEN I TOLD THE SECRETARY WHAT I WAS DOING, SHE SAID THAT THERE WAS
163 Mr. Haymond said that he just does not have the time to do this**MY
164 receptionist said contact wouldn't want to participate in survey**
165 "I don't have the time"**JRJ
166 Company just been purchased. Knowledgeable people there too busy.**
167 THE ONLY PERSON WHO CAN ANSWER THESE QUESTIONS IS THE OWNER.**MJP
168 WHEN I EXPLAINED WHAT WE WERE ABOUT, HE SAID "NO NOT REALLY."**MJP
169 REFUSED.**RSD
170 THEY WERE INTERESTED IN A WRITTEN SURVEY, BUT THEY WEREN'T**MJP
171 REFUSED. SHE WAS NICE ABOUT IT, BUT SHE DOESN'T HAVE THE TIME.**MJP
172 I EXPLAINED OUR SURVEY, AND THE RECEPTIONIST SAID WE WOULD HAVE TO
173 REFUSAL.**KAR
174 spoke w\Bert, who said "I really hate questions, you know that?
175 REFUSED**MJP

OBS COMMENT2

151 A BLATENT REFUSAL.**CLK
152 SHE WOULDN'T TELL ME WHEN HE WAS GOING TO BE BACK IN HIS OFFICE.**M
153 to talk to them. Politely refused.**REZ
154
155 answer questions, then she ended the call**KAY
156 PHONE SHE SAID "DENTIST'S OFFICE" SO MAYBE IT WASN'T WHO WE WANTED*
157 1992
158 TYPE OF INFORMATION**REJ
159 **MJP
160
161 as time for that.**JRJ
162 NOBODY WHO COULD ANSWER OUR QUESTIONS.**MJP
163 now..and he has done surveys for PG&E before...no thanks**MYT
164
165
166 **BB
167 THE RECEPTIONIST SAID THAT IT WON'T HAPPEN.**MJP
168 THEN HE ended the call.**MJP
169
170 INTERESTED IN THE FOLLOW-UP VISIT.**MJP
171
172 SPEAK WITH THEIR ARCHITECT. NOBODY KNEW WHO THAT WOULD BE.
173
174 I really hate when people call me & ask oddball questions."
175

OBS COMMENT1

176 WHEN I TOLD THE RECEPTIONIST WHO I WAS AND WHAT THE CALL WAS**MJP
177 REFUSED.**KAR
178 THE WOMAN I SPOKE WITH WAS QUITE NOT INTERESTED.**MJP
179 REFUSED.**MJP
180 Mr. Ragsdale was not able to complete the survey, however he was ve
181 Nancy Nelson said,"this is the 3rd time someone has called...not**M
182 THE WOMAN I SPOKE WITH SAID THAT SHE HAD JUST HAD AN ONSITE FROM**M
183 The American Cancer Society will be moving their office in one week
184 Richard Smith said "I do not want to give out our priavte records"*
185 Lisa said she was not interested in participating in this survey***
186 BARBARA SAID THAT ALL THE INFO WAS AVAILABLE FROM THE BLDG. OWNER.*
187 REFUSED.**MJP
188 THEY WEREN'T INTERESTED**MJP
189 Roxanne said "we are going through a merger, I am not one to talk**
190 I WAS TRANSFERRED TO 3 DIFFERENT PEOPLE, NOT ONE OF THEM UNDERSTOOD
191 REFUSED.**RSD
192 DONNA WAS VERY BUSY AND WOULDN'T HAVE TIME TO ANSWER ANY QUESTIONS.
193 Les said "I'm not interested" before I could say anything beyond my
194 THE RECEPTIONIST SAID THAT THE BUILDING MNGT. CO. COULD ANSWER OUR*
195 DON IS VERY BUY AND WILL PROBABLY NOT HAVE TIME TO DO OUR SURVEY.**
196 Was hung-up on even before I could fully explain that it was a
197 THE SECRETARY WAS AN UNCOOPERATIVE PERSON. REFUSED.**MJP
198 Shirley said that they are busy right now and won't be able to help
199 THE MAN WHO ANSWERED SAID THAT WE WOULD HAVE TO SPEAK W/ THE MNGT.*
200 said that they were not interested in doing a survey & ended the call**KAY

OBS COMMENT2

176 REGARDING SHE SENT ME TO LYNN'S VOICE MAIL. I THINK IT'S A BLOW OFF
177
178
179
180 ry nice in assuring me he was not able to.**KAR
181 sure if it's ur company...but enough already***MYT
182 PG&E. SHE SAID THEY LOOKED AT LIGHT FIXTURES ETC.**MJP
183 , so at the present time their is no one available to answer questi
184 **MYT**MYT
185 ***MYT
186 BARBARA WOULDN'T GIVE US THE OWNER'S #. SHE WAS NOT INTERESTED.**MJP
187
188
189 to..don't know who to talk to"***MYT
190 WHAT INFO. I NEEDED. LADY #3 SAID THEY WEREN'T INTERESTED.**MJP
191
192 SHE WAS VERY ABRUPT, BUT I FOUND OUT THAT THEY ARE A 40 ANYWAY.**MJ
193 name..he said thanks then ended the call.**MYT
194 QUESTIONS. HE WAS BUSY AND DIDN'T GIVE ME THE MNGT CO'S #.**MJP
195 **MJP
196 survey...
197
198 in this survey...***MYT
199 CO. ONE PROBLEM-HE DOSEN'T KNOW WHO THEY ARE.**MJP
200

OBS COMMENT1

201 REFUSED.**RSD
202 HE SAID THAT HE WAS THE ONLY PERSON AT THE BUILDING AND THAT HE**MJ
203 Donna said "I don't have time right now but we do appreciate your**
204 He is the knowledgeable contact but is too busy to do the survey.**
205 Ms. Roper did not seem thrilled about spending time answering
206 REFUSED.**CLK
207 Ken told me he already talked to somebody about this. DON't**BAC
208 " Y'KNOW WE REALLY CAN'T DO ANY TYPE OF SURVEY" AKA REFUSED.**MJP
209 John Doesn't feel that this is straight forward enough..doesn't**MY
210 REFUSED.**LMC
211 MS.CASELLI SAID SHE WOULDN'T BE INTERESTED IN PARTICIPATING IN SURV
212 Will not have the time to take place in the survey.
213 SAID HE'S NOT INTERESTED IN PARTICIPATING BECAUSE HE'S ALWAYS BUSY.
214 Refused saying they have very strict rules about giving out any**JR
215 MS. GEE SAID SHE REALLY DOESN'T HAVE TIME TO DO THIS SHE'S PRETTY B
216 Was hung-up on as soon as I could say I was calling on behalf of**R
217 NOT IMTERESTED. ended the call**LIT
218 don't do surveys over the phone**LMC
219 After several attempts to contact, finally reached Marty (female)
220 CATHY SAID SHE GENERALLY DON'T PARTICIPATE IN SURVEYS TAKES TOO MUC
221 she was very busy and reluctant, she didn't actually refuse...**LMC
222 Person said that she would not have time for a telephone survey.
223 refused**LMC
224 don't do surveys**LMC
225 Receptionist asked me to call back and speak to Lolita Pyonne.**LIT

OBS COMMENT2

201
202 WOULD'N'T HAVE THE TIME OR THE NECESSARY INFORMATION.**MJP
203 calling" then ended the call.**MYT
204
205 a survey that would take 15 minutes of her time.
206
207 CALL BACK
208
209 want to give any info w/o a call from PG&E first. refused**MYT
210
211 EY AT THIS TIME
212
213
214 information over the phone**JRJ
215 USY.**RRF
216 PG&E. Wasted time with previous callbacks. Definite refusal.**REZ
217
218
219 and she told me they are not comfortable talking about the (F10)
220 H TIME**RRF
221 Dante says DO NOT CALL BACK.**REZ
222 Refusal.
223
224 **LMC
225 call around 3:00pm. out to lunch**LIT Lolita not interested.**LIT

OBS COMMENT1

226 Call any day except monday.**LIT
227 Was told that they would pass on this at this time.
228 Owner claimed he could only give me 2 minutes of time because he**R
229 did not want to participate.
230 Joe said " we are so small and so it doesn't matter anyways. I thi
231 "We're just a small Travel agency, try someone else..."
232 John Traverso died eight years ago.**JCM
233 I RECEIVED THEIR ANSWERING SERVICE SHE SAID WE HAVE TO C/B WITHIN**
234 Has zero time to do a "stupid survey that deals with something I do
235 said that someone already called them**LMT**LMT
236 Bob said, " I don't know what this is about...you are wasting my
237 SHE SAID THAT SHE DOES NOT HAVE ANYTIME THEY ARE CLOSING THE BUSINE
238 Ida wanted to know how this survey will benefit her...she seemed**M
239 did not want to take part during business hours**LMT
240 Mr. Song was very impatient and extremely not interested. He ended the call on me
241 SAID THAT SOMEONE ALREADY CALLED HER**LMT
242 Mr.Wong was not in but will be in tomorrow.**FH3
243 Guy said he didn't have time.**LIT
244 The number given to me by 411 was some lady who I did not understnd
245 BEFORE I HAD A CHANCE TO EXPLAIN TH LADY SAID THAT IF IT IS A SURVE
246 BEFORE I HAD A CHANCE TO EXPLAIN LADY SAID THAT THEY WERE NOT INTER
247 John said that the owner of the building is kind of wierd and does*
248 Refusal
249 said that he just will NEVER have the time to do the survey.**LMT
250 The guy could not speak english at all and when I asked for someone

OBS COMMENT2

226 He did not want to do the survey.
227
228 is on the sales force... Was sorry he could not help. Refusal.**R
229
230 nk I'll just pass on this one"***MYT
231
232
233 THE OFFICE HOURS WHICH ARE FROM 7:30A-4PM**RRF info on next screen
234 nt give a hoot about".Nice guy eh?**LMT
235
236 time"***MYT
237 SS IN A WEEK**JMT
238 eager to hang up.. said thank you and *click* ***MYT
239
240 **JCM
241
242 I don't have any need to take part.
243
244 and then she ended the call on me.**BAC
245 Y THEY WERE NOT INTERESTED**JMT
246 ESTED AND ended the call
247 not wish to get involved w/ this..anyways...a refusal.***MYT
248
249
250 who spoke english he ended the call and said,"You no call here."**LMT

OBS COMMENT1

251 person on phone wouldn't give his name, and was hesitant to agree**
252 Rosa's Beauty Salon is name of business and Elba said they are in
253 Person ended the call after I read Intro.**LIT
254 GLENN SAID, "WE ARE NOT INTERESTED IN A SURVEY."**JRC
255 PERSON WHO ANSWERED THE PHONE WAS VERY
256 ED IS DEAD.ASK FOR WAYNE HE'S NOT DEAD**LMT
257 Grigor is NOT interested.
258 DIDN'T WANT TO DO IT, SAID, "GOODBYE."**JRC
259 Was Not interested onthe phone**LMT
260 Did not want to participate**LMT
261 DBA: Universal Electrics (?) Mr. Chu said that he won't be able to*
262 Nina said, " that's ok, NO" then ended the call***MYT
263 Did not want to participate.**LMT
264 Mr. Leybin said "it's not my building so I don't know" therefore a*
265 Reached a Barber shop. Person not interested.**LIT
266 Person said no thank-you and ended the call. I don't think he understood a
267 DO NOT CALL. PER SUPERVISORS.**LMT
268 the woman who answered the phone said" we rather not participate"***
269 SECRETARY TOOK 800# AND SAID HE WOULD MOST LIKELY NOT TAKE PART IN*
270 was very anxious to get off the phone**LMT
271 I reached Rudy's answering machine.**LIT
272 could not speak english**LMT
273 Dana Freeze said she had to go and ended the call abruptly.**LIT
274 DBA: Vision Gallery..the receptionist said that they don't have the
275 ask for Silva ***MYT Silva said she does not have time for this***

OBS COMMENT2

251 to anwering other questions**REJ
252 the middle of selling the place and doesn't wish to do survey now.
253
254
255
256 guy was not too happy on this survey stuff**LMT
257
258
259
260
261 participate in this survey at this time..therefore refusal***MYT
262 **MYT
263
264 refusal***MYT
265
266 nything I said.**LIT
267
268 then hung up***MYT
269 THE SURVEY SO DON'T CALL BACK**JQS
270
271 SPOKE TO RALPH GLINSEK, HE WAS NOT INTERESTED IN TAKING PART**JQS
272
273
274 time to do this now...don't c/b***MYT
275 ***MYT and she couldn't answer the qualifier question***MYT

OBS COMMENT1

276 JIM SAID HE'S NOT INTERESTED AND ended the call**RRF
277 She just gave me some response and ended the call on me.**BAC
278 Manager said that he won't have 15 min. to spare and doesn't want
279 I had trouble understanding Henry, but he told me to talk to**BAC
280 LES claimed that someone else had already called and asked him a**M
281 Man who answered said he had no idea who could answer questions**BA
282 MS. STEVENS STATED THAT IT WOULD BE NO PURPOSE TO THIS SEEING AS
283 This man only wanted to answer questions if it were to his benefit,
284 "We're not interested in this kind of stuff"**BAC
285 "No we're a business, that's OK", than he ended the call...**BAC
286 Monica said she was very busy and did not have time to answer**BAC
287 SPOKE W\MIKE,WHO SAID "I'M JUST REAL BUSY, & IT'S HARD FOR**REJ
288 RECEPTIONIST VERY UNCOOPERATIVE.
289 Jim said I was probably the 5th or 6th person calling representing*
290 Muriel was manager at the store, she did not want to answer**BAC
291 HE STATED THAT HE' JUST TOO BUSY FOR THIS AND ended the call.**DSH
292 THERESA SAID THAT THE PERSON WE NEED TO SPEAK TO IS MR.LAKIN IS THE
293 see sc2***CLK
294 Martha answered a couple of questions, then decided she was too**BA
295 They are swamped w/ weddings so they can not do it at this time***M
296 June said owner could answer questions, but she would not give**BAC
297 WHEN I TOLD HIM THAT IT WOULD TAKE ABOUT 10 MINUTES, HE SAID THAT
298 "I don't think anyone wants to bother with it." .**BAC
299 I SPOKE W/MR.DUNKINS WHO IS MR. SCHOLLES PARTNER AND HE SAID THAT HE
300 I was told there was nobody that I could talk to

OBS COMMENT2

276
277
278 a call back.**FH3
279 Mr. Zieo, landlord at (310) 928-0100, he didn't want to talk to me**
280 bunch of questions***MYT
281
282 THOUGH THEY ARE MOVING SHORTLY.
283 if PG&E were going to cut his power in half**BAC
284
285
286 questions.**BAC
287 ME TO TAKE THE TIME TO DO THIS"**REJ
288
289 PG&E but not actually PG&E, "I'm not interested"....**BAC
290 questions**BAC
291
292 ONE TO TALK TO HE'S THE CONTROLLER, GO TO SCR. 2 FOR MORE INFO.**RR
293
294 busy to talk to me**BAC
295 ***MYT
296 me his number**BAC
297 MAYBE WE SHOULD PASS HIM BY
298
299 APOLIGIZES BUT THEY JUST DON'T HAVE THE TIME TO PARTICIPATE**RRF
300

OBS COMMENT1

301 THEY SAID THEY WERE NOT INTERESTED IN PARTICIPATING**RRF
302 VALLEY WEST REALTY SEE SC2 4 CB**CLK**CLK
303 master craft dry cleaning*clk**CLK
304 Mr. Seiler was tired of taking pg&E surveys. He retrofitted**BAC
305 Just did a survey, last month...
306 Ron says, "This is a business, we have customers. We don't have**B
307 JANIE SAID "I KNOW NOTHING ABOUT IT."**REJ
308 C\B AND ASK FOR CORREIN, WHO SAID SHE'D TRY TO HELP**REJ
309 STEVE FELT THAT QUESTIONS, LIKE SC001d should be submitted in**REJ**
310 Mike does not have the time if I am not directly from PG&E**BAC
311 "Don't have time for this"**BAC
312 amber said "we are a retail store, very busy, thank you, bye"**MYT
313 NYT=MYT..typo...the woman who answered the phone said "not interest
314 THE PERSON WHO ANSWERED THE PHONE WAS NOT INTERESTED AND STATED THAT**DS
315 SAID THAT SHE'S GOING THROUGH A CONSTRUCTION AT THE TIME AND THERE
316 Kevin, upon reflection and a return call decided two minutes**BAC
317 They were not interested to do this survey**MYT
318 Tammy said "I don't have the physical time for this, I'm sorry."
319 Mr. Lang told me to call Michael's Art supplies at 421-1576, he**BA
320 "We're already on that special program." However it sounded**BAC
321 see sc2**CLK
322 joe wagner, the corporate head, said that he is way too busy to do*
323 PG&E is on their premises now doing the EMS and Mr. Wardlow doesn't
324 said that he was too busy to do phone survey but will be willing to
325 Mr. Zart said that they are extremely busy now, they are a mail**MY

OBS COMMENT2

301
302 CALLED MICKEY; ALREADY EVALUATED VISITED**CLK
303 not interested**MYT
304 the lights at his location, but would not take survey**BAC
305
306 an time**BAC
307 **REJ
308
309 writing.**REJ**REJ
310 **BAC
311
312
313 ed.." then ended the call**NYT
314 THERE WAS NO ONE WHO COULD ANSWER ANY QUESTIONS AND ended the call.**DSH
315 WILL BE NO TIME SOON THAT SHE CAN TAKE AND ANSWER QUESTIONS
316 was all he could spare, w/ no better time to c/b. Polite, though**B
317
318
319 said he was not best person, but he did not want to talk to me*****
320 more like an excuse to get me off the phone**BAC
321
322 the survey**KAY
323 feel like doing this evaluation **MYT
324 do a survey on paper**KAY
325 order business and won't be able to help out**MYT

OBS COMMENT1

326 Was informed that they are in very close contact with their PG&E
327 Secretary did not seem too keen on us contacting Ben.**RSD
328 Norman does not participate in surveys in general. Told me not to*
329 Was referred from one person to another throughout company, before
330 Jeff referred me back to San Jose store, which referred me back to*
331 did not have the time to help; refused politely
332 JACK BEGAN TO DO SURVEY, THEN HE SAID, "THAT'S ENOUGH, I DON'T**JRC
333 Jon said, "I'm not interested, thanks," and ended the call.**JCM
334 Sayeth Jeff, "Anybody who would sit on the phone for 10 or 15 minut
335 Mark Tavarez said PG&E did the same sort of thing a year ago, and**
336 I spoke to a woman who said, "This is a pay phone. We're not inter-
337 see sc 2**CCL
338 Greg said that someone already called him, so either it is a**BAC
339 EXT. 10**RSD
340 Refused saying "we've already replaced our lights and done a survey
341 I really don't have time for that. I'm in the middle of selling**J
342 see sc 2**CLK
343 Recept. quickly refused to participate**BAC
344 Mgr didn't want to give out much info, we started the survey & afte
345 PAT JUST DOESN'T HAVE TIME TO DO THE SURVEY**JRC
346 The man I spoke to said, "We'll do it through the mail, but not**JC
347 the receptionist said " I answer 6 lines here and I can't help you,
348 Mgr said she doesn't have that much time to use the phone for a***
349 The woman who answered the phone had no idea who I can talk to and
350 Genie does not have time to do a survey over the phone for 15 min.

OBS COMMENT2

326 account rep. and that they do not have time for a survey.
327
328 take it personally.**RSD
329 finally coming full circle. They claim they really don't have >F10
330 Cathy Roland at corporate office, who finally refused.**RSD
331
332 WANT TO DO ANYMORE.**JRC
333
334 es for a survey I wouldn't want working for me. Goodbye"**JRJ
335 he wasn't interested.**JCM
336 ested.**JCM
337
338 refusal or something else.**BAC
339
340 on that"
341 the dealership and I have about 30 people to deal with right away**
342 **CLK
343
344 r a few questions, he didn't want to continue**KAY**KAY
345 **JRC
346 over the phone.**JCM
347 I am sorry" then ended the call**MYT
348 survey**KAY
349 wasn't willing to give me a name nor number that I can call*
350 She is the assistant manager.

OBS COMMENT1

351 didn't see the first result before dialing this number***MYT
352 Greg said that it would be a waste of time to do survey w/him**KAY*
353 REFUSED.**CLK
354 "I don' tink we need to do that; we,uh,jus change everyting"***JRJ
355 Agatha, the mgr, said that she didn't have the time, she cut me off
356 Doesn't want to disclose any information regarding the company**KAY
357 Sandy is the contact, but she is very busy, but keep trying**BAC
358 politely declined**JRJ
359 Bob Holman said he has no time and he would regrettably have to**JC
360 Fran, the office mgr, said that they don't answer any questions on*
361 L.A. said that 15 minutes was too long for a phone survey.**RSD
362 Spoke w/mgr & she said that they really don't participate in any**K
363 Roger "wouldn't be interested" .**BAC
364 Mgr said that she was not interested in answering any questions**KA
365 B. participated a few months ago and doesn't feel like participatin
366 Jeff is the controller,but he said that he never participates in**KA
367 She said, "I'm not interested" and ended the call**JRJ
368 SPOLKE WITH MR. SCOTT HE SAID THAT AT THIS POINT IN TIME THEY ARE
369 Jim said he is much too busy to do a 15 minute survey.**RSD
370 i started my greeting but before i could say what i was calling
371 mr. johnson said that they're moving in may so there really was no
372 ANTOINE WANTED A HARD COPY OF SURVEY. I SAID OK BUT THAT WE WOULD
373 REFUSED NICELY -- BUSY**LMC
374 Jeff Downs called our 800#. Said he couldn't do the survey bec.**D
375 The man I talked to said that the office at the school was closed**

OBS COMMENT2

351
352
353
354
355 before I had a chance to explain**KAY
356
357 WON'T HAVE TIME UNTIL AFTER 8/15**JQS
358
359 pass on this survey.**JCM
360 the phone at all**KAY
361
362 kind of survey**KAY**KAY
363
364
365 again.**RSD
366 telephone surveys**KAY
367
368 COMPLETELY SWAMED THEY HAVE NO TIME TO SPEND ON THE PHONE**JMT
369
370 about she stated that she dosen't want to deal with(see scr.2)
371 point in this survey
372 HAVE TO CALL HIM BACK TO DO ORAL SURVEY AND HE SAID HE HAD NO TIME
373
374 he only has a pager, no regular phone. Coded refused.DRN--SUPVSR**D
375 and that there was no one there to answer our questions.**MJP

OBS COMMENT1

376 SAID THAT HE HAD BETTER THINGS TO DO THAN SIT AND ANSWER QUESTIONS*
377 Fae said that she has customers to tend to and that it's probably**
378 Dan said "I don't have time for this. Thank you." and then he**REZ
379 Too busy. If we wanted to stop by and talk to him, it would be
380 the woman who answered the phone said that she doesn't know who we*
381 Mrs. Thomas said " we have been here for forty years and we don't**
382 "No thank you... I pass." Refusal.**REZ
383 Yong Lee said he couldn't understand why we didn't do this on paper
384 The receipt pretended like Katie was busy, after answering a**BAC
385 paul mazzella is always really busy**JGP
386 Respondent did not want to have a supervisor listening in... He
387 SMALL BUSINESS, NOT INTERESTED IN DEALING WITH THIS.**JGP
388 WORKS ALONE, DOES NOT HAVE THE TIME**JGP
389 Carolin says she's trying to do taxes right now and won't have the*
390 Ms. Frye said that there is really no good time to do a survey**MYT
391 SPOKE TO BOB HE STATED THAT HE'S IN RETAIL AND WILL NEVER HAVE ANY
392 Kathy says talk to Jerry**JRJ Jerry says he can't spare 10 minutes*
393 Advised not to call back. These people do not like PG&E to put it*
394 **JGP
395 Mr. Flood is in the process of settling a monetary dispute with
396 Claudio Lane Sr. said that he'll have to pass ..refused**MYT
397 Robert said, "I think I'm not inclined to take this survey."
398 accidental login**JRJ
399 not interested**JGP
400 polite (but firm) declination**JRJ

OBS COMMENT2

376 OVER THE PHONE.**DSH
377 better to forget her survey***MYT
378 promptly ended the call. I'd guess this is a refusal.**REZ
379 better... Refusal.**REZ
380 are and have done other PG&E evaluations before; "not interested"*
381 need any of that, thanks" then ended the call*
382
383 and he said he didn't want to continue.**JCM
384 couple of questions, told me we could not finish**BAC
385
386 hung on the phone before I could continue.
387
388
389 time. I guess it's a refusal, since she ended the call while I was F10**R
390 b/c she was in the store alone***MYT
391 TIME. BUT HE SAID IT IN A POLITE WAY
392 for a survey**JRJ
393 mildly. Refusal.**REZ
394
395 PG&E so he isn't really willing to do this for them at this time*
396
397
398 Just got to SC21 before she refused to go on.Very busy**JRJ
399
400

OBS COMMENT1

401 Bub said that they are pretty happy with everything but like to**MY
402 does not have time**JGP
403 SAID HE'S TOO BUSY, AND HE ended the call.**JRC
404 The woman who answered the phone said that she doesn't know anythin
405 no time -- nicely refused
406 this is a bar, he's got to take care of business, thus, he cannot**
407 no time for phone survey; refused nicely**LMC
408 Doris said, "we're not interested" and ended the call.**MYT
409 extremely busy; very small restaurant; very nicely refused survey**
410 Person on phone said "No thankyou during opening paragraph and hung
411 no, thank you**JGP
412 Carl Mohrmann is passed away. Agnes does not wish to be called**JCM
413 Leticia said she'll never have fifteen or twenty minutes for a**JCM
414 RICHARD HAD NO TIME, DID PART OF SURVEY AND HAD TO STOP**JRC
415 Leticia said she just didn't have the 10-15 min. necessary**REJ**RE
416 THEY ARE GOING OUT OF BUSINESS**JGP
417 Christine had left the building. She may be avaiilable again**REJ
418 SEC WOULD NOT PUT ME THROUGH TO HIM SHE SAID THAT HE IS ABOUT TO RE
419 BEFORE I HAD A CHANCE TO EXPLAIN MUCH HE SAID THAT HE WAS NOT INTER
420 SPOKE TO VICTOR COLER AND HE SAID THAT HE IS NOT INTERESTED AND NEV
421 MICHELLE SPOKE WITH THE DOCTOR AND HE SAID THAT THIS DOES NOT SOUND
422 DR. SCOTTON SAID THAT THIS LINE IS OPEN FOR ONLY HIS PATIENTS AND H
423 THE LADY DIDN'T EVEN LET ME EXPLAIN SHE JUST SAID THAT SHE WAS NOT
424 BEFORE I HAD A CHANCE TO REALLY SAY MUCH HE SAID THAT HE WAS NOT IN
425 HE SAID THAT HE JUST DOES NOT WANT TO SPEND ANY TIME ON TELEPHONE

OBS COMMENT2

401 pass on this survey..John Sr. is only there weekend mornings**MYT
402
403
404 g, she said thank you and then ended the call**
405
406 speak to me**JGP
407
408
409
410 up**JRJ
411
412 back.**JCM
413 survey.**JCM
414 WHEN ASKED FOR A BETTER TIME, SAID HE DIDN'T HAVE ONE.**JRC
415 for the survey**REJ
416
417 @ the above date.**REJ Christine did not want to take survey**BAC
418 TIRE AND WOULD NOT BE INTERESTED.**JMT
419 ESTED AND HUNG THE PHONE UP**JMT
420 ER HAS ANY TIME TO SPEND ON THE PHONE**JMT
421 LIKE SOMETHING HE WOULD BE INTERESTED IN**JMT
422 E DOES NOT HAVE ANOTHER LINE SO DO NOT CALL ANY MORE**JMT
423 INTERESTED**JMT
424 TERESTED AND HUNG THE PHONE UP**JMT
425 SURVEY**JMT

OBS COMMENT1

426 BEFORE I HAD A CHANCE TO SAY WHAT I WAS CALLING FOR SHE SAID THAT S
427 THE PERSON I SPOKE WITH SAID THAT HE CHOOSES NOT TO DO PHONE SURVEY
428 BEFORE I HAD A CHANCE TO EXPLAIN VERY MUCH SECRETARY SAID THAT THEY
429 SPOKE WITH RICHARD HE DID NOT REALLY UNDERSTAND WHAT I WAS SAYING I
430 CINDY SAID THAT THEY DON'T HAVE ANY TIME FOR THIS**DSH
431 HE SAID THAT HE DOES NOT HAVE ANYTIME RIGHT NOW AND HE DOES NOT WAN
432 BEFORE I COULD FINISH SHE SAID THAT SHE DOES NOT HAVE ANY TIME TO
433 TRIED TO EXPLAIN PROGRAM BUT SHE ACTED AS THOUGH SHE DIDN'T UNDER-
434 person on ph wasn't intersted in survey**REJ
435 spoke w\Jill Jacobs, who didn't have time for survey**REJ
436 spoke w\Nancy Finch, who said they pay for power through rent, &
437 c\b & ask for Linda Taylor or Mr. Ohaver**REJ
438 person on ph didn't know about power usage, & didn't know**REJ
439 VERY HOSTILE, ASKED FOR HARD COPY, BUT REFUSED TO CONFIRM**REJ
440 sec said that they don't have anyone who can answer questions. she
441 did not want to disclose information w/organization that they are**
442 ignore sc 156, the person on the ph "Ben" refused to share his last
443 Sharon said "I'm swamped, I just don't have the time for a survey,
444 said that they just don't have time to do any survey**KAY
445 "WE DON'T HAVE TIME FOR THIS...."
446 spoke w\Dorothy, who said "I don't know why all this is necessary**
447 refused nicely**LMC
448 Polite refusal
449 "We wouldn't have time to take a survey"**JRJ
450 does not want to participate in a survey.**LMT

OBS COMMENT2

426 HE DOES NOT HAVE ANY TIME AND SHE IS NOT INTERESTED.**JMT
427 S**JMT
428 WERE NOT INTERESTED AND HUNG THE PHONE UP**JMT
429 EXPLAINED EVERYTHING THOROWLY BUT HE IS NOT INTERESTED**JMT
430 **DSH
431 T US TO CALL HIM BACK**JMT
432 TALK AND HUNG THE PHONE UP**JMT
433 STAND
434
435
436 landlord is impossible to reach**REJ
437 linda siad that she didn't have time for this & then ended the call**KAY
438 # of property management firm**REJ
439 ADDRESS. IGNORE SC 156 SAID GLORIA**REJ
440 was not very helpful when i asked her to find another contact**KAY
441 not aware of, so they refused**KAY
442 name, and was very sarcastic
443 I'm sorry."
444
445 SAID THE RECEPTIONIST**REJ
446 for PG&E, all they want to to is charge us for kw\h.**REJ
447 no time**LMC
448
449
450

OBS COMMENT1

451 The Embassy; Might try to talk to Gaston, but George, there refused
452 Was very irate on the telephone.**LMT
453 Fred is NOT INTERESTED. Its a "waste of time".
454 "No time."
455 refused politely; too busy
456 The man who answered the call said "I'm on another line now, we app
457 Stan said that they are in the process of moving to a different**MY
458 Refused
459 Shelly (manager) said " I don't have time for this now" then HUNG**
460 Mr. Agnetti said, "no, I don't think so" and then ended the call***MYT
461 the receptionist said that they do not give out names..and in this*
462 The man who answered the phone said that the lighting is taken care
463 DID NOT PARTICIPATE IN PROGRAM, AND WOULD LIKE TO KEEP IT THAT WAY*
464 NOT INTERESTED**JGP
465 DOES NOT HAVE THE TIME**JGP
466 Recpt. said "She's already worked with PG&E to save money on her
467 Dave (district mgr) said that they just did a PG&E survey last**MYT
468 The receptionist said that the only person who can answer the ques*
469 every decision is made out of their Houston Office and the woman**M
470 Right now they are not interested in anything we have to say***MYT
471 Sharon said "We really don't have time to do this survey...our time
472 There is no one there knowledgeable about their energy usage there*
473 the recep said," this is a office and no one here would be interest
474 the woman who ans the phone said,"this is the busiest season of the
475 They are really busy in the summer so won't be able to answer any**

OBS COMMENT2

451
452
453
454
455
456 reciate your call but we don't need anything now" and ended the call.**MY
457 location, he said thanks and then ended the call***MYT
458
459 UP.***MYT
460 **MYT
461 case they probably just can not participate in the survey***MYT
462 by the owner and he couldn't give me the name nor the phone#***MYT
463
464
465 **JGP
466 bill, so thanks, but no thanks . { Refusal }
467 month and at this time he would rather not do this one***MYT
468 is really busy and wouldn't do a survey...but we can try to fax***M
469 who answered the phone would rather not give out that number***MYT
470
471 is valuable"***MYT
472 and there was no one that the recep. could refer me to***MYT
473 ed in doing any survey at this time"***MYT
474 yr and unless this is required by law, there's no one to answer***M
475 questions***MYT